



155 East Broad Street
20th Floor
Columbus, Ohio, 43215
o: 614-222-1330
f: 614-222-1337

March 13, 2019

Ms. Tanowa M. Troupe, Secretary
Ohio Power Siting Board
180 East Broad Street, 11th Floor
Columbus, OH 43215-3716

Re: OPSB Case No. 19-445-EL-BNR, Duke Energy Ohio
F3881 Wards Corner Re-Feed Project

Dear Ms. Troupe:

In accordance with O.A.C. 4906-6-07, Duke Energy Ohio, Inc., (Duke Energy Ohio or Company) is hereby filing its notice of compliance with requirements concerning service and public distribution of the application filed in the above-referenced proceeding.

A copy of the application is available for public inspection at the main office of Duke Energy Ohio at 139 E. Fourth Street, Cincinnati, Ohio 45202, and at the offices of the Ohio Power Siting Board, 180 East Broad Street, Columbus, Ohio 43215.

It is also available on the Duke Energy Ohio website, at: <https://www.duke-energy.com/our-company/about-us/electric-transmission-projects/wards-corner>, together with instructions on how to obtain a paper copy. Additionally, the application is on the Ohio Power Siting Board's website, at: www.opsb.ohio.gov. Lastly, a notice containing a link to a copy of the application has been electronically sent to the Clermont County Public Library.

The attached correspondence demonstrates that on March 8, 2019, the Company electronically served a copy of the application on the following individuals:

- Chris Wick, Director of the Clermont County Public Library, at cwick@clermontlibrary.org
- David Painter, President of the Clermont County Commissioners, at dpainter@clermontcountyohio.gov
- Edwin Humphrey, Vice President of the Clermont County Commissioners, at ehumphrey@clermontcountyohio.gov
- Claire Corcoran, Clermont County Commissioner, at ccorcoran@clermontcountyohio.gov
- Thomas Eigel, Clermont County Administrator, at teigel@ClermontCountyOhio.gov
- Taylor Corbett, Clermont County Planning Commission, at tcorbett@clermontcountyohio.gov



155 East Broad Street
20th Floor
Columbus, Ohio, 43215

o: 614-222-1334
f: 614-222-1337

- Hannah Lubbers, Clermont County Director of the Office of Environmental Quality, at hlubbers@clermontcountyohio.gov
- Douglas Barry, President of the Miami Township Trustees, at dbarry@miamitownship.com
- John Morris, Vice President of the Miami Township Trustees, at jmorris@miamitownship.com
- Donald Culp, Miami Township Trustee, at dculp@miamitownship.com
- Gregory Rogers, Miami Township Administrator, at grogers@miamitownship.com

Please contact me with any questions.

Sincerely,

/s/ Jeanne W. Kingery

Jeanne W. Kingery

Associate General Counsel

Olive, Emily A.

From: Olive, Emily A.
Sent: Friday, March 8, 2019 1:50 PM
To: 'cwick@clermontlibrary.org'
Cc: Kingery, Jeanne W.
Subject: Duke Energy Ohio Power Siting Board Case No. 19-445-EL-BNR / Wards Corner Project
Attachments: Letter to Library-WC.PDF

Good Afternoon:

Please see attached notification regarding the above-referenced project.

This notice is being provided in accordance with Ohio Power Siting Board rules.

Thank you.

Emily A. Olive, CP

Paralegal | Duke Energy Law Department

Duke Energy Corporation | PNC Bank Plaza, 155 East Broad Street, 20th Floor | Columbus, Ohio 43215

o: 614-222-1345 | f: 614-222-1337 | emily.olive@duke-energy.com



CONFIDENTIAL NOTIFICATION:

The information in this email may be confidential and/or privileged. This email is intended to be reviewed by only the individual or organization named above. If you are not the intended recipient or an authorized representative of the intended recipient, you are hereby notified that any review, dissemination or copying of this email or its attachments, if any, or the information contained herein is prohibited. If you have received this email in error, please immediately notify the sender by return mail and delete this email from your system. Thank you.



Duke Energy Ohio
139 East Fourth Street
Cincinnati, Ohio 45202

March 8, 2019

Clermont County Public Library
5920 Buckwheat Road
Milford, Ohio 45150

Via Electronic Mail

**Construction Notice
Wards Corner Substation Improvements**

Dear Sir or Madam:

Please find below a link to an electronic copy of a Construction Notice that Duke Energy Ohio, Inc., (Duke Energy Ohio) has filed with the Ohio Power Siting Board regarding its proposed project to add approximately 800 feet of new transmission line just outside the substation along the west side of the property. The new transmission line on Duke Energy Ohio property will be supported by 8 steel poles, ranging from 69 feet to 142 feet above ground. The width of the base of the poles is approximately 6-feet in diameter, with a concrete foundation ranging from 8 to 9 feet in diameter. The equipment is designed to withstand the extreme summer temperatures as well as the plunging temperatures in the winter months. The work also will involve the removal of a lattice tower on Duke Energy Ohio property.

In accordance with O.A.C. 4906-1-01 Appendix A, we are required to prepare this Construction Notice for the Ohio Power Siting Board and, in compliance with O.A.C. 4906-6-07, we are hereby providing you with a link to an electronic copy.

A copy of the application is available for public inspection at the main office of Duke Energy Ohio at 139 E. Fourth Street, Cincinnati, Ohio 45202, and at the offices of the Ohio Power Siting Board, 180 East Broad Street, Columbus, Ohio 43215. The Application is also available on the Duke Energy Ohio website, at: <https://www.duke-energy.com/our-company/about-us/electric-transmission-projects/wards-corner> and on the Ohio Power Siting Board's website, at: <http://dis.puc.state.oh.us/CaseRecord.aspx?CaseNo=19-445&x=0&y=0>.

Cordially,

Duke Energy Ohio, Inc.

/s/ Rick Hicks

Senior Project Manager

Olive, Emily A.

From: Olive, Emily A.
Sent: Friday, March 8, 2019 1:53 PM
To: 'dpainter@clermontcountyohio.gov'; 'ehumphrey@clermontcountyohio.gov';
'ccorcoran@clermontcountyohio.gov'; 'teigel@ClermontCountyOhio.gov';
'tcorbett@clermontcountyohio.gov'; 'hlubbers@clermontcountyohio.gov';
'dbarry@miamitownship.com'; 'jmorris@miamitownship.com'; 'dculp@miamitownship.com';
'grogers@miamitownship.com'
Cc: Kingery, Jeanne W.
Subject: Duke Energy Ohio Power Siting Board Case No. 19-445-EL-BNR / Wards Corner Project
Attachments: Letter to Public Officials-WC.PDF

Good Afternoon:

Please see attached notification regarding the above-referenced project.

This notice is being provided in accordance with Ohio Power Siting Board rules.

Thank you.

Emily A. Olive, CP

Paralegal | Duke Energy Law Department

Duke Energy Corporation | PNC Bank Plaza, 155 East Broad Street, 20th Floor | Columbus, Ohio 43215

o: 614-222-1345 | f: 614-222-1337 | emily.olive@duke-energy.com



 please consider the environment before printing this email

CONFIDENTIAL NOTIFICATION:

The information in this email may be confidential and/or privileged. This email is intended to be reviewed by only the individual or organization named above. If you are not the intended recipient or an authorized representative of the intended recipient, you are hereby notified that any review, dissemination or copying of this email or its attachments, if any, or the information contained herein is prohibited. If you have received this email in error, please immediately notify the sender by return mail and delete this email from your system. Thank you.



March 8, 2019

PUBLIC OFFICIAL

Via Electronic Mail

**Construction Notice
Wards Corner Substation Improvements**

Dear Sir or Madam:

Please find below a link to an electronic copy of a Construction Notice that Duke Energy Ohio, Inc., (Duke Energy Ohio) has filed with the Ohio Power Siting Board regarding its proposed project to add approximately 800 feet of new transmission line just outside the substation along the west side of the property. The new transmission line on Duke Energy Ohio property will be supported by 8 steel poles, ranging from 69 feet to 142 feet above ground. The width of the base of the poles is approximately 6-feet in diameter, with a concrete foundation ranging from 8 to 9 feet in diameter. The equipment is designed to withstand the extreme summer temperatures as well as the plunging temperatures in the winter months. The work also will involve the removal of a lattice tower on Duke Energy Ohio property.

In accordance with O.A.C. 4906-1-01 Appendix A, we are required to prepare this Construction Notice for the Ohio Power Siting Board and, in compliance with O.A.C. 4906-6-07, we are hereby providing you with a link to an electronic copy.

A copy of the application is available for public inspection at the main office of Duke Energy Ohio at 139 E. Fourth Street, Cincinnati, Ohio 45202, and at the offices of the Ohio Power Siting Board, 180 East Broad Street, Columbus, Ohio 43215. The Application is also available on the Duke Energy Ohio website, at: <https://www.duke-energy.com/our-company/about-us/electric-transmission-projects/wards-corner> and on the Ohio Power Siting Board's website, at: <http://dis.puc.state.oh.us/CaseRecord.aspx?CaseNo=19-445&x=0&y=0>.

Cordially,

Duke Energy Ohio, Inc.

/s/ Rick Hicks

Senior Project Manager