

**Duke Energy Ohio
Case No. 20-1610-EL-BLN
STAFF Second Set of Data Requests
Date Received: January 13, 2021**

STAFF-DR-02-001

REQUEST:

The Existing structure 107H-1695 appears to be located very close to an eroding stream bank. Staff would recommend that this structure be removed by cutting it at the grade level and leaving the underground portion in place in order to prevent further erosion issues. Is this the applicant's present plan, and if not, is the applicant willing to commit to this removal method for this structure?

RESPONSE: Duke Energy Ohio is willing to commit to this removal method for this structure.

PERSON RESPONSIBLE: Dustin Giesler