

Appendix A

1 Customer Annual Energy Use

The customer uses over 20 million kWh per year. The monthly energy use for the previous three financial years is presented in tables below.

Monthly Energy Use for FY 2011		Monthly Energy Use for FY 2012		Monthly Energy Use for FY 2013	
Month - Year	Billed kWh	Month - Year	Billed kWh	Month-Year	Billed kWh
May-2011	1,198,507	May-2012	1,810,000	May-2013	1,796,706
June-2011	1,636,334	June-2012	2,091,000	June-2013	2,499,739
July-2011	2,114,151	July-2012	2,131,000	July-2013	1,793,126
August-2011	2,076,914	August-2012	1,972,742	August-2013	1,914,226
September-2011	2,117,751	September-2012	2,132,232	September-2013	2,221,714
October-2011	1,870,025	October-2012	1,685,863	October-2013	1,773,470
November-2011	1,844,978	November-2012	1,405,725	November-2013	1,708,325
December-2011	1,436,422	December-2012	1,490,256	December-2013	1,622,851
January-2012	1,434,834	January-2013	1,346,760	January-2014	1,316,544
February-2012	1,452,519	February-2013	1,377,700	February-2014	1,321,296
March-2012	1,526,821	March-2013	1,605,250	March-2014	1,640,976
April-2012	1,524,814	April-2013	1,585,795	April-2014	1,518,000
Total	20,234,070	Total	20,634,323	Total	21,126,973

The 3-year average baseline is thus:

$$\begin{aligned} & (20,234,070 \text{ kWh/year} + 20,634,323 \text{ kWh/year} + 21,126,973 \text{ kWh/year}) / 3 \\ & = 20,665,122 \text{ kWh/year} \end{aligned}$$

2 Project Implementation

1. The compressed air project was completely implemented and operational by the start of May 2014
2. The LED project upgrade was completed by the end of October 2013.

Note: Complete project details, along with energy savings calculations and methodologies are available in the *Energy Savings Analysis for General Mills* document provided with the application.

3 Project Life

The savings from both the projects will be realized for the entire useful life of the equipment. The project life for each project is explained below.

1. The useful project life for an air compressor is 15 years based on the OHIO TRM¹.
2. The useful project life for LED lighting is about 6 years, based on current runtime and studies conducted by Dept. of Energy².

¹ http://amppartners.org/pdf/TRM_Appendix_E_2011.pdf

² http://apps1.eere.energy.gov/buildings/publications/pdfs/ssl/lifetime_white_leds.pdf

4 Exemption Period

The savings from both the lighting and compressed air projects is 4% of the average annual energy use for the facility:

$$\begin{aligned} \text{Total savings} &= 508,033 \text{ kWh/year (compressed air)} + 327,624 \text{ kWh/year (lighting)} \\ &= 835,657 \text{ kWh/year} \end{aligned}$$

$$\text{Percent savings} = 835,657 \text{ kWh/year savings} / 20,665,122 \text{ kWh/year baseline} = 4.04\%$$

Hence the ongoing exemption period for the facility can be extended beyond the standard 24 months to 48 months. This should be acceptable based on the requirement of 1% savings per year. Furthermore the project life for both projects is well beyond 4 years.

5 Total Resource Cost Test

“The TRC value of the program is calculated by dividing the value of our avoided supply costs (generation capacity, energy, and any transmission or distribution) by the sum of our program overhead and installation costs and any incremental measure costs paid by either the customer or the electric utility.” – PUCO application

The TRC for the lighting and compressed air projects are presented in the table below.

Term	Value	Units
Savings		
Lighting Energy Savings (LS)	327,624 kWh/year	
Lighting Project Life (LL)	6 years	
Compressed Air Energy Savings (CAS)	508,033 kWh/year	
Compressed Air Project Life (CAL)	15 years	
Avoided Costs		
Average Utility Avoided Cost (AC)	\$0.050 /kWh	
Project Costs		
Lighting (\$L)	\$39,319 -	
Air Compressor (\$A)	\$153,033 -	
Other Administrative (\$O)	\$9,520 -	
Total Resource Cost Test		
Avoided Costs = (LS x LL + CAS x CAL) x AC	\$479,312	
Total Program Cost = \$L + \$A + \$O	\$201,872 -	
TRC = Avoided Costs / Total Program Cost	2.37	-

Table 1: TRC Calculations

The energy savings for the projects are presented in Appendix B followed by the invoices for the projects costs in Appendix C.

Appendix - B

Energy Savings Analysis

for

General Mills

By



June 2014

Table of Contents

Appendix - B	iii
1 Executive Summary	5
2 Compressed Air System Upgrade	6
2.1 Equipment Information and Project Description	6
2.2 Description of Calculation Methodology	6
2.3 Energy and Demand Savings Calculations	7
2.3.1 Compressed Air Flow Profile.....	7
2.3.2 Pre and Post- upgrade Power Profile.....	8
2.3.3 Normalized Compressed Air System Energy and Demand Savings.....	10
3 Lighting Upgrade	13
3.1 Equipment Information and Project Description	13
3.2 Description of Calculation Methodology	13
3.3 Energy and Demand Savings Calculations	13
Appendix – C	15

1 Executive Summary

Go Sustainable Energy was contracted by General Mills to perform energy savings analysis for the different energy efficiency projects implemented at the facility. The projects are briefly described below,

1. **Compressed Air System Upgrade:** This upgrade consisted of installing a new 125-hp variable frequency drive (VFD) compressor along with changes in the control system. General Mills anticipates that installing a smaller VFD compressor along with the changes in the control system would improve system efficiency resulting in energy and cost savings.
2. **Lighting Upgrade:** The majority of the facility’s lighting fixtures were 150-watt high pressure sodium (HPS) lamps. The upgrade consisted of replacing 275 of these HPS lamps and ballasts with 54-watt LED lamps and integral drivers. The reduced lamp wattage results in energy and demand savings for the facility.

Table 1 below summarizes the energy and demand savings from both projects. Details about the analysis and calculation methodologies are presented in the following sections.

Project	Energy Savings (kWh/year)	Peak Demand Reduction (kW)
Compressed Air System Upgrade	508,033	43.0
Lighting Upgrade	327,624	37.4
Total	835,657	80.4

Table 2: Summary of Energy and Demand Savings

2 Compressed Air System Upgrade

2.1 Equipment Information and Project Description

The facility currently has a total of four oil-free rotary-screw Atlas Copco compressors. Table 2 below lists the basic information about each compressor.

Comp #	Air Output (Nominal) acfm	Control	Model #	Nominal HP	Full Load CAGI Output (acfm)	CAGI Rated Power (kW)
C-1	900	Variable Speed	ZR 160 VSD	215	865	175
C-2	1100	Const Speed w. load/unload	ZR 200	250	1,087	197
C-3*	500	Variable Speed	ZR 90 VSD	125	504	112
C-4	1100	Const Speed w. load/unload	ZR 200	250	1,087	197

* New VFD Compressor (Post upgrade)

Table 3: Equipment Summary

We obtained trended data from the facility's ManageAir control system. The trended data ranges from November 2013 through mid-June 2014. This includes time periods before and after the upgrade.

The pre-upgrade scenario consisted of compressors C-1, C-2 and C-4. A typical VFD compressor can effectively vary its capacity, by reducing speed, to as low as 30%. However, below 30% fraction capacity a VFD compressor needs to turn on and off. This is not energy efficient and also increases wear on the compressor reducing its useful life. In the pre-upgrade scenario, the VFD compressor (C-1) was too large to trim effectively during production transition periods, and would have cycled on and off as we've described. To prevent excessive cycling of the VFD compressor, the control system was setup such that a load/unload compressor (C-2 or C-4) would run in the unload mode, during the low flow transition times as a standby compressor. A load/unload compressor produces no airflow in the unload mode. This control strategy was not efficient because an extra compressor would remain in the unload mode drawing power but not providing any air-flow.

The post-upgrade scenario consists of a new smaller VFD compressor (C-3). This compressor was sized such that it could be used as the trim compressor in the transition ranges where the larger VFD could not trim. The control sequences were modified to benefit from the addition of the smaller VFD. In addition to improved system performance, this also eliminated the need for having a large constant speed compressor in the unload mode. This results in a more efficient system than the baseline scenario.

2.2 Description of Calculation Methodology

The energy savings calculated here are based on the International Performance Measurement and Verification Protocol (IPMVP). The methodology uses the *Retrofit isolation – Option B (all parameter measurement)* path to quantify energy savings. The detailed methodology and calculations are outlined in the following sections.

2.3 Energy and Demand Savings Calculations

When performing measurement and verification on compressed air power draw, it is important to account for overall compressed air flow. Normalizing for flow is particularly important when analyzing a manufacturing facility's compressed air system, which will likely vary based on production over time. Flow normalization creates a flow profile for both the pre- and post-upgrade periods and then calculates a power draw based on the compressed air system's power profile. This method allows for a true comparison of the overall power draw in pre- and post-upgrade periods.

2.3.1 Compressed Air Flow Profile

The compressed air flow profile is a representation of the compressed air needs of a facility, which is mainly dependent on production. Hence the flow profile is independent of the air compressors and the control system. To generate a representative profile it is better to have a larger data set of typical production operation. We generated the flow profile using hourly flow data from the facility's compressed air control system for the time period January 5, 2014 through June 8, 2014, a total of about 22 weeks. This time period was selected after discussions with plant personnel to eliminate any erroneous and non-typical data points. Figure 1 below presents the flow data that was used to generate the flow profile. It includes both the pre- and post-upgrade scenarios as C-3 was fully operational by the start of May 2014.




Figure 1: Pre- and Post-Upgrade Compressed Air Consumption

It can be observed that compressed air flow is fairly consistent with some periods of high compressed air use. The flow profile is then generated by creating bins of the flow data and calculating the percentage time and average air flow in each bin. Table 4 and Figure 2 below, present the compressed air flow profile data.

Flow Bins (acfm)	Average Flow (acfm)	% Time	Hours Per Year
0	-	-	-
100	-	-	-
200	174	0%	15
300	265	1%	100
400	362	6%	538
500	446	8%	704
600	544	1%	127
700	652	2%	145
800	756	4%	347
900	853	10%	885
1,000	952	15%	1,335
1,100	1,050	21%	1,815
1,200	1,144	16%	1,420
1,300	1,238	6%	517
1,400	1,353	3%	287
1,500	1,455	3%	236
1,600	1,541	2%	190
1,700	1,636	1%	100
1,800	-	-	-
Total			8,760

Table 4: Flow Profile




Figure 2: Flow Profile

2.3.2 Pre and Post- upgrade Power Profile

A power profile characterizes the system’s power draw relative to the compressed air flow. It accounts for variables that cannot be accounted for in a theoretical approach, such as compressed air storage, unloaded time of a compressor etc. A power profile can be generated from the system power and air-flow for a representative period.

The system power and flow-data were obtained from the compressed air control system. Plant personnel stated that the power for C-2 was not being recorded due to a meter error. This was confirmed through the available data. Since only total system power was available, rather than power of each individual compressor, we chose January 2014 to create the pre-upgrade power profile, as C-2 was not operated in this month.

The new compressor C-3 was on site by the end of March 2014. However plant personnel stated that the compressor was offline due to a failed motor and a damaged compressor seal. This was also observed through the available data. C-3 was fully operational by mid May 2014. Eliminating the time periods when C-2 was operated, we used four weeks of data from May 11, 2014 through June 7, 2014 to create the post-upgrade power profile.

Figure 3 and Figure 4 below present the power and flow data used to generate the power profiles for the pre- and post-upgrade scenarios.




Figure 3: Pre-upgrade Flow and Power Data




Figure 4: Post-upgrade Flow and Power Data

Similar to the flow-profile, the average compressed air flow and the corresponding average power draw for the pre- and post-scenarios were calculated over a range of bins. Figure 5 below graphically presents the power profiles for both cases. The actual data for the pre- and post-scenarios are presented in Table 5 and Table 6 respectively




Figure 5: Pre- and Post-upgrade System Power Profiles

Flow Bins (acfm)	Average Flow (acfm)	Average Power (kW)
0		
100		
200	138	54.8
300	278	154.7
400	366	154.9
500	438	156.9
600	551	161.6
700	650	162.2
800	758	183.2
900	863	195.2
1,000	955	197.3
1,100	1,058	258.4
1,200	1,150	314.0
1,300	1,242	345.1
1,400	1,353	352.2
1,500	1,452	352.2
1,600	1,544	352.2
1,700	1,641	352.3
1,800		

Table 5: Pre-Upgrade Power Profile

Flow Bins (acfm)	Average Flow (acfm)	Average Power (kW)
0		
100		
200	166	62.1
300	250	63.3
400	365	68.9
500	427	70.2
600	546	93.5
700	660	125.9
800	757	144.9
900	853	162.7
1,000	963	184.9
1,100	1,048	203.7
1,200	1,138	222.1
1,300	1,237	241.1
1,400	1,361	274.2
1,500	1,452	285.5
1,600	1,550	301.5
1,700	1,637	309.4
1,800		

Table 6: Post-Upgrade Power Profile

2.3.3 Normalized Compressed Air System Energy and Demand Savings

The normalized system energy and peak demands are found by applying the system power profiles to the compressed air flow profile. The total system power for both scenarios is found for each average flow bin in Table 4 by linearly interpolating the flow and power data in Table 5 and Table 6. Figure 6 below, presents the data from the flow profile along with the pre- and post-upgrade power profiles.




Figure 6: Flow Profile along with Pre and Post-upgrade Power Profiles

Energy consumption for each bin is calculated by multiplying the power draw by the number of hours per year. The following example shows the calculation of power draw and energy consumption for the 200 cfm pre-upgrade scenario bin.

$$\begin{aligned}
 \text{Power}_{\text{pre}} (200 \text{ cfm}) &= 54.8 \text{ kW} + (154.7 \text{ kW} - 54.8 \text{ kW}) \times (174 \text{ cfm} - 138 \text{ cfm}) / (278 \text{ cfm} - 138 \text{ cfm}) \\
 &= 80.6 \text{ kW},
 \end{aligned}$$

$$\text{Energy}_{\text{pre}} (200 \text{ cfm}) = 80.6 \text{ kW} \times 15 \text{ hours/year} = 1,209 \text{ kWh/year}.$$

Similar calculations are performed to calculate the post-upgrade power and energy use. The energy savings is then the difference between the pre- and post- upgrade scenarios. Table 7 presents the annual energy analysis along with the savings.

Flow Bins (acfm)	Average Flow (acfm)	% Time	Hours Per Year	Pre Upgrade		Post Upgrade		Savings	
				Power (kW)	Energy (kWh)	Power (kW)	Energy (kWh)	Power (kW)	Energy (kWh)
0	-	-	-	-	-	-	-	-	-
100	-	-	-	-	-	-	-	-	-
200	174	0%	15	80.6	1,209	62.2	933	18.4	276
300	265	1%	100	145.8	14,580	64.1	6,410	81.7	8,170
400	362	6%	538	154.9	83,336	68.8	37,014	86.1	46,322
500	446	8%	704	157.3	110,739	74.0	52,096	83.3	58,643
600	544	1%	127	161.4	20,498	93.3	11,849	68.1	8,649
700	652	2%	145	162.5	23,563	123.7	17,937	38.8	5,626
800	756	4%	347	182.7	63,397	144.7	50,211	38.0	13,186
900	853	10%	885	194.1	171,779	162.9	144,167	31.2	27,612
1,000	952	15%	1,335	197.2	263,262	182.8	244,038	14.4	19,224
1,100	1,050	21%	1,815	254.1	461,192	204.2	370,623	49.9	90,569
1,200	1,144	16%	1,420	310.6	441,052	223.2	316,944	87.4	124,108
1,300	1,238	6%	517	343.5	177,590	241.3	124,752	102.2	52,838
1,400	1,353	3%	287	352.2	101,081	272.1	78,093	80.1	22,988
1,500	1,455	3%	236	352.2	83,119	286.0	67,496	66.2	15,623
1,600	1,541	2%	190	352.2	66,918	300.1	57,019	52.1	9,899
1,700	1,636	1%	100	352.3	35,230	309.3	30,930	43.0	4,300
1,800	-	-	-	-	-	-	-	-	-
Total			8,760		2,118,545		1,610,512		508,033

Table 7: Annual System Energy Analysis

The normalized annual energy savings is equal to the difference between the pre- and post-installation energy consumption, and is about,

$$\begin{aligned} \text{Annual energy savings} &= 2,118,545 \text{ kWh/year} - 1,610,512 \text{ kWh/year} \\ &= 508,033 \text{ kWh/year.} \end{aligned}$$

Since the flow profile is based on hourly flow data, the electrical demand will correspond with the peak flow. Hence, the demand savings is the difference in power draw for the bin with the highest air flow. In this case it is the difference in power for the 1,700 cfm bin.

$$\text{Demand Savings} = 352.3 \text{ kW} - 309.3 \text{ kW} = 43.0 \text{ kW}$$

3 Lighting Upgrade

3.1 Equipment Information and Project Description

In the pre-upgrade scenario, the majority of the facility’s lighting requirement was met by 275 150-watt high pressure sodium (HPS) lamps.

The upgrade consisted of replacing the HPS lamps with 54-watt LED lamps. The upgrade was completed by the end of October 2013. First, the HPS lamps were removed and the ballasts were disconnected. Then, direct replacement LED lamps with integral drivers were installed in the existing fixture. The reduced lamp wattage results in energy and demand savings for the facility. Figure 7 below shows an installed LED fixture.




Figure 7: Installed LED Fixtures

3.2 Description of Calculation Methodology

The energy savings calculated here are based on the International Performance Measurement and Verification Protocol (IPMVP). The methodology uses the *Retrofit isolation – Option A (key parameter measurement)* path to quantify energy savings. The detailed calculations are outlined in the following sections.

3.3 Energy and Demand Savings Calculations

Table 8 below presents the pre- and post-upgrade lighting fixtures.

Fixture Qty	Light Type	Fixture Draw (W)	Replacement Type	Fixture Draw (W)
275	150 W HPS	190	54W LED	54

Table 8: Pre and Post Lighting fixtures³

The demand reduction from the lighting upgrade can be calculated as,

$$\text{Demand reduction (kW)} = [\text{Current Power (kW/fixture)} - \text{Proposed Power (kW/fixture)}] \times \text{Quantity of Fixtures}$$

To determine the yearly electric energy reduction we multiply the power reduction by the number of annual operating hours of the fixtures. According to facility personnel these lights operate year round. Hence we use an operating time of 8,760 hours per year.

³ Fixture draw includes ballast for HPS lamps and drivers for LED lamps based on manufacturer’s data

$$\text{Energy reduction (kWh/year)} = \text{Demand reduction (kW)} \times \text{Annual operating hours (hours/year)}$$

The equations presented above were used to calculate the demand savings and electrical energy savings. The results are presented in Table 9 below.

Current Wattage (W)	Proposed Wattage (W)	Demand Reduction (kW)	Annual Hours (hr)	Energy Reduction (kWh/year)
190	54	37.4	8,760	327,624

Table 9: Energy and Demand Savings

Appendix – C

General Mills PURCHASE ORDER CONTRACT 41-1838090 Tax ID: Contract:		Render Invoice to: ACCOUNTS PAYABLE General Mills Operations, LLC Cincinnati Plant PO BOX 59145 MINNEAPOLIS, MN 55459-0145		Show Complete order number on delivery slips, invoices & outside of each package 70735403 Not valid for purchase	
OMNIQ LCC 5701 E INDIAN SCHOOL RD PHOENIX, AZ 85018 Contact: Phone: 480-264-1816 Vendor Nbr: 251023 Fax:		DELIVER CINCINNATI CEREAL 11301 MOSTELLER RD CINCINNATI, OH 45241-1827 Customer Nbr: Attention: DEL HOURS/M-F 7AM-3PM MAINT DOCK "B" GMI HOLDS DIRECT PAY PERMIT#98-002707. DO			
Payment Terms:		Freight Terms:		Ship Via:	
NT00 PAYABLE IMMEDIATELY		ZDD DOMESTIC - Destination Prepaid Add		BEST WAY	
				To Arrive: 9/18/2013	
				P.O. Date 9/10/2013	
Line	Qty	Units	Item	Description	Total
NEW ORDER					
1	275	EA		LL-E39 54W LED bulb for Mogul Base 277 Volt 5000 K color 2 Year warranty Lights to be 5000 K in color	
				UNIT	\$139.00
				TAX	0.00 %
				ITEM SUBTOTAL =	\$ 38,225.00
			Account Nbr	CL.-461003-2346....-7001	
			Project #	2346	Mark # 7001
			Requisition	1112610	
2	1	EA		Shipping	
				UNIT	\$1,094.00
				TAX	0.00 %
				ITEM SUBTOTAL =	\$ 1,094.00
			Account Nbr	CL.-461003-2346....-7001	
			Project #	2346	Mark # 7001
			Requisition	1112610	
					SUB TOTAL: \$ 39,319.00
					SUB TOTAL: \$ 0.00
					TOTAL: \$ 39,319.00
Comments:					

Figure 8: Implementation Cost for LED Lights

General Mills
PURCHASE ORDER CONTRACT
41-1838090
Tax ID:
Contract:

Render Invoice to: ACCOUNTS PAYABLE
General Mills Operations, LLC Cincinnati Plant
PO BOX 59145
MINNEAPOLIS, MN 55459-0145

Show Complete order number on delivery slips, invoices & outside of each package 70723622 Not valid for purchase

AIR TECHNOLOGIES
400 WRIGHT DR
MIDDLETOWN, OH 45044

Contact: TIM KILLEN
Phone: 513-539-8411
Vendor Nbr: 208934
Fax: 513-539-8416

DELIVER
CINCINNATI CEREAL
11301 MOSTELLER RD
CINCINNATI, OH 45241-1827
Customer Nbr:
Attention:

DEL HOURS M-F 7AM-3PM MAINT DOCK "B"
GMI HOLDS DIRECT PAY PERMIT#98-002707. DO

Payment Terms:	Freight Terms:	Ship Via:	To Arrive:	P.O. Date	
NT30 NET 30 DAYS	ZDD DOMESTIC - Destination Prepaid Add	BEST WAY	8/6/2013	8/6/2013	
Line	Qty	Units	Item	Description	Total

NEW ORDER

1	1 EA			125HP Vairable Speed Air Compressor, 159 - 547 cfm @ 125 psi ZR90VSDFFIMD (125 HP) oil free, variable speed, water-cooled, rotary screw air compressor 460/3/60, Rated for 159 - 547 cfm @ 125 psi, Includes integrated heat of compression dryer ZR90VSDFFIMD	
---	------	--	--	---	--

UNIT	\$152,348.00	\$	152,348.00
TAX	0.00%	\$	0.00
ITEM SUBTOTAL =		\$	152,348.00

Account Nbr CI..461000-2340.....-2001
Project # 2340
Requisition 1096678
Mark # 2001

2	1 EA			Air Technologies factory authorized start-up service	
---	------	--	--	--	--

UNIT	\$685.00	\$	685.00
TAX	0.00%	\$	0.00
ITEM SUBTOTAL =		\$	685.00

Account Nbr CI..461000-2340.....-2096
Project # 2340
Requisition 1096678
Mark # 2096

SUB TOTAL:	\$	153,033.00
SUB TOTAL:	\$	0.00
TOTAL:	\$	153,033.00

Figure 9: Implementation Cost for Compressed Air Project

GENERAL MILLS OPERATIONS, LLC PURCHASE ORDER CONTRACT TAX ID NUMBER: 41-1838090		RENDER INVOICE TO: ACCOUNTS PAYABLE PO BOX 59145 MINNEAPOLIS, MN 55459-0145 Telephone: 763-293-2755 Fax Invoices to: 763-293-3318 Email Invoices to: AP.US@genmills.com		Show complete order number on delivery slips, invoices & outside of each package 70810374	
GO SUSTAINABLE ENERGY LLC 3709 N HIGH ST STE 100 COLUMBUS, OH 43214 CONTACT: PHONE: 614-268-4263 VENDOR# CI 253094 FAX: 866-623-7716		DELIVER TO: CINCINNATI CEREAL 11301 MOSTELLER RD CINCINNATI, OH 45241-1827 CUSTOMER# ATTN: * DEL HOURS/M-F 7AM-3PM MAINT DOCK "B" * GMI HOLDS DIRECT PAY PERMIT#98-002707. DO NOT CHARGE OHIO SALES/USE TAX		PAGE 1	
FREIGHT TERMS DOMESTIC - Destination Prepaid Add		PAYMENT TERMS NET 30 DAYS		SHIP VIA BEST WAY	
				TO ARRIVE 04/27/2014	
				P.O. DATE 04/27/2014	
LN#	QUANTITY	UNIT	DESCRIPTION		PRICE
*** New Purchase Order ***					
1	1	EA	Energy Consultant and PUCO Representative Study, Report Prep, and Presentation to PUCO Collect all data and present documentation for submission of the energy projects to the PUCO. The PUCO stated that a robust and defensible energy savings calculation would need to be submitted for the projects. This is what they said was the biggest deficiency of the previous submission. Unfortunately, calculations for several of the projects would require logging the power and performance of the systems. Furthermore, the analysis would be time intensive, and would be greater than what the OMA could support.		
			REQUISITION #	1209966	
			UNIT PRICE	= USD	9,520.00
			TAX @ 0.0	= USD	0.00
			ITEM SUBTOTAL	= USD	9,520.00
			SUBTOTAL ITEMS	= USD	9,520.00
			SUBTOTAL TAX	= USD	0.00
			TOTAL	= USD	9,520.00
COMMENTS: Energy Consultant PUCO					

Figure 10: Other Administrative Costs for the Project