

**FILE**

**Staff Investigation Report and Recommendation**

**Case No.:** 07-615-EL-BLN

**Project:** Eastlake-Lloyd 138 kV Transmission Line  
Tap to Progressive Substation

**Applicants:** American Transmission Systems, Inc.  
Cleveland Electric Illuminating Company

**Report Date:** 28 June 2007

**Automatic Approval Date:** 7 July 2007 (Letter of Notification process)

**Waiver Requests:** None

**Inspection Date(s):** 5 June 2007

**Staff Assigned:** J. O'Dell

**Summary of Staff Recommendations (see report text for discussion):**

Application: ☒ Approval ☐ Disapproval ☐ Approval with Conditions  
Waiver: ☐ Approval ☐ Disapproval ☒ Not Applicable

**Summary of Staff Recommended Conditions (see report text for discussion):**

- None

**Projected Docket Closure Date (if automatically approved):** 31 January 2010

**Investigation Report**

**Project Description:** This project involves the installation of approximately 15 feet of double circuit 138 kV transmission line. A new three-pole tap structure would also be installed within the r-o-w of the existing transmission line. The line is needed to provide service to a proposed new distribution substation.

**Site Description:** Land use in proximity to the project consists of commercial and interstate highway uses. The project is located in the Village of Mayfield, Cuyahoga County. No significant vegetative clearing is required and access is available from an adjacent parking lot.

**Discussion/Comments/Concerns:** The construction of this project should pose only minimal negative social and ecological impacts.

This is to certify that the images appearing are an  
accurate and complete reproduction of a case file  
document delivered in the regular course of business.  
Technician JO Date Processed 6-29-07

RECEIVED-DOCKETING DIV  
2007 JUN 29 AM 7:34  
PUCO