

FILE

2



Bricker & Eckler
ATTORNEYS AT LAW

COLUMBUS • CLEVELAND

BRICKER & ECKLER LLP
100 South Third Street
Columbus, Ohio 43215-4291
MAIN: 614.227.2300
FAX: 614.227.2390

www.bricker.com
info@bricker.com

Sally W. Bloomfield
614.227.2368
sbloomfield@bricker.com

August 5, 2008

VIA HAND DELIVERY

Ms. Renee Jenkins
Public Utilities Commission of Ohio
Administration/Docketing
180 East Broad Street, 13th Floor
Columbus, OH 43215-3793

**Re: Case No. 07-252-WS-UNC
Ohio American Water Company
Stipulation Page No. 17, ¶15**

Dear Ms. Jenkins:

Pursuant to the Commission's March 7, 2007 Opinion and Order in Case No. 06-433-WS-AIR, Ohio American Water Company submits for filing the July 2008 Hardness Report for the Marion district.

If you have any questions, please call me at the number listed above.

Sincerely,

Sally W. Bloomfield

Enclosure

cc: Parties of Record (w/Enclosure)

RECEIVED-DOCKETING DIV
2008 AUG -5 AM 11:49
PUCO

This is to certify that the images appearing are an accurate and complete reproduction of a case file document delivered in the regular course of business
Technician And Date Processed 8/17/08

OHIO AMERICAN WATER COMPANY
MARION - DISTRICT

2008

EFFLUENT HARDNESS / MG/L

July	RAW HARDNESS MG/L	EFFLUENT HARDNESS MG/L
1	450	140
2	388	137
3	388	142
4	415	145
5	441	144
6	420	141
7	410	140
8	406	139
9	413	139
10	399	148
11	350	143
12	357	141
13	362	147
14	374	147
15	366	145
16	366	143
17	373	143
18	385	145
19	416	142
20	426	146
21	423	145
22	418	137
23	418	140
24	410	136
25	414	141
26	442	143
27	435	143
28	420	136
29	420	132
30	430	143
31	464	149
AVERAGE	406	142
MAX	464	149
MIN	350	132

JULY 2008
EFFLUENT HARDNESS AVG - 142 MG/L
MARION DISTRICT

