

FILE

13



Bricker & Eckler
ATTORNEYS AT LAW

COLUMBUS | CLEVELAND
CINCINNATI-DAYTON

BRICKER & ECKLER LLP
100 South Third Street
Columbus, Ohio 43215-4291
MAIN: 614.227.2300
FAX: 614.227.2390

www.bricker.com
info@bricker.com

Sally W. Bloomfield
614.227.2368
sbloomfield@bricker.com

October 16, 2008

VIA HAND DELIVERY

Ms. Renee Jenkins
Public Utilities Commission of Ohio
Administration/Docketing
180 East Broad Street, 13th Floor
Columbus, OH 43215-3793

**Re: Case No. 07-252-WS-UNC
Ohio American Water Company
Stipulation Page No. 20, ¶18 L**

Dear Ms. Jenkins:

Pursuant to the Commission's March 7, 2007 Opinion and Order in Case No. 06-433-WS-AIR, Ohio American Water Company ("Ohio American") submits for filing its compliance with the Stipulation and Recommendation, page 20 paragraph 18 L pertaining to the submission of leak logs for the third quarter of 2008.

If you have any questions, please call me at the number listed above.

Sincerely,

Sally W. Bloomfield

Enclosure

cc: Parties of Record (w/Enclosure)

RECEIVED-DOCKETING DIV
2008 OCT 16 PM 3:40
PUCO

This is to certify that the images appearing are an
accurate and complete reproduction of a case file
document delivered in the regular course of business.
Technician Date Processed

OCT 16 2008

Ohio American Water Company

Ashtabula District

2007 Water Leak Log

CSL = Company Service Leak; CWM = Company Water Main; HYD = Hydrant; VLV = Valve; CO = Company Other; PSL = Private Service Leak; PWM = Private Water Main; PO = Private Other; DR = Door Tag DTID = Door to Door															
Location	Service Area	Township	Leak Type	Size	Boil Order (Y or N)	Number of Services Affected	Method of Notification	Date Boil Order Lifted	Report Date	Repair Date	Elapsed Days	Size of Restoration	Type of Restoration	Restoration Completed	Comment
1 DANE	E SIDE		CSL	3/4"	N		1 DR		12/31/2007	1/2/2008		2 8 x 3	STREET	7/08	
2 WILSON	E SIDE		CWM	6"	Y	75	DTID	1/8/2008	1/4/2008	1/4/2008	0	20 x 8	STREET	7/08	
3 EASTWOOD	HARBOR		CWM	6"	Y	11	DTID	1/6/2008	1/4/2008	1/4/2008	0	14 x 7	DRIVEWAY	4/08	
4 MICHIGAN	CENTRAL		CWM	2"	N	0			1/7/2008	1/8/2008	0	1 6 x 12	STREET	4/08	
5 HUMPHREY	CENTRAL		CWM	2"	N	0			1/3/2008	1/8/2008	0	6 3 x 5	TREELAWN	5/08	
6 GLOVER	CENTRAL		CSL	8"	N	0			1/2/2008	1/7/2008	0	0 12 x 8	TREELAWN	5/08	
7 FERN	W SIDE		CWM	2 1/2"	N	0			1/8/2008	1/11/2008	0	3 10 x 5	STREET	4/08	
8 W 9TH	HARBOR		CWM	6"	N	0			1/8/2008	1/14/2008	0	5 8 x 8	STREET	4/08	
9 CHURCH	NK		CWM	6"	Y	16	DTID	1/19/2008	1/16/2008	1/16/2008	0	8 x 10	STREET	4/08	
10 TIVISON	HARBOR		CSL	2"	Y	5	DTID	1/19/2008	1/17/2008	1/17/2008	0	1 3 x 4	STREET	7/08	
11 ALLEN	HARBOR		CWM	6"	N	0			1/25/2008	1/25/2008	0	0 8 x 8	DRIVEWAY	6/08	
12 E 20TH	E SIDE		CWM	2"	Y	3	DTID	1/30/2008	1/28/2008	1/28/2008	0	1 10 x 13	STREET	5/08	
13 PARK	CENTRAL		CWM	12"	N	0			1/28/2008	1/28/2008	0	0 12 x 20	STREET	5/08	
14 FOREST & TALL TREES	N CENTRAL		CWM	6"	N	0			1/25/2008	1/28/2008	0	1 12 x 12	OTHER	5/08	
15 W 59TH	CENTRAL		CWM	6"	N	0			1/27/2008	1/27/2008	0	0 4 x 8	STREET	4/08	
16 HUMPHREY	CENTRAL		CWM	2"	N	0			1/22/2008	1/28/2008	0	8 12 x 14	STREET	4/08	
17 SCHENLEY	CENTRAL		CWM	6"	Y	12	DTID	1/30/2008	1/28/2008	1/28/2008	0	8 x 8	STREET	4/08	
18 TIVISON	HARBOR		CWM	2 1/2"	N	0			1/28/2008	1/28/2008	0	0 4 x 20	STREET	5/08	
19 WEST	W SIDE		CWM	6"	N	50			1/30/2008	1/30/2008	0	1 12 x 18	STREET	5/08	
20 TOPPER	E SIDE		CLS	3/4"	N	0			1/30/2008	1/30/2008	0	4 x 5	TREELAWN	5/08	
21 LAIRD	HARBOR		CWM	6"	N	0			1/31/2008	2/6/2008	0	4 x 5	STREET	4/08	
22 RT 20	CENTRAL		VLV	10"	N	0			1/31/2008	2/6/2008	0	8 x 8	STREET	4/08	
23 LAKE	CENTRAL		VLV	10"	N	0			2/1/2008	2/1/2008	0	4 x 5	STREET	4/08	
24 CRAWFORD	W SIDE		CWM	2 1/2"	N	0			2/1/2008	2/1/2008	0	0 10 x 40	TREELAWN	6/08	
25 W 9TH	HARBOR		CWM	10"	Y	26	DTID	2/5/2008	2/3/2008	2/3/2008	0	0 5 x 12	STREET	4/08	
26 PARK	CENTRAL		CSL	2"	N	0			2/4/2008	2/4/2008	0	0 4 x 5	STREET	4/08	
27 MICHIGAN	CENTRAL		CWM	2"	N	0			2/7/2008	2/7/2008	0	0 4 x 8	STREET	4/08	
28 SILVUS	E SIDE		CWM	2"	N	0			2/7/2008	2/7/2008	0	1 4 x 8	STREET	4/08	
29 S RIDGE W	E SIDE		CSL	3/4"	N	0			2/13/2008	2/13/2008	0	0 4 x 8	STREET	4/08	
30 E 15TH	HARBOR		CWM	10"	N	0			2/14/2008	2/15/2008	0	1 4 x 8	STREET	4/08	
31 WALNUT	HARBOR		CSL	3/4"	N	0			2/14/2008	2/14/2008	0	0		5/08	
32 LAKE	E SIDE		CWM	12"	N	0			2/15/2008	2/22/2008	0	7 8 x 10	TREELAWN	6/08	
33 RT 193	NK		CWM	4"	N	0			2/18/2008	2/18/2008	0	0		5/08	
34 TIVISON	HARBOR		CWM	2 1/2"	N	0			2/19/2008	2/19/2008	0	0 4 x 8	STREET	4/08	
35 E 42ND	E SIDE		CWM	6"	N	0			2/22/2008	2/22/2008	0	0 8 x 25	TREELAWN	6/08	
36 MCNUTT	W SIDE		CWM	8"	N	0			2/23/2008	2/23/2008	0	0 8 x 8	STREET	4/08	
37 TIVISON	HARBOR		CWM	2 1/2"	N	0			2/24/2008	2/25/2008	0	1 5 x 8	STREET	4/08	
38 CARPENTER	HARBOR		CWM	8"	Y	55	DTID	2/27/2008	2/27/2008	2/27/2008	0	0 4 x 4	TREELAWN	6/08	
39 HOMEWOOD	E SIDE		CSL	8"	Y	41	DTID	3/2/2008	2/29/2008	2/29/2008	0	0 4 x 10	TREELAWN	6/08	
40 FARGO & E 9TH	E SIDE		VLV	6"	N	0			3/3/2008	3/3/2008	0	0 6 x 14	STREET	4/08	
41 RT 20	NK		HYD	6"	N	0			3/7/2008	3/7/2008	0	0 5 x 8	TREELAWN	7/08	
42 AVONDALE	E SIDE		HYD	6"	N	0			3/7/2008	3/8/2008	0	1 5 x 7	TREELAWN	7/08	
43 E 39TH	E SIDE		VLV	2"	N	0			3/8/2008	3/9/08	0	4 x 7	STREET	6/08	
44 E 29TH	E SIDE		CWM	2"	N	0			3/10/2008	3/10/08	0	0 5 x 8	STREET	6/08	
45 W 29TH	W SIDE		CWM	2"	N	0			3/10/2008	3/10/08	0	0 5 x 8	STREET	6/08	
46 E 29TH	E SIDE		CWM	2"	N	0			3/20/2008	3/20/08	0	0 8 x 8	STREET	6/08	
47 ANN & W 41ST	CENTRAL		CSL	3/4"	N	0			3/20/2008	3/20/08	0	0 6 x 12	STREET	6/08	
48 LAKE	HARBOR		CSL	2"	N	0			3/20/2008	3/21/08	0	1 11 x 15	STREET	7/08	
49 2930 S RIDGE E	E SIDE		CSL	3/4"	Y	0			4/1/2008	4/8/08	0	7 20 x 3	STREET	7/08	
50 333 FOX	CENTRAL		CWM	2 1/2"	N	0			4/1/2008	4/1/08	0	0 5 x 18	STREET	7/08	
51 4117 LAKE	HARBOR		VLV	2"	N	0			4/2/2008	4/3/08	0	1 6 x 5	STREET	6/08	
52 3610 SILVUS	E SIDE		CWM	2"	N	0			4/3/2008	4/3/08	0	0 8 x 8	STREET	7/08	
53 LAKEWEST/CARPENTER	HARBOR		CWM	12"	N	0			4/1/2008	4/4/08	0	3 6 x 8	STREET	6/08	
54 4117 LAKE	HARBOR		CSL	2"	N	0			4/2/2008	4/4/08	0	2 6 x 8	STREET	6/08	
55 3824 SILVUS	E SIDE		CSL	3/4"	N	0			4/4/2008	4/4/08	0	0 8 x 8	STREET	7/08	
56 WOODLEY	HARBOR		CWM	2"	N	0			4/6/2008	4/6/08	0	0 7 x 8	STREET	7/08	
57 FOX	CENTRAL		CWM	2 1/2"	N	0			3/21/2008	4/2/08	0	12 5 x 18	STREET	7/08	
58 KAVELA	HARBOR		CWM	2"	Y	8	DTID	4/11/2008	4/10/2008	4/10/08	0	0 4 x 8	STREET	7/08	
59 5514 MAIN	CENTRAL		CSL	3/4"	N	0			4/14/2008	4/16/08	0	2 4 x 18	DRIVEWAY	6/08	
60 5618 MADISON	CENTRAL		CWM	2"	N	0			4/15/2008	4/16/08	0	1 5 x 8	STREET	6/08	
61 5636 REED	CENTRAL		CO	3/4"	N	0			4/15/2008	4/16/08	0	3 4 x 5	TREELAWN	6/08	
62 3215 BLAIR	E SIDE		CWM	2"	N	0			4/16/2008	4/16/08	0	2 12 x 8	TREELAWN	6/08	
63 5127 REED	CENTRAL		CSL	3/4"	N	0			4/17/2008	4/18/08	0	1 2 x 4	TREELAWN	6/08	
64 7416 AUSTINBURG	CENTRAL		CSL	3/4"	N	0			4/24/2008	4/25/08	0	1 3 x 12	TREELAWN	6/08	
65 1735 W 8TH	HARBOR		CSL	3/4"	N	0			4/24/2008	4/25/08	0	1 4 x 4	TREELAWN	7/08	
66 2723 TRYON	W SIDE		CSL	3/4"	N	0			4/24/2008	4/24/08	0	0 8 x 3	TREELAWN	7/08	
67 2514 ASHBROOK	W SIDE		CWM	8"	Y	15	DTID	4/30/2008	4/24/2008	4/29/08	0	9 4 x 3	TREELAWN	6/08	
68 1841 S EDWARD	CENTRAL		CWM	2 1/2"	N	0			4/23/2008	5/1/08	0	7 4 x 8	STREET	6/08	

CSL = Company Service Leak; CWM = Company Water Main; HYD = Hydrant; VLV = Valve; CO = Company Other; PSL = Private Service Leak; PVM = Private Water Main; PC = Private Other DR= Door Tag DTD= Door to Door

Location	Service Area	Township	Leak Type	Size	Boil Order (Y or N)	Number of Services Affected	Method of Notification	Date Boil Order Lifted	Report Date	Repair Date	Elapsed Days	Size of Restoration	Type of Restoration	Date Restoration Completed	Comment
69 833 BUNKER HILL	CENTRAL		CWM	2"	N	0			4/25/2008	4/25/2008	0	18 x 8	STREET	8/08	
70 1817 W 9TH	HARBOR		CSL	6"	N	0			5/1/2008	5/1/2008	0	6 x 7	STREET	8/08	
71 5006 N WOODMAN	W SIDE		CWM	6"	Y	19		5/5/2008	5/4/2008	5/4/2008	0	6 x 6	TREELAWN	8/08	
72 6243 RUNKLE	CENTRAL		CWM	2"	N	0			4/23/2008	5/5/08	12	3 x 4	STREET	8/08	
73 1424 AUSTINBURG	CENTRAL		CSL	3/4"	N	0			4/25/2008	5/5/08	10	10 x 5	TREELAWN	8/08	
79 783 E 14TH	HARBOR		CSL	3/4"	N	0			5/5/2008	5/5/08	0	4 x 4	SIDEWALK	8/08	
80 2868 E CENTER	NK		VLV	5"	N	0			5/5/2008	5/5/08	0	4 x 4	TREELAWN	7/08	
81 2001 BROADWAY	W SIDE		CWM	6"	N	0			5/15/2008	5/15/08	0	6 x 8	STREET	9/08	
82 6317 AUSTIN	CENTRAL		CWM	6"	N	0			5/15/2008	5/15/08	0	4 x 8	TREELAWN	9/08	
83 1257 HARMON	E SIDE		CWM	6"	N	0			5/15/2008	5/15/08	0	8 x 12	DRIVEWAY	8/08	
84 401 THAYER	HARBOR		CSL	3/4"	N	0			5/1/2008	5/1/08	0	4 x 6	STREET	8/08	
85 UNCON N	E SIDE		CWM	6"	N	0			5/21/2008	5/21/08	0	8 x 10	DRIVEWAY	8/08	
86 6236 AUSTIN	CENTRAL		VLV	6"	N	0			5/30/2008	5/30/08	0	8 x 12	TREELAWN	7/08	
87 6431 FOREST	CENTRAL		CSL	3/4"	N	0			6/2/2008	6/6/08	4	3 x 4	TREELAWN	7/08	
88 1520 W 7TH	HARBOR		CWM	2 1/2"	N	0			6/12/2008	6/12/08	0	3 x 4	TREELAWN	7/08	
89 1542 COLUMBUS	HARBOR		CWM	8"	Y	80		6/14/2008	6/13/2008	6/13/08	0	12 x 12	STREET	8/08	
90 5019 S MAIN	CENTRAL		CSL	2"	N	0			6/13/2008	6/18/08	5	3 x 6	STREET	8/08	
91 1016 W 54TH	W SIDE		CSL	3/4"	N	0			6/18/2008	6/18/08	0	4 x 5	TREELAWN	8/08	
92 1316 W 47TH	W SIDE		CWM	2"	N	0			6/18/2008	6/18/08	0	17 x 14	STREET	8/08	
93 3113 BLAIR	E SIDE		CWM	2"	N	0			6/18/2008	6/19/08	0	4 x 10	STREET	9/08	
94 2511 HIGHLAND	HARBOR		CWM	2"	N	0			6/21/2008	6/19/08	0	4 x 7	STREET	9/08	
95 2730 SOUTHLANE	HARBOR		CSL	3/4"	N	0			6/21/2008	6/21/08	0	5 x 7	TREELAWN	8/08	
96 3817 WEST	W SIDE		CSL	6"	N	0			6/25/2008	6/25/08	0	5 x 5	STREET	8/08	
97 1211 NORWOOD	HARBOR		CSL	3/4"	N	0			6/21/2008	6/21/08	0	4 x 4	TREELAWN	8/08	RESTORATION TO BE DONE
98 FERRY DR	HARBOR		CWM	6"	N	0			7/2/2008	7/2/08	0	8 x 5	TREELAWN	8/08	
99 LAKE AVE & RODGERS PL	CENTRAL		VLV	6"	N	0			7/2/2008	7/7/08	5	6 x 8	STREET	8/08	
100 727 W 36TH ST	CENTRAL		CWM	2"	N	0			7/17/2008	7/18/08	1	15 x 5	STREET	9/08	
101 3207 BLAIR AVE	E SIDE		CWM	2"	N	0			7/18/2008	7/25/08	6	3 x 9	DRIVEWAY	9/08	
102 915 W 34TH ST	CENTRAL		CSL	3/4"	N	0			7/28/2008	7/28/08	0	4 x 4	TREELAWN	9/08	
103 FOREST & TALL TREES	N. CENTRAL		CWM	6"	N	0			7/28/2008	7/28/08	0	8 x 12	STREET		RESTORATION TO BE DONE
104 1011 W PROSPECT	CENTRAL		PSL	3/4"	N	0			8/1/2008	8/1/08	0	0	STREET		RESTORATION TO BE DONE
105 5816 MAIN AVE	CENTRAL		PSL	3/4"	N	0			8/1/2008	8/1/08	0	3 x 6	TREELAWN		RESTORATION TO BE DONE
106 7320 KINGSBORO	CENTRAL		CSL	6"	N	20			8/7/2008	8/7/08	0	4 x 6	TREELAWN		RESTORATION TO BE DONE
107 822 W 36TH ST	CENTRAL		CSL	3/4"	N	0			8/13/2008	8/15/2008	2	4 x 4	TREELAWN		RESTORATION TO BE DONE
108 674 SANBORN RD	CENTRAL	SAVYBROOK	CWM	8"	N	24			8/13/2008	8/15/2008	2	3 x 4	TREELAWN		RESTORATION TO BE DONE
109 W 69RD ST & RUNKLE AVE	S. CENTRAL		CWM	2"	N	4			8/15/2008	8/20/2008	5	6 x 5	STREET		RESTORATION TO BE DONE
110 4709 FERN AVE	W. CENTRAL		CWM	2"	N	7			8/21/2008	8/21/2008	0	4 x 15	STREET		RESTORATION TO BE DONE
111 WESTSHORE DR	HARBOR		HYD	5"	N	23			8/21/2008	8/25/2008	4	12 x 12	TREELAWN		RESTORATION TO BE DONE
112 1803 W 14TH ST	HARBOR		CWM	2"	N	0			8/28/2008	8/28/2008	0	3 x 8	STREET		RESTORATION TO BE DONE
113 4629 TOPPER AVE	E CENTRAL		CWM	6"	N	0			8/28/2008	8/28/2008	0	4 x 6	STREET		RESTORATION TO BE DONE
114 105 W 36TH ST	S. CENTRAL		CWM	2"	N	0			8/29/2008	8/29/2008	0	5 x 8	TREELAWN		RESTORATION TO BE DONE
115 628 TALL TREES	HARBOR		CWM	2"	N	0			9/2/2008	9/5/2008	3	4 x 6	TREELAWN		RESTORATION TO BE DONE
116 3817 SILVIEUS	E SIDE		CWM	6"	N	0			9/2/2008	9/5/2008	3	4 x 6	STREET		RESTORATION TO BE DONE
117 CARPENTER	HARBOR		CWM	8"	N	0			9/2/2008	9/8/2008	6	4 x 12	STREET		RESTORATION TO BE DONE
118 1207 W 3RD ST	HARBOR		CSL	3/4"	N	0			9/10/2008	9/15/2008	4	5 x 13	STREET		RESTORATION TO BE DONE
119 2533 W 8TH ST	HARBOR		CWM	2"	N	0			9/15/2008	9/22/2008	7	8 x 5	STREET		RESTORATION TO BE DONE
120 4015 DENISE DR	NK		CWM	6"	N	22			9/16/2008	9/23/2008	7	10 x 15	TREELAWN		RESTORATION TO BE DONE
121 E 31ST & COLUMBUS	CENTRAL		CWM	20"	N	0			9/16/2008	9/25/2008	9	7 x 10 x 12	TREELAWN		RESTORATION TO BE DONE
122 3328 BLAKE	CENTRAL		CWM	6"	N	0			9/25/2008	9/25/2008	0	4 x 6	TREELAWN		RESTORATION TO BE DONE
123 UNION & HIGHLAND CRCL	HARBOR		CWM	2"	N	0			9/28/2008	9/28/2008	0	7 x 8	STREET		RESTORATION TO BE DONE
124 831 COLUMBUS AVE	CENTRAL		CWM	6"	N	1			9/25/2008	9/29/2008	4	4 x 5	TREELAWN		RESTORATION TO BE DONE

**Ohio American Water Company
Franklin County District
2008 Water Leak Log - Ending 3rd Quarter**

rank; VLV = Valve; CO = Company Other; PSL = Private Service Leak; PHM = Private Water Main; PO = Private Other

	Location	Service Area	Township	Leak Type	Size	Boil Order (Y or N)	Number of Customers Affected	Method of Notification	Date Boil Order Filed	Report Date	Repair Date	Elapsed Days	Size of Restoration	Type of Restoration	Date Restoration Completed	Comment
1	3318 Letonia	BL	Madison	CSL	3/4"	N	1	N/A	N/A	1/10/08	1/14/08	4	3X5	Dirt	6/24/2008	Customer made appt. to have service shut off for repairs. Curb valve would not shut off completely. CV found leaking while replacing.
2	3510 Verdun	BL	Madison	CSL	3/4"	N	1	N/A	N/A	1/10/08	1/14/08	4	3X5	Dirt	4/30/2008	Curb valve leaking. CV replaced
3	3137 Wendover Court	BL	Madison	PSL	3/4"	N	1	N/A	N/A	1/18/08	1/25/08	7	PSL	Dirt	PSL	Private Leak Replaced
4	3559 Wyndale	BL	Madison	CSL	3/4"	N	1	N/A	N/A	2/13/08	2/19/08	6	3X5	Dirt	4/30/2008	Curb valve leaking. CV replaced
5	3270 Wyndale	BL	Madison	CSL	3/4"	N	1	N/A	N/A	2/12/08	2/20/08	13	3X5	Dirt	6/24/2008	Curb valve leaking. CV replaced
6	5463 Sedalia	BL	Madison	CSL	3/4"	N	1	N/A	N/A	2/22/08	3/5/08	11	3X5	Dirt	4/30/2008	Curb valve leaking-CV replaced
7	3809 Lefebvre	BL	Madison	CSL	1/2"	N	0	N/A	N/A	3/2/08	3/2/08	1	3X5	Dirt	6/24/2008	12" Raw water main leak-Repaired with clamp
8	5116 Sedalia	BL	Madison	PSL	1"	N	1	N/A	N/A	3/13/08	3/14/08	1	PSL	PSL	PSL	Contractor hit meter inside shopping center while doing demolition-Shut off at curb valve-Suite are being combined
9	4937 Brewster Drive	BL	Madison	PSL	3/4"	N	1	N/A	N/A	3/25/08	4/1/08	7	PSL	PSL	PSL	Private Leak Replaced
10	4937 Brewster Drive	BL	Madison	CSL	3/4"	N	1	N/A	N/A	4/1/08	4/3/08	2	3X5	Dirt	6/24/2008	Flare fitting leaking at corp stop. Replaced service from main to new curb valve
11	3549 Transview	BL	Madison	CSL	3/4"	N	1	N/A	N/A	4/23/08	4/29/08	6	3X5	Dirt	6/24/2008	Curb valve leaking-CV replaced
12	3424 Beachworth	BL	Madison	CSL	3/4"	N	2	N/A	N/A	5/12/08	5/23/08	14	3X5	Dirt	6/24/2008	Curb valve leaking. 2 CV's replaced
13	3172 Portman	BL	Madison	PSL	3/4"	N	1	N/A	N/A	5/9/08	5/19/08	11	PSL	Dirt	PSL	Private Leak Replaced
14	3262 Fontaine	BL	Madison	CSL	3/4"	N	1	N/A	N/A	5/20/08	5/28/08	8	3X5	Dirt	6/24/2008	Curb valve leaking. CV replaced
15	5019 Brewster	BL	Madison	CSL	3/4"	N	1	N/A	N/A	5/28/08	5/31/08	3	3X5	Dirt	6/24/2008	Company service leak-Repaired
16	2868 Olivette	BL	Madison	PSL	3/4"	N	1	N/A	N/A	6/9/08	6/12/08	4	PSL	PSL	PSL	Private Leak Replaced
17	3384 Araby	BL	Madison	PSL	PSL	N	1	N/A	N/A	6/11/08	6/12/08	1	PSL	PSL	PSL	Private Leak Replaced
18	4870 Euclid	BL	Madison	CSL	3/4"	N	1	N/A	N/A	7/11/08	7/14/08	3	3X5	Dirt	Pending	Company service leak-Repaired
19	5590 Newport Court	BL	Madison	CSL	3/4"	N	1	N/A	N/A	7/10/08	7/14/08	4	3X5	Dirt	Pending	Company valve leaking-CV replaced
20	4854 Brewster	BL	Madison	CSL	3/4"	N	1	N/A	N/A	7/14/08	7/21/08	7	6X10	Pavement	Pending	Company service leak-Repaired
21	3511 Rodell	BL	Madison	CSL	3/4"	N	1	N/A	N/A	7/17/08	7/22/08	5	3X5	Dirt	Pending	Company valve leaking-CV replaced
22	4847 Albany	BL	Madison	PSL	PSL	N	1	N/A	N/A	7/22/08	7/25/08	3	PSL	PSL	PSL	Private Leak Replaced
23	3699 Alpina	BL	Madison	PSL	3/4"	N	1	N/A	N/A	7/23/08	8/16/08	15	PSL	PSL	PSL	Private Leak. Shut off on 8/6/08. Replaced on 8/16/08
24	4988 Euclid	BL	Madison	CSL	3/4"	N	1	N/A	N/A	8/5/08	8/12/08	7	3X5	Dirt	Pending	Company service leak-Repaired
25	5452 Newport	BL	Madison	CWM	1 1/2"	Y	59	Door to Door	8/12/08	8/10/08	8/14/08	1	5X5	Pavement	Pending	Company water main leak-Repaired
26	3434 & 3436 Beachworth	BL	Madison	CSL	3/4"	N	1	N/A	N/A	8/13/08	8/14/08	2	6X10	Dirt	Pending	Company service leak-Repaired
27	3649 Evanston	BL	Madison	CSL	3/4"	N	1	N/A	N/A	8/17/08	8/29/08	12	3X5	Dirt	Pending	Company service leak-Repaired
28	5043 Fullerton	BL	Madison	CSL	3/4"	N	1	N/A	N/A	9/10/08	9/24/08	14	3X5	Dirt	Pending	Company service leak-Repaired
29	2560 Rodell	BL	Madison	CSL	3/4"	N	1	N/A	N/A	9/12/08	9/24/08	12	3X5	Dirt	Pending	Company service leak-Repaired
30	3283 Dunwoode	BL	Madison	CSL	3/4"	N	1	N/A	N/A	9/19/08	9/24/08	5	3X5	Dirt	Pending	Company service leak-Repaired
31	3203 Sundale Road	BL	Madison	PSL	PSL	N	1	N/A	N/A	9/29/08	10/10/08	11	PSL	PSL	PSL	Private Leak-Repaired
32	3019 Fleet	BL	Madison	CSL	3/4"	N	1	N/A	N/A	10/12/08	Pending	Pending	Pending	Pending	Pending	Company service leak-Pending
33	Aurelia & Bender	BL	Blendon	CWM	6"	N	0	N/A	N/A	10/25/08	11/26/2007	2	6X5	Pavement	6/24/2008	Company water main leak-Repaired
34	3454 Salgon	BL	Blendon	CWM	6"	N	N/A	N/A	N/A	12/25/2007	12/26/2007	2	6X5	Pavement	6/24/2008	Drive approach replaced in January. Soil touched up in June
35	6337 Sunbury Rd.	BL	Blendon	CWM	8"	N	N/A	N/A	N/A	1/18/2008	1/23/2008	5	3X5	Soil	4/24/2008	Leak occurred while disconnecting customer who had turned service on illegally.
36	3580 Panama	BL	Blendon	CWM	6"	Y	19	Door Hangers	2/12/2008	1/30/2008	1/31/2008	2	3X5	Soil	4/24/2008	Service up lead under street. Sidewalk restored 4/25/08
37	3570 Carriage Ct.	BL	Blendon	CWM	6"	Y	22	Door Hangers	3/7/2008	3/6/2008	3/6/2008	1	3X5	Soil	4/25/2008	Driveway approach replaced 4/25/08
38	5298 Montevideo	BL	Blendon	CSL	3/4"	N	N/A	N/A	N/A	3/27/2008	3/27/2008	1	3X5 (2)	Pavement	4/25/2008	Service replaced under street. Soil restoration completed both sides of street.
39	6006 Sunwood Pl	BL	Blendon	CSL	3/4"	N	N/A	N/A	N/A	3/27/2008	3/29/2008	1	3X5	Pavement	4/25/2008	Hydrant valve - no excavation necessary
40	4261 Valley Quail N	BL	Blendon	VLV	4 1/2"	N	N/A	N/A	N/A	5/30/2008	5/30/2008	1	N/A	N/A	N/A	Turned water off 6/11/08 for not making repairs.
41	5580 Copanham	BL	Blendon	PSL	3/4"	N	N/A	N/A	N/A	5/29/2008	6/20/2008	23	N/A	N/A	N/A	Customer claimed he had W/P but was trying to sign up after leak confirmed
42	3878 Panama	BL	Blendon	PSL	3/4"	N	N/A	N/A	N/A	6/18/2008	7/17/2008	29	N/A	N/A	N/A	
43	4497 Valley Quail N	BL	Blendon	PSL	3/4"	N	N/A	N/A	N/A	7/2/2008	7/10/2008	8	N/A	N/A	N/A	
44	4456 Salsbail Loop	BL	Blendon	PSL	3/4"	N	N/A	N/A	N/A	7/2/2008	7/10/2008	8	N/A	N/A	N/A	
45	4419 Valley Quail N	BL	Blendon	PSL	3/4"	N	N/A	N/A	N/A	7/15/2008	7/25/2008	11	N/A	N/A	N/A	
46	4432 Salsbail Loop	BL	Blendon	PSL	3/4"	N	N/A	N/A	N/A	7/16/2008	7/23/2008	8	N/A	N/A	N/A	
47	6482 Purdillinch Ct	BL	Blendon	PSL	3/4"	N	N/A	N/A	N/A	7/18/2008	7/24/2008	7	N/A	N/A	N/A	
48	3358 Hunt Club N	BL	Blendon	PSL	3/4"	N	N/A	N/A	N/A	8/7/2008	8/21/2008	9	N/A	N/A	N/A	Turned off for Non Pay 8/7/08, still off
49	3350 Hunt Club N	BL	Blendon	PSL	3/4"	N	N/A	N/A	N/A	8/5/2008	8/5/2008	1	N/A	N/A	N/A	
50	6053 Paris N	BL	Blendon	PSL	3/4"	N	N/A	N/A	N/A	8/6/2008	9/3/2008	27	N/A	N/A	N/A	
51	4221 Valley Quail S	BL	Blendon	PSL	3/4"	N	N/A	N/A	N/A	8/20/2008	9/23/2008	1	N/A	N/A	N/A	
52	4027 Beauty Rose	BL	Blendon	PSL	3/4"	N	N/A	N/A	N/A	9/16/2008	9/23/2008	7	N/A	N/A	N/A	
53	6488 Woodhurst	BL	Blendon	PSL	3/4"	N	N/A	N/A	N/A	9/26/2008	Pending	7	N/A	N/A	N/A	
54	6822 Stillwater Drive	LD	Prairie	PSL	PSL	N	1	N/A	N/A	1/1/08	1/7/08	6	PSL	PSL	PSL	Private Leak-Repaired
55	742 Lakeridge Drive	LD	Prairie	PSL	3/4"	N	1	N/A	N/A	1/22/08	1/24/08	2	PSL	PSL	PSL	Private Leak Replaced. Meter was replaced per length of service
56	8871 Cranbridge Court	LD	Prairie	PSL	PSL	N	1	N/A	N/A	2/4/08	2/11/08	7	PSL	PSL	PSL	Originally thought to be a meter shut off valve leak. Turn out to be a leak in customer's house plumbing.
57	287 Hubbard Road	LD	Prairie	PSL	PSL	N	1	N/A	N/A	2/26/08	2/26/08	1	PSL	PSL	PSL	Private Leak-Repaired
58	8782 Crestwater Drive	LD	Prairie	PSL	3/4"	N	1	N/A	N/A	3/26/08	3/31/08	5	PSL	PSL	PSL	Private Leak Replaced

Ohio American Water Company
Lake White District
2008 Water Leak Log

CSL = Company Service Leak; CWM = Company Water Main; HYD = Hydrant; VLV = Valve; CO = Company Other; PSL = Private Service Leak; PWM = Private Water Main; PO = Private Other DR= Door Tag; DTD = Door to Door

Location	Service Area	Township	Leak Type	Size	Boil Order (Y or N)	Number of Services Affected	Method of Notification	Date Boil Order Lifted	Report Date	Repair Date	Elapsed Days	Size of Restoration	Type of Restoration	Date Restoration Completed	Comment
1 11740 St Rt 104	Lake White	PP	CO	3/4	N	1	In person	None needed	1/23/2008	1/23/2008	0	In meter pit	None needed	1/10/2007	Bottom of meter blew out
2 83 Virginia	Lake White	PP	CO	6	N	1	In person	None needed	1/24/2008	1/24/2008	0	4 x 4	blacktop	5/21/2008	Sealco blew off. Blacktop completed in spring.
3 11724 St Rt 104	Lake White	PP	CO	3/4	N	1	In person	None needed	2/25/2008	2/25/2008	0	In meter pit	None needed	2/25/2008	Bottom of meter blew out
4 1294 St Rt 552	Lake White	PP	CO	2	N	1	In person	None needed	3/13/2008	3/13/2008	0	4 x 4	Dirt & gravel, grass seed	3/13/2008	2 inch T blew off at deadend line
5 195 Crestwood	Lake White	PP	CO	6	N	0	N/A	None needed	5/19/2008	5/19/2008	0	4x4	dirt	5/19/2008	Boils on old band rusted away. Replaced with new band
6 14 Shady	Lake White	PP	CO	3/4	N	1	In person	None needed	6/12/2008	6/12/2008	0	4x4	blacktop	6/19/2008	3/4 inch line replaced under road. House vacant to service.
7 365 Evans	Lake White	PP	CO	3/4	Y	16	In person	6/23/2008	6/23/2008	6/25/2008	2	8x4	blacktop		Service line replacement. Old line cut. New line installed.

8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60

Ohio American Water Company
Lawrence County District
2008 Water Leak Log

CSL = Company Service Leak; CWM = Company Water Main; HYD = Hydrant; VLV = Valve; CO = Company Other; PSL = Private Service Leak; PWM = Private Water Main; PO = Private Other DR= Door Tag; DTD = Door to Door

Location	Service Area	Township	Leak Type	Size	Boil Order (Y or N)	Number of Services Affected	Method of Notification	Date Boil Order Lifted	Report Date	Repair Date	Elapsed Days	Size of Restoration	Type of Restoration	Date Restoration Completed	Comment
1 Thompson Rd.	Union	Union	CWM	2	N	3			01/09/08	01/09/08	0	6 X 6	Dirt	1/8/08	
2 116 Twp. Rd. 1202	Union	Union	CSL	3/4	N	1			01/02/08	01/07/08	6	5 X 6	Yard	5/20/08	
3 417 Riverside Dr.	Chesapeake	Chesapeake	CWM	2	N	15			01/07/08	01/07/08	0	4 X 6	Pavement	5/20/08	
4 6816 County Rd. 1	Fayette	Fayette	CWM	8	N	75			01/28/08	01/28/08	0	4 X 6	Berm	12/8/08	
5 8148 County Rd. 15	Fayette	Fayette	CWM	6	N	60			02/25/08	2/25/08	0	6 X 6	Pavement	5/20/08	
6 177 County Rd. 104	Union	Union	CSL	3/4	N	2			03/14/08	03/19/08	4	4 X 8	Berm	3/18/08	
7 286 Twp. Rd. 1302	Union	Union	CSL	3/4	N	1			02/22/08	02/29/08	7	4 X 6	Yard	5/20/08	
8 33 Twp. Rd. 1342	Union	Union	CWM	2	N	10			04/10/08	04/10/08	0	4X6	Berm	5/20/08	
9 8388 County Rd. 1	Fayette	Fayette	CSL	3/4	N	0			04/20/08	04/24/08	4	4X6	Yard	5/20/08	
10 240 Twp. Rd. 1356	Union	Union	CSL	3/4	N	1			04/23/08	04/24/08	1	6X6	Yard	5/20/08	
11 Township Rd. 1202	Union	Union	CWM	6	N	4			05/05/08	05/09/08	.5	6X6	Berm	5/20/08	
12 318 County Rd. 275	Fayette	Fayette	CWM	2	N	6			06/04/08	06/04/08	0	8X8	Pavement	7/20/08	
13 318 County Rd. 275	Fayette	Fayette	VLV	2	N	6			06/05/08	06/05/08	0	N/A	N/A	7/20/08	
14 46 Twp. Rd. 1436	Fayette	Fayette	CSL	3/4	N	1			06/07/08	06/07/08	0	2X4, 8, 4X4	Yard	7/20/08	
15 Forest Drive	Union	Union	CSL	3/4	N	1			06/25/08	07/01/08	7	5X5	Yard	8/20/08	
16 189 Twp. 1026	Fayette	Fayette	CSL	3/4	N	0			07/04/08	07/10/08	6	4X8	Berm	8/20/08	
17 Robertson Rd.	Chesapeake	Chesapeake	CWM	2	N	0			07/10/08	07/14/08	4	5X5	Pavement	8/20/08	
18 519 Rockwood Ave.	Chesapeake	Chesapeake	CO	5/8	N	1			7/10/08	7/17/08	7	4X4	Yard	8/20/08	
19 62 Township Rd. 1043	Union	Union	CSL	3/4	N	1			8/04/08	8/05/08	2	4X6	Berm	8/20/08	
20 70 County Rd. 120	Fayette	Fayette	CWM	2	N	12			8/05/08	8/07/08	2	4X4	Berm	8/20/08	
21 335 Township Rd. 1273	Union	Union	CSL	3/4	N	1			8/14/08	8/18/08	4	4X6	Yard	9/10/08	
22 Willow St.	Union	Union	CO	5/8	N	1			9/22/2008	9/22/2008	0	N/A	N/A	N/A	
23 313 4th. Ave.	Chesapeake	Chesapeake	CSL	3/4	N	1			9/31/2008	9/12/2008	2	3X6	Yard	9/10/08	
24 Walnut Street	Fayette	Fayette	CWM	2	N	0			9/8/2008	9/10/2008	2	6X6	Yard	10/05/08	
25 Big Branch Rd.	Union	Union	CWM	6	N	10			9/15/2008	9/15/2008	0	8X4	Berm	10/05/08	
26 1405 Big Branch Rd.	Union	Union	CSL	3/4	N	1			9/22/2008	9/22/2008	2	6X6	Yard	10/05/08	
27 1405 County Rd. 31	Union	Union	CSL	3/4	N	1			9/22/2008	9/22/2008	1	6X6	Yard	10/05/08	

CSL = Company Service Leak; CWM = Company Water Main; HYD + Hydrant; VLV = Valve; CD = Company Other; PSL = Private Service Leak; PWN = Private Water Main; PO = Private Other; DR = Door Tag; DTD = Door to Door

6ft x 3ft	Asphalt	39,709	Oyster paving made repairs
-----------	---------	--------	----------------------------

Ohio American Water Company

Marion District

2008 Water Leak Log

CSL = Company Service Leak; CWM = Company Water Main; HYD = Hydrant; VLV = Valve; CO = Company Other; PSL = Private Service Leak; PNM = Private Water Main; PO = Private Other DR= Door Tag; DTD = Door to Door															
Location	Service Area	Township	Leak Type	Size	Boil Order (Y or N)	Number of Services Affected	Method of Notification	Date Boil Order Lifted	Report Date	Repair Date	Elapsed Days	Size of Restoration	Type of Restoration	Date Restoration Completed	Comment
1 3172 Schell	Marion	Grand Prairie	PSL	P	N	1 HH	NA	NA	1/23/2007	1/7/2008	7	None	NA	N/A	Repaired
2 183 Sharp	Marion	Marion	CWM	2	N	0 HH	NA	NA	1/1/2008	1/6/2008	5	6 x 7	Dirt	6/3/2008	Repaired
3 306 W of Pole Lane	Marion	Marion	CWM	12	Y	10	DR	1/3/2008	1/2/2008	1/2/2008	0	10 x 12	Pavement	6/30/2008	Repaired
4 303 W of Pole Lane	Marion	Marion	Flush	F	N	0	NA	NA	1/2/2008	1/2/2008	0	NA	NA	NA	Flushed
5 424 Ballentine	Marion	Marion	CWM	6	N	0 HH	NA	NA	1/2/2008	1/3/2008	1	7 x 8	Dirt	1/3/2008	Repaired
6 Delaware & Executive	Marion	Marion	CWM	12	Y	30	DR	1/6/2008	1/5/2008	1/5/2008	0	25 x 35	Pavement	7/1/2008	Repaired
7 Delaware & Executive	Marion	Marion	Flush	F	N	0	NA	NA	1/5/2008	1/5/2008	0	None	NA	NA	Flushed
8 177 Jefferson	Marion	Marion	PSL	P	N	1 HH	NA	NA	1/6/2008	1/6/2008	0	None	NA	NA	Water service was off and leak repaired.
9 507 Silver	Marion	Marion	CSL	3/4"	N	1 HH	NA	NA	1/7/2008	1/7/2008	0	6 x 7	Dirt	6/10/2008	Repaired
10 813 Uncapher	Marion	Marion	CSL	3/4"	N	1 HH	NA	NA	1/7/2008	1/6/2008	1	8 x 10	Dirt	6/3/2008	Repaired
11 Latourrette & Bennett	Marion	Marion	Flush	F	Y	50	DR	1/11/2008	1/10/2008	1/10/2008	0	7 x 8	Pavement	6/25/2008	Flushed
12 Bennett & Nye	Marion	Marion	Flush	F	Y	30	DR	1/12/2008	1/11/2008	1/11/2008	0	6 x 7	Pavement	6/25/2008	Flushed
13 Gooding & Klingel	Prospect	Prospect	CWM	12	Y	500	News Media	1/27/2008	1/1/2008	1/23/2008	15	20 x 25	Dirt	6/10/2008	Repaired Waiting on repair parts
14 John & High	Marion	Marion	Flush	F	N	0	NA	NA	1/4/2008	1/4/2008	0	NA	NA	NA	Flushed
15 Lake Blvd & Bayside	Marion	Marion	Flush	F	N	0	NA	NA	1/4/2008	1/4/2008	0	NA	NA	NA	Flushed
16 Flow Test E Fairground	Marion	Marion	Flush	F	N	0	NA	NA	1/6/2008	1/6/2008	0	NA	NA	NA	Flushed
17 Flow Test Wilson Av	Marion	Marion	Flush	F	N	0	NA	NA	1/6/2008	1/6/2008	0	NA	NA	NA	Flushed
18 Dekalb	Marion	Clarendon	CWM	2	N	0 HH	NA	NA	1/6/2008	1/6/2008	3	7 x 8	Dirt	6/10/2008	Shut off abandoned line
19 291 Waterloo	Marion	Marion	PSL	P	N	1 HH	NA	NA	1/7/2008	1/23/2008	11	None	NA	N/A	Customer asked for the weekend, plumber scheduled.
20 554 Fair Park Ave	Marion	Marion	PSL	P	N	1 HH	NA	NA	1/18/2008	1/18/2008	0	None	NA	N/A	Water service was off and leak repaired.
21 376 N Greenwood	Marion	Marion	PSL	P	N	1 HH	NA	NA	1/18/2008	1/18/2008	0	None	NA	N/A	Water service was off and leak repaired.
22 228 Tully	Marion	Marion	CWM	6	Y	16	DR	1/20/2008	1/20/2008	1/21/2008	1	7 x 8	Pavement	6/23/2008	Repaired
23 589 Herman	Marion	Marion	CWM	2	N	0 HH	NA	NA	1/20/2008	1/21/2008	1	5 x 8	Dirt	6/10/2008	Repaired
24 1270 Bahama Dr	Marion	Marion	PSL	P	N	1 HH	NA	NA	1/23/2008	1/23/2008	0	None	NA	N/A	Water service was off and leak repaired.
25 Main & South	Caledonia	Clarendon	CWM	6	N	0 HH	NA	NA	1/24/2008	1/25/2008	1	7 x 8	Pavement	7/1/2008	Repaired
26 975 Villandy	Marion	Marion	PSL	P	N	1 HH	NA	NA	1/25/2008	1/25/2008	0	None	NA	N/A	Water service was off and leak repaired.
27 370 Silver	Marion	Marion	CSL	3/4"	N	1 HH	NA	NA	1/25/2008	2/3/2008	8	6 x 7	Pavement	Complete	Repaired other work took precedent
28 Gooding & Klingel	Prospect	Prospect	Flush	12	N	0 HH	NA	NA	1/28/2008	1/28/2008	0	NA	NA	NA	Flushed
29 Farnum & Orchard	Prospect	Prospect	CWM	12	Y	50	DR	1/31/2008	1/29/2008	1/30/2008	4	12 x 14	Pavement	7/1/2008	Repaired
30 Weiss & Schell	Marion	Grand Prairie	CWM	8	N	0 HH	NA	NA	1/29/2008	1/30/2008	0	7 x 8	Pavement	7/2/2008	Repaired
31 Farnum & Orchard	Prospect	Prospect	Flush	F	N	0	NA	NA	1/30/2008	1/30/2008	0	NA	NA	NA	Flushed
32 461 Fies	Marion	Marion	PSL	P	N	1 HH	NA	NA	1/30/2008	1/30/2008	0	None	NA	N/A	Water service was off and leak repaired.
33 Grand at Central Soja	Marion	Marion	CWM	6	N	0 HH	NA	NA	1/31/2008	1/31/2008	0	NA	NA	NA	Shut off Line - Engineering working on new installation.
34 888 Vernon His Circle	Marion	Marion	CWM	2	N	0 HH	NA	NA	1/31/2008	1/31/2008	0	6 x 7	Pavement	7/2/2008	Repaired
35 641 Van Buren	Marion	Marion	PSL	P	N	1 HH	NA	NA	1/31/2008	1/31/2008	0	None	NA	N/A	Shut Off
36 GP Properties	Marion	Marion	PSL	P	N	1 HH	NA	NA	1/31/2008	1/31/2008	0	None	NA	N/A	Repaired
37 276 Cass	Marion	Marion	PSL	P	N	1 HH	NA	NA	1/6/2008	2/4/2008	26	None	NA	N/A	WLPP has not fixed the leak yet. Checking 2/4/8
38 462 Patterson	Marion	Marion	PSL	P	N	1 HH	NA	NA	1/18/2008	2/20/2008	35	None	NA	N/A	Found property leak had been fixed by the customer.
39 333 Waterloo	Marion	Marion	PSL	P	N	1 HH	NA	NA	1/22/2008	2/4/2008	13	None	NA	N/A	WLPP has not fixed the leak yet. Checking 2/4/8
40 884 Amherst	Marion	Marion	CSL	3/4"	N	1 HH	NA	NA	1/24/2008	2/3/2008	28	8 x 7	Dirt	6/10/2008	Repaired other work took precedent
41 374 Silver	Marion	Marion	PSL	3/4"	N	1 HH	NA	NA	1/25/2008	2/3/2008	9	5 x 8	Pavement	6/23/2008	Repaired other work took precedent
42 1075 Langlais	Marion	Marion	PSL	P	N	1 HH	NA	NA	1/25/2008	2/4/2008	10	None	NA	N/A	Checking leak on 02/04/08, if not fixed, termination
43 1000 Ambrose	Marion	Marion	PSL	P	N	1 HH	NA	NA	1/30/2008	2/4/2008	7	None	NA	N/A	Checking leak on 02/04/08, if not fixed, termination
44 1104 Cheney Ave	Marion	Marion	PSL	P	N	1 HH	NA	NA	1/30/2008	2/4/2008	5	None	NA	N/A	WML check on 02/08/08
45 288 S High	Marion	Marion	CWM	6	N	0 HH	NA	NA	1/31/2008	2/2/2008	2	5 x 13	Pavement	Complete	Repaired
46 1962 Bellefontaine	Marion	Marion	CWM	V	N	0 HH	NA	NA	2/1/2008	2/7/2008	6	7 x 10	Dirt	4/18/2008	Repaired Valve
47 1068 Barbadoes	Marion	Marion	CSL	3/4"	Y	35	DR	2/3/2008	2/3/2008	2/3/2008	0	8 x 10	Dirt	By Contractor	Repaired Contractor Tear Service out of Main
48 1068 Barbadoes	Marion	Marion	Flush	F	N	0	NA	NA	2/3/2008	2/3/2008	0	NA	NA	NA	Flushed
49 Hyd behind Palco	Marion	Marion	Flush	F	N	0	NA	NA	2/4/2008	2/4/2008	0	NA	NA	NA	Flushed
50 310 Edgewood	Marion	Marion	PSL	P	N	1 HH	NA	NA	2/7/2008	2/7/2008	0	None	NA	N/A	Shut off at all
51 St Rt 257 & Weller	Prospect	Prospect	CWM	12	Y	25	DR	2/14/2008	2/13/2008	2/13/2008	5	18 x 20	Dirt	4/2/2008	Repaired
52 196 Bain	Marion	Marion	PSL	P	N	1 HH	NA	NA	2/11/2008	2/11/2008	0	None	NA	N/A	Property leak found and turned off same day.
53 Mt Vernon & Hane	Marion	Marion	Flush	F	N	0	NA	NA	2/12/2008	2/12/2008	0	NA	NA	NA	Flushed
54 St Rt 257 & Weller	Prospect	Prospect	Flush	F	N	0	NA	NA	2/12/2008	2/12/2008	0	NA	NA	NA	Flushed
55 Weiss & Pole Lane	Marion	Grand Prairie	CWM	6	N	0 HH	NA	NA	2/13/2008	2/13/2008	0	NA	NA	NA	Flushed
56 Weiss & Pole Lane	Marion	Grand Prairie	Flush	F	N	0	NA	NA	2/20/2008	2/20/2008	0	15 x 20	Dirt	6/11/2008	Repaired
57 845 Woodrow	Marion	Marion	CSL	3/4"	N	1 HH	NA	NA	2/20/2008	2/20/2008	0	NA	NA	NA	Flushed
58 845 Woodrow	Marion	Marion	Flush	F	N	0	NA	NA	2/21/2008	2/21/2008	0	4 x 8	Pavement	6/22/2008	Repaired
59 429 Avondale	Marion	Marion	CSL	3/4"	N	0	NA	NA	2/21/2008	2/21/2008	39/59	0	NA	NA	Repaired
60 328 Oliver	Marion	Marion	PSL	P	N	1 HH	NA	NA	2/28/2008	3/3/2008	28	None	NA	N/A	Repaired - Contractor responsible for restoration
61 420 Euclid	Marion	Marion	PSL	P	N	1 HH	NA	NA	2/4/2008	3/4/2008	19	None	NA	N/A	Staffing issues have not had a chance to check-Repaired
62 887 N State St	Marion	Marion	CSL	3/4"	N	1 HH	NA	NA	2/14/2008	3/13/2008	22	6 x 7	Pavement	6/16/2008	Repaired-Customer had problems finding plumber
63 965 Toulon	Marion	Marion	CSL	3/4"	N	1 HH	NA	NA	2/20/2008	3/2/2008	5	6 x 7	Dirt	6/10/2008	Repaired
64 470 Jefferson St	Marion	Marion	PSL	P	N	1 HH	NA	NA	2/26/2008	3/17/2008	20	None	NA	N/A	Repaired
65 531 Bellefontaine	Marion	Marion	PSL	P	N	1 HH	NA	NA	2/28/2008	4/17/2008	39	None	NA	N/A	Repaired-Customer had problems finding plumber
66 Flush Prospect	Prospect	Prospect	Flush	F	Y	1	DR	3/4/2008	3/3/2008	3/3/2008	0	NA	NA	NA	Flushed

CSL = Company Service Leak; CWM = Company Water Main; HYD = Hydrant; VLV = Valve; CO = Company Other; PSL = Private Service Leak; PWM = Private Water Main; PO = Private Other DR= Door Tag; DTD = Door to Door

Location	Service Area	Township	Leak Type	Size	Boil Order (Y or N)	Number of Services Affected	Method of Notification	Date Boil Order Lifted	Report Date	Repair Date	Elapsed Days	Size of Restoration	Type of Restoration	Date Restoration Completed	Comment
67 2424 Pole Line Rd	Marion	Marion	PSL	P	N	1 HH	NA	NA	3/5/2008	3/5/2008	0	None	N/A	N/A	Done
68 E Marion	Caledonia	Marion	CWM	8	N	0 HH	NA	NA	3/5/2008	3/5/2008	0	8 x 10	Pavement	7/1/2008	Done
69 125 N Water	Marion	Marion	CWM	6	Y	6	DR	3/7/2008	3/6/2008	3/6/2008	0	8 x 10	Dirt	6/10/2008	Done
70 Niles & Silver	Marion	Marion	CWM	6	N	0 HH	NA	NA	3/12/2008	3/12/2008	0	8 x 8	Pavement	5/25/2008	Done
71 1174 Montego	Marion	Marion	PSL	P	N	1 HH	NA	NA	3/16/2008	3/16/2008	0	None	N/A	N/A	Done
72 1600 Cascade	Marion	Marion	CWM	10	N	0 HH	NA	NA	3/16/2008	3/16/2008	0	12 x 14	Dirt	3/16/2008	Done
73 Flush Liens	Marion	Marion	Flush	F	N	0	NA	NA	3/17/2008	3/17/2008	0	NA	NA	NA	Flushed
74 966 Richmond	Marion	Marion	PSL	P	N	1 HH	NA	NA	3/19/2008	3/25/2008	7	None	N/A	N/A	Repaired-Customer had problems finding plumber
75 963 Normandy Circle	Prospect	Marion	CWM	2	Y	6	DR	3/21/2008	3/18/2008	3/20/2008	2	20 x 30	Dirt	5/27/2008	Done
76 Flush 257 & 47	Marion	Marion	HYD	H	N	0	N	N	3/24/2008	3/24/2008	0	NA	NA	NA	Flushed
77 Johnson & Wilson	Marion	Marion	Flush	F	N	0	NA	NA	3/31/2008	3/31/2008	0	NA	NA	NA	Done
78 Flush University Dr	Marion	Marion	PSL	P	N	1 HH	NA	NA	3/14/2008	4/2/2008	19	None	N/A	N/A	Repaired-Customer had problems finding plumber
79 473 Merchant	Marion	Marion	PSL	P	N	1 HH	NA	NA	3/10/2008	3/14/2008	4	None	N/A	N/A	Done
80 1086 Wilson	Marion	Marion	PSL	P	N	1 HH	NA	NA	3/10/2008	4/2/2008	23	None	N/A	N/A	Repaired-Customer had problems finding plumber
81 988 S Underwood	Marion	Marion	PSL	P	N	1 HH	NA	NA	3/10/2008	4/2/2008	23	None	N/A	N/A	Repaired-Customer had problems finding plumber

Ohio American Water Company
Portage County District
2008 Water Leak Log

CSL = Company Service Leak; CWM = Company Water Main; HTD = Hydrant; VLV = Valve; CO = Company Other; PSL = Private Service Leak; PWM = Private Water Main; PO = Private Other DR= Door Tag; DTD = Door to Door

Location	Service Area	Township	Leak Type	Size	Ball Order (Y or N)	Number of Services Affected	Method of Notification	Date Ball Order Filed	Report Date	Repair Date	Elapsed Days	Size of Restoration	Type of Restoration	Status Restoration Completed	Comment
FIRST QUARTER															
3547 Ivanhoe	Beechcrest	Brimfield	CWM	8"	Y	27	Door hangers	1/18/2008	1/18/2008	1/18/2008	0	10x10	Dirt	3/20/08	Shear break on 8" C.I. pipe that runs behind homes
3547 Ivanhoe	Beechcrest	Brimfield	CWM	8"	Y	27	Door hangers	1/18/2008	1/18/2008	1/18/2008	0	10x10	Dirt	3/20/08	Shear break on 8" C.I. pipe that runs behind homes
2758 Shawnee	Aurora East	Shalersville	CSL	8"	N	14	Door hangers	N/A	4/6/2008	4/6/2008	0	5x4	Slag stone	None needed	Service Saddle rotted bolts from tower ground, replaced saddle
THIRD QUARTER															
3593 Gary Drive	Beechcrest	Brimfield	CO	4"	Y	55	DTD	9/5/2008	9/4/2008	9/4/2008	0	5x5	Dirt	Not yet	Replaced Flush point Blow off below grade
10348 Winthrop	Aurora East	Shalersville	CSL	7.5"	N	1			10/2/2008	10/2/2008	0	5x6	Dirt	Not yet	While straightening a CB discovered Service leaking on Company Side of CS. At about 1 pm I'm guessing for 6 months or more copper was buried through 24mm size hole

Ohio American Water Company Tiffin District 2008 Water Leak Log

CSL = Company Service Leak; CWM = Company Water Main; HYD = Hydrant; VLV = Valve; CD = Company Other; PSL = Private Service Leak; PWH = Private Water Main; PO = Private Other DR= Door Tag, DTD = Door to Door															
Location	Service Area	Township	Leak Type	Size	Ball Order (Y or N)	Number of Services Affected	Method of Notification	Data Ball Order Linked	Report Date	Repair Date	Elapsed Days	Size of Restoration	Type of Restoration	Data	Comment
														Restoration Completed	
1 46-52 BRADEN	Tiffin City	Tiffin City	CWM	2"	N	N/A	N/A	N/A	1/2/2008	1/3/2008	1	5 X 5	STREET	01/03/08	
2 32 HALL	Tiffin City	Tiffin City	CSL	3/4"	N	N/A	N/A	N/A	12/3/2007	1/2/2008	2	5 X 5	BLVD	01/02/08	
3 136 SECOND	Tiffin City	Tiffin City	CWM	12"	N	N/A	N/A	N/A	1/4/2008	1/9/2008	5	5 X 6	BLVD/STREET	01/09/08	
4 40 HUSS	Tiffin City	Tiffin City	PSL	8"	N	N/A	N/A	N/A	1/16/2008	1/19/2008	2	4 X 10	BLVD	01/19/08	
5 928 W MARKET	Tiffin City	Tiffin City	PSL	8"	N	N/A	N/A	N/A	1/20/2008	N/A	N/A	N/A	N/A	N/A	Shut off
6 235 N SANDUSKY	Tiffin City	Tiffin City	CSL	6"	N	N/A	N/A	N/A	1/22/2008	1/23/2008	2	3X5-4X8	BLVD/STREET	01/23/08	
7 411-415 S WASHINGTON	Tiffin City	Tiffin City	CSL	6"	N	N/A	N/A	N/A	1/22/2008	1/22/2008	0	3 X 5	STREET	01/22/08	
8 115 OHIO	Tiffin City	Tiffin City	CWM	8"	Y	40	door hangers	1/24/2008	1/25/2008	1/25/2008	0	4 X 8	STREET	01/25/08	
9 MAIN	Tiffin City	Tiffin City	CWM	6"	N	N/A	N/A	N/A	1/27/2008	1/27/2008	0	5 X 5	STREET	01/27/08	
10 14 ASH	Tiffin City	Tiffin City	CWM	2"	N	N/A	N/A	N/A	2/2/2008	2/2/2008	0	10 X 25	BLVD/STREET	02/02/08	
11 711 N SANDUSKY	Tiffin City	Tiffin City	CSL	12"	N	N/A	N/A	N/A	2/9/2008	2/11/2008	2	3X5-4X8	BLVD/STREET	02/11/08	
12 157 WENTZ	Tiffin City	Tiffin City	PSL	3/4"	N	N/A	N/A	N/A	2/12/2008	2/19/2008	7	N/A	N/A	02/19/08	Contractor Dug out line Service line hit by contractor
13 735 W MARKET	Tiffin City	Tiffin City	CSL	4"	N	N/A	N/A	N/A	2/13/2008	2/13/2008	0	3 X 5	BLVD	02/13/08	
14 80 CENTER	Tiffin City	Tiffin City	PSL	3/4"	N	N/A	N/A	N/A	2/22/2008	2/22/2008	0	N/A	N/A	02/22/08	Contractor Dug out line
15 TEAKWOOD CT.	Tiffin City	Tiffin City	PSL	1"	Y	15	door hangers	2/24/2008	2/25/2008	2/25/2008	0	N/A	N/A	02/25/08	Contractor Dug out line
16 42 CLINTON	Tiffin City	Tiffin City	PSL	5/8"	N	N/A	N/A	N/A	2/26/2008	2/26/2008	0	N/A	N/A	02/26/08	
17 241 FIRST	Tiffin City	Tiffin City	CSL	2"	N	N/A	N/A	N/A	2/28/2008	3/4/2008	4	4 X 6	BLVD	03/04/08	
18 545 E Perry	Tiffin City	Tiffin City	CO	5/8"	N	N/A	N/A	N/A	3/3/2008	3/5/2008	1	2x5 4x5	BLVD	3/5/08	
19 119 Apple	Tiffin City	Tiffin City	PSL	5/8"	N	N/A	N/A	N/A	3/5/2008	3/5/2008	0	3 X 5	BLVD	3/5/08	
20 214 Sidn	Tiffin City	Tiffin City	CO	3/4"	N	N/A	N/A	N/A	3/6/2008	3/6/2008	1	4 X 5	BLVD	03/06/08	
21 60 Hudson	Tiffin City	Tiffin City	CSL	1"	N	N/A	N/A	N/A	3/6/2008	3/7/2008	4	4 X 8	Street	03/07/08	
22 202 Hudson	Tiffin City	Tiffin City	CSL	5/8"	N	N/A	N/A	N/A	3/17/2008	3/24/2008	7	3 X 4	Sidewalk	03/24/08	
23 350 Main	Tiffin City	Tiffin City	CSL	6"	N	N/A	N/A	N/A	3/24/2008	3/25/2008	1	5 x 4 3 x 5	Street/Sidewalk	03/25/08	
24 241 First	Tiffin City	Tiffin City	CSL	3/4"	N	N/A	N/A	N/A	3/25/2008	3/31/2008	6	4 x 7	BLVD	03/31/08	
25 1548 S State Route 53 #24	Tiffin City	Tiffin City	PSL	1"	N	N/A	N/A	N/A	4/2/2008	4/2/2008	0	N/A	N/A	04/02/08	
26 359 W Perry	Tiffin City	Tiffin City	CSL	6/8"	N	N/A	N/A	N/A	4/10/2008	4/14/2008	4	4 X 6	Street/BLVD	04/14/08	
27 368 W Market	Tiffin City	Tiffin City	HYD	6"	N	N/A	N/A	N/A	4/16/2008	4/17/2008	2	12 x 7	BLVD	04/17/08	
28 338 Main	Tiffin City	Tiffin City	VLV	6"	N	N/A	N/A	N/A	4/17/2008	4/22/2008	5	3 X 5	street	04/22/08	Replace Hydrant
29 79 Gibson	Tiffin City	Tiffin City	VLV	8"	N	N/A	N/A	N/A	4/17/2008	4/25/2008	8	4 X 6	Street	04/25/08	Repaired Valve
30 211 Wentz	Tiffin City	Tiffin City	VLV	6"	N	N/A	N/A	N/A	4/17/2008	4/29/2008	12	4 x 5	street	04/29/08	Repaired Valve
31 811 Erie	Tiffin City	Tiffin City	CSL	3/4"	N	N/A	N/A	N/A	4/25/2008	4/28/2008	4	3 x 5 3 x 5	Street/BLVD	04/28/08	
32 258 Jefferson	Tiffin City	Tiffin City	PSL	6/8"	N	N/A	N/A	N/A	4/17/2008	5/1/2008	14	3 X 5	Street	05/01/08	
33 137 S Washington	Tiffin City	Tiffin City	CSL	6/8"	Y	4	door hangers	5/10/2008	5/5/2008	5/7/2008	2	3 X 5	Street	05/07/08	Repaired Hydrant
34 106 E Market	Tiffin City	Tiffin City	HYD	6"	N	N/A	N/A	N/A	5/5/2008	5/9/2008	15	4 X 5	street	05/09/08	
35 137 S Washington	Tiffin City	Tiffin City	PSL	5/8"	N	N/A	N/A	N/A	4/30/2008	5/12/2008	12	10 x 10	Street/BLVD	05/12/08	
36 101 Douglas	Tiffin City	Tiffin City	CSL	5/8"	N	N/A	N/A	N/A	5/7/2008	5/19/2008	8	4 X 6	BLVD	05/19/08	
37 353 Greenfield	Tiffin City	Tiffin City	HYD	8"	N	N/A	N/A	N/A	5/7/2008	5/13/2008	6	3 X 6	Street	05/13/08	
38 Melissa & W Market	Tiffin City	Tiffin City	VLV	4"	Y	43	door hangers	5/11/2008	5/15/2008	5/11/2008	8	3 X 6	Street	05/11/08	
39 475 Coe	Tiffin City	Tiffin City	HYD	8"	N	N/A	N/A	N/A	5/15/2008	5/20/2008	5	5 X 5	BLVD	05/20/08	
40 68 N Monroe	Tiffin City	Tiffin City	CWM	8"	N	N/A	N/A	N/A	5/16/2008	5/21/2008	5	6 X 6	Street	5/21/08	
41 67 Oak	Tiffin City	Tiffin City	CO	5/8"	N	N/A	N/A	N/A	5/23/2008	5/29/2008	8	5 x 4	BLVD	05/29/08	
42 119 Douglas	Tiffin City	Tiffin City	PSL	3/4"	N	N/A	N/A	N/A	6/17/2008	6/25/2008	8	N/A	N/A	06/25/08	
43 46 Jackson	Tiffin City	Tiffin City	PSL	3/4"	N	N/A	N/A	N/A	7/9/2008	7/31/2008	22	N/A	N/A	N/A	
44 635 E St Rt 18	Tiffin City	Tiffin City	CO	3/4"	N	N/A	N/A	N/A	7/14/2008	7/14/2008	4	3 X 5	bvd	07/14/08	
45 140 S Monroe	Tiffin City	Tiffin City	CO	3/4"	N	N/A	N/A	N/A	7/14/2008	7/15/2008	1	3 X 5	bvd	07/15/08	
46 Clay & Jackson	Tiffin City	Tiffin City	CWM	n/a	N	N/A	N/A	N/A	7/16/2008	7/18/2008	0	N/A	N/A	N/A	
47 163 Schonhardt	Tiffin City	Tiffin City	PSL	n/a	N	N/A	N/A	N/A	7/23/2008	8/25/2008	32	N/A	N/A	N/A	
48 49/50 Clay Street	Tiffin City	Tiffin City	CO	1"	N	N/A	N/A	N/A	7/23/2008	7/24/2008	1	4 X 8	bvd	07/24/08	
49 200 St. Francis	Tiffin City	Tiffin City	CWM	6"	Y	1	door hangers	7/28/2008	7/28/2008	7/28/2008	0	4 x 13	parking lot	07/28/08	
50 69 Douglas	Tiffin City	Tiffin City	CO	n/a	N	N/A	N/A	N/A	7/24/2008	7/28/2008	5	4 X 5	bvd	07/28/08	
51 187 Walker	Tiffin City	Tiffin City	CWM	6"	N	N/A	N/A	N/A	7/26/2008	7/30/2008	2	6 X 8	BLVD/STREET	07/30/08	
52 240 W Market	Tiffin City	Tiffin City	CWM	6"	N	15	N/A	N/A	7/30/2008	7/30/2008	0	4 X 8	street	07/30/08	
53 13 Wentz	Tiffin City	Tiffin City	PSL	n/a	N	N/A	N/A	N/A	8/5/2008	8/12/2008	7	N/A	N/A	N/A	
54 635 E St Rt 18	Tiffin City	Tiffin City	CWM	3"	N	N/A	N/A	N/A	8/6/2008	8/6/2008	0	4 X 6	street	08/06/08	
55 195 & 197 S Washington	Tiffin City	Tiffin City	CO	12"	N	N/A	N/A	N/A	8/6/2008	8/7/2008	1	3 X 5	street	08/07/08	Killed Service
56 Intersection Oil & W Market	Tiffin City	Tiffin City	CO	6"	Y	77	door hangers	8/15/2008	8/12/2008	8/12/2008	2	4X8 / 5x8	street	08/14/08	Replaced Valve
57 183 Clinton	Tiffin City	Tiffin City	CWM	4"	N	N/A	N/A	N/A	8/16/2008	8/16/2008	0	4 X 6	street	08/16/08	
58 68 Schonhardt	Tiffin City	Tiffin City	CWM	n/a	N	N/A	N/A	N/A	8/16/2008	8/22/2008	4	3 X 6	bvd	08/22/08	
59 263 Main	Tiffin City	Tiffin City	CO	n/a	N	N/A	N/A	N/A	8/21/2008	8/21/2008	0	3 X 6	bvd	08/21/08	
60 481 E Perry	Tiffin City	Tiffin City	PSL	n/a	N	N/A	N/A	N/A	8/20/2008	8/29/2008	9	N/A	N/A	08/29/08	
61 128 Oak	Tiffin City	Tiffin City	CWM	3"	N	N/A	N/A	N/A	8/25/2008	8/29/2008	3	6 X 4	street	08/29/08	
62 246 First	Tiffin City	Tiffin City	CO	n/a	N	N/A	N/A	N/A	8/28/2008	9/8/2008	9	4 X 5	sidewalk	09/08/08	
63 151 First	Tiffin City	Tiffin City	CO	n/a	N	N/A	N/A	N/A	9/5/2008	9/16/2008	11	3 X 7	street	09/16/08	
64 main street	Tiffin City	Tiffin City	cwm	n/a	N	N/A	N/A	N/A	9/11/2008	9/18/2008	5	3 X 8	parking lot	09/18/08	
65 S Washington & Gibson	Tiffin City	Tiffin City	cwm	8"	N	12	N/A	N/A	9/23/2008	9/23/2008	0	4 x 12	Street/BLVD	09/23/08	Killed main, remove hydrant
66 24 Beechwood	Tiffin City	Tiffin City	CO	6"	N	N/A	N/A	N/A	9/24/2008	9/25/2008	1	3 X 9	street	09/25/08	
67															

Location	Location of leak; may include street address of nearest residence or distance from intersecting street
Service Area Township	If Network service are is segmented, this information should be included Township in which leak occurred
Leak Type Size	List is found at top of sheet; each leak will be either Company or Private; This pertains to mains, valves and services
Service Affecting	Yor N answer; Service affecting leaks are determined to be those leaks that leave customers with little or no pressure
Report Date	The date the Company became aware of the leak
Repair Date	The date the leak was repaired
Elapsed Days	The number of days from the report date to repair date; under normal conditions, this should be between 0 to 1 days for service affecting leaks and 0 to 7 days for non-service affecting leaks
Boil Order	Was a boil order issued to customers
Comments	Any additional useful information; should include an explanation of any repair outside the regulated number of elaped days
Method of Notification	

CSL	Company Service Line
CWM	Company Water Main
HYD	Hydrant
VLV	Valve
CO	Company Other
PSL	Private Service Line
PWM	Private Water Main
PO	Private Other

Yes
No