



Bricker & Eckler
ATTORNEYS AT LAW

COLUMBUS | CLEVELAND
CINCINNATI-DAYTON

BRICKER & ECKLER LLP
100 South Third Street
Columbus, Ohio 43215-4291
MAIN: 614.227.2300
FAX: 614.227.2390

www.bricker.com
info@bricker.com

Sally W. Bloomfield
614.227.2368
sbloomfield@bricker.com

FILE

2

November 4, 2008

RECEIVED-DOCKETING DIV

2008 NOV -4 PM 4:46

PUCO

VIA HAND DELIVERY

Ms. Renee Jenkins
Public Utilities Commission of Ohio
Administration/Docketing
180 East Broad Street, 13th Floor
Columbus, OH 43215-3793

Re: Case No. 07-252-WS-UNC
Ohio American Water Company
Stipulation Page No. 17, ¶15

Dear Ms. Jenkins:

Pursuant to the Commission's March 7, 2007 Opinion and Order in Case No. 06-433-WS-AIR, Ohio American Water Company submits for filing the October 2008 Hardness Report for the Marion district.

If you have any questions, please call me at the number listed above.

Sincerely,

Sally W. Bloomfield

Enclosure

cc: Parties of Record (w/Enclosure)

This is to certify that the images appearing are an accurate and complete reproduction of a case file document delivered in the regular course of business.
Technician SM Date Processed NOV 05 2008

EFFLUENT HARDNESS / MG/L

October	RAW HARDNESS MG/L	EFFLUENT HARDNESS MG/L
1	490	144
2	514	147
3	483	112
4	486	138
5	515	150
6	541	148
7	580	144
8	644	153
9	640	145
10	623	159
11	640	157
12	651	156
13	590	166
14	580	135
15	560	143
16	550	138
17	545	143
18	550	145
19	555	152
20	580	146
21	640	142
22	627	150
23	570	130
24	556	137
25	531	129
26	505	143
27	533	142
28	557	139
29	522	145
30	529	128
31	546	135

Using temporary feed system during the installation of our 2 new soda ash dissolvers.
Using temporary feed system during the installation of our 2 new soda ash dissolvers.
Using temporary feed system during the installation of our 2 new soda ash dissolvers.
Using temporary feed system during the installation of our 2 new soda ash dissolvers.

AVERAGE	562	143
MAX	651	166
MIN	483	112

October 2008
EFFLUENT HARDNESS AVG - 143 MG/L
MARION DISTRICT

