

FILE

Staff Investigation Report and Recommendation

Case No.: 09-44-EL-BLN

Project: Delta-Wauseon 138 kV Transmission Line
Tap to Zinc Ox

Applicants: American Transmission Systems, Inc.
Toledo Edison Company

Report Date: 2 March 2009

Automatic Approval Date: 9 March 2009 (Letter of Notification process)

Waiver Request: None

Inspection Date(s): 29 January 2009 & 10 February 2009

Staff Assigned: J. O'Dell

Summary of Staff Recommendations (see report text for discussion):

Application: ☒ Approval ☐ Disapproval ☐ Approval with Conditions
Waiver: ☐ Approval ☐ Disapproval ☒ Not Applicable

Summary of Staff Recommended Conditions (see report text for discussion):

- None

Projected Docket Closure Date (if automatically approved): 1 October 2011

Investigation Report

Project Description: This project involves the installation of approximately one mile of 138 kV transmission line, utilizing 19 new wood pole structures. The line would provide service to the Zinc Ox Substation, a new industrial customer.

Site Description: The project is located in York Township, Fulton County. Land use is confined to industrial and agricultural uses. The new poles will be installed and maintained using nearby service roads. This project is not expected to require any appreciable vegetative clearing.

Discussion/Comments/Concerns: The construction of this project should pose only minimal negative social and ecological impacts.

This is to certify that the images appearing are an
accurate and complete reproduction of a case file
document delivered in the regular course of business
technician _____ Date Processed - MAR 02 2009

RECEIVED-DOCKETING DIV
2009 MAR -2 PM 3:46
PUCO