

FILE

SPARKSELECTRIC
SERVICE, INC.

SINCE 1945

STEVE GLASER, President
8242 N. Dixie Dr. • Dayton, OH 45414
(937) 890-7188 • FAX (937) 890-6211
1-888-772-7579 • (1-888-SPARKS91)
www.sparkselectric.com

October 9, 2009

Glenda & Isaac Andrews
3511 Wales Drive
Dayton, Ohio 45405

09-511-EL-055

PUCO

2009 NOV -5 PM 12:36


RECEIVED-DOCKETING DIV

RE: Electrical Inspection

Dear Mrs. Andrews:

Upon our inspection of your electrical system on October 8, 2009, we found no evidence of electric radiant ceiling heat present in your home. We did note that several circuit breakers marked "cable heat" but there were no thermostats, no load on the breakers. The breaker legend is original. I do not know if it was miss-marked or if some kind of cable heat was replaced with the natural gas furnace and no one changed the legend. We found no working cable heat system in use at this time.

Thank you for your business,



Steve Glaser
Sparks Electric Service Inc

This is to certify that the images appearing are an
accurate and complete reproduction of a case file
document delivered in the regular course of business
Technician Am Date Processed 11/5/09