

FILE



Legal Department

4
RECEIVED-DOCKETING DIV
2010 JAN -6 AM 10:13
PUCO

January 5, 2009

Docketing Department
Public Utilities Commission of Ohio
180 E. Broad St.
Columbus, Ohio 43266-0572

Re: Case No. 09-511-EL-CSS

To Docketing:

Please accept for filing, pursuant to the November 18, 2009 Entry in this case, an original and eleven copies of the prefiled testimony of Paul Salyers, on behalf of the Dayton Power and Light Company. I would appreciate your time-stamping the extra copy and returning it in the enclosed self-addressed envelope.

Sincerely,

A handwritten signature in cursive script, appearing to read "Edward N. Rizer".

Edward N. Rizer

cc: Isaac Andrews
3511 Wales Drive
Dayton OH 45405

This is to certify that the images appearing are an accurate and complete reproduction of a case file document delivered in the regular course of business.
Technician ASJ Date Processed 1/6/10

BEFORE
THE PUBLIC UTILITIES COMMISSION OF OHIO

Isaac Andrews

v.

The Dayton Power and Light Company

)
)
)
)
)

Case No. 09-511-EL-CSS

**DIRECT TESTIMONY OF PAUL SALYERS
ON BEHALF THE
DAYTON POWER AND LIGHT COMPANY**

Edward N. Rizer
The Dayton Power and Light Company
P.O. Box 8825
Dayton OH 45401
(937) 259-7235
Edward.Rizer@dplinc.com

Q1. Please state your name and business address.

A1. My name is Paul Salyers and my address is The Dayton Power and Light Company, 1900 Dryden Road, Dayton, Ohio.

Q2. What are your responsibilities at DP&L?

A2. I am Supervisor of Metering. My duties include supervision of operations related to electric meter installation, maintenance and testing.

Q3. Are you familiar with a situation involving the electric meter at 3511 Wales Dr. in Dayton?

A3. Yes I received an order for that address in early February, 2009 to check the accuracy of the meter because the customer had received an unexpectedly high bill.


Q4. Please explain what you did and what you concluded about the meter.

A4. I, and people working under my supervision, conducted a standard meter test, which tests the meter's accuracy under varying electric loads. The test results showed that the meter was accurate at 100.6% under light load and 100.2% under full load, both well within the 2% margin of accuracy permitted by the PUCO. So whatever the cause of the unexpectedly high bill, the meter had properly tracked the electricity consumed at that address.

Q5. Does this conclude your testimony?

A6. Yes.

Respectfully submitted,



Edward N. Rizer

#0029567

The Dayton Power and Light Company

P.O. Box 8825

Dayton OH 45401

(937) 259-7235

CERTIFICATE OF SERVICE

I hereby certify that a copy of the foregoing has been sent via ordinary U.S. Mail to Isaac Andrews, 3511 Wales Drive, Dayton OH 45405 this 5th day of January, 2010.



Edward N. Rizer

#0029567