

**BEFORE THE  
PUBLIC UTILITIES COMMISSION OF OHIO**

In the Matter of the Energy Efficiency and	)	
Peak Demand Reduction Program	)	
Portfolio of Ohio Edison Company, The	)	Case Nos. 09-951-EL-EEC
Cleveland Electric Illuminating Company,	)	09-952-EL-EEC
and The Toledo Edison Company	)	09-953-EL-EEC
	)	
	)	
	)	
	)	
	)	

---

**NOTICE OF CORRECTED EXHIBITS**

---

Please take notice that on October 14, 2009, Ohio Edison Company, The Cleveland Electric Illuminating Company and The Toledo Edison Company (collectively, "Companies") filed an application for approval of certain transmission and distribution projects ("Application"). The Application included Exhibits A and C, which listed the amount of energy savings and described the various projects. Subsequently, the Companies learned that the total amount of Transmission System Annualized Energy Savings listed on Exhibit A was less than the Companies' actual energy savings. The Companies also learned that Exhibit C listed the incorrect in-service date for one of the Companies' projects, the Hubbard Sub Project. Thus, the Companies are filing Revised Exhibit A with the correct amount of energy savings and Revised Exhibit C with the correct in-service date for the Hubbard Sub Project.

Accordingly, the Companies hereby file the revised Exhibits, which are attached to this Notice and labeled Revised Exhibit A and Revised Exhibit C.

Respectfully submitted,

/s/ Kevin Shannon

Kathy J. Kolich, (0038855)  
FIRSTENERGY SERVICE COMPANY  
76 South Main Street

Akron, OH 44308  
(330) 384-4580  
(330) 384-3875 (fax)  
kjkolich@firstenergycorp.com

James F. Lang (0059668)  
Kevin P. Shannon (0084095)  
CALFEE, HALTER & GRISWOLD LLP  
1400 KeyBank Center  
800 Superior Ave.  
Cleveland, OH 44114  
(216) 622-8200  
(216) 241-0816 (fax)  
jlang@calfee.com  
kshannon@calfee.com

ATTORNEYS FOR APPLICANTS, OHIO  
EDISON COMPANY, THE CLEVELAND  
ELECTRIC ILLUMINATING COMPANY,  
AND THE TOLEDO EDISON COMPANY

Summary of Energy Savings from Transmission and Distribution Projects

Projects placed in service 2009 (a)  
Case No. 09-951-EL-EEC et al.

	(in MWhs)			
	OE	CEI	TE	Total
Transmission System Annualized Energy Savings (b)	9,672	2,731	2,522	14,926
Distribution System Annualized Energy Savings	200	150	987	1,336
Total Energy Savings	9,871	2,882	3,509	16,262

(a) For Transmission project listing & sample projects, see Exhibit C and D; for Distribution project listing & sample projects, see Exhibit E and F  
(b) Allocation of transmission energy savings is based on transmission line miles within each operating company compared to total FirstEnergy (Ohio) transmission line miles

	OE	CEI	TE
Loss Allocation %	64.80%	18.30%	16.90%

### FE-Ohio Transmission Level Projects

Based on new transmission facilities placed in service 2009.  
Case No. 09-951-EL-EEC et al.

Revised Exhibit C

A (column descriptions below)		B	C	D	E	F (D - E)	G
Ohio Projects		Pri kV	Actual In Service Date	FE-Ohio Total Losses (Before)	FE-Ohio Total Losses (After)	2009 MW Loss Reduction	2009 Annualized MWH Loss Reduction
<u>RE-CONDUCTORINGS</u>							
1 Cardington-Tangy 69kV line - Phase 3 - 2009 R/C		69	12/31/2009	408.105	407.404	0.701	2,598
<u>TRANSMISSION SUBSTATIONS</u>							
2 Avon 92-AV-T New Transformer		345	6/1/2009	409.903	407.404	2.499	9,260
<u>TRANSMISSION CAP BANKS</u>							
3 Babb (50 MVAR) (6/09)		138	6/1/2009	408.134	407.404	0.73	2,705
5 Hubbard Sub - Add 23 kV, 7.2 Mvar capacitor bank		23	10/1/2009	407.404	407.306	0.098	363
			Total		Total	4,028	14,926

#### Column Description

- A Project description (see Exhibit D for projects detail)  
B Primary voltage  
C Date project was put into service  
D FE-Total Losses Before - system modeled using PSLF software prior to project completion. For a description of the system, see [http://www.gepower.com/prod\\_serv/products/utility\\_software/en/ge\\_pslf/index.htm](http://www.gepower.com/prod_serv/products/utility_software/en/ge_pslf/index.htm)  
E FE-Total Losses After - system modeled using PSLF software after project completion  
F MW Loss Reduction (column D - column E)  
G Calculation of MWhs  
Formula: MW Loss Reduction x Average Loss Factor x 8760

## CERTIFICATE OF SERVICE

I hereby certify that a copy of the foregoing *Notice of Corrected Exhibits* was served this 5th day of April, 2010 by first-class United States Mail, postage prepaid (with copies provided electronically), upon the persons listed below.

/s/ Kevin Shannon  
One of the Attorneys for Applicants

### SERVICE LIST

Henry W. Eckhart  
50 West Broad Street, Suite 2117  
Columbus, OH 43215

Attorney for the Natural Resources  
Defense Council

Todd M. Williams  
P.O. Box 6885  
Toledo, OH 43612

Attorney for the Ohio  
Environmental Council

Will Reisinger  
Nolan Moser  
Trent Dougherty  
The Ohio Environmental Council  
1207 Grandview Ave., Suite 201  
Columbus, OH 43212-3449

Attorneys for the Ohio  
Environmental Council

Samuel C. Randazzo  
Lisa G. McAlister  
Joseph M. Clark  
MCNEES WALLACE & NURICK LLC  
21 East State Street, 17th Floor  
Columbus, OH 43215

Attorneys for Industrial Energy Users-Ohio

David C. Rinebolt  
Colleen C. Mooney  
Ohio Partners for Affordable Energy  
P.O. Box 1793  
Findlay, OH 45839-1793

Attorneys for Ohio Partners for Affordable  
Energy

Theodore S. Robinson  
Citizen Power  
2121 Murray Avenue  
Pittsburgh, PA 15217

Attorney for Citizen Power

Duane Luckey  
Assistant Attorney General  
Public Utilities Commission of Ohio  
180 E. Broad St., 6th Fl.  
Columbus, OH 43215

Attorney for Public Utilities Commission of  
Ohio

**This foregoing document was electronically filed with the Public Utilities**

**Commission of Ohio Docketing Information System on**

**4/7/2010 9:11:15 AM**

**in**

**Case No(s). 09-0951-EL-EEC, 09-0952-EL-EEC, 09-0953-EL-EEC**

Summary: Notice of Corrected Exhibits. electronically filed by Mr. Kevin P. Shannon on behalf of Ohio Edison Company and The Cleveland Electric Illuminating Company and The Toledo Edison Company