

**FILE**

**Ohio Power Siting Board**

**Staff Investigation Report and Recommendation**

**Case No.:** 10-793-EL-BLN

**Project:** Brookside Cloverdale 138 kV Transmission Line  
Structure Replacement

**Applicant:** American Transmission Systems, Inc.

**Report Date:** 30 July 2010

**Automatic Approval Date:** 11 August 2010 (Letter of Notification process)

**Waiver Request:** None

**Inspection Date(s):** 25 June 2010

**Staff Assigned:** J. O'Dell

**Summary of Staff Recommendations (see report text for discussion):**

Application: ☒ Approval    ☐ Disapproval    ☐ Approval with Conditions  
Waiver:        ☐ Approval        ☐ Disapproval    ☒ Not Applicable

**Summary of Staff Recommended Conditions (see report text for discussion):**

- None

**Projected Docket Closure Date (if automatically approved):** 31 December 2012

**Investigation Report**

**Project Description:** This project involves the replacement of an existing steel lattice tower structure with a self-supporting steel pole structure. The existing line height must be raised to allow a new AEP 69 kV line to pass underneath. The replacement structure will be located within the existing transmission line r-o-w.

**Site Description:** The land adjacent to the existing structure and transmission line is primarily agricultural. The project is located in Wayne Township, Wayne County.

**Discussion/Comments/Concerns:** The construction of this project should pose only minimal negative social and ecological impacts.

**This is to certify that the images appearing are an accurate and complete reproduction of a case file document delivered in the regular course of business.**  
Technician SB Date Processed 7/30/10

RECEIVED-DOCKETING DIV  
2010 JUL 30 PM 4:25  
PUCO