Large Filing Separator Sheet

Case Number: 09-512-GE-UNC

File Date: 11/15/2010

Section: 3 of 3

Number of Pages:

156

Description of Document: Replies

Attachment D:

"Advanced Power Strip background"

1.1 DESCRIPTION

The measure reduces stand-by equipment energy by turning off the power supplied to equipment that is plugged into a power strip when it's not in use. Typical uses are home-office and home-entertainment systems. The power strip monitors the power draw on one outlet to control the availability of power on the other outlets on the strip.

This measure applies to new and existing homes.

The savings have been quantified for two power strip sizes: a 5-plug strip and a 7-plug strip.

1.2 BASIS FOR SAVINGS

We studied the provided spreadsheets showing savings estimates and the report done for BC Hydro by Power Smart Engineering. We also studied three papers that present the research on phantom energy use. The documents are:

Smart Strip Electrical Savings and Usability, Power Smart Engineering, October 27, 2008
Final Field Research Report, Ecos Consulting, October 31, 2006. Prepared for California Energy Commission's PIER Program.
Developing and Testing Low Power Mode Measurement Methods, Lawrence Berkeley National Laboratory (LBNL), September 2004. Prepared for California Energy Commission's Public Interest Energy Research (PIER) Program.
2005 Intrusive Residential Standby Survey Report, Energy Efficient Strategies, March, 2006.

In our search for a comprehensive study done for this measure we found a detailed study done by Navigant Consulting for San Diego G&E, March 31, 2009 titled, Smart Strip Portfolio of the Future.

The study done by Navigant compiles findings from various sources including ECOS and LBNL studies referenced above and a home electronics survey done by Hiner and Partners in California, October 2008 titled Statewide Home Electronics Assessment Survey.

1.3 SAVINGS ANALYSIS

The analysis considers two applications: home entertainment and home office. For each peripheral piece of equipment there are two consumption rates to consider: the standby mode consumption and the off mode consumption. For each of these modes the percent time in that mode is also considered along with the percent time that each peripheral is used with out the control device (TV or computer). The home office computer is assumed to not be in use 85.6% of the time while the home entertainment TV is assumed to not be in use for 77.7% of the time based on the Hiner and Partners survey.

The average savings per peripheral is calculated using the following formula:

Power = [(Power in standby) x (time standby) + (power in off) x (time in off)] x [1-(%time used without PC/TV)]

The following table presents the values used to calculate the savings per peripheral.

					reterritori	Present
Equipment	Power Consumption in Standby Mode (W)	Power Consumption in Off Mode (W)	% of Time in Standby Mode	% of Time in Off Mode	Peripherals Used Without PC/IV	Everage Saprage PAC Pertables of EWh/years
Flat panel monitor	1.36	1.25	38.5%	61.5%	0.0%	9.66
CRT	3.95	1.47	38.5%	61.5%	0.0%	18.13
Printer	3.44	1.435	41.3%	58.7%	20.0%	13.54
Multifunction printer no fax	7.85	7.75	55.6%	44.4%	33.3%	38.89
Multifunction printer with fax	7.6	7.5	69.3%	30.7%	42.7%	32.44
Speakers, subwoofers, bass	20.44	1.62	16.7%	83.3%	0.0%	35.55
Scanner	4.05	0.46	26.9%	73.1%	4.5%	10.17
Copier	1.2	0.052	23.3%	76.7%	41.9%	1.39
Modem	7.21	1.74	86.3%	13.7%	9.6%	43.66
Shredder	0	0	29.6%	70.4%	51.3%	0.00
Router	5.85	0.06	86.5%	13.5%	6.7%	35.34
External hard drive	4.53	0	25.0%	75.0%	0.0%	8.46
DVD player	11.77	1.57	5.4%	94.6%	6.7%	13.43
VCR	12.85	5.02	11.5%	88.5%	2.1%	39.31
Stereo	27.38	2.29	7.1%	92.9%	49.3%	14.00
Speakers, subwoofers	11.07	11.07	20.7%	79.3%	13.8%	64.74
Video game consoles	4.05	0.88	12.0%	88.0%	2.0%	8.38
Computer only used for video/music entertainment	46.97	3.17	33.3%	66.7%	33.3%	80.37

For the 5-plug strip three equivalent control peripherals have been assumed. For the 7-plug strip five equivalent control peripherals have been assumed. The following table shows the allocation of peripherals and savings per strip for both the home office and home entertainment.

	Three Peripherals	per Power Strip	Five Peripherals	per Power Strip
Equipment	% of Peripherals plugged into APS	Average Savings Per Peripheral Plugged into APS (kWh/year)	% of Peripherals plugged into APS	Average Savings Per Peripheral Plugged into APS (kWh/year)
Flat panel monitor	73.4%	7.09	73.4%	7.09
CRT	26.6%	4.82	26.6%	4.82
Printer	77.8%	10.53	77.8%	10.53
Multifunction printer no fax	7.2%	2.80	7.2%	2.80
Multifunction printer with fax	15.0%	4.87	15.0%	4.87
Speakers, subwoofers, bass	1.3%	0.45	3.8%	1.35
Scanner	17.0%	1.73	50.9%	5.18
Copier	10.9%	0.15	32.7%	0.45
Modem	18.5%	8.07	55.4%	24.21
Shredder	29.1%	0.00	87.3%	0.00
Router	22.5%	7.96	67.6%	23.89
External hard drive	0.8%	0.06	2.3%	0.19
Home Office Total	300.0%	48.53	500.0%	85.37
DVD player	100.0%	13.43	100.0%	13.43
VCR	40.8%	16.02	100.0%	39.31
Stereo	59.2%	8.29	100.0%	14.00
Speakers, subwoofers	27.1%	17.57	54.3%	35.15
Video game consoles	68.6%	5.75	137.1%	11.49
Computer only used for video/music entertainment	4.3%	3.44	8.6%	6.89
Home entertainment total s	300.0%	64.51	500.0%	120.27

	Five-plu	Strip Summary		
	Home Office	Home Entertainment	Home Office	Home Entertainment
Average savings (kWh/year)	48.5	64.5	85.4	120.3
Total savings per home (kWh/year)		113.0		205.6
Savings per unit (kWh)		56.5		102.8
Demand savings (kW)	0.006	0.010	0.011	0.018
Peak demand savings per unit (kW)		0.008		0.015
Average demand savings per unit (kW)		0.006		0.012

The tab labeled "power strips" in the "DSD Input Summary" spreadsheet contains the assumptions and the detailed savings calculations.

1.4 COST

The pricing for this measure is based on the data in the following table.

Smart Strip		5 plug	7 olua
Supplier	Manufacturer	Cost of Sm	art Strip
Bits Ltd	Bits Ltd	\$31.95	\$41.95
SmartHome USA	Bits Ltd	\$30.95	\$40.00
Ace Hardware	Coleman Cable, Inc	\$29.99	
Average	The state of the s	\$30.96	\$40.88
Power Strip	THE TANK OF THE PARTY OF THE PA		
Supplier	Manufacturer	Cost of Pov	ver Strip
Best Buy	Spike Master	\$14. 99	\$14.99
Circuit City	Cyber Power	\$14.49	\$14.49
Ace Hardware	Ace	\$13.99	\$13.99
Average		\$14,49	114.40
		5 plug	7 plug
Incremental Cost		\$16.47	\$26,49

	•		
		·	
		·	
		:	

Attachment E:

"Estimated Energy Savings with HiR Windows"

Estimates of Potential Energy Savings with High Performance Windows

With input from Lawrence Berkeley National Laboratory and the Consortium for Energy Efficiency, the Alliance to Save Energy conducted simulations to estimate the energy savings potential and economics of specifying high-performance windows for new homes and window replacement. The simulation tool used was RESFEN 5.0, a program based on DOE-2.1E and developed by LBNL for modeling the thermal performance of homes based on window choices. The results of these simulations and the assumptions used are summarized below.

Purpose

The primary purpose of our estimates is to determine whether deeper energy savings beyond those achieved through the market penetration of ENERGY STAR® windows are viable. We are mainly looking at the potential of highly-insulating windows that significantly exceed the performance of typical ENERGY STAR Windows in cold and mixed climates. To date, the potential of these windows has remained largely untapped, primarily because of higher retail cost, resulting from higher manufacturing cost and lacking economies of scale.

Highly-insulating windows provide superior energy performance due to advanced frames combined with three glass panes or a heat-reflecting film between two panes of glass. These windows surpass dual-pane windows in energy savings, peak demand reduction and enhanced comfort. Simulated energy savings and peak demand reduction are part of our analysis.

In addition to highly-insulating windows, we looked at the cooling demand reduction potential for solar control windows in cooling climates.

Window Types Examined

Conventional window

U-factor:

0.50

- SHGC:

0.55

Double-pane windows without low-E coatings in vinyl, wood, or hybrid/composite frames. Although many building energy codes and incentive programs encourage the use of windows with better energy performance than conventional windows can offer, use of these windows is still relatively common due to trade-off options in building codes and lacking code enforcement.

Conventional code-compliant window (South)

U-factor:

0.50

- SHGC:

0.40

If trade-off options in codes are not used, most codes in the U.S. require in their prescriptive path that windows with better than conventional solar control are used. The U-factor requirements of windows in southern climates are rarely more stringent than 0.50, which is less energy-efficient than the U-factor needed to qualify for ENERGY STAR. Nevertheless, southern codes widely require an SHGC of no more than 0.40 to limit cooling demand.

¹ RESFEN can be downloaded at http://windows.lbl.gov/software/resfen/resfen.html.

Acknowledgment: "This material is based upon work supported by the Department of Energy, National Energy Technology Laboratory under Award Number DE-FC26-06NT42766."

Disclaimer: "This publication was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof."

Typical Energy Star window

U-factor;

0.35

- SHGC:

0.50 (high solar gain), 0.30 (low solar gain)

In our analysis, we define a typical ENERGY STAR window as a window that meets the ENERGY STAR U-factor criterion for the Northern climate zone (0.35). Such windows typically include low-E coatings, gas fills, and low-conductance spacers. In the North, ENERGY STAR windows can either have high-solar-gain, low-solar-gain, or low-E coatings. The type of low-E coating used can alter the SHGC dramatically. In the South, only windows with a low SHGC qualify for ENERGY STAR.

The prescriptive requirements of most northern energy codes specify windows with a U-factor of 0.35 or less. Therefore we did not include a separate category for common code-compliant windows in the North, as this would be equivalent to ENRGY STAR windows. However, due to trade-off options in codes and imperfect code compliance, conventional windows still hold substantial market share in many northern states.

Solar control low-E window

U-factor:

0.35

- SHGC:

0.25

These windows are similar in performance to typical low-E windows, but have advanced low-E coatings that provide maximum control of solar radiation while still transmitting most visible light.

Moderate cost highly-insulating window

U-factor:

0.25

SHGC:

0.40 (high solar gain), 0.25 (low solar gain)

Window U-factor can be reduced to 0.25 or below through glazing upgrades (additional glazing layers and/or krypton gas fills) without expensive upgrades of the frame. Depending on the choice of low-E coatings, highly-insulating windows can be designed for high or low solar gain.

Best-case highly-insulating window

U-factor:

0.20

SHGC:

0.40 (high solar gain), 0.25 (low solar gain)

Windows with optimized glazing, spacer, and frame performance are available with U-factors below 0.20. Depending on the choice of low-E coatings, highly-insulating windows can be designed for high or low solar gain.

Future highly-insulating window

U-factor;

0.17

- SHGC:

0.40 (high solar gain), 0.25 (low solar gain)

In its 2007-12 multi-year plan for window research and development, U.S. DOE states the goal of developing and deploying cost-competitive windows with a 0.17 U-factor by 2010. Such performance increases and cost effectiveness can be achieved either through new lower cost window technologies, such as currently researched by LBNL, or through economies of scale for current best-performing technologies.

Selected Analysis Results

The energy-saving technologies used in typical ENERGY STAR windows have found wide acceptance as cost-effective energy-efficiency features. Highly-insulating windows with additional glazing layers, on the other hand, can be substantially more expensive. Therefore it is not surprising that we found the cost-effectiveness of currently available highly-insulating windows to be low when compared to typical ENERGY STAR windows (see Figure 1 in the appendix). However, this finding does not account for the ancillary benefits of highly-insulating windows: reduced heating and cooling peak demand and opportunities for HVAC system downsizing.

If conventional windows instead of ENERGY STAR windows are used as the baseline for comparison, the cost-effectiveness of highly-insulating windows is more significant. However, it is important to note the differences between highly-insulating windows that allow high solar gain (Figures 2 through 5) and those made for low solar gain (Figure 6 and 7), since solar heat gain improves overall annual energy savings in heating dominated climates.

High-solar-gain windows save more energy in the heating-dominated North and are thus more cost effective. However, low-solar-gain windows provide much higher cooling peak load reduction (Figures 8 and 9).

In addition to the energy and peak demand saving benefits that we estimated through simulation, there are other benefits of high-performance windows that are harder to simulate but that could lead to further substantial energy and cost savings:

- If integrated in a well-insulated building envelope, highly-insulating windows make the consideration of alternative duct designs possible. For instance, traditional perimeter heating, which is used to offset discomfort from cold window surfaces, is not necessary for a highly-insulated envelope. By avoiding perimeter heating and reducing duct runs, energy loss from duct leakage as well as first cost for duct installation can be reduced.²
- High-performance windows improve the comfort of building occupants. Studies by the Center for the
 Built Environment at UC Berkeley have found that occupants tend to compensate for thermal
 discomfort, such as from cold window surfaces or strong solar radiation, by setting their thermostat at
 more extreme temperatures, thus further increasing energy use.³ Our savings estimates do not take
 this effect into account, which leads to somewhat conservative results.

Free Riders vs. Spill-over

Although typical ENERGY STAR windows are currently more cost effective than highly-insulating windows, promotion of highly-insulating windows has the potential to create spill-over effects and lasting market transformation. While continued promotion of ENERGY STAR windows can help further increase the market share of energy-efficient windows where energy codes provide insufficient traction, financial incentives for current ENERGY STAR windows are bound to create free riders. Incentives for highly-insulating windows, on the other hand, would potentially provide a spill-over effect by promoting underutilized high-efficiency options that can become more attractive with increasing awareness and economies of scale.

Incremental cost of High-Performance Windows

It is difficult to make assumptions about the incremental cost of one window option versus another because the market is very diverse and window retailers tend to set prices depending on what customers are willing to pay. Nevertheless, a few general assumptions can be made about the incremental cost of energy-efficient windows compared to more conventional windows. Here, we concentrate on the basic window options used in our simulations:

² Building America contractor Ibacos (www.ibacos.com) can serve as a source on compact duct design.

³ Huizenga et al. 2006. Window Performance for Human Thermal Comfort. University of California, Berkeley.

- Conventional windows. Windows without low-E coatings, gas fills, or similar energy-efficiency features are our baseline option and thus have no incremental cost.
- Typical ENERGY STAR Windows (U-factor 0.35). These windows have low-E coatings, which, according to U.S. DOE's website, typically increase window prices by 10-15 percent. Northeast Energy Efficiency Partnerships surveyed retailers about the incremental cost for their customers to purchase ENERGY STAR Windows instead of conventional double-pane windows and received answers that ranged from 5-15 percent, depending on market saturation. If \$15/ft² is assumed as the base cost, an average cost premium of \$1.50/ft² could be assumed, which matches closely with observations made by the Southwest Energy Efficiency Project. According to PNNL's Building Energy Codes Resource Center, low-E windows typically retail for only about \$1/ft² more than non-low-E windows. Since we define typical ENERGY STAR windows as having gas fills and low-conductance spacers in addition to low-E coatings, we assume an incremental cost of \$1.50/ft².
- Moderate-cost highly-insulating windows (U-factor 0.25). Literature is sparser on the incremental cost of windows that exceed ENERGY STAR performance. In its evaluation of windows with a U-factor of less than 0.25, ACEEE assumes a cost increment of \$5/ft² over conventional windows. Based on conversations with window retailers and window manufacturers, we conclude that this assumption is too optimistic if used for retail prices. A more realistic assumption is the goal set by DOE of achieving an incremental cost of no higher than \$5/ft² for windows with a 0.2-0.25 U-factor by 2007 relative to typical windows used in new construction (which would include low-E windows). In conversations with manufacturers, we learned that window U-factor can be reduced to 0.25 or below through glazing upgrades (additional glazing layers and/or krypton gas fills) without modifications in the frame. This can be achieved at an incremental cost as low as \$2.50/ft² wholesale price compared to typical ENERGY STAR windows. For retail, we assume the incremental cost for a 0.25 U-factor window to be \$4.5/ft² if compared to a window with a 0.35 U-factor and \$6 per square foot if compared to a conventional window.
- Best-case highly-insulating windows (U-factor 0.20). Since windows with a U-factor of 0.25 (moderate-cost HI windows) generally have three glazing layers, improving the U-factor to 0.20 (best-case HI windows) does not require the addition of glazing layers. However, changes in the frame may be necessary to allow for optimum gap width between the glazing layers or to improve frame insulation and stability. Anecdotal price data from window manufacturers suggests that improving the U-factor to 0.20 yields a 50 percent higher incremental cost than going from U-factor 0.35 to 0.25. For our simulations, we therefore assume that the incremental cost of best-case HI windows is \$2.50/ft² over moderate-cost HI windows and \$7/ft² over typical ENERGY STAR windows.
- Future highly-insulating windows (U-factor 0.17). In its 2007-12 multi-year plan for window research and development, U.S. DOE states the goal of achieving an incremental cost by 2010 of no more than \$5/ft² for windows with a 0.17 U-factor compared to currently common windows. For our simulations, we assume this to be the incremental cost relative to typical code-compliant windows. Such performance increases coupled with cost reduction can be achieved either through new lower

⁴ U.S. Department of Energy. A Consumers Guide to Energy Efficiency and Renewable Energy: Low-emissivity Window Glazing and Glass. Accessed November 27, 2007.

http://www.cere.energy.gov/consumer/your home/windows doors skylights/index.cfm/inytopic=13430.

⁵ Larry Kinney. 2004. Windows and Window Treatments. Southwest Energy Efficiency Project.

⁶ Pacific Northwest National Laboratory. Low Solar Heat Gain Windows – Successful Market Transformation in Georgia and Texas. Last modified January 11, 2006. http://resourcecenter.pnl.gov/cocoon/morf/ResourceCenter/article/1298.

⁷ Sachs, Harvey et al. 2004. Emerging Energy-Saving Technologies and Practices for the Buildings Sector as of 2004.

Sachs, Harvey et al. 2004. Emerging Energy-Saving Technologies and Practices for the Buildings Sector as of 2004. American Council for an Energy Efficient Economy.

⁸ U.S. Department of Energy. Multy Year Program Plan 2007-2012. Last updated January 2007. http://www.cere.energy.gov/buildings/about/pdfs/mypp 2007/mypreport_ch2.pdf.

cost window technologies, such as currently researched by LBNL, or through economies of scale for current best-performing technologies.

In Europe, windows with a 0.17 U-factor are already becoming more common (for example, windows certified as Passive House windows), while a Swiss market study asserts that due to the maturing triple-pane window market, "the cost for triple glazing (coated and inert-gas-filled) decreases faster than the one of the already well-established double glazing and, therefore, the costs of the two glazing types can be expected to converge in the longer term". The same is likely to happen once the market for triple-glazed windows reaches maturity in the United States.

Presently, there are few incentives for the use of beyond-code windows in the US, so the demand for highly-insulating windows among home-builders remains low. Therefore, most retailers of highly-insulating windows are focusing on niches in the replacement market. To change this situation and enable window manufacturers develop economies of scale for beyond-code windows, market transformation efforts are essential.

Other Basic Assumptions Used in the Analysis

Locations

Since highly-insulating windows provide the most benefits in heating-dominated climates, we mostly focused our savings estimates on locations throughout the northern part of the United States. However, to also assess the potential of windows with special solar-control low-E glass, we included two locations in cooling-dominated climates in the analysis.

Building types

We simulated the performance of windows for both new construction and replacement. We simulated new construction with 2,400 ft² floor space and 360 ft² window area and existing homes with 2,000 ft² floor space and 300 ft² window area. For building shell performance and other parameters, the climate-specific settings of the RESFEN software were used. All homes are assumed to be heated with natural gas furnaces (AFUE 0.78) and cooled with central air conditioning (SEER 13 in new construction, SEER 10 in existing buildings).

Energy prices

Natural gas prices used for the analysis were based on ASE (Alliance to Save Energy) projections, which used ElA data of historic winter heating fuel prices and ElA projections of price developments for the winter of 2007 to project state-specific residential retail prices for natural gas used for heating. The electricity prices used in the analysis are average residential retail prices by state for the warm months (May through September) of 2006. ElA has not yet published the complete state-specific residential retail prices for the period of May-September 2007.

Cost per saved therm of natural gas

Modeled after the CEC formula to determine the levelized cost of conserved energy, we used the following formula to determine the cost per saved therm of natural gas as a result of window efficiency increases:

Ix CRF / S

I = Incremental cost for higher performing windows

CRF = Capital recovery factor = $r(1+r)^{n-1} / (1+r)^{n-1}$


r = discount rate (we used 5%)

n = planning horizon / measure lifetime: (25 years)¹⁰

S = annual savings in therms

⁹ Martin Jakob and Reinhard Madlener. 2003. Exploring Experience Curves for the Building Envelope: An Investigation for Switzerland for 1970-2020. Centre for Energy Policy and Economics, Swiss Federal Institutes of Technology: p. 27. ¹⁰ 25 years is, for example, used by Questar Gas as the measure lifetime for window energy-efficiency measures (see http://www.pse.utah.gov/gas/05docs/05057T01/QGC%20DSM%20Exhibit%201.5%20(Audit%20&%20Wx)12-5-06.doc).

Figure 1: Annual return on investment in higher-performing windows
Base case: Code compliant / ENERGY STAR Windows



If windows meeting prescriptive energy code requirements (ENERGY STAR windows in the North) are used as the base case, the energy savings that can be achieved with current highly-insulating (HI) windows are estimated to provide only low return on their incremental cost. Only the more cost-effective highly-insulating windows that DOE is envisaging for 2010 (highlighted in blue) would provide good return on investment in cold climates. In hot climates, good return on investment can presently be achieved with solar control low-E windows.




Figure 2: Annual return on investment in high-solar-gain high-performance windows

Base case: Conventional windows

If conventional windows are used as the base case, the energy savings that can be achieved with current highly-insulating (HI) windows designed for high solar gain are estimated to offer significant return on investment in cold climates with high energy prices. Even more cost-effective highly-insulating windows are envisaged by DOE for 2010 (highlighted in blue).

Figure 3: Cost per saved therm of natural gas with high-solar-gain high-performance windows Base case: Conventional window

With highly-insulating windows that allow high solar gain, substantial heating energy use reductions can be achieved. Current highly-insulating windows are still a very expensive option for natural gas savings, but market transformation toward economies of scale and improved performance can lead to very cost-effective options for cold climates.

* Note: the average natural gas price used here is the projected average retail price for natural gas for residential heating in the respective states according to Alliance to Save Energy projections that are based on regional price projections by the Energy Information Administration..






Figure 4: Heating gas savings in new homes with high-solar-gain high-performance windows Base case: Conventional windows




In our estimates, average natural gas consumption for heating across the four sample climates is about 18 percent lower in homes with future highly-insulating windows than in homes with conventional windows, and about 11 percent lower than in homes with typical ENERGY STAR windows.

Figure 5: Annual return on investment in low-solar-gain high-performance windows Base case: Conventional windows




In heating-dominated climates, windows designed for low solar gain are not estimated to provide as high energy savings as windows designed for high solar gain. Nevertheless, low-solar-gain windows can provide substantial cooling peak load reductions and allow for HVAC system downsizing (see Figure 5).

Figure 6: Heating gas savings in new homes with low-solar-gain high-performance windows Base case: Conventional windows



High performance windows can lead to more heating energy use if they block a substantial fraction of solar heat gain. This is particularly obvious in climates with strong solar heat even in wintertime.

Figure 7: Cooling peak load in new homes depending on window type (low-solar-gain windows marked blue)



According to our estimates, low-solar-gain HI windows reduce peak cooling load by an average 28 percent if compared with conventional windows across different climates. Even high-solar-gain HI windows would achieve an average peak load reduction by 18 percent.

Figure 8: Cooling peak load reduction in new homes depending on window type (low-solar-gain windows marked blue)





Figure 9: Cooling electricity savings in new homes depending on window type (low-solar-gain windows marked blue)



Attachment F:

"09-06-30 Pool Pumps Exploration Memo"



98 N. Washington St., Suite 101 Boston, MA 02114 617.589.3949 www.cee1.org

Memorandum

To

CEE Residential Appliances Committee

From Date

Eileen Eaton June 30, 2009

Re

Pool Pumps Exploration

Background

Starting in 1997, members of the CEE Appliance Committee have been promoting clothes washers, dishwashers, refrigerators, and room air-conditioners in their programs. Over this time period, the market penetration of ENERGY STAR models in these four product categories has increased significantly. As a result, the ENERGY STAR criteria and CEE's high efficiency specifications for these products have been revised many times. Even so, members have communicated difficulty managing free-ridership issues and getting their programs to pass total resource cost (TRC) tests. This combined with the need to deliver even greater energy savings, has led to the Appliance Committee's interest in exploring new technologies.

In the spring of 2008, the Appliance Committee created a list of technologies of interest, established a criterion for evaluating them, and identified their top three priorities. At CEE's June Program Meeting, the Committee discussed the potential for pursuing pool pumps, clothes dryers, and dehumidifiers. Given the existence of the ENERGY STAR program for dehumidifiers, and the significant market barriers associated with clothes dryers, the Committee chose to focus on pool pumps first. [Unfortunately work in this area was postponed due to revisions to the ENERGY STAR criteria for dishwashers and CEE's residential dishwasher specification during the fall of 2008 and first half of 2009.]

This memo outlines the potential energy savings, existing pool pump programs, relevant standards, additional information needed, market challenges, and potential next steps with regards to pool pumps. It will be used to inform the Committee's discussion on our July 7 call, during which we'll review the information in sections I-III to ensure it is consistent with current program experience and then focus our discussion on enhancing sections IV-VI.

I. Potential Energy Savings

The following information on potential energy savings was gathered from a 2009 Pool and Spa Marketing study, San Diego Gas & Electric's Pool Motor Brochure dated 9/06/07, and the online Pentair Pool Pump Cost Calculator. If you are currently running a program, please compare these numbers and assumptions to the ones you are using to see if there are significant discrepancies.

Energy use

Standard (single speed) pumps

- a. 6 hours/day
- b. 13.8 kWh/dayii
- c. Warm climate (365 days) 5,037 kWh/yr
- d. Cool climate (100 days)¹ 1,380 kWh/yr

Two-speed pumps

- a. 10 hours/dayⁱⁱⁱ
- b. 9.4 kWh/day^{iy}
- c. Warm climate (365 days) 3,431 kWh/yr
- d. Cool climate (100 days) 940 kWh/yr

Variable speed pumps

- a. 10 hours/day^v
- b. 2.1 kWh/day^{vi}
- c. Warm climate (365 days) 767 kWh/yr
- d. Cool climate (100 days) 210 kWh/yr

Per Unit Energy Savings

These savings were calculated based on the above energy use estimates.

Two-speed savings over standard (single speed)

- a. 4.4 kWh/day
- b. Warm climate (365 days) 1,606 kWh/yr
- c. Cool climate (100 days) 440 kWh/yr
- d. Approximately 30% savings

Variable speed savings over standard (single speed)

- a. 11.7 kWh/day
- b. Warm climate (365 days) 4,270 kWh/yr
- c. Cool climate (100 days) 1,170 kWh/yr
- d. Approximately 85% savings

Total Energy Savings Potential

The above savings numbers were multiplied by the number of in-ground pools in a particular climate zone to determine aggregate savings. The market regions as defined by Pool & Spa Marketing were grouped as follows: Warm Climate – Southeast, South Central, and Southwest and Cool Climate – Northeast, East Central, West Central, and Northwest.

Two-speed savings over standard (single speed)

a. 5.1 million in-ground pools nationally in 2007vii

¹ Assumes pools are open from Memorial Day through Columbus Day in cool climates.

- 1. 3.3 million in-ground pools in warm climates (65%)
- 2. 1.8 million in-ground pools is cool climates (35%)
- b. 6.1 billion kWh/yr saved nationally
 - 1. Warm climate (365 days) 5.32 billion kWh/yr
 - 2. Cool climate (100 days) 0.78 billion kWh/yr

Variable speed savings over standard (single speed)

- a. 5.1 million in-ground pools nationally in 2007^{viii}
 - 1. 3.3 million in-ground pools in warm climates (65%)
 - 2. 1.8 million in-ground pools is cool climates (35%)
- b. 16.1 billion kWh/yr saved nationally
 - 1. Warm climate (365 days) 14 billion kWh/yr
 - 2. Cool climate (100 days) 2.1 billion kWh/yr

II. Existing Programs

The following information was collected by CEE staff as part of its research for the July 7 call. The list of program offerings among CEE members may not be comprehensive but reflects the program details staff were able to find through web research and member outreach.

CALIFORNIA

- Pacific Gas & Electric
 - Rebate:
 - Efficient two-speed pool filtration pump and motor with automatic controller \$100
 - Efficiency variable speed pool filtration pump and motor \$100
 - Requirements: A controller capable of automatically switching speeds must be purchased and installed, if the existing controller does not have this capability.
 - Resources:
 - List of qualified two speed pumps, motors, and controllers and variable pumps and controllers
 http://www.pge.com/myhome/saveenergymoney/rebates/seasonal/poolpumps/
- San Diego Gas & Electric
 - o Rebates: SDG&E provides a \$100 rebate for Multi-Speed or Variable-Speed Pool Pump and Motors.
 - o Requirements: A qualifying automatic controller is required for most multi-speed pool pump and motor sets.
 - o Resources:
 - List of qualifying pool pumps and controllers <u>http://www.sdge.com/residential/poolPumps.shtml</u>

- Southern California Edison
 - o Rebate: \$200 back for a two-speed pool pump or variable-speed pool pump. This rebate is part of the Home Energy Efficiency Rebate Program (HEER).
 - o Requirements: For those models that require an automatic control system capable of controlling both high and low speeds, a controller must be installed.
 - o Resources:
 - List of qualifying pool pumps and motor models http://www.sce.com/residential/rebates-savings/pool/pool-pump-motor.htm

Note: Two-speed pumps don't always deliver correct speeds, and so existing programs are experiencing more buy in from contractors with variable pumps. However, calculating savings on variable speeds is more complex. PG&E verified service providers model is being pursued an upstream rebate program. It is important to note that the baseline may be different in CA because of Title-24.

MASSACHUSETTS AND RHODE ISLAND

- Cape Light Compact, NSTAR Electric, National Grid, Western Massachusetts Electric, and Unitil
 - Rebates:
 - Two-speed customer rebate \$50, contractor \$50
 - Variable speed customer rebate \$100, contractor \$50
 - o Requirements: To be eligible, installations must include a qualifying controller.
 - Resources:
 - List of qualified products
 http://www.myenergystar.com/documents/RebateForms/MA and RI Qualified Pool Pump List May 2009.pdf
 - List of qualified controllers
 http://www.myenergystar.com/documents/RebateForms/MA and
 RI Qualified Controller List May 2009.pdf

NEW YORK

- Long Island Power Authority
 - Rebates:
 - Two-speed installer rebate \$75 and two-speed customer rebate \$75
 - Variable speed installer rebate \$100 and variable speed customer rebate \$200
 - o Requirements: The pool pumps must be installed with an eligible controller by a participating dealer in order to qualify for the rebate. Eligible pumps must be 1/2 HP or larger.
 - o Resources:
 - List of qualified products http://www.lipower.org/pdfs/cei/qualified-poolv.pdf
 and http://www.lipower.org/pdfs/cei/qualified-pool2.pdf
 - List of participating dealers/installers http://www.lipower.org/pdfs/cei/retailers-pool.pdf

NEVADA

- NV Energy
 - Rebate: NV Energy is providing instant rebates on energy-efficient residential pool pumps.
 - \$100 instant rebate for two-speed pumps
 - \$200 instant rebate for variable-speed pumps
 - o Requirements: Must use a participating retailer, pool builder, or distributor to receive instant rebate. Pump must be new; rebuilt motors do not qualify.
 - o Resources:
 - They have developed a list of participating retailers and pool builders as well as service professionals.
 - http://www.nvenergy.com/saveenergy/home/rebates/poolpumps.cfm

TEXAS

- Austin Energy
 - o Rebates: \$200 for an Austin Energy qualified variable-speed pump and motor
 - o Requirements: Must be Austin Energy qualified and a replacement for an existing pump and motor, or installed with a new in-ground pool (existing pools with solar heating are not eligible)
 - o Resources:
 - List of qualified models
 http://www.austinenergy.com/Energy%20Efficiency/Programs/Rebates/Residential/Pool%20Pump/qualifyingSystems.htm
 - List of participating pool professionals
 http://web.memberclicks.com/mc/directory/viewSaveSearch,do?saveSearchReturn=3 and
 http://www.austinenergy.com/Energy%20Efficiency/Programs/Rebates/Residential/Pool%20Pump/index.htm

III. Current Standards CALIFORNIA

- Title 20 (http://www.energy.ca.gov/2006publications/CEC-400-2006-002/CEC-400-2006-002-REV2.PDF) addresses pumps, motors, and controls and was adopted in October 2005.
- Title 20 specifies:
 - o Service Factor
 - o Motor Efficiency
 - Employs standard test procedure to make motor efficiency comparisons
 - o Two-Speed Capability
 - Pump Motors

- Pump Controls
- Title 24 (http://www.energy.ca.gov/title24/index.html) includes information on pump motor selection, pipe design, and filter size selection. The standards are in a 2008 update process now.
- Title 24 Recommendations:
 - o Compliance with Title 20
 - o Accessible On/Off Switch
 - o Posted Instructions for Energy Efficient Pool Operation
 - o No Electric Resistance Heating
 - Exceptions for heaters with fully insulated covers/enclosures or 60% of heat from solar or recovery
 - o Pump Sizing and Flow Rate Requirements
 - System Piping Requirements
 - o Filtration Equipment Sizing Requirements
 - Peak Demand Controls
 - Cover Required for All Pools

IV. Additional Information Needed

This is a list of information needs identified at CEE's June Meeting in 2008. Efficiency programs may have other information needs that aren't included in this list. Please consider what should be added.

- Market channel information
 - O Where pumps are purchased
 - Who installs them
- Installation considerations
 - o Correct sizing of pump for pool
 - There maybe a study from Ecos on this topic
 - o Design of pipes, filters, pump and pool

V. Challenges

Again, this list of challenges is from CEE's 2008 June Meeting. Please consider other challenges that should be included.

- Customer awareness
- Industry support
- Getting pumps installed
- Regional differences
- High cost equipment
- High cost installations
- Complicating factors
 - o Efficient pool designs
 - o Filtration systems and where filters and pumps are installed

- o Pool timers (timers may not be a good for programs because they don't address water quality/filtration requirements and are also based on consumer behavior).
- Pool heaters

VI. Potential Next Steps

The items under each heading are not comprehensive. As in the previous sections, additional inputs are welcome.

- Identify additional resources
 - o Progress Energy in Florida as they may have a new standard in place.
 - o CA studies (SDG&E pool timers)
 - o Pool permit data
 - o Real estate data
- Talk with industry
 - o International Pool Spa Service Association (IPSSA)
 - o Experienced programs stressed that training industry and installers is key.
- Determine Role for CEE
 - o Information sharing
 - o CEE specification
 - o Product lists
 - o ENERGY STAR label would help manufacturers be consistent in reporting/testing

¹ San Diego Gas & Electric Pool Motor Brochure. Page 2. September 6, 2007. http://www.sdge.com/documents/residential/PoolMotorBrochure.pdf

ⁱⁱ San Diego Gas & Electric Pool Motor Brochure. Page 2. September 6, 2007.

http://www.sdge.com/documents/residential/PoolMotorBrochure.pdf

San Diego Gas & Electric Pool Motor Brochure. Page 2. September 6, 2007.

http://www.sdge.com/documents/residential/PoolMotorBrochure.pdf

San Diego Gas & Electric Pool Motor Brochure. Page 2. September 6, 2007.

http://www.sdge.com/documents/residential/PoolMotorBrochure.pdf

Y Pentair Pool Pump Cost Calculator. Accessed June 10, 2009 http://www.pentairpool.com/pool_pump_calc/index.htm.

[&]quot; Calculated based on Pentair Pool Pump Cost Calculator: \$/day divided by utility rate \$/kWh.

http://www.pentairpool.com/pool_pump_calc/index.htm.

vii Hubbard, Richard. U.S. Swimming Pool Industry Experiences Downturn in 2007. Pool & Spa Marketing. March 2009. Pages 12-13. http://www.poolspamarketing.com/public/stats/pdf/2007 US Swiming Pool Stats.pdf

Hubbard, Richard. U.S. Swimming Pool Industry Experiences Downturn in 2007. Pool & Spa Marketing. March 2009. Pages 12-13. http://www.poolspamarketing.com/public/stats/pdf/2007_US_Swiming_Pool_Stats.pdf

Attachment G:

"PGE Updated Proposal Information Template for Residential Pool Pump Measure Revisions"

Proposal Information Template for: Residential Pool Pump Measure Revisions

Submitted to:

California Energy Commission
In consideration for the 2008 Rulemaking Proceeding on Appliance Efficiency Regulations,
Docket number 07-AAER-3

Prepared for:
Pacific Gas and Electric Company

Pat Eilert
Gary Fernstrom
Ed Elliot



Prepared by: Leo Rainer Davis Energy Group

Last Modified: July 23, 2008

This report was prepared by Pacific Gas and Electric Company and funded by the California utility customers under the auspices of the California Public Utilities Commission.

Copyright 2008 Pacific Gas and Electric Company. All rights reserved, except that this document may be used, copied, and distributed without modification.

Neither PG&E nor any of its employees makes any warranty, express of implied; or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any data, information, method, product, policy or process disclosed in this document; or represents that its use will not infringe any privalely-owned rights including, but not limited to, patents, trademarks or copyrights

Proposal Information Template - Residential Pool Pump Measure Revisions

2008 Appliance Efficiency Standards

Leo Rainer Davis Energy Group July 23, 2008

CONTENTS

Purpose	2
Background	2
Overview	
Methodology	
Analysis and Results	
Recommendations	
Bibliography and Other Research	

Purpose

This document is a report template to be used by researchers who are evaluating proposed changes to the California Energy Commission's (Commission) appliance efficiency regulations (Title 20, Cal. Code Regs., §§ 1601 – 1608) This report specifically covers revisions to current Residential Pool Pump appliance standards which were adopted by the California Energy Commission on Oct 11, 2006.

This template covers the following 3 pool pump topics:

- Replacement pool pump motors
- · High-efficiency multi-speed motor and control clarifications
- New pool pump test curve

Background

There are approximately one million above ground residential swimming pools in California, the vast majority of which use a single-speed motor to drive the filtration pump to circulate and filter swimming pool water in order to remove particulate debris and maintain clarity. Residential pump motors range in size from one half to three horsepower (hp), are operated an average of about 4.6 hours per day, but in some cases up to 10 hours per day, and draw approximately one kW per nominal horsepower.

Using pumps with 2-speed motors offer a significant opportunity for energy savings by taking advantage of pump affinity laws. Operating a pump equipped with a two-speed motor at half speed for twice as long moves the same volume of water, but in theory uses only one-quarter the amount of energy. In reality, currently available two-speed motors are less efficient at the lower speed, so energy savings are closer to 55%. Low speed operation is generally adequate for filtering, but high speed may be needed for operating pool sweeps for a few hours daily, and for reforming DE filters after backwashing.

Residential Pool Pumps were first included in the 2005 Title-20 appliance standards that were adopted at the end of 2005. Residential Swimming Pool standards are included in the 2008 Title-24 building standards which are expected adopted in April, 2008 and will become effective July 1, 2009. The 2005 Title-20 standards regulated pool pump motor types and required testing and listing of pool pump motor combinations effective January 1st, 2006. In addition, multi-speed motors and controls were required for pool pumps of greater than 1 HP effective January 1st, 2008. The 2008 Title-24 standards require pool design standards that include minimum pool turnover times and maximum flow velocities.

Since the implementation of the standards there have been ongoing discussions between PG&E and the pool industry (principally the Association of Pool and Spa Professionals, APSP) in regards to updates and revisions including the following:

- · Accommodate new pool equipment such as variable-speed motors
- · Clarify whether or not replacement motors are covered
- Add a third pool pump test curve to represent efficient pool piping design.

Overview

Replacement pool pump motors

The current pool pump standards do not refer to pool pumps, pool pump motors, and pool pump motor combinations consistently. In addition, pool pump motors are not explicitly identified in the scope of the standards. Because of this, it is currently the interpretation of the CEC that the standards do not cover replacement pool pump motors, although this was the intent of the those involved in writing the standards.

Description of Standards Proposal	The scope of Residential Pool Pumps should be amended to explicitly include the pump, pump motor, and replacement motors.
California Stock and Sales	There are approximately 1.1 million private, residential, in-ground swimming pools in California, with annual sales of 34,000. Approximately 113,000 pool pump motors are replaced each year.
Energy Savings and Demand Reduction	Energy savings of replacing an average single-speed pool pump motor with a two-speed motor is estimated to be 1088 kWh/yr which will result in statewide savings of 497 GWh and 132 MW over the first ten years of the standard.
Economic Analysis	Installation of a two-speed replacement motor is estimated to cost an average of \$450 more than a single-speed replacement. Net present value of the energy savings over the 10 year lifetime of the motor is \$563 with a 2.2 benefit-to-cost ratio.
Non-Energy Benefits	Operating swimming pool filtration equipment at low flow rates greatly reduces noise and can reduce entrapment issues due to high flow velocities.

Environmental Impacts	None
Acceptance Issues	Not all pool service companies have experience with two-speed motors. Increasing the cost of a pool pump motor replacement above \$500 may require that it be done by a licensed contractor.
Federal Preemption or other Regulatory or Legislative Considerations	Pool pump motors are definite purpose motors and as such are not presently covered by federal efficiency regulations.

High-efficiency multi-speed motor and control clarifications

When the current standards were written the vast majority of residential pool pump motors were either single-speed or two-speed. Since then manufacturers have brought out an increasing variety of multi-speed and variable-speed motors. These can provide significant energy savings over conventional motors, but their performance is more difficult to characterize. Section 1605.3(g)(5)(B) needs to define what the lowest speed is.

New Pool Pump Test Curve

The 2008 Title-24 pool standards rely on a new pool system curve to size pumps for pools of greater than 25,000 gallons. This curve, referred to as "Curve C", was suggested by pool pump stakeholders and represents the system curve of a well designed, low pressure-drop pool. Adding Curve C to the test and listing requirements of filtration pumps will allow the data to be easily used for Title-24 compliance.

Methodology

The current appliance efficiency data base for pool pumps was used to estimate the efficiency of typical 1.5 hp single- and two-speed pumps. The data base was sorted by pump type and total horsepower and single- and two-speed pumps with close to 1.5 total hp were selected. Average energy factors for each type of pump was used to estimate annual energy use.

Two-speed motors can replace single-speed motors directly in most pumps, but they require a new two-speed controller and wiring which requires additional labor to install. Pool pump motors have an expected lifetime of 10 years, although the pump head can last much longer. We estimate that 113,000 pool pump motors are replaced each year, of these, we estimate:

- 30% will be replaced with a less than 1 hp motor and remain single-speed.
- 20% will replace the whole pump and will be covered by the current standard.
- 50% will be a motor replacement of greater than 1 hp.

Analysis and Results

Three sizes of pool pump motors were evaluated for this analysis: 1.25, 1.65, and 2.2 total hp. 84 pool pumps with these total capacities were selected from the current CEC appliance data base. Single-speed pump operation time was assumed to be the California average of 4.6 hours. High-speed pump operation depends on whether the pool has a filter pump powered automatic pool cleaner and whether there is a sand or DE filter that needs backwashing and high-speed start-up. An average of 1.3 hours per day was assumed. Low-speed operation was set to the number of hours required to filter the same amount of water as the single-speed system. Operating assumptions based on Curve A characteristics are summarized in the Table 1.

Table 1: Pool Pump Operation

		Flow	Power	EF	Run Time	Energy
Total HP	Motor	(gpm)	(W)	(gal/Wh)	(hrs/day)	(kWh/yr)
	Single-speed	57.0	1360	2.51	4.6	2286
1.25	Two-speed High	58.1	1488	2.34	1.3	680
	Two-speed Low	<u>32.1</u>	334	5.77	5.9	720
	Single-speed	60.7	1637	2.22	4.6	2753
1.65	Two-speed High	61.3	1814	2.03	1.3	829
	Two-speed Low	33.0	427	4.64	6.1	958
	Single-speed	63.0	1958	1.93	4.6	3291
2.2	Two-speed High	65.6	1913	2.06	1.3	874
	Two-speed Low	33.0	414	4.79	6.3	953
Weighted	Average Savings		1246			1088

The two-speed pumps operate an average of 7.4 hours per day, but due to the significantly lower power use on low-speed the average savings is 1088 kWh/yr. Average demand savings on low-speed is 1.2 kW.

Economic calculations are shown in Table 2. Average incremental cost of a two-speed motor is \$210, but an additional \$160 is required for the controller and \$80 for the added installation labor.

Table 2: Life Cycle Economics

Design						
Life	Annual Energy		Present Value of		Net Customer	
(years)	Savings (kWh)	LCC (\$/kWh)	Energy Savings	Incremental Cost	Present Vejue	BCR
10	1088	0.931	\$1013	\$450	\$563	2.25

Statewide savings estimates are shown in Table 3. 30% of motor replacements are assumed to be with less than one hp single-speed motors, and 20% are assumed to be whole pump change-outs, resulting in on one-half of required motor replacements being two-speed replacements. Full savings are realized in 2019 after all existing single-speed motors have been replaced. Demand savings are based on one-third of pool pumps operating on-peak.

Table 3: Statewide Energy and Demand Savings

Fraction Annual Motor Replaced with		Energy Savi (GWh/yea	Demand Savings (MW)		
Replacements	2-speed	First Year	2019	First Year	2019
113,000	50%	61	615	23	232

Recommendations

Replacement pool pump motors

Make the following changes in sections 1602 and 1604 to explicitly include replacement pool pump motors in the regulations:

1602(g)

"Residential pool pump" means a pump-motor combination used to circulate and filter pool water in order to maintain clarity and sanitation, and includes the centrifugal pump and the pump motor.

1604(g)

- (3) Test Method for Residential Pool Pumps and Replacement Motors
 - (B) ANSI/HI 1.6-2000 shall be used for the measurement of pump and motor combinations efficiency.

High-efficiency multi-speed motor and control clarifications Add the following definition to section 1602(g):

"Auxiliary pool load" means a feature or device that circulates pool water, in addition to that required for pool filtration, including, but not limited to, solar pool heating systems, filter backwashing, pool cleaners, waterfalls, fountains, and spas.

Make the following changes in section 1605.3(g)(5) to better accommodate high-efficiency multi-speed motors and to clarify control specifications as they relate to multi-speed products:

- (B) Two Multi-Speed Capability.
- (i) Pump Motors. Pool pump motors with a capacity of greater than 1 total HP or more which are manufactured on or after January 1, 2008, including but not limited to those installed in existing residential pool pumps as replacement residential pool pump motors, shall have the capability of operating at two or more speeds with a low the lowest speed having a rotation rate that is no more than one-half of the motor's maximum rotation rate.
- (ii) Pump Controls. Pool pump motor controls manufactured on or after January 1, 2008 that are sold for use with a two- or more speed pump shall have the following minimum capabilityies:
 - (a) The ability to operate the pool pump at two or more speeds.
 - (b) A filtration speed that is the default when no auxiliary pool loads are operating and is no more than one-half of the motor's maximum rotation speed.

(c) A high-speed override capability that returns to the filtration speed within twenty four hours.

New Pool Pump Test Curve

1604 (g) (3) Test Method for Residential Pool Pumps

(C) Two Three curves shall be calculated:

Curve A: H = 0.0167 x F2 Curve B: H = 0.050 x F2 Curve C: H = 0.0082 x F2

Where:

H is the total system head in feet of water. F is the flow rate in gallons per minute (gpm).

(D) For each curve (A&B&C), the pump head shall be adjusted until the flow and head lie on the curve. The following shall be reported for each curve and pump speed (two-speed pumps shall be tested at both high and low speeds). See Table V.

1606 Table V Data Submittal Requirements

	Appliance	Required Information	Permissible Answers
G	Residential Pool Pumps	Motor Construction	PSC, Cap Start-Cap Run, ECM, Cap Start-induction run, split-phase
		Motor Design	Single-speed, two-speed, multiple-speed, variable- speed
		Frame	
		Speed (apm)	
		Motor has Capability of Operating at Two or More Speeds with the Low Speed having a Rotation Rate that is No More than One-Half of the Motor's Maximum	Yes, no
		Rotation Rate	
		Pool Pump Motor Service Factor	
		Motor Efficiency (%)	
		Nameplate Horsepower	
		Flow for Curve 'A' (in gpm)	
		Power for Curve 'A' (in watts)	
		Energy Factor for Curve 'A' (in gallons per watt-hour)	
		Flow for Curve 'B' (in gpm)	
		Power for Curve 'B' (in watts)	
		Energy Factor for Curve 'B' (in gallons per watt-hour)	
		Flow for Curve 'C' (in gpm)	
	1	Power for Curve 'C' (in watts)	<u> </u>
	<u> </u>	Energy Factor for Curve 'C' (in gallons per watt-hour)	

Bibliography and Other Research

ANSI/NSPI – 1 2003. American National Standard for Public Swimming Pools, American National Spa & Pool Institute, March 2003.

ANSI/NSPI – 5 2003. American National Standard for Residential In-ground Swimming Pools, American National Spa & Pool Institute, December 2002.

APSP 2007. Association of Pool & Spa Professionals, *Portable Electric Spa Stand-by Energy Test Protocol (Draft)*, APSP-14-200X, October 2007.

DEG 2005. Davis Energy Group, CASE Initiative for Title 20 Standards Development: Analysis of standards options for residential pool pumps, motors, and controls. Prepared for PG&E, March 2005.

DEG 2007. Davis Energy Group, CASE Initiative for Title 24 Standards Development: Draft Report on Residential Swimming Pools. Prepared for PG&E, March 2007.

IAPMO 1997. *Uniform swimming pool, spa and hot tub code*. International Association of Plumbing & Mechanical Officials, 1997 Edition.

NSF/ANSI 50 – 2005. Circulation system components and related materials for swimming pools, spas/hot tubs. NSF International Standard/American National Standard.

Hydraulics and Filtration Manual, P1-700, Pentair Pool Products, 2002 Edition.

PK Data 2006. California Swimming Pool and Hot Tub Information, P.K. Data, April 2006.

STA-RITE Commercial Pool/Spa Engineering Design Manual

Attachment H:

"28 - Pump and Motor Single Speed"

Residential Swimming Pool Pumps

Measure Name	Residential Swimming Pool Pump
Target Sector	Single Family Residential Establishments
Measure Unit	Pool Pump
Unit Energy Savings	694 kWh
Unit Peak Demand Reduction	0.357kW
Measure Life	10 years

1.1 Introduction

Residential pool pumps ranging from 0.75 hp to 3 hp are often oversized, have inefficient motors and operate at higher flow rates than necessary. This work paper documents the calculation methodology and the assumptions regarding baseline equipment, high efficiency equipment, and usage patterns used to estimate annual energy savings expected from the replacement of a standard pool pumps with high efficiency pool pumps.

1.2 Measure Applicability

This work paper documents the energy savings attributable to efficient pool pumps in small residential applications. The most likely areas of application are swimming pools in single family establishments. There are two energy efficient scenarios described in this paper. The first scenario replaces a standard efficiency 1.5 HP pump with a premium efficiency 1.5 HP pump. The second scenario, called the "right-sizing" scenario, replaces a standard efficiency 1.5 HP pump with a premium efficiency 1.0 HP pump. In this scenario, the smaller pump runs slightly longer hours but filters approximately the same number of gallons per day.

1.3 Savings Calculations

The DSMore Michigan Database of Energy Efficiency Measures' refers to the California Energy Commissions' extensive field study for the energy savings analysis. The energy savings and demand reduction obtain through the following calculations:

Energy Usage:

$$E_{Base} = (HP_{Base} \times LF_{Base} \times .746) \times \left(\frac{1}{PME_{Rase}}\right) * HrD_{Base} \times DY = 2,121 \, kWh$$

$$E_{Eff} = \left(HP_{Eff} \times LF_{Eff} \times .746\right) \times \left(\frac{1}{PME_{Eff}}\right) * HrD_{Eff} \times DY = 1,467 \ kWh$$

$$E_{RS} = (HP_{RS} \times LF_{RS} \times .746) \times \left(\frac{1}{PME_{RS}}\right) * HrD_{RS} \times DY = 1,386 \text{ kWh}$$

Peak Demand:

$$D_{Base} = \left\{ HP_{Base} \times \left(\frac{LF_{Base}}{PME_{Base}} \right) \times 0.746 \frac{kW}{HP} \times CF \right\} = 2.272 \ kW$$

$$D_{Eff} = \left\{ HP_{Eff} \times \left(\frac{LF_{Bff}}{PME_{Eff}} \right) \times 0.746 \frac{kW}{HP} \times CF \right\} = 0.799 \ kW$$

$$D_{RS} = \left\{ HP_{RS} \times \left(\frac{LF_{RS}}{PME_{RS}} \right) \times 0.746 \frac{kW}{HP} \times CF \right\} = 0.697 \ kW$$

Energy Savings:

The energy savings are taken as the difference between the baseline energy usage and the average energy usage for the two efficient scenarios.

$$E_{Savings} = E_{Base} - \frac{1}{2} (E_{Eff} + E_{RS}) = 694kWh$$

Demand Reduction:

The demand reductions are taken as the difference between the baseline peak coincident demand and the average peak coincident remand for the two efficient scenarios.

$$D_{Savings} = D_{Base} - \frac{1}{2} (D_{Eff} + D_{RS}) = 0.357 \, kWh$$

1.4 Definition of Variables

The parameters in the above equations are listed in Table 1 below.

Table 1: Calculation Assumptions

Component	Type	Value	Source
HP _{base} : Baseline Pump HP	Fixed	1.5	i
HP _{Eff} : Efficient Pump HP	Fixed	1.5	i
HP _{RS} : Right-Sized Pump HP	Fixed	1.0	i
PME _B : Baseline Pump-Motor Efficiency	Fixed	0.325	i
PME _{Eff} : Efficient Pump-Motor Efficiency	Fixed	0.455	i
PME _{RS} : Efficient Right-Sized Pump-Motor Efficiency	Fixed	0.455	i
LF _{Base} : Load Factor	Fixed	0.66	i
LF _{Eff} : Load Factor	Fixed	0.65	i
LFRS: Right Sized Pump Load Factor	Fixed	0.85	i
HrDBase: Baseline Operating Hours/ day	Fixed	6.10	i
HrD _{Eff} : Baseline Operating Hours/ day	Fixed	6.00	ì
HrD _{RS} : Baseline Operating Hours/ day	Fixed	6.50	i

DY: Days per Year	Fixed	153	i
D _{Base} : Baseline pump demand (kW)	Calculated	2.27	i
D _{Eff} : Efficient pump demand (kW)	Calculated	1.60	i
D _{RS} : Efficient, right-sized pump demand (kW)	Calculated	1.39	i
CF: Coincidence Factor	Fixed	0.50	i

1.5 Prescriptive Deemed Savings

The deemed savings for the installation of a residential pool pump compared to a standard efficiency pool pump is 694 kWh per year with a demand savings of .357 kW.

Measure Life

The Database for Energy Efficiency Resources estimates the measure life at 10 yearsⁱⁱ which also matches with the DSMore useful life used in the energy savings analysis.

1.6 Evaluation Protocols

The most appropriate evaluation protocol for this measure is verification of installation coupled with assignment of stipulated energy savings.

References

ⁱ Please find original documentation from DSMore Ml DB attached herein:



Microsoft Office Word 97 - 2003 Docu



"DEER EUL values, updated October 10, 2008

http://www.deeresources.com/index.php?option=com_content&view=article&id=65<emid=57

Attachment I:

"LED Refrig Lighting ERCO Talking Pointsv3"

Efficient Refrigerated Case Options

Summary of Program



Pacific Gas and Electric Company®

Frozen Food & Refrigerated cases are typically illuminated by fluorescent lighting


The lighting is located

door behind a mullion

Rows or aisles of

doors are built in

on either side of the



modules ranging from

2-door modules to 6-

door modules

If we look at a 5-door module we will find 6-lamps per module, one lamp at each end and one lamp between each door.


Cases also are differentiated by Low temperature (freezer) and Medium temperature



(beverage).

Denotity of LED Case Lighting


depending on the existing light, LED refrigerated case lighting can save 30-60% of the energy usage as compared to the existing fluorescent lighting.




50,000 hour useful life (significantly longer than fluorescents) can Reduced Maintenance Costs – 5 year warrantee and estimated dramatically reduce costs associated with maintenance over the lifetime of the product. N



- and long life, LEDs are highly durable and contain no mercury. 3. Better for the Environment - apart from the energy savings
- 4. Improved Product Visibility LEDs have directional lighting which limits glare and light loss. Converse to fluorescent operation, LEDs function better at cooler temperatures.







T8 Lighting

Door Average: 93.61 Center Average: 55.13 **←** Left Side Average: 106.31

Right Side Average: 114.53 Both Sides Average: 112.97

ED Lighting

Door Average: 44.13 Center Average: 40.01

Left Side Average: 50.15◀ Right Side Average: 39.75 Both Sides Average: 45.54 SACRAMENTO MUNICIPAL UTILITY DISTRICT The POWER TO DIS MARKE?



Incentive Amount	\$100	\$75	\$65	\$45
System Waffage	≥ 46	≥ 59	≥ 38	> 50
Lumens Per Watt	> 35	≥ 25	> 35	≥ 25
ProvIIIot calcigory	Premium LED Case Light replacing 6' Fluorescent	Standard LED Case Light replacing 6' Fluorescent	Premium LED Case Light replacing 5' Fluorescent	Standard LED Case Light replacing 5' Fluorescent

CRI = >70; Color <5700k; Power Supply Efficiency >85%; PF > .90; THD <20%; 4 year Warranty





Lighting Options - Input Wattage Per Frame Section	ittage Per Frame Section	,		<i>,</i>			
Lighting System	Nom, Fixture Length	1-Door Watts	2-Door Watts	3-Door Watts	4-Door Watts	5-Door Watts	6-Door Watts
Fluorescent T8	72"	144.0	228.0	300.0	372.0	0.444	528.0
Fluorescent T8	09	120.0	180.0	228.0	288.0	348.0	408.0
Fluorescent T12/H0	72"	168.0	252.0	336.0	420.0	504.0	588.0
Fluorescent T12/HO	.09	156.0	234.0	312.0	390.0	468.0	546.0
Fluorescent T10/VHO	72"	174.0	270.0	348.0	444.0	522.0	618.0
Fluorescent T10/VHO	.09	162.0	246.0	324.0	408.0	486.0	570.0
Average watts per door, 5' T8	T8	120	06	76	72	70	පි
Average watts per door, 6' T12HO	T12H0	168	126	112	105	101	86
Best in class watts per door, 5' LED	r, s' LED	42	40	39	39	39	38
Best in class watts per door, 6' LED	r, 6' LED	48	45	44	43	43	42
Max watts per door, 5' LED Premium Tier	Premium Tier	38	38	38	38	88	38
Max watts per door, 5' LED		50	20	20	20	20	20
Max watts per door, 6' LED Premium Tier	Premium Tier	46	46	46	46	46	46
Max watts per door, 6' LED		වරි	28	58	59	59	59
Pacific Gas and							


Flectric Company.

LED Refrigerated Case Work Paper Summary Calculations

Base Case Lighting Energy Consumption	ghting Ener	gy Consumpt	ion	Proposed Case Lighting Energy Consumption	ighting Ene	rgy Consul	nption
System	W/ door	Annual operation (hrs/yr	Lighting kWh/Yr	System	W/ door	Annual operation (hrs/yr	kWh/Yr
5' fluorescent	9/	6,570	499	5', premium efficiency	38	6.570	250
				5', standard efficiency	90	6,570	329
6' fluorescent	112	0/9'9	982	6', premium efficiency	46	6,570	302
				6', standard efficiency	59	6,570	388

	Refriç	perated Case	Savings,	igerated Case Savings, Lighting and Compressor	essor		
		Lighting		Refrigeration	u	Total	ta/
System	Lighting load per door (W)	Annual operation (hrs/yr	Lighting Savings kWh	Refrigeration W saved per door	Refrigerati on Savings kWh	Total load (kW)	Total kWh Savings
5', premium efficiency	38	6,570	249	13	2	0.051	233
5', standard efficiency	26	6,570	170	6	26	0.035	23.
6', premium efficiency	99	6,570	434	22	143	0.088	•
6', standard efficiency	53	6,570	348	18		0.071	*8 3





Sat to sort to

- Manufacturers have stepped up
- Hussmann, GE, Phillips, Electraled, 1Source Electric, Efficient Lights, Energy Solutions
- Door Method is working
- Easy to count and inspect
- LM-79 at LTL and ITL have meet our needs
- However we are seeing some inconsistencies between labs
- We are seeing advancements in the products Lm/W has increased and wattage has dropped
- Color is settling at 35k and 41k
- Attention to uniformity and wider distribution
- Control options available
- Cost is coming down



œ


- Manufacturers and Labs aren't on the same page
 - Missing information
- Increased testing costs
- Inconsistencies in test procedures
- Constant Voltage Power Supply loading has impact on efficiency
- PER THE PG&E ERCO PROCEDURE FOR CONSTANT VOLTAGE LED
 RODUCTS, THE LUMINAIRE WAS TESTED WITH THE LED DRIVER OPERATING
 UNDER A SIMULATED FULL LOAD CONDITION, SPECIFIED BY THE LUMINAIRE
 MANUFACTURER AS TWO CENTER AND ONE END LUMINAIRE. IN ORDER TO
 DETERMINE EFFICACY, THE FULL LOAD LUMENS WERE EXTRAPOLATED BY
 MULTIPLYING THE MEASURED LUMEN OUTPUT OF THIS CENTER LED LUMINAIRE


 × 2 AND ADDED THE LUMEN OUPUT FROM ITL61639. THE SYSTEM EFFICACY WAS
 THEN CALCULATED BY DIVIDING THE EXTRAPOLATED FULL LOAD LUMENS BY
 THE MEASURED INPUT WATTAGE TO THE FULLY LOADED LED DRIVER.
- Leading Power Factor
- One manufacturer has been adamant that a leading PF of .50 should be preferred to lagging of >.90
- Trophy built products,




BACRAMENTO MUNICIPAL UTILITY DISTRICT. The Power To Do Mere.

LEDs + motion sensors - a great application! *











About sensors:

- Dimming preferable to on/off systems.
- Ramping time should be ≤ 1 second.
- Sensors need to be specifically designed for food cases.
- Sensor location & adjustments impact savings potential & customer reaction.






store are 'definitely not likely' or 'probably not likely' to buy "SMUD survey found that 85% of customers in a grocery because they were concerned about food safety." products from a frozen food case with its light out



Optics: one size does not fit all

- Size, shape and shelving systems of food cases vary significantly even cases from the same manufacturer.
- Even well-designed fixtures from respected manufacturers may not be right for every application.
- Recommend customers install a sample before making a major commitment.



Whole Foods Market, Sacramento, CA





- Time to review specifications
- Drop standard tier?
- Is 35 Lm/W the standard or Raise to 40 Lm/w?
- Include Controls option
- Require 5-year system warranty or, L₇₀ at 50,000 hours
- Is there LM-80 and In-situ testing available?
- Is Power Supply Efficiency Necessary?

Revise Qualification process

- Drop Thermal Chamber test and rely on 25c LM-79
- Develop better method to measure light bars and power supply in typical loaded conditions
- Possible solution measure as 2-door system

One Center and Two End Bars





- Links to our programs can be found at
- www.cainstantrebates.com/erco
- www.pge.com/led
- http://www.smud.org/en/business/rebates/Documents /2009LEDLightingSpecs.pdf



Dave Alexander
Sr. Program Manager
Customer Energy Efficiency
Pacific Gas & Electric Company
DJAJ@pge.com

Customer Advanced Technologies Program Sacramento Municipal Utility District dbisbee@smud.org Dave Bisbee, CEM Project Manager



Attachment J:

"Compressed Air Analysis"

Assumptions:

Capacity (gals)

- Baseline: Rotary screw compressor with load/no load and 1 gal/cfm air receiver, or modulating w/ BD control
 High Efficiency: Rotary screw compressor with load/no load control and 3 gal/cfm air receiver or greater
 Full Load Package RW is nearly equal for compressors of the same nominal hp (regardless of control type)

		: • • • • • • • • • • • • • • • • • • •
731.00		Air Receiver Cost per Gallon
267.00		
767.00	\$7,00	87,000
905.00	8	
267.00	ì	
1,132.00		\$5,000
_		
1,130.00		
2,282.00		83.000
		52.000 (10 minutes)
1.142.00		
3,371.00	8 ₩	000′1
1 955 00	•	3.
1 770 00		0 200 400 600 800 1000 1200
2.374.00		Capacity (gals)

• Noticularity of BD		8
gisting		•
	•vFD	8
5		8
Full Load Package kW vs trp		20 25
Load Pac		20
1		ŧ
		9
		WP
11	ភិជិសីសីសីសីគ _ម គ	

3,464,00 3,278,00 6,535,00 5,756,00 5,393,00

3,677,00

8

7,599.00

1550 \$

http://hansontank.us/airtanks.html

<accessed on 1/11/2008>

Source: "Compiled Data Request Results.xls"

tors (CF)	-				es.xis"
Compressor Factors (CF)	0.890	0.909	0.831	908.0	essor Load Praff
Control System C	odulating w/ BD	Load/No Load w/ 1 gal/CFM	Load/No Load w/ 3 gal/CFM	Load/No Load w/ 5 gal/CFM	ource. "BHP Weighted Compressor Load Profiles xis'
Contro	Modula	Load	Load/N	Load/N	Source

Algorithms:

Incremental Cost (\$) = $5 \times (TANK_a - TANK_b)$ (see graph at left) Incremental Cost

5 = slope from linear regression TANK = Efficient tank size (gal) TANK, = Existing tank size

KWn Savings

 $\Delta k Mh = (0.94 \times Compressor Motor Nominal hp + 0.54) \times HOURS \times (CF_o - CF_o)$ 0.94 x Compressor Motor Nominal hp x HOURS x (CF_b - CF_a)

Млеле

0.95 and 0.54 = Compressor hp to Full Load kW HOURS = Total compressor operating hours CF_{\bullet} = Efficient Compressor Factor CF_{b} = Baseline Compressor Factor respectively (see graph at left) conversion factor and offset,


AKW = AKWh / HOURS


0.20	40	Cost per kWh Savad:
2,000	64	incremental Cost:
10057		AKWh:
\$		TANK
2005		TANK.
0.806		<u>.</u>
0.909		p
4160		HOURS
25		Compressor Nominal hp
		Savings Calculator:

Cycling Refrigerated Air Dryers

Assumptions:

- Baseine: Non-cycling refrigerated air dryer
 High Efficiency: Cycling refrigerated air dryer
 Installed Package kW is nearly equal for cycling and non-cycling refrigerated air dryers
 Alf dryers are sized to accommodate maximum compressor capacity





Source: "Complied Data Request Results.xls"

Algorithms:
Incremental Cost (from graph at left)
Incremental Cost = 0.167 x Dryer Rated CFM + 732.6
Incremental Cost = 0.167 x (Compressor Norwinal hp x Compressor CFM/hp) + 732.6
= 0.167 x (Compressor Norwinal hp x Compressor CFM/hp) + 732.6

 $\Delta k Wh = [\{Baseline Dryer kW x HOURS_a\} - (Cycling Dryer kW x HOURS_a)] x Chilled Coil Response Time Derate Where$ kWn Savings

HOURS, = Baseline Dryer hours of operation, same as compressor hours

HOURS, = Cycling Dryer hours of operation = HOURS, x Average %Capacity

Chilled Coil Response Time Derate = 0.925 (from Air Dryer Calcuds)

Simplified kWn Saungs AbWh = (Compressor hp x Compressor CFMhp) x 0.0097 x HOURS x (1 - Average %Capacity) x Chilled Colf Response Time Derate Where

0.0087 = CFM to Baseline Dryer kW conversion factor (see graph at left)

Average %Capacity = 65% (from "BHP Weighted Compressed Air Load Profiles.xis")

HOURS = Total compressor operating hours

∆KW = ∆KWh / HOURS

\$ 0.64	Cost per kWh Saved: \$ 0.64
\$ 750 00	incremental Cost:
0.281663	ΔKW.
1171.716	ΔKWPI:
0.925	Chilled Cail Response Time Derate:
86%	Average %Capacity.
0.87	Baseline Dryer kW:
4160	HOURS
25	Compressor Nominal hp:
	Savings Calculator:


Efficient Compressors 40 hp and Below

- Assumptions:

 1) Baseline: Rolary screw compressor with modulating w/BD control

 2) High Efficiency: Variable speed control

 3) Full Load Package kW is nearly equal for compressors of the same nominal hp (regardless of control type)



Control System	Compressor Factors (CF)
Modulating w/ B□	0.890
Variable Speed Control	0.675
Source, "BHP Weighted Compressor Load Profiles.xis'	npressor Load Profiles.xis

Algorithms: Incremental Cost Incremental

kWfh Savings $\Delta kWh = (0.94 \times Compressor Motor Nominal tip + 0.54) \times HOURS \times (CF_b - CF_a)$

 $\simeq 0.94 \times Compressor Motor Nominal hp <math display="inline">\times$ HOURS \times (CF, - CF,)

0.95 and 0.54 = Compressor hp to Full Load kW conversion factor and offset, respect HOURS = Total compressor operating hours CF_e = Efficient Compressor Factor

CF_b = Baseline Compressor Factor

AKW = AKWM/HOURS

Savings Calculator:		l	
Compressor Nominal hp			ĸ
HOURS			4160
CF,			0.890
cf.			0.675
	ΔKWh:		21022
	ΔKW:		5.05
pu	incremental Cost:	49	4,621
•		•	5
Cost pe	Cost per Kyvn Saved: \$ U.22	A	77

re difference of the two linear regressions)

ively (see graph at left)

Air-Entraining Air Nozzles

Assumptions:

- Baseline: Open copper tube or inefficient air gun @ 26 CFM (1/8" hole at 100 PSI)
 High Efficiency: Air nozzles capable of amplifying the air stream 25 fold, blowgun mounted or stationary. Assume 14 CFM max.

Algorithms:

Incremental Cost

Incremental Cost = \$14 per unit

KWh Savings

AkWn = (Baseline Nozzle CFM - Efficienct Nozzle CFM) x Compressor kWi/CFM x HOURS x %USE Where

Baseline Nozzle CFM = 26

Efficient Nozzle CFM = 14

Compressor kW/CFM = 0.32 (assumes modulating w/BD compressor - see calculations below)

HOURS = compressor total operating hours

%USE = 5% (assume 3 second of operation per minute or 5% of total compressor operating hours)

DKW = DKWh / HOURS

Average Compressor KWICFM Calculations:

	Modulating w/ BD
	«VFD

Source: "Compiled Data Request Results.xls"

Compressor Full Load Package kW/Max CFM = 0.225
Average %Capacity = 65% (from "BHP Weighted Compressed Air Load Profiles.xls")

Average Compressor kWrCFM = "Full Load Package kWrMax CFM" x "%Full Load kW @ Average %Capacity" / "Average % Capacity" = 0.225 x (92%65%) = 0.32 Modulating w/ BD Compressor %Full Load kW @ 65% Capacity = 92% (from "BHP Weighted Compressed Air Load Profiles.xks")

0.225 Calculations for other compressor types: Compressor Full Load Package kWMax CFM

Average %Capacity

Average Compressor kW/CFM	0.32	0.32	0.30	0.28	0.23
%Full Load @ 65% Capacity	%Z6	94%	86 %	87%	67%
Compressor Control Type	Modulating w/ BD	Load/No Load w/ 1 gal/CFM	Load/No Load w/ 3 gal/CFM	Load/No Load w/ 5 gal/CFM	Variable Speed w/ Unloading

		Γ
Savings Calculator:		ć
Daseine Muzzie Crivi.		Ş
Efficient Nozzle CFM:		14
Compressor kW/CFM:	0	0.32
HOURS	4	4160
%USE:	5.	5.0%
ΔKWħ:	798	798.72
ΔKW:	0	0.19
Incremental Cost: \$		14.00
1		
Cost per kWh Saved: \$		0.02

Equipment Cost	st	
Manufacturer	Model	Cost
AirTX	48008	S 15
ExAir	1009	S
Vortec	1200	\$ 13

No Loss Condensate Drains

Assumptions:

- 1) Baseline: Timer controlled valve to the atmosphere with set frequency and duration
- 2) High efficiency: Operate by sensing the condensate level and opening when necessary, and closing before any compressed air escapes

Algorithms:

Incremental Cost

Incremental Cost = \$200 (see "Compiled Data Request Results.xis" for details)

kWh Savings

ΔkWh = Air Loss Rate x Compressor kW/CFM x OPEN x % Not Condensate Where

Air Loss Rate = An hourly average rate dependent on the Drain Orifice Diameter and Pressure, expressed in CFM (see table below) Compressor kW/CFM = The average amount of electrical demand in kW required to produce one cubic foot of air at 100 psi OPEN = Hours per year the timed drain is open

% Not Condensate = Percentage of time compressed air escapes instead of condensate

Simplified kWh Savings

AkWh = Air Loss Rate x Compressor kW/CFM x OPEN x AF x % Not Condensate Where

Air Loss Rate = 25.22 (analysis assumes 1/8" orifice diameter (2) 100 psi)

Compressor kW/CFM = 0.32 (assumes modulating w/ BD compressor - see analysis in the "Nozzles" sheat for additional compressor types)
OPEN = 146 (assumes timed drain vents 10 seconds every 10 minutes)

AF = [(Total compressor operating hours + 8760) / 2] / 8760 (Assume timed drain operates 8760, but the actual number of hours that compressed at % Not Condensate = 75% (EVT assumption)

 $\Delta kW = \Delta kWh / HOURS$

Where

HOURS = compressor total operating hours

ΔkWh:	645.0 0.16
HOURS	4160
% Not Condensate	75%
AF	0.74
OPEN:	146.0
Air Loss Rate (CFM): Compressor kW/CFM:	25.22 0.32
Savings Calculator:	

Compressor Control Type	%Full Load @ 65% Capacity	Average Compressor kW/CFM
Modulating w/ BD	92%	0.32
Load/No Load w/ 1 gal/CFM	94%	0.32
Load/No Load w/ 3 gal/CFM	B6%	0.30
Load/No Load w/ 5 gal/CFM	B2%	0.28
Variable Speed w/ Unloading	67%	0.23

Source: "Nozzles" sheet in this workbook

Leakage Rates (CFM)

Pressure (psig)		Orifice	Diameter (inches)			
	1/64	1/32	1/16	1/8	1/4	3/8	1
70	0.29	1.16	4.66	18.62	74.4	167.8	1
80	0.32	1.26	5.24	20.76	83.1	187.2	
90	0.36	1.46	_5.72	23.10	92.0	206.6	1
95	0.38	1.51	6.02	24.16	96.5	216.8	interpolated from original table
100	0.40	1.55	6.31	25.22	100.9	227.0	
105	0.42	1.63	6.58	26.31	105.2	236.7	interpolaled from original tebli
110	0.43	1.71	6.85	27.39	109.4	246.4	interpolated from original table
115	0.45	1.78	7.12	28.48	113.7	256.1	interpolated from original table
120	0.46	1.86	7.39	29.56	117.9	265.8	interpolated from original table
125	0.48	1.94	7.66	30.65	122.2	275.5]

Source: "Compressed Air Systems Analysis Tool v2a.xls"


 $i \}$

enting and leakage when the compressor is down

Measure	ΔkWh	ΔkW	Incre	mental Cost
Air Receiver	10057	2.42	\$	2,000.00
Dryers	1172	0.28	\$	750.00
Compressors	21022	5.05	\$	4,621.00
Nozzles	799	0.19	\$	14.00
Condensate Drains	645	0.16	\$	200.00

Attachment K:

"deeminglighting13nov09 evaluationreport"



			2	PCAR	90	ğ	
_	200	Š	Schools	Waht.	ō	ž	
Meters	0	0	1009	180	154	DG.	
Burveya	1,276	\$400	•	۰	•	۰	
Semole Size	127	Ä	909	134	Ş	\$	
Manghe	43.	37%	70%	ŝ	21%	č	_
Haurs yalves and weighted averages	crave bad	5					i
1	PGBF		N. N.	20	130	30CAC	T L
Common and	.9861	8	BO9698	Richal Id	2	2006	Average
Food Bales	5.800	9K.5	L	¥9.	9. 1860 *	990.5	Š
Food Service	4.600	385.4		4.278	14.5	8	4,4
Month Care	*	4,617			2 689	255	3,627
Plotatificial	5,500	3,027			2.307		3.368
Order	4 (B)	3,760	_	255	3.792	7,694	3,526
Public Amenda		68	_			7.84	2,72
Public Services (mon-food)	3,400	3,431					ğ
Racial	3	Ę		29	5.43	3,840	7
Warmbourse	3,560	1,7			121	2	1,664
- Schmol	2,58	2774	2.14	_	1.7	2786	2 gg
College	3,800						8,5
Productivies		300	_	3,547	2252	2.588	7,745
Other	4,500	1,723	_		3,647	2,804	1,672
			/0.00	ŀ	316	į	ų.

Coincidence Factor weightling	and solven.				
	POSE	MIN.	30,3610	37772	-
•	1985	Schools	100	Time of	
Post Months	EO-Gray	Jun-Sent	But mul	des len	ALC: NO
Peak rous	12 · 6 mm	5.5 pm	1-500		- 4
Terri Posts Hours	1,104		200	450	270
House to Facus Parit	276				R
Parsont in Foods Proby	2				9
Page Payed Wagners Pages	Ē	5	Ä	Ä	
•	127		-		
Samole Stat Welahan Factor	*	762			
Change of the Party Press Co.		X			

15 To 10 To	Colnicidence Sector meltipliers
15. 12 0.800 Mg/s 15. 5. 12 0.800 Mg/s 15. 5. 5. 100 Day 15. 10. 100 Day 16. 100 Day	Givida hours by 12
15.5 10.25 CM PM	divide hours by. 18
이렇다보았 바깥다도 장독합병 기업이 파인 문항다음 무건됐음	Childre hours by √a (GF =0)
리하나 다음 유민이 또 중요함(함 리용이보다 등등의 등다음을	
보다 다음 유튜디 노 장소란 등 보다 마다 당황리왕 참고함을	
나 대문 유한대소 정확하다 마마선 성환대형 현대화경	
5 8 2 1 4 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2	
ని అమ్బంగ్ సౌలభ్యే స్క్రామంలో ప్రస్తుత్వ	
ត់ <u>កំ</u> បក ភិ <i>ត</i> ស៊ីគ មិន១៦ ខិដ្ឋានិធ	
ក់ ក្រោក ភាស់ដែ មិនបាន ភិព្យានិន	
20 x 2 x 2 x 3 x 3 x 3 x 3 x 3 x 3 x 3 x 3	
u	
~ 것 # 12 명 명	
다 다 다 다 다 다 다 다 다 다 다 다 다 다 다 다 다 다 다	
2 * * 5 * 4 * 4 * 4 * 4 * 4 * 4 * 4 * 4 *	
6 27 8 27 28 28 28 28 28 28 28 28 28 28 28 28 28	
25 82 26 84	
3	
Total/Aug 372 87%	
teg Houndyr 4,000	

March Marc				1			
Account of the control of the contro	Buston Black	PGAE YOUR	\$choots	1	Time of the	Attention.	
### 1975 1975 1975 ### 1975 1975 ### 1975 1975 ### 1975 1975 1975 ### 1975 1975 1975 ### 1975	Pood Salen	81%		% %	%.0G	₩26	
Annual Control of Cont	Food Benylon	ě		i i	3,	Z	
60% 75% 75% 75% 75% 75% 75% 75% 75% 75% 75	Health Care	24%		#.Z	*2	78%	
### 1755 7755 7755 7755 7755 7755 7755 7	HotelMichel	67.5			23.4	Š	
### 100 PS	Office	51.5		X II	78%	É	
Tribine (month of month) 1879	Public Assembly	!				%_78	
15.5 20.5 20.5 20.5 20.5 20.5 20.5 20.5 2	Public Services (non-topd)	, s				¥	
25 25 25 25 25 25 25 25 25 25 25 25 25 2		É		85%	*8	84.8	
60% 60% 50% 60% 50% 60% 60% 60% 60% 60% 60% 60% 60% 60% 6	Wantehouse	ž		200	ž	20%	
200% 600% 600% 600% 600% 600% 600% 600%	Sethous	42%	33%	7.59	23.4	Š	
20% 20% 20% 20% 20% 20% 20% 20% 20% 20%	College	100		*88		**	
700 Co. 100 Co	Industrial	!		738	* 56	***	
7477 7677 7477	Other	Ş		37	3.5	67%	
200	Weighting Factor	š	21.8	59	24%	1001	
			3704	RLW	RUNCE	Time of	Faces
RLW RLW CF STEAT	Don't Months		Meno	Sec.	Jun-Aug	May Seo	N. A.
RLW RLW CF Strang Schools Jun-Aug May Sept		_					

		. :				
			Proped	e pe	ared Sask	ă
Bullding Use	ţ	ħ	2.0810.170	2	2,0417.170	8
			IM	É	W.	ichte.
Food Sulles	1544	959	5,0214	82	900	2
Food Sarvies	į		98.00	Ď	8	Š
HALID CEM			2,016.2	8	1050	ş
Hotelskole	1360		19000	Ę	0.00	ĝ
000	S, E			S	6.0912	\$
Public Assembly	2.720		90.00	3	9000	3
Public Barrions	3.42		ap:48	8	75700	
Retail	77	Ž		89	41000	ş
Warehouse.	Š			5	1000	413
Bonodi	2300			*	9.0808	274
Coffege	3,000		90134	ž	0.0910	ş
DOM:	9			Ŋ	0.0083	15
Preferental	7		90.00	•		
Apricultural	8			410		
	3,672					

1 -	201	ı	Propeded Beared Sevengs	ڀِ
	2.0810.170	2	028711907	22
1	ы	Ē	ж	E SERVICE
Ŕ	5,0214	ζ.	\$301.8	8
×	0.00	ģ	8	ş
ź	2,010.0	8	0.000	Ş
5%	19000	Ę	0.10	6
X	QL0176	8	6.0912	ŝ
ž	40155	3	1000 pp	ě
4%	QD:48	8	75/010	â
Ç	00197	89	0.100	å
š	200	5	4.0961	4
×	0.0122	*	9 0825	274
6	0.0139	2	0.0910	ě
7,4	9140 E	Ŋ	0.0083	11.7
4	*****	į	0.000	

440	4.016)	11%	360	CHAS (I
27.08	DC . 1810 C	92,610	202	95 E
22	2,0160,170	NA	123	F/12
Input Wet	Measure	Suspipies,	Input Waltage	Fixture Tippe
				Proposed Values for Existing Watta
	988	141	Average	
	90%	10%	Warmstose	Bren with Gezpro Lightbulb:
	#S9	15%	Minawkee	Nether Lightbuffer (sales retribeentalive)
	92%	% 0	Milwankae	Gene Scholler with Sylvania Lighting Services
	24 40	DHA %	(Location	Interview:
	installed Pixtures	popperation		Lighting Rep. Conversations on VHO vs. MC
	110	107	22	11,170 TB 41,46 High Partiements Replacing T12HOAMD 21-81
	*	0	ă	10.170 TO 41-48 High Performance Performent Participal T12.21-94

							Input Welts	12	728												
installed Fixtures	, 4 0	92%	82¥	80%	89%		Measure	2.0160.170	7038130		4 Mey 2000)										
Installed	OHA %	*0	15%	ģ	741		Weighting	W	9,610	*-	Medic (updated	4	42	72	130	ŧ	122	302	Š	ĺŘ.	i di
	Location	Milwackae	Minawkee	Warmstose	Average		Input Waltage	123	202	380	T12 Flature We	Fixture Type	(1) 4 Lange	(2) 4 Lemp	۰	F	OH 8(1)	(1) 8' VIED Lamp	(2) 8' emb	(2) 5 HO LETTO	CAR WHO aron

	st factors from VinSeerita
New Wallage's	Average ballast fr

₽	Avg. Ballant Factor	0.80
from WiSee	Stoffeds Projects	%ZZ
last factors	Projects Reviewed	8 7 25
Average ballast factors from WiSeerts	Messure	20810170

40	prepeti	Input Watte	Propagad Input
Category	Factor	21 BF91,08	Wattage
TO.	080	921	001
Normal	28.0	123	101

input Natta £85=100 above are calculated from CEE date that given variant for Balloon Efficiony factor (RE 8Ft is usuad to convert CEE sevenge feater waterges to a vering input waterges, for five 8Ff a 1 co. Quentying Product - App-Particulations 120 and 277V 78 Ballooks CEE Pupp-Performence Commercial Lighting Systems inhibition. Updated 0331/08.

Recommended Savings

Outlier of the contract of the		į	2.5170.170	170	25180.170	170	2.5182.170	170	2,5185,170	170	2.5186.170	170
	FIGURE	2	M¥	kWh	MΑ	кWh	ΚM	KW.	MΜ	kwn	MM	KWH
Food Sales	5,544	95%	0.1388	837	0.2265	1,366	0.095Z	574	2859 0	3 975	91050	3,025
Food Service	4,482	84%	0.1269	677	0.2070	1 104	0.0870	48	0 6025	3,214	0.4584	2,445
Health Care	3,677	78%	0.1180	555	0 1925	908	0.0809	8	0.5604	2,636	0.4264	2,005
Hotel/Motel	3,356	35%	0.0528	507	0.0861	82	0.0362	Ŕ	0.2505	2,406	0.1906	1.83
Office	3,526	77%	0 1156	532	0.1686	88	0.0793	365	0.5489		2,528 0.4177	223
Public Assembly	2,729	67%	0.1006	412	0 1641	872	00000	283	0.4776	966	0.3634	1,489
Public Services	3.425	64%	6960 0	517	0.1564	캶	0.0657	355	0.4552	2,456	0.3464	1,869
Refail	4.226	84%	0.1275	638	0.2081	9.	0.0875	438	0.6065	3,030	0 460B	2,305
Warehouse	3,464	% <u>87</u>	0 1192	523	0.1945	86	0.0818	359	0.5661	2,484	0.4308	068,
School	2,302	25%	0.0792	347	0.1292	557	0.0543	238	0.3760	1,650	0.2861	1,256
College	3,900	28%	0.1026	586	0.1675	98	0.0704	₹	0.4875	2,796	0.3710	2,128
Dormstory	986	ř	0.0106	40	0.0172	\$	0.0072	\$	0.0502	707	0.0382	538
Industrial	4,745	£	0.1163	716	0.189B	1,169	0.0798	6	0.5523	3 400	0.4203	2.589
Agricultural	4,668	67%	0.1010	20	0.1548	1,157	0.0693	\$	0.4797	3,368	0.3650	2,563
Other	3,672	¥-16	0.1006	554	554 0.1641	90	0.0690	380	380 0.4776 2,633	2,633	0.3634 2,003	2 003

epog ysel	Measure Description	New Watts	Old Watts
2.5170.170	T8 4 lamp or T5HO 2 lamp Replacing 250-399 W HID	144	295
2 5180 170	T8 6 larup or T5HO 4 lamp Replacing 400-999 W HID	212	824
2.5182.170	T8 8 lamp or T5HO 6 lamp Replacing 400-999 W HID	359	4 62
2.5185.170	T8/T5HO <= 500 Watts Replacing >= 1000 W HID	363	1,080
2.5186.170	TB or TSHO <= 800W, Replacing >= 1000 W HID	535	1,080

xisting Fixture Wattages

Fixture Type	Watts	to 2/4 lamp	to 4/6 Jamp	to 6/8 Jamp	AN009=>	W008-108
-24			1		3	
JUMPH NES	3	85	8	\$	7	4
400M HPS	465	%0	3%	3%	80	%0
250W HPS	285	300	%0	350	*0	
ADDIN MILY	455	%0	18,	34	960	
250W MV	290	*	%0	960	3,0	
1000W MH	1,080	Š	%0	\$5	%9 6	%96 6
750W MH	650	*6	%0	*1	740	
400M MM	458	Š	38 38	9666	%0	%0
250W WH	295	88%	\$	%0	960	
750W PS MH	818	%0	% 0	%0	%0	80
320W PS MH	362	%0	960	*6	960	
250W PS MH	388	%0	%0	% 0	D%	%0
Total:		100%	100%	100%	100%	%001
Average Watts:		W 265	W 834	482 W	1080 W	1080 W

^{*} Wetts taken from SPC. Percentages are based on a sample from WiScerts.

New Fixture Wattages

	200		-			
		Weec-082	M666-90P	M665-007	1000W+ to	og +M0000\$
Fixture Type	Watts	to 2/4 lamp	to 4/6 tamp	to 6/8 lamp	<=500W	501-800W
4L F32T8 HBF	141	%001	5%	%0	%0	%0
6L F3218 HEF	227	%D	48%	%0	7%	%0
BL F3278 HBF	2888	%0	%0	5%	13%	**
161, F3278 HBF	576	8	*6	%0	%0	28%
21, F54T5 HO	418	%0	13%	%0	%Q	6%
AL FSATS HO	237	%0	37%	%0	88	80
SL F54TS HO	360	8	***	*.es	* 1	Š
(2) 4L FS4TS HO	474	80	*0	%o	2%	%0
al, FS4TS HO	474	*0	%	%0	21%	ž
10L F54T5 HO	283	8	%0	%0	960	%£39
Z 6. F54T5 HD	720	350	960	0%	950	98¢
Totaf:		100%	%001	%ast	%001	100%
Average Watts:		W 141	W 212 W	/A 696	W 285	836 W

Walts taken from Advance Atlas, Percentages from a WiSearts sample.

				Space Type	Type		
	_			Wh Salvings	CTCA		
	_					- Pittir	
Quildran Tune	Health	Cymonettem	Industrial	Retail	Wanshouse	Assembly	ě
Popt Sales	100	215	165	187	701	518	225
Fond Service	4.682	418	B.7	8	567	496	÷
Health Care	3,677	343	•	Ē	#82	4 10	348
Hobal/Motol	338	913	Ä	119	757	374	3.8
onion	9,576	EZE	sre	5	3	288	22
Рыбис Авсентову	2,128	Ą	Ŕ	5	346	306	258
ublic Services	3,63	319	365	Ē	433		324
Retail	4 226	H.	4	ğ	À		909
Mansherae	199	323	370	123	438		Ř
School	2,302	215	346	2	2	78	218
College	000	Ř	416	28	<u>S</u>	Ş	98
Dormittory	86	8	100	A	R	OL.	3
Actuatria	743	442	2 8	2	200	526	449
Acrostre	960	2	57	69	3	22	3
Į.	3,872			131	454	409	Ħ
Percent Off		36%	ľ	15%	71.55		40%
Coincidence Factor		15%	164	¥.9	*92	12%	÷
			P. D. L.	0.0143	2000	PHEFY	A 4325

Wattage from High Bay Fluorescent Measure

		Mew Watts Old Warts	Old Warte
	Measure Description		
25170.170	2.5170.170 TR 4 lamp or TSHO 2 lamp Replacing 250-389 W ND	74	8
25180170	2 5180 170 T8 S large or TSHO 4 large Replacing 4004809 W HID	ZLZ	83
25187170	2 5182 172 TB Risman of 1940 Risman Supposite 400-899 William	98	794
2,5185170	2.5185 170 TB/TBHO 500 Wate Resisting >= 1000 W HID	52	1,080
0.0000000	Control of the contro		

15 15 15 15 15 15 15 15									_			-0	,	,	21	_	1
144 225 445 225 445 225 445 225 445 225 445 225 445 225 445 225 445 225 445 225 445 225 445 225 445 225 445 225 425						7			Percent	5	2	5		1		Ŕ	
144 255						Teta		-	~1	7,568	9	1343	2000	100	7	2	
144 256						Ţ			Perconn	76.5%	44.0	7	,	2	0.7%	Į12	
144 226						38		TO JOURNAL OF	Fortune	1.062	€ 043	534	•	6	9	5.742	
144 225 455 525						Ī,			Percent	9.7%	74.9%	40.3%	•	, 0.1	0.73	80	
144 256						٤		Mumber of	Fourier	5,080	19 281	4440				\$2,6039	
144 255							-		Percont	3,1%	4			25.5	880	Ŗ	
255 429 462 255 1000 255 1000 255 1000 255 255 1000 255 255 255 255 255 255 255 255 255						ڻ ا ا		Aumber of	Fintures	1,230	14.739	1 200	1	8	ō.	24.010	
27.2 4.59 27.2 4.59 28.3 1,000 28.9 1,000 28									Percent	13.0%	K		7	20.0	3600	100	
2 2 2 3 868 8 8 8 8 8 8 8 8 8 8 8 8 8 8 8 8 8	8 2	8	791	CBO.I	1,080	*		Number of	FEGURE	186	1039		=			1 406	
Test Code 25:100.170 16.8 tare or Test C4 tare Replacement 200-3 tare Wind 25:100.170 16.8 tare or Test C4 tare Replacement 200-3 tare Wind 25:100.170 16.8 tare or Test C4 tare Replacement 400-900 W HD 25:100 170 18.100	27.	212	8	20	535				W.	1	ŗ		Ī		200		
25102170 25102170 25102170 25103170 25108170 251082170 251082170 25108 25108 25108 25108 25108	T8 4 lamp or TSHO 2 lamp Replacing 250-389 W MD	T8 S trans or TSHO 4 trans Replaceing 400-830 W HID	TB Biang of TSHO Blamp Replacing 400-889 W HID	TB/TBHO <= 500 Watts Replacing >= 1000 W MD	T8 or T5HO <= 800W, Replacing >=1000 W HID	Average Wattage (mg WiSeerts Date	man an annual time to the same and the same		Manager Description	TR & leave or Paris Demo Bardenies 250 and 60 His	Chick Code Code - 1, -1, - o		CHARGE OF BUILDING PURPLE PROBLEMS AND	TH IN TOHO OF SOOM, Repairing PH 1000 W HID	TH or TOHO or ROOM Resiscing and COD WHD	Total D	
	2.5170.170	25180170	2.5162170	2.5185170	2,5186170	Developi			Touch Cooks	1		1	7	25185	7.5168		

| Continuent of State | Continuent of State

ı	ı	-	_	7	ı
l	Annual Selection of Selections	757		1.5	
Ì	ì	70.0	Γ	1	Į,
i	Ł	L	L	_	ľ
ł	Π	3	ŧ		
			ì	ĺ	į
ŀ			ŝ	į	ı
ļ	ľ	8	8		ĺ
ı		ž	ŀ		l
ı		ğ	ŧ		ŀ
ı	ľ	9	į	ş	l
ı	š	Į	1	ì	ľ
ı	7	ř	3	ŧ	ŀ
ı	å	Ŋ	ı	į	l
		5	CFL willpater flood lengt 4-389V opinions incandemant	į	l
ı	2	6	ᄬ	-	l
ļ	ŧ	į		ğ	ĺ
ļ	Tech Code Memors Description	2 Gard Hath Cif. or 32M, revisions musicolations on 100m.		2 6207 1050 nelactor long serge 100M	l
Ì	ė.		_	r.	

Account of the control of the contro	CFL Hyb Watten 21-115 Wate. resident 9 65.0 200.0	hode Sersor In. Netsong Postilistion 4.0	CPL CHEST BASIN ASSESSED ACADOMICAL VITS POSSESSED CONSULT ON FACTOR PROPERTY PROCESSED SERVE	Paping scandacourt lange uith 14 Mei conjuin Burnacett langs, MFS Plansager Cheficig	Markers former) brought brought auth 30 WES CONTROLS 20.0 75.7 Annelson's famour. WFS Horselines Cheecks.	Recitate inclinification temps with 23 Wild Compact Automoral langue, WRS Homerope, Cheering	Redex hambeure social amos with 19 Ned spelight compact flowers of large, WPS terminan Chains	200 Apr. 100
Solved Sector	11.0	Bond Bron			- 150 - 100			9.28
Machine Care	200.0 0.44 0.113 0.106 0.44 0.100	810.0 (80.8 avas avas 8:00) 0.016			75.7 0.051 d.047 d.044 e.019 0.043			100
Motes Autro	H7 8.108	810 D OH			20 B			į.
Public Assertity	0.080	100			28.	_		×.49
andware debut (heartable)	98000	0.013			8			25 AND ALGO AND AND AND AND AND AND
MIN	11.1	BIO.			8			**
barine	Q.144 Q.167 Q.277 Q.502 Q.104 D.868 Q.50 Q.503	IOTO NO PAR PIET NO IATE LIDO BITO			100 0 000 0 1000 CHRO BEST 0 0000 1100 0 1100	_		ŝ
2 0	0.00	10.014			0.00			á
Pulsabel	1010	218.0			12			į.
мана	8				- 100			ž
	8	2 2			- 63	_		ř

COULE CONTROL OF CONTROL OF CONTR	EE. 96P LET LEG LEG LES LIE 86P DAS 2700 88E 040 E50 400 500 401 0000E 000	12	# # # # # # # # # # # # # # # # # # #
AGENERAL OBDOR	842 639 600	12 K	# # # # # # # # # # # # # # # # # # #
Amin' 640	98.0 200.0 749	9 <u>8</u>	2
Section of the sectio	CP. High Wathay 31-115 Wats, spokeng	2.006.600 CCR. Cod Cultural Somethin, replicing intervience	The country of the co
114467N	2,0001168	2.0306.460	2 CON 166 2 CON

CATI Survey Analysis	Analyses						Į
	1	, mes	up egpa	artinor.	aryep far	'Ayessa''	
0.00	,	P	3	Fox	V 43	2.35	2,802
100		Į,	2	R	3	¥	5
T. C.			18.3	E.F.	0	3	1,527
!	- 7	\$	8 51	34.4	ĭ	0.49	3.337
18 MCF			_				
MA.	7	ĸ	R	É	5	5	7
FYDE	•	ğ	ë	77.5	57.3	26	2
18 MCP	ilenano	96	6.0	S,E	58.6	900	1
101	De la constante	\$	2	70.6	ŝ	43.4	2,27
- X08	- December	5	R	7.7	87.6	90.8	3,170
Landord	, open	FREG		-		tri estra	6
	2	8	Ľ	7.17	3	47	2.00
	Core	8	10.7	73.5	815	9	3.12
•	Chance	ģ	S.	77	2	7	1,30
	7	2	20.0	75.7	166	27.6	7.80
Reflector Flood Lang Analysis	A camp be	Talyal.					ı
Lienter	gauge g	Test	Persen	Ann Tinfo			
and the same	Ŀ		1001	2			
Commission	24.V	26.47	**	ì			
reconstruction.	26.	192	503	775	_		
Contact Board	0,470	1,16	Ę				
	!	3	į				

Alternate Recommended Hours and CF by Sector

)
Sector	HOURS	5
Agriculture	4,698	%19
Commercial	3,730	7.1%
Industrial	4,745	12%
Contract Co.	2.038	E.49.

hours and of by building type

Bales 5,444 Sarvica 5,544 Sarvica 3,977 Motel 3,326 Motel 3,326 Motel 3,326 Motel 3,425 C Sarvices 3,425 Louis 3,426 Louis 3,425 Louis 3,404 Louis 3,404 Motel 3,4			
5,544 4,482 3,366 3,366 3,366 3,484 4,726 3,900 9,900 9,900 4,745 4,745 4,745 4,745 4,745 4,745 4,745	Building Use	Haurs	p
4,482 3,387 3,386 3,386 3,386 4,286 4,286 2,302 3,900 9,900 4,745 4,745 4,745 3,670 3,870 3,870 3,870 3,870	Food Sales	5,544	92%
3,877 3,336 3,336 3,336 3,425 4,226 2,332 3,800 9,88 4,745 4,745 4,745	Food Service	4,482	84%
3,356 3,526 3,526 4,226 3,426 3,426 2,230 3,800 9,86 4,745 4,745 4,745 4,745	Health Care	3,877	78%
3,526 2,729 3,425 4,226 3,484 2,302 3,900 9,900 4,745 4,599 4,599	Hotel/Motel	3,356	35%
2,729 4,245 4,246 2,302 3,900 9,900 4,745 4,745 4,745	Office	3,526	77%
3,425 4,226 3,464 2,302 2,302 9,800 9,88 4,745 4,745 3,672 3,672	Public Assembly	2,729	67%
4,226 4,226 3,464 2,302 3,800 ny 986 ini 4,745 turnal 4,698	Public Services	3,425	F 10
3,464 2,302 3,900 1998 191 191 191 192 193 193 193 193 193 193 193 193 193 193	Retail	4,226	84%
2,302 3,900 my 988 inf 4,745 turmi 4,598	Wanehouse	3,484	79%
3,900 rry 996 inf 4,745 turni 4,698	School	2,302	52%
77y 986 ini 4,745 rumi 4,698	College	3,900	9689
4,745 rai) 4,698	Dormitory	98	1%
4,69B	Industrial	4,745	77%
3.672	Agricultural	4,69B	67%
	Other	3,672	67%

commercial hours weighted average

Building Use	Weight	Hours
Food Sales	3.60%	5,544
Food Service	3.60%	4,482
Health Care	8.50%	3,677
Hotel/Motel	6.00%	3,358
Office	25.30%	3,526
Public Assembly	7.30%	2,72
Public Services (non-food)	8.00.9	3,425
Refail	24.00%	4,226
Warehouse	15.70%	3.484
Average	100%	3,730
Weights based on DOE study	*	

commercial CF weighted average

3,90% 3,90%	Weight	Average CF
2 000	- *	%26
	ž	84%
Health Care 9.20%	×	78%
Hotel/Motel 6.50%	%	35%
Office 27.30%	%0	12%
Public Services (non-food) 6.50%	*	**
Retail 25.90%	Š	84%
Warehouse 16.90%	%	79%
7001 100%	%.	77%
Weights trasect on DOE study		

S&G weighted average

		Average	Average
Building Use	Weight	Hours	უ წ
Office	23%	3,526	77%
School	% %	2,302	25%
College	41%	3,900	68%
Average	%001	3,238	64%
• Weights based on WiSeerts analysis	Seerts analysi	.92	

Tach Code Maren	COUNTY TO TEAL IN HEAD PARAMETER SEASON			Lygword Hep. Conversion	(Distribut)	Change Scholler with Nynami	The state of the s
y by S	ě	É	ğ	¥	9	Ŕ	
d Savings Using CF/Hours by Sector	and better	£3	26000	21600	0.00	0.0163	
Ę	9	E	110	8	I.	£	
Ser Co	\$ mage 173	A	294 0	0.6179	00100	00100	
N.	3		50	77.	175	ž	١

TA TA	IND TOD TEACH HIGH PURPORTMANN RESISTENCE TO ZELOSS.	27.	100		
	Labelton Han. Conversations on VIIO vs. HO		422244	Installed Petitrum	_
	Г	Cecalibra	CHA.7	매송	_
	the wife Sylvania Lighting Services	Wetwest Upped	%9	%Z0	_
	_	and post	45.	2	_
		Piguretto es	701	É	_
		AVE TAX	11%	%.BQ	_
	ı				i
	Consequent between the Potentian Wests.				
		Input Waltage	Durantenda	age constant	MP CH
		12	ž	2,5120,130	123
		202	268		<u>:</u>

1 keay 2000										
(September 1	Market	42	2	115	144	23	ŝ	123	Ź	250
T12 Fother Wa	Frequent Color	CI+ Lem	2) 4 (amp	34.1	(4) 4 Lavin	CH S HO	ms. William	(2) 6' Lattro	(2) 8: HO Laving	C) T VHO Lamp

			_
		Avg. Ballatt	to let o
	from WiSagnts	% of Total	-
n	Less factors	Projects	
new walkings	Accepte halles		

		ş	10.7	
ı		8	2	
	200	\$	240	
	Catagory	ğ	Normal	

	you Walte at BP-1,00 above are salcated from CEE take that gives so has the Balvan BR-say Forter (BEP). Ff is taken to threat CEE was wadays to be receipt your versely as the PEP in 1 to 1. Manuse Publican, such Personales 1,000 FZIV B Saldass CEE replief versions Commentation (uptor Birganic Hillshim, Libration 1003100).	
	Fart.00 alone we calculated from power CEE premays focus well note. Hitto-Performance 120 and	
1	out Watte at EF is send to	

Alternate Recommended Savings Using CF/Hours by Sector

0.040		7.	2.6170.170	170	2.5180,170	0.170	2,5182,170	170	2,6185,170	170	2,5186,170	170
Sector	HOURS CF	5	ΚW	KWI	KW	KWh	KW	KWh	ΚW	KWh	κM	KWh
Agriculture	4,898	67%	4,898 67% 0.1010	709	0 1648	1,157	0 1648 1,157 0.0693	486	0.4797 3.368	3,368	0.3650 2,563	2,563
Commercial	3,730	77%	3,730 77% 01156	563	0 1886		819 D 0793	386	0.5480	2,674	0.5480 2,674 0.4178	2,035
Industrial	4,745	77%	77% 01163	718	0.1898	1,169	0.1598 1,169 0.0798	491	0.5523	3.402	0.5523 3,402 0.4203	2.589
Schools-Gov1	3,238		64% 0.0972	489	0.1586	798	0.0666	335	0,4615	2,322	0,4615 2,322 0,3512	1,767

Tech Code	Measure Description	New Watts	Old Watts
2,5170.170	T8 4 Iamp or T5HO Z Iamp Replacing 250-389 W HID	144	295
2 5180 170	T8 5 Jamp or T5HO 4 Jamp Replacing 400-999 W HID	212	458
2.5182.170	T8 8 lamp or T5HO 6 lamp Replacing 400-999 W HID	359	462
2.5185.170	T&T5HO <= 500 Watts Replacing >=1000 W HID	363	1,080
2.5188.170	18 or 15HO <= 800W, Replacing >=1000 W HID	535	1,080

Existing Fixture Wattages

SAH MOOOL						
	1,100	%0	9%0	% 0	2%	2%
Self Moor	465	%0	3%	3%	Š	80
250W HPS	295	3%	9%0	%0	%0	360
400W NV	455	%0	1%	1%	%0	%0
260W MV	290	%	%0	%	36	8
1000W MH	1,080	%0	960	8	38%	%96
750W MIH	650	8	%0	1%	86	86
400W WH	458	%0	96%	86%	ž	8
280W IAH	295	\$8	%	8	Š	Š
750W PS MH	818	960	9%0	%0	%	8
320W PS MH	365	%D	6%	2%	360	86
250W PS MH	288	0%	9%0	0%	0%	0%
rotat:		100%	100%	100%	100%	100%
Average Watts:		785 W	458 W	462 W	1080 W	1080 W

^{*} Watts taken from SPC. Percentages are based on a sample from WiSeerts.

New Fixture Wattages

	and General					
		250-39PW	M866-00#	M666-000	1000MV+ to	1000W+ to
Fixture Type	Watts	to 2/4 lamp	to 4/6 lamp	to 6/3 lamp	<=500W	501-800W
4L F32T8 HBF	144	%001	%2	%0	%0	200
6L F32T8 HBF	222	%0	48%	%0		Š
81, F32T8 HBF	288	%0	%0	2%	13%	Š
16L F32T8 HBF	576	%0	%0	%	8	
21. FS4TS HO	119	%0	13%	8	%6	
AL FS4TS HO	237	%0	37%	%	3%	š
64. F54TS HO	360	9%		%86	5496	
(2) 4L F54T5 HO	474	%0	%0	*6	**	
AL. FE4TE HO	474	%6	%0	80	21%	Š
10L F54T5 HO	593	%0		%		•
(2) OL FS4TS HO	720	86	9%0	%0	9,0	\$
不够		%901	36001	1001	%00F	100%
Average Watte:		M 771	W STS W	360 W	An 892	636 W

^{*} Wetts taken from Advance Altas, percentages from a WiSeerts semple.

Alternate Recommended Savings Using CFR are by Sector

the second of th	3						
				ž	Space Type		
				¥¥	dWn Savings		
	_		ſ			P. P. P. C.	
State	Hours	Gymnasium	ndvetna	Retail	Warehouse	Assembly	Oppe
Agnouture	4,698	BE)*	105	187	<u>28</u>	523	\$
Commercial	3,730	348	BOE	133	472	416	8
ndustrial	4.725	441	204	169	765	528	\$
5 chools-Gov?	3,230	302	346	115	80+	361	301
Percent Off		366	45%	15%	MCS	%25	4 04
Cempidence Factor		18%	18%	969	781	12%	7.7
Muney My		0.0344	0.0427	0.0142	0.0427	0 0284	88

Wattage from High Bay Fluorescent Measure

HD 222 HD 222 HD 388	Tech Code	Measure Description	New Watts	New Watts Old Watts
- F F 73	2,5170,170	78 4 lamp or TBHO 2 tamp Replacing 250-399 W HID	14,	982
A B	2 6180 170	TB S lamp or TSHO 4 temp Replacing 400-999 WHID	212	£
28	2,5162,170	T8 8 lamp or T5HO 6 lamp Replacing 400-899 WHID	SE SE	\$
	2,5185,170	2.5185.170 T8/T5HO <= 500 Wetts Replecing >=1000 W/HID	8	1,080

evetoping	g Average Wattage from WiSeerts Data		¥		3	E	Ē	_	278		Total	
S Code	Messure Description	1	Number of Fixtures	Paroent	Number of Fixtures	Parsent	Number of Fixtures	Persent	Number of Fixtures	Percent	Number of Fixtures	Percent
25170	18 4 jamp or 13/10 2 tamp Replacing 250-389 WHO	ž	961	200	1230	5.1%	9 090	87.4	700	16.5%	7,568	8
2.5180	TB 6 larms or TSHO 4 larms Recisions 400-869 VV HID	212	1,036	73.5%	14,739	61 4%	39,381	74 0%	5.04	70.4%	661,55	70.79
25162	TS Blamp or TSHO 6 fame Receiping 400-889 VV RD	R	17.	12.8%		30.4%	5,440	10.3%	a	97.0	13,439	18.0%
2,5185	TB or 1540 <= 500W Replaces >=1000 WHID	28	,	900	601	2.5%	2.327	4	3	3.1.5	2,981	9.0
2,6186	TB or TSHO BOOM, Replacing >=1000 W HiD	98	1	9500	150	969(0	381	A.C.O	4	0.78	574	0.73
	Total/Average Method	Ī	1.409	221	24.010	528	\$2,606	330	2143	217	113,77U	237

Afternate Recommended Savings Lising Chitours by Sa

N Gode Manager Beardglan

Op. 192 Col. 1 and special george (1927)

Op. 192 Col. 2 and special george (1927)

Op. 192 Col. 2 and special special collection conditions

1.1 a. 20.

ermended Savings for Related Measures, CVF

Witness	Meaning Description	Mer Male	Ost Weeks	Astradust	Schools and Section of Action (Commercial Indicative) Generality	iodwatria	Schools see
2 0501 165	CFL Mgh Watergo 31-136 Water, Applicated	6,69	D 002	7080 6	10 x 0 31	0.000	SEE CO.
2 (Berti, 0,2)	CFL Cald Cultures Some in replaces	9	38.0	1	1910*	20,000	School
2.0310.163	2 (2) (2) (6) (5) (5) (5) (4) (4) (4) (4) (4) (4) (4) (4) (4) (4						
į	Ropius somojesceni lenge with 14 Maji rompaci fuomoseni temps, MPS Homeson Depting						
	beginne interchanted brook and, 20 Male something to specifical transfer of the following becomes	e R	134	6 feets	1.0427	8 DEC8	2007
4	Negative promises on large with 23 Ward compact fluctuation bridge. WPB Hormitean Chadles						
1	Parallect (constituent applicat harmonth 16 West spolight compani lacencers from a 1475 Assession Charles						
Ì		į	The second	į	į	1	

		١

	With-min		Here Wide	Get Web.	Acrosher	Mary Well (SO Mells Acros Commercial Industrial Commercial	Indonesia	Contracts and
	581,1000,1	CPT High Wantage 31-315 Wells, replacing	089	o sast	150	705	29	ĝ
	DAGRECO Z	OF Chiriches Sourch, reporting	4.0	9°42	15	75	100	8
	30 0000 F 4 4 8	100 Description approach (1992) 100 Description approach (1992)	SAK C	121	*	Ā	Ä	
_			Ŷ	HOUSE OF UNIT	2,480	3.78	4,745	737

Privo	The state of the	9	E STATE OF	Withmore	-	See See	3
2	-	3	£	ž	28	15.7	1
FYEL	-	ĸ	2	ğ	ŝ	35.6	ſ
E	-	•	£	2	3	ă	2.23
TOTAL RE	`	2	143	ž	ž	3	м
1	~1	#	300	-		46.0	ñ
FY#1	٥	6	202	275	57.3	41.7	ಗ
607.11	the same	*	÷	763	ŝ	900	_
26	pi de la	÷	100	ģ	ŝ	436	~
204	-	3	8	ã	57.0	809	~

Attachment L:

"Strip curtains for walk-in units"

Strip Curtains for Walk-In Freezers and Coolers

Measure Name	Strip Curtains for Walk-In Coolers, Freezers
Target Sector	Commercial Refrigeration
Measure Unit	Walk-in unit door
Unit Energy Savings	Variable: 2,974 kWh for Freezers, 422 for coolers, 1,118 kWh weighted average for all walk-ins
Unit Peak Demand Reduction	Variable 0.35 kW for freezers, 0.05 kW for coolers 0.14 kW weighted average for all walk-ins
Measure Life	4 years

1.1 Introduction

Strip curtains are used to reduce the refrigeration load associated with the infiltration of non-refrigerated air into the refrigerated spaces of walk-in coolers or freezers. This paper quantifies the savings that result from using strip curtains as energy efficiency measures for walk-in freezers.

The air density difference between two adjacent spaces of different temperatures is the primary cause of air infiltration into walk-in coolers and freezers. The total refrigeration load due to infiltration through the main door into the unit depends on the temperature differential between the refrigerated and non-refrigerated airs, the door area and height, and the duration and frequency of door openings. The avoided infiltration depends on the efficacy of the newly installed strip curtains as infiltration barriers, and on the efficacy of the supplanted infiltration barriers, if applicable. The calculation of the refrigeration load due to air infiltration, and the energy required to meet that load, is rather straightforward, but, relies on critical assumptions regarding the aforementioned operating parameters. For all the above assumptions, this paper uses values that were determined by direct measurement and monitoring of over 100 walk-in units in a recent evaluation for the CA Public Utility Commission. Some weather dependent parameters, such as the temperature and humidity of the infiltrating air, and the average annual coefficient of performance (COP) of the refrigeration system, are modified to reflect the climate in PA.

1.2 Measure Applicability

This work paper documents the energy savings attributable to strip curtains applied on walk-in freezer doors in many commercial applications. The most likely areas of application are large and small grocery stores, supermarkets and restaurants.

1.3 Savings Calculations

The energy savings due to infiltration barriers in refrigeration are described by the following equation, which is based on Tamm's equation (an application of Bernoulli's equation), and the ASHRAE handbookⁱⁱⁱ

$$kWh = 365 \times t_{open} (\eta_{new} - f_{old} \eta_{old}) 20C_D A\{(T_i - T_r)/T_i)gH\}^{0.5} \times 60 \times (\rho_i h_i - \rho_r h_r) \times 3413^{-1} \times COP^{-1}$$

1.4 Definition of Variables

The variables in the above equation are defined below:

t_{open} =minutes of time walk-in door is open

 η_{new} = the efficacy of the new strip curtain – an efficacy of 1 corresponds to the strip curtain thwarting all infiltration, while an efficacy of zero corresponds to the absence of strip curtains.

 η_{old} = the efficacy of the old strip curtain

 f_{old} = the fraction of customers that have old strip curtains

20 is the product of 60 minutes per hour and an integration factor of 1/3iv

 C_D = Discharge Coefficient: empirically determined scale factors that account for differences between infiltration as rates predicted by application Bernoulli's law and actual observed infiltration rates

 $A = doorway area, ft^2$

 T_i = drybulb temperature of infiltrating air, Rankine

T_r = drybulb temperature of refrigerated air, Rankine

 $g = gravitational constant = 32.174 ft/s^2$

H = doorway height, ft

 h_i = enthalpy of the infiltrating air, Btu/lb

 h_r = enthalpy of the refrigerated air, Btu/lb

 ρ_i = density of the infiltration air, lb/ft³

 $\rho_r =$ density of the refrigerated air, lb/ft^3

3413 = the number of BTUs in one kWh

COP = the time-dependent (weather dependent) coefficient of performance of the refrigeration system

The parameters in the above equations are listed in Table 1 below. The equation above and the values for the input parameters are taken from the 2006-2008 California Public Utility Commission's evaluation of strip curtains'. The original work included 8760-hourly bin calculations. The values used herein represent annual average values. For example, the differences in the temperature between the refrigerated and infiltrating airs are averaged over all times that the door to the walk-in unit is open. The value for the baseline curtain efficacy of 0.26 is taken from CA. It assumes that approximately 50% of customers are replacing old, degraded strip curtains, and the remaining customers are installing strip curtains for the first time.

Table 1: Calculation Assumptions

Component	Туре	Value: Restaurants	Value: Convenience Stores	Value: Chain Supermarket s	Source (Endnote)
η_{new}	Fixed	.85	.85	.85	v
ηοισ	Fixed	.58	.58	.58	V
fald	Fixed	.5	.5	.5	v
Ср	Fixed	0.48 (freezer) 0.43 (cooler)	0.45 (freezer) 0.44 (cooler)	0.56 (freezer) 0.38 (cooler)	٧
t _{open} (minutes/day)	Fixed	38 (freezer) 45(cooler)	9 (freezer) 39 (cooler)	102 (freezer) 132 (cooler)	v
A (ft²)	Fixed	21	21	35	ν
H (ft)	Fixed	7	7	7	٧
T _i (°F)	Fixed	67	64	67	٧
Т _г (° F)	Fixed	10 (freezer) 39 (cooler)	7 (freezer) 39 (cooler)	9 (freezer) 37 (cooler)	V
RH, (%)	Fixed	50	50	50	v
RH _r (%)	Fixed	80	80	80	v
COP	Fixed	2.0 (freezers) 3.8 (coolers)	2.0 (freezers) 3.8 (coolers)	2.0 (freezers) 3.8 (coolers)	Y

Demand Savings

The demand savings are taken to be the annual energy savings divided by 8760 – essentially, a flat load shape is assumed, which, for commercial refrigeration in PA, is slightly conservative.

Demand Savings (kW) = Energy Savings
$$= 8760$$

1.5 Deemed Savings

The partially deemed savings for the installation of strip curtains can be calculated using the equation above with the parameters specified in Table 1. Calculated energy and demand savings are shown in Table 2 below^{vi}.

Table 2: Deemed Energy Savings and Demand Reductions

Application	Energy Savings (kWh)	Demand Savings (kW)
Supermarket-Freezer	7,412	0.85
Convenience Store-Freezer	294	0.03
Restaurant-Freezer	1,216	0.14
Average Freezer	2,974	0.34
Supermarket -Cooler	959	0.11
Convenience Store - Cooler	143	0.02
Restaurant – Cooler	165	0.02
Average Cooler ^a	422	0.05
Average Walk-In Unitb	1,188	0.14
a: Unweighted average acros	s all sectors	
	es 30% freezers, 70% coolers	

1.6 Measure Life

The measure life is estimated to be four years.

1.7 Evaluation Protocols

The most appropriate evaluation protocol for this measure is verification of installation coupled with assignment of stipulated energy savings according to store type. The strip curtains are not expected to be installed directly. As such, the program tracking / evaluation effort must capture the following key information:

- Fraction of strip curtains installed in each of the eight categories (e.g. freezer / cooler and store type, including one type for "other")
- Fraction of customers that had pre-existing strip curtains

The rebate forms should track the above information. During the M&V process, interviews with site contacts should track this fraction, and savings should be adjusted accordingly.

References

http://www.cpuc.ca.gov/PUC/energy/Energy+Efficiency/EM+and+V/2006-

2008+Energy+Efficiency+Evaluation+Report.htm

The scale factors have been determined with tracer gas measurements on over 100 walk-in refrigeration units during the California Public Utility Commission's evaluation of the 2006-2008 CA investor owned utility energy efficiency programs.

The door-open and close times, and temperatures of the infiltrating and refrigerated airs are taken from short-term monitoring of over 100 walk-in units

The temperature and humidity of the infiltrating air and the COP of the units have been modified to reflect the PA climate.



vi The supporting calculations are in the embedded spreadsheet:

We define *curtain efficacy* as the fraction of the potential airflow that is blocked by an infiltration barrier. For example, a brick wall would have an efficacy of 1.0, while the lack of any infiltration barrier corresponds to an efficacy of 0.

[&]quot;Kalterveluste durch kuhlraumoffnungen. Tamm W., Kaltetechnik-Klimatisierung 1966;18;142-144

iii American Society of Heating, Refrigeration, and Air-Conditioning Engineers (ASHRAE). 2006. ASHRAE Handbook, Refrigeration: 13.4, 13.6

In the original equation (Tamm's equation) the height is taken to be the difference between the midpoint of the opening and the 'neutral pressure level' of the cold space. In the case that there is just one dominant doorway through which infiltration occurs, the neutral pressure level is half the height of the doorway to the walk-in refrigeration unit. The refrigerated air leaks out through the lower half of the door, and the warm, infiltrating air enters through the top half of the door. We deconstruct the lower half of the door into infinitesimal horizontal strips of width W and height dh. Each strip is treated as a separate window, and the air flow through each infinitesimal strip is given by $60C_DA\{(T_i-T_r)/T_i)g\Delta H_{NPL}\}^{0.5}$ where ΔH_{NPL} represents the distance to the vertical midpoint of the door. In effect, this replaces the implicit wh1.5 (one power from the area, and the other from ΔH_{NPL}) with the integral from 0 to h/2 of wh'0.5 dh' which results in wh1.5/(3×2^{0.5}). For more information see: Are They Cool(ing)? Quantifying the Energy Savings from Installing / Repairing Strip Curtains, Alereza, Baroiant, Dohrmann, Mort, Proceedings of the 2008 IEPEC Conference.

Attachment M:

"BHP Weighted Compressed Air Load Profiles - OH TRM"

Introduction:

or equal to 40 hp. The number of compressor run hours at a given capacity from a typical work day was recorded and tabulated in the following sheet. The load profile data in the "Compressor Factors" tab was collected from 50 facilities on Long Island, NY employing air compressors less than

These load profiles were weighted by compressor motor bhp and used to determine theaverage percent capacity for a small air compressor.

incorporate average demand curves and part load curves. When multiplied against total operating hours and full load kW for a given compressor, the result is The percent full load compressor kW from DOE data was multiplied against the percent total compressor operating hours for each percent capacity bin. The results were then added to obtain the "compressor factors" for each of the given compressor types. Therefore, the "compressor factors" DOE part load curves for various compressor types were used in conjunction with the collected data to develop "compressor factors." a reliable estimate of a small compressor's annual kWh consumption.

						Total Control	The state of the s
A. #00.PS	춵똣쀼쓁핃믔돧퀅쭳둤믔구똣쀼◆캶컜곀쳠헍	다 한 단 단 단 한 번 보고 보고 보고 있는 보고 있는 보고 보고 있는 다음 보고 있는 보고		हैं. 20		200 4 4 4 4 4 4 4 4 4 4 4 4 4 4 4 4 4 4	
\$ \$	<u> </u>	************		* £		REFER	
*	62 000000000000000000000000000000000000			- <u>r</u>		869914	
\$	00 606000000000000			- %		151516	
3		ассастово серевенно		≅ €		CSESEE	
1	# # # # # # # # # # # # # # # # # # #			_s.€		****	
1		5 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0		L.		11111	
¥		D000-000044-0000000	,	Γ.		616616	
3	егогумаоврааен фя			Γ		*****	
	-NAND-40ES40D NOR	B = 4 0 - 2 2 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0		l ⁻		556655	
پر	\$ \$ \$0 = 0 = 0 = 0 = 0 = 0 = 0 = 0 = 0 = 0 =			9		*****	
* \$				F		*****	
9	епретеняцовет год	୍ଟି ଅଟେଟ୍ଟିସ୍ଟେମ୍ବର ଅବସ୍ଥ କଥା । ଅଟେଟ୍ଟିସ୍ଟେମ୍ବର ଅବସ୍ଥ କଥା କଥା ।		*		****	
€	できます 1 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	李章章专项四十六分章 是不知识的目录中央。 6		₹		ezzees	
				=		214E22	
	а Выча аймантаська сей	0000-000049-responses		5		*****	
	8 8 8 8 8 8 8 8 8 8 8 8 8 8	ಆದರ್ಭರಂಭವಾಗರದಹರ್ವಹಸ್ಥೆಚಿತ್ರದ		Q		*****	
				^R ∰		*****	
				8		EEEEE	
		ဝိတ္ဝင္းလင္ရင္သည္ မအခုခုခ ိုင္ရတည္သ		B			
2	00-					******	
"	<u>-</u>			7		£¥###	
ğ	දෙස මහණවට ආශාව සිට වුය	000000000000000000000000000000000000000		3 E	Truck policing 2.2. 2.2.	****	
Total Pactage Evil Load input	**************************************	2	2 建筑 4 作 4 汽车 2 流动 4 位 2 元 8 位 2 元 8 元 8 円 作 4 届 4 日 4 年 8 月 8 日 8 日 8 日 8 日 8 日 8 日 8 日 8 日 8 日	81		Mary Mary Mary Mary Mary Mary Mary Mary	
For Page	콜콜콜콜콜콜콜리카지지롱성용일등등을프롤용유다	· · · · · · · · · · · · · · · · · · ·]] 数章等等的和目录音等等等等等等等等等	Lead Day		connection by the connection of the connection o	
1	ALTHOUGH HAMINGTON	य स्थानमञ्जूष श्रास्थालय		T T T T T T T T T T T T T T T T T T T			
9	\$ 6 2 3 5 5 5 5 5 5 5 7 7 7 7 7 7 7 7 9 3 8 8 8 7 7 7 7 7 7 7 7 7 7 7 7 7 7 7 7	2	*******************			James C.	
N.	图 B = 8 验 B & B & B # # # # \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$	· · · · · · · · · · · · · · · · · · ·	: 福祉 : 1 · 1 · 1 · 1 · 1 · 1 · 1 · 1 · 1 · 1		٠	A Delivery	
Cantorne Name	Distriction D. S. Common D. S.	Commence of a co				de Corponad Destroal deuse Caran, Refold Genero de Destroard al Carago, Corponado Creaz alda aprillo referentes tidado	

Attachment N:

"ECM-Pigg"

State of Wisconsin Department of Administration Division of Energy

Residental Programs

Electricity Use by New Furnaties

A Wasconsin Field Study

October 2003

Contractor: Energy Center of Wisconsin



230-1

Technical Report

Electricity Use by New Furnaces


A Wisconsin Field Study

October 2003

Prepared by

Scott Pigg
Energy Center of Wisconsin
455 Science Drive, Suite 200
Madison, WI 53711
608.238.4601

Prepared for



Project Manager

Scott Pigg Energy Center of Wisconsin

Acknowledgements

This publication was funded by the State of Wisconsin, Wisconsin Department of Administration, Division of Energy, and was funded through the Focus on Energy program.

Focus on Energy is a public-private partnership offering energy information and services to energy utility customers throughout Wisconsin. The goals of this program are to encourage energy efficiency and renewable energy, enhance the environment and ensure the future supply of energy for Wisconsin. (800.762.7077, focusonenergy.com)

A number of individuals and organizations contributed to this effort. The project was commissioned by Wisconsin Energy Conservation Corporation, in its role as the administrator of residential programs under Focus on Energy. In particular, Ed Carroll was instrumental in making the study possible. Field work for the study was conducted by Greg Dalhoff (Dalhoff and Associates), George Penn (Global Energy Options) and Scott Pigg (Energy Center of Wisconsin). Brett Bergee (Energy Center of Wisconsin) recruited and scheduled participants in the study, and took the lead in managing the monitoring data—a task that required mailing out and subsequently downloading more than 750 data loggers over the course of the study. Steve Buss (Energy Center of Wisconsin) compiled the voluminous testing data for the 31 sites. Alex Weisheim (Auer Steel Corporation) and Dan Naidan (TSI, Inc.) provided useful technical sleuthing for two sites in the study. Scott Pigg (Energy Center of Wisconsin) managed the project, conducted the primary data analysis, and wrote the report.

The following individuals provided useful comments on draft versions of this report:

Wayne Deforest, Wisconsin Energy Conservation Corporation George Edgar, Wisconsin Energy Conservation Corporation Skip Hayden, Advanced Combustion Technologies Stephanie Jones, Consortium for Energy Efficiency Alex Lekhov, Lawrence Berkeley Laboratory Jim Lutz, Lawrence Berkeley Laboratory Harvey Sachs, American Council for an Energy Efficient Economy

Needless to say, the final report does not necessarily reflect the views of these individuals or organizations.

Finally, this study would not have been possible without the cooperation of the 31 families that participated in the study. These families not only allowed multiple intrusions into their homes, but also actively assisted with the monitoring effort by swapping data loggers through the mail over a seven-month period.

Copyright © 2003 State of Wisconsin All rights reserved

This document was prepared as an account of work sponsored by Focus on Energy. Neither Focus on Energy, participants in ECW, the organization(s) listed herein, nor any person on behalf of any of the organizations mentioned herein:

- (a) makes any warranty, expressed or implied, with respect to the use of any information, apparatus, method, or process disclosed in this document or that such use may not infringe privately owned rights; or
- (b) assumes any liability with respect to the use of, or damages resulting from the use of, any information, apparatus, method, or process disclosed in this document.

This report is the property of the State of Wisconsin, Wisconsin Department of Administration, Division of Energy, and was funded through the Focus on Energy program.

Technical Report 230-1

Contents

Abstract	i
Report Summary	iii
Introduction	1
Background	1
Research Objectives	<u></u> 2
Methods	3
Recruitment and Site Selection	3
Testing and Monitoring	3
Testing Approach	4
Monitoring Approach	7
Results	9
Overview of Air Handler Power Requirements — ECM versus Non-ECM Furnaces	9
Heating Mode	12
Steady-State Power Draw	13
Heating Speed Selection and Temperature Rise	14
Heating Cycles and Hours of Operation	15
Low/High-Fire Ratio for Two-Stage Furnaces	17
Operation of Fully Modulating Furnaces	18
Annual Electricity Use in Heating Mode	20
Heating Electricity Use — Field Results and GAMA Ratings	21
Electricity Use by Component and Operating Phase	24
Cycling Behavior	26
Cycling Behavior	.:26
Heating Season Temperature Control	32
Heating Season Temperature Control	32
Cooling Mode	33
Airflow and Operating Watts	33
Operating Hours and Cooling-Mode Electricity Savings.	34
Continuous-Fan Mode	35
Hours of Operation and Savings	37
Central Ventilation and Furnace Air Handler Operation	
Standby Power Consumption	. <u></u> 39
Summary of Electricity Use Results	41
Geographic Variation	42
Filter Static Brassura Drop	

Filter Static Pressure Drop	44
Impact of ECM Furnaces on Gas Consumption.	45
A Note on Power Factor.	45
Discussion	47
Implications for Wisconsin Focus on Energy Program Efforts	47
Implications for National Energy Efficiency Standards and Program Efforts	48
Implications for Consumers	49
Implications for Heating Contractors and Furnace Distributors	49
Limitations	51
References	53

.

Figures

Figure 1: Static pressure and temperature monitoring points.	5
Figure 2: Blower power versus airflow curves for study furnaces.	10
Figure 3: Electrical profile of a typical heating cycle.	12
Figure 4: Heating mode power draw.	13
Figure 5: Extrapolated temperature rise	14
Figure 6: Annual heating cycles.	16
Figure 7: Annual operating hours.	16
Figure 8: Percent of full capacity at design conditions.	17
Figure 9: Low/High-fire proportions for two-stage furnaces.	18
Figure 10: Typical day of operation for a modulating furnace.	19
Figure 11: Distribution of output for modulating furnaces.	19
Figure 12: Annual electricity use in heating mode.	20
Figure 13: Annual electricity use per therm of gas consumed.	21
Figure 14. Modeled versus rated heating kWh per therm.	22
Figure 15. Percent deviation of heating electricity use per therm from rating value	23
Figure 16: Heating-mode electricity use by component.	25
Figure 17: Heating-mode electricity use by cycle phase.	25
Figure 18: Median firing cycle length.	26
Figure 19: Typical daily thermostat setbacks.	27
Figure 20: Maximum daily firing cycle length under typical winter conditions	28
Figure 21: Maximum firing cycle length at design conditions.	28
Figure 22: Daily heating cycles versus outdoor temperature for one site	29
Figure 23: Typical daily number of heating cycles	29
Figure 23: Typical daily number of heating cycles.	30
Figure 24: Blower-off delay.	31
Figure 25: Heating season indoor temperature swing	32
Figure 26: Airflow per ton of air conditioning capacity at cooling speed.	33

Figure 27: Cooling-mode wattage versus airflow	34
Figure 28: Annual cooling-mode hours.	35
Figure 29: Continuous-fan mode power draw	36
Figure 30: Continuous-fan and cooling airflow DIP switches for Site 2	37
Figure 31: Hours of operation in continuous-fan mode.	38
Figure 32: Standby mode power consumption.	39
Figure 33: Annual hours of standby mode	40
Figure 34: Location of weather stations used for modeling	43
Figure 35. Filter static pressure drop.	44

Tables

Table 1: Continuous-fan use by study participants	35
Table 2: Continuous-fan electricity use, by furnace type.	38
Table 3: Summary of annual electricity use and ECM savings.	41
Table 4: Median change in selected modeled values for other locations, relative to Madison, Wisconsin	42
Table 5: Median measured power factor, by operating mode.	45

Appendices

The appendices are bound separately under report number 230-2.

Appendix A: Furnace and Site Details

Appendix B: Test Results and Heating Cycle Plots

Appendix C: Modeling Approach

Appendix D: Indoor Temperature and Heating Cycle Length Analysis

Appendix E: Duct Resistance Characteristics

Appendix F: Daily Summary Scatterplots

Abstract

Field tests and monitoring of 31 new Wisconsin furnaces showed that multi-stage furnaces with electronically commutated blower motors (ECMs) use significantly less electricity than conventional new condensing furnaces, especially when operated in year-round continuous-fan mode. The data suggest that a typical Wisconsin home will save about 465 kWh of electricity per year for heating and cooling operation, with the median ECM furnace using about half the electricity per therm for heating compared to the median non-ECM furnace. These savings increase significantly to more than 3,000 kWh when continuous-fan operation is included. Electricity use for heating operation was higher on average than standard rating data would indicate for ECM furnaces; this is most likely due to generally higher static pressures encountered in the field compared to rating test conditions. The study suggests that there are opportunities to further reduce electricity use by ECM furnaces through careful attention to filter static pressure drop. In addition, several ECM furnaces were found to be field configured for continuous-fan airflow well above the factory defaults; fan-only savings would be mitigated or non-existent in homes where this occurs. The ECM furnaces with two-stage heating capability typically operated more than 80 percent of the time at the low stage, with high-fire mainly invoked for setback recovery—but two sites operated mostly in high-fire. The study showed that most of the furnaces were oversized to the point that low-fire operation alone could meet design heating loads for the homes; setback recovery appears more to be the limiting factor in heating system sizing.

Report Summary

This study examines electricity consumption by new Wisconsin furnaces, particularly with regard to differences between furnaces with multi-stage firing and electronically commuted blower motors (ECMs) versus single-stage furnaces with standard blower motors. The study also quantifies some basic furnace operational parameters such as annual operating hours and beating cycle length.

To conduct the study, 31 new furnaces were tested for electrical consumption, static pressure and airflow in various operating modes. The furnaces were also monitored over the latter part of the 2001/02 heating season and the entire 2002 cooling season. A model of furnace operation was developed for each site to standardize the results to typical weather conditions. Fourteen of the furnaces in the study used ECM blower motors, and most of these featured multi-stage firing operation.

From a technology perspective, the study provides basic confirmation that multi-stage ECM furnaces do provide substantial electricity savings over conventional condensing furnaces. Top findings from the study are as follows:

- 1. The multi-stage ECM furnaces in the study used significantly less electricity than the standard single-stage furnaces with permanent-magnet split capacitor (PSC) blower motors. Though the study could not control for differences from home to home in factors such as duct resistance, the results tend to confirm claims that ECM blower motors are inherently more efficient than standard blowers. The test results also demonstrate that furnaces equipped with ECM blowers are capable of operating over a much wider airflow range than standard PSC blowers. Since air handler power requirements increase with the cube of airflow, the ability to reduce airflow when appropriate—such as when providing background air circulation in continuous-fan mode—can mean dramatically lower air handler energy.
- 2. The results suggest that an ECM furnace in a typical Wisconsin home will use about 465 kWh per year less electricity than a non-ECM furnace. The majority of these estimated savings derive from heating mode electricity savings: the median ECM furnace in the study used about half the electricity for heating (0.5 kWh per therm of gas) compared to median non-ECM furnaces (1.0 kWh per therm). The data also showed lower blower power draw in cooling mode, which would also reduce the load on the air conditioning compressor. These savings far offset the finding that the ECM furnaces in the study averaged about 30 additional kWh per year in standby mode compared to the non-ECM furnaces.
- 3. The study results indicate electricity savings in excess of 3,000 kWh when year-round continuous-fan operation is practiced. Most of the ECM furnaces in the study used less than 200 Watts in this operating mode (and about half used less than 100 Watts), compared to 400 to 800 Watts for the non-ECM furnaces, which typically delivered air in continuous-fan mode at the heating speed. Over the 7,000-plus hours of operation in this mode that the data suggest would be typical of a furnace in Madison, Wisconsin, an ECM furnace using 100 Watts would use nearly 3,000 fewer kWh than a non-ECM furnace drawing 500 Watts in this mode. With the above heating- and cooling-mode savings, this would bring the total annual electricity savings to about 3,400 kWh for a typical Wisconsin home.
- 4. Most of the two-stage ECM furnaces in the study operated in low stage for the majority of the time. Eleven of the furnaces were two-stage ECM models, and the data suggest that nine of these would operate in low-fire mode for 80 percent or more of the time for typical Madison, Wisconsin weather. Although these furnaces run for more hours over the course of a heating season, their total electricity consumption is substantially less than a conventional single-stage furnace. Similarly, the two fully modulating furnaces in

the study appear to operate at or near their lowest firing rate for about half of the time. For all of these furnaces, high-fire is mainly invoked only to recover from periods of thermostat setback. Two furnaces operated mainly in high fire; these were both smaller furnaces with long heating cycles.

- 5. On average, ECM furnaces in the study used more electricity per therm for heating than would be indicated by standard rating data. The Gas Appliance Manufacturer's Association (GAMA) publishes standard ratings for annual gas and electricity consumption (in addition to gas efficiency) for furnaces based on standardized test procedures. The ECM furnaces in the study averaged nearly twice the electricity use per therm of gas than their GAMA ratings would indicate, and only three out of 14 furnaces used less than the rated kWh per therm. Static pressure appears to be a general factor: static pressure drop across the furnace and evaporator coil averaged about twice the value typically used in the standard rating test procedure, and ECM sites with higher static pressure drop tended to have higher deviation from the rated electricity use per therm. This is consistent with the fact that most ECM furnaces compensate for high static pressure by increasing the blower speed. (Note, however, that despite using more electricity than the rating data would indicate, the ECM furnaces still used considerably less electricity than the non-ECM furnaces in the study.) In addition, faulty field configuration was clearly a factor in one case, and substantial use of high-fire operation came into play for several other sites. The study suggests that heating electricity use of 0.6 kWh per therm of gas consumed could serve as a useful demarcation line between electrically efficient and less-efficient furnaces: this value neatly separates the ECM and non-ECM furnaces in the study both in terms of rating data and observed electricity use in the field.
- 6. Additional electricity savings for ECM furnaces could be realized through careful attention to filter (and duct) pressure drop. Static pressure drop across the filter varied widely among the sites, and no obvious correlations were found between type of filter or filter condition. Because ECM furnaces generally compensate for higher static pressure by boosting the blower speed to maintain a consistent airflow, additional savings could be realized by minimizing the static pressure that the system sees. This includes selecting filters with low pressure-drop characteristics, and (for new homes) minimizing duct friction. The data from the study suggest additional electricity savings may be obtained with ECM furnaces by using filters with low static pressure drop and by changing or cleaning filters regularly, since filters were found to represent about half of the total static pressure drop seen by the furnace on average. More research is needed to better understand the pressure drop characteristics of various types and brands of furnace filters, however.
- 7. Field configuration of continuous-fan airflow was an issue at some sites. Although ECM furnaces have an advantage of being capable of delivering continuous airflow at much lower electricity cost, this will occur only if the systems are configured properly. Fortunately, most of the furnaces in the study appear to be factory-set to operate at the lowest possible speed setting in continuous-fan mode—and are left that way by the installer. However, four of the 14 ECM furnaces were found to be set to a higher airflow for continuous-fan operation (including one furnace that was actually used in this mode). Non-ECM furnaces generally operated at the heating speed when called upon for continuous-fan operation, so the ability to modify the continuous-fan airflow is limited. However, at least one line of furnaces can be set to a separate lower fan speed for continuous-fan operation, though none of the four such furnaces in the study were configured in this way.
- 8. Nearly all of the furnaces in the study were considerably oversized in terms of meeting design heating loads—but setback recovery may be more of a limiting factor. The data suggest that at a 90F° indoor/outdoor temperature difference, the majority of the furnaces will operate at only 40 to 60 percent of

their full output capacity on a daily basis. In fact, nearly all of the multi-stage furnaces could meet these design conditions using only the lowest firing rate. At the same time, analysis of setback recovery length indicates that about a third of the furnaces will have a setback recovery period that exceeds three hours at design conditions. Even under typical winter conditions, about a third of the homes had setback recovery periods of an hour or more. This raises interesting questions about whether the savings from thermostat setback outweigh the penalties of needing an oversized furnace for quick setback recovery.

9. The ECM furnaces in the study had lower power factors on average than non-ECM furnaces. Power factor can be an issue for utilities, because distribution equipment such as transformers must be sized to accommodate current flows, which are proportionally larger for loads with low power factors. The ECM furnaces generally had operating power factors in the range of 0.6 to 0.8, though individual tests sometimes showed far lower values at low operating speeds. Nearly all of the non-ECM furnaces in the study had power factors between 0.8 and 0.9. Since the ECM furnaces draw considerably less power than non-ECM furnaces, the displacement of a non-ECM furnace with an ECM model would still reduce the overall utility system capacity requirements.

It should be noted that the furnaces included in the study were deliberately chosen to include a variety of models, and may not be representative of the distribution of furnaces sold in the state each year. Energy savings figures above are couched in terms of what a typical Wisconsin homeowner might experience. In this sense, the study results do not necessarily reflect the savings attributable to program efforts to promote ECM furnaces: program participants may differ in their gas usage and furnace operational characteristics from the group of homeowners studied here, and this study does not deal with causal linkages between sales of ECM furnaces and program efforts to promote such sales.

Introduction

Background

Space heating and cooling are by far the largest energy expenditure in most Wisconsin homes; energy use for space conditioning is estimated to constitute more than half of the total energy use in the typical home (Pigg and Nevius, 2000). This gives the warm-air furnace—which is found in more than three fourths of Wisconsin single-family homes—a central role in consumer energy costs.

In the 1980s and 1990s, energy efficiency programs geared toward residential furnaces concentrated on the gas efficiency of these devices. These efforts have been successful; recent studies have shown that high efficiency condensing furnaces are currently present in about half of all single-family homes (Pigg and Nevius, 2000), and represent nearly eight out of every ten furnaces sold in the state each year.

The Wisconsin success in creating a sustained market for high efficiency furnaces has led to a refocusing of program efforts to target electrical consumption by furnaces. While the benefits of high gas efficiency are generally understood, it is probably safe to say that many consumers do not realize that furnaces use a substantial amount of electricity, especially when the air handler is operated continuously (typically for air filtration or mitigation of temperature differences in the home). Moreover, standard ratings of furnace energy use, such as those published by the Gas Appliance Manufacturers Association (GAMA) show a tremendous variation in furnace electrical consumption, from less than 100 kWh per year to more than 1000.

To promote the installation of furnaces that are electrically efficient as well as efficient in terms of combustion, the Wisconsin statewide Focus on Energy program began offering a \$150 reward for the installation of furnaces that use electronically commutated motors (ECM) in 2002. These ECMs (also sometimes referred to as brushless DC motors) have several advantages over the typical permanent-magnet split capacitor (PSC) blower motors found in most furnaces sold in the state each year. First, ECMs are claimed to be 20 to 30 percent more efficient than standard blower motors (Bryne, 2000; Sachs et al., 2002). Because the air handler represents a large proportion of the total electrical draw by the furnace, using an ECM in place of a standard PSC motor for this application offers an immediate boost in electrical efficiency. Some furnace models also use ECMs for the much smaller blower that moves combustion air through the venting system for power-vented and sealed combustion systems.

Second, the typical ECM blower can produce a much wider range of airflow than the PSC blower used in most furnaces, which typically have only three or four set speeds over a fairly narrow range. This can have a large impact on electrical draw, because power consumption by an air handler rises with the cube of airflow. Furnaces that can produce less airflow when appropriate (such as during continuous background circulation) will use substantially less electricity.

Furnace manufacturers have taken advantage of this fact by bundling ECM-based air handlers with multi-stage firing capability. The idea behind this approach is that the furnace can operate at a lower firing rate and less airflow for the majority of the heating season when heating loads are far below the design maximum. This results in quieter and less drafty operation in addition to reduced electrical consumption. Also—in contrast to most PSC-based furnaces—ECM furnaces also have a separately configurable continuous-fan settings and better ability to fine-tune

¹ Data on Wisconsin furnace sales comes from the Energy Center of Wisconsin's Furnace and A/C Sales Tracking Project.

airflow in cooling mode. In terms of the latter, ECM furnaces in theory provide better ability to maximize the efficiency of central air conditioning systems that use the furnace air handler.

Finally, the dominant ECM blower used in the market (manufactured by General Electric) uses a patented approach to monitor airflow and dynamically adjust the motor speed to deliver the target airflow over a wide range of static pressures. This eliminates most of the uncertainty surrounding whether a furnace is delivering the appropriate airflow for the task at hand. Standard blower motors simply run at a constant speed in any given operating mode. Differences in static pressure from home to home—or over time for a given home as the filter becomes loaded with dirt—means that airflow from these furnaces will vary, with potential adverse effects on performance.

Research Objectives

Despite the market presence of ECM furnaces since the late 1980s, little publicly available data exist to document the claimed performance advantages of these models. For example, do these furnaces indeed run most of the time at a reduced firing rate during the heating season? How much electricity do they draw compared to standard PSC furnaces in various operating modes?

Moreover, there is a general lack of field data on furnace operation in general. The number of hours that a furnace operates in a year—and the number of heating cycles it goes through—affects overall electricity use, but little field data exist on these parameters.

This study was therefore undertaken with the main objective of gathering field data on the operation of new ECM and non-ECM furnaces. The underlying premise is that the primary point of comparison should be between a new multi-stage ECM furnace and a single-stage non-ECM furnace, representing the choice faced by the consumer considering a furnace purchase.

A secondary objective of the research was to look at sizing and field configuration issues with these furnaces, with an eye towards efforts to improve installation practices.

Methods

Recruitment and Site Selection

To implement the study, a total of 31 sites were recruited, representing a mix of new ECM and non-ECM furnaces and a variety of models. The sites were recruited from three sources:

- Participants in a previous study of energy use in new Wisconsin homes who responded to a solicitation of
 interest in participating in a field study of furnaces. These homes were a mix of homes in the Wisconsin
 Energy Star® Homes program and comparable non-participants.
- A sample of participants from the Wisconsin Energy Star® Homes program for which program records showed the make and model of the furnace that was installed.
- A sample of participants in a previous state-funded rewards program for owners of older homes who
 purchased a new furnace.

Despite an effort to balance the study between new homes and older homes, all but five of the recruited sites ended up being new homes. All of the furnaces in the study were sealed combustion, condensing units with 90 percent or better combustion efficiency, and all were upflow "northern" models. The furnaces ranged from 50,000 to 120,000 Btu/hour input, and were all less than three years old at the start of the study. More detail about the furnaces and the sites can be found in Appendix A.

With a few exceptions, the furnaces in the study fall into two main categories: single-stage furnaces with PSC blower motors (14 sites) and two-stage furnaces with ECM blower motors (12 sites). The study also included:

- two sites with fully modulating (ECM) furnaces;
- one site with a two-stage, non-ECM furnace; and,
- one site with a (discontinued) single-stage, pulse-combustion furnace with an ECM blower.

Testing and Monitoring

The study involved a combination of short-term tests on each furnace and monitoring of operation over time. The rationale was that short-term measurements of electricity use could be combined with information about how long the furnaces operated to estimate total seasonal and annual electricity consumption. The timing of the study also precluded monitoring over an entire heating season, so the ability to extrapolate to a standard heating season was required.

Testing Approach

Two rounds of testing were conducted on each furnace. These corresponded with site visits to install; and remove monitoring equipment. The first round was conducted in the latter part of February 2002; the second round was mostly conducted between September and November of 2002 (though two sites were tested in August).

Each round of testing involved putting the furnace through various operating modes while recording data on electricity use, static pressure, and temperature. Monitored parameters are summarized below:

Electrical Data

- Amperage, wattage, and power factor for the furnace, as well as the separate measurements for these
 parameters for the air handler blower and the combustion blower
- Voltage at the furnace electrical connection

Static Pressure Drop (see figure 1)

- Between the supply ductwork (just after the AC coil) and furnace blower compartment
- Across the filter
- Between the furnace supply ductwork (at the location described above) and the basement (second round only)
- Across the Trueflow[®] airflow meter (used to determine airflow in the second round of testing only)

Temperature (see figure 1)

- Supply air dry-bulb temperature
- · Return air dry-bulb temperature
- Return air wet-bulb temperature (second round of testing only)




Figure 1: Static pressure and temperature monitoring points.

5

Instrumentation

Power measurements were made using Dent instruments ElitePro® loggers with 15 Amp CTs connected to the overall electrical connection to the furnace, as well as the power leads to the air handler and combustion blowers (to allow disaggregation of these loads). A single voltage measurement was made at the service entrance to the furnace. The loggers were configured to record data as three-second averages of all values. The loggers have a stated typical accuracy of 0.5 percent for all values, including true wattage.

Static pressure measurements were made with Autotran Series 750 pressure transducers with a range of 0-1 inch of water column (IWC) (0.75% accuracy) using static pressure probe tips inserted into holes in the ductwork. The pressure transducers produced a 4-20mA signal that was sampled and recorded once a second by Onset Hobo[®] 4-channel data loggers (H08-006-04).

Temperature measurements were made with a single probe (TMC20-HA, 0.9F° accuracy) at each location sampled and recorded at one-second intervals by the Hobo® 4-channel loggers. Soda straws were used to hold the probes away from the ductwork metal and 4 to 6 inches into the air stream. The wet-bulb temperature measurement was made by sewing a cotton wick over the temperature sensor and saturating it with water.

The on/off status of the gas valve and air handler was recorded during testing using relays and Hobo[®] state loggers (H06-001-02) as described in more detail below in the Monitoring Approach section.

In the first round of testing, no changes were made to the blower speed settings. Data were recorded over a heating cycle that typically lasted at least 5 minutes, under continuous-fan operation, and in standby mode. Two-stage furnaces were tested in low- and high-fire modes.

These tests were repeated in the second round of tests, which also involved operating the furnace at the cooling speed. When weather permitted, this was done by actually initiating a call for cooling at the thermostat, and monitoring for a minimum of 15 minutes. When the weather was too cold to operate the air conditioning, the blower was simply set to the cooling speed and the furnace operation was monitored for a few minutes.

For the second round of testing, airflow was also measured using a Trueflow airflow meter. This device replaces the filter with a flow plate with known pressure drop characteristics. Pressure drop across the flow plate was logged in the same way as the other static pressure measurements. Because the flow plate does not necessarily have the same pressure drop characteristics as the filter it replaces, a correction factor was employed based on the square root of the ratio of the supply duct pressure with the filter and the flow plate in place. Used in this way, the Trueflow has a stated accuracy of ± 10 percent. Flow measurements were generally made at the end of cycle, so as not to disturb other measurements. Flow measurements during actual cooling cycles were made after 15 minutes of operation.

Data (including airflow) were also collected at alternate air handler speed settings in the second round of testing. For non-ECM furnaces, this generally meant measuring at each of four speed tap settings. The ECM furnaces in the study had many possible speed settings; four to six settings across a range of available speeds were selected for testing.

Finally, firing rates for the furnaces were also established during the second round of testing. This was done by timing how long it took for the furnace to consume two to three cubic feet of gas according to the home's gas meter.

Testing — Data Reduction Protocol

Raw data from the testing were in the form of one-second snapshots (pressure and temperature) and three-second averages (power, amperage, power factor, and volts) over the entire testing period. The three-second power data were first converted to one-second level data (by replicated observations between actual data points) and then merged with the pressure and temperature data to produce a single, one-second interval stream of data for the testing. Status change information from the state loggers was also merged into this dataset.

The beginning and ending points of individual tests, such as a heating cycle or a period of continuous-fan operation were marked in the data based on field notes, and average values over a core period of steady-state operation was identified for each. The core period was generally defined by removing the first and last 30 seconds of data, then taking the mean of the remaining data. For heating cycles, steady-state operation was defined as the period between blower startup at the beginning of the heating cycle and gas valve shutoff at the end. The identified core periods were visually inspected to ensure that transient effects (such as a spike in blower motor wattage at the time of startup) were not inadvertently included. For airflow measurements, the process involved also identifying a core period of operation with the flow plate and the filter in place.

The analysis also relied on measurements of total electricity use over relatively fixed operations, such as the startup phase of a heating cycle. These were calculated by simply summing the watt-seconds of electricity use between relevant events. For example, the electricity consumption during heating cycle shutdowns was calculated by summing the watt-seconds of electricity used from the point the gas valve closed (denoting the termination of a call for heat) to the point the blower motor shut down.

Time constraints typically prevented operating the furnaces to the point of steady-state conditions in terms of temperature rise. The field data were extrapolated to steady-state conditions using methods described in Appendix R

Monitoring Approach

The goal of the monitoring was to track the amount of burner and blower on-time and cycling behavior of the furnaces as a function of outdoor temperature. This was generally done by monitoring the status of the gas valve and the air handler.

Gas valve status was recorded by wiring a relay (RIBUC1) in parallel with the gas valve such that whenever the gas valve was energized the relay contacts also closed. The relay contacts were connected to a Hobo® state logger (H06-001-02), which recorded the date and time (to the nearest 0.5 seconds) each time the gas valve opened and closed. For two-stage furnaces, two relays and data loggers were used; one recorded the status of the first stage, and the other tracked the status of the second stage. The gas valve used in some lines of furnaces in the study. (Sites 12, 18, 24 and 27) was not amenable to connecting a relay; for these sites, the status of the combustion inducer blower was tracked, and the data were adjusted based on measured time delays between the inducer and gas valve operation.

Blower status was similarly monitored by attaching a relay with a state logger to the electronic air clear (EAC) terminals on the furnace control boards. The EAC terminals are typically energized whenever the blower operates.

In addition to tracking gas valve and blower status, a 20-amp current transformer (Hobo® CTV-A) was attached to the furnace to measure total amperage draw by the furnace. This was sampled every 90 seconds and recorded by a 4-channel Hobo® data logger. The amperage data was mainly used as a cross-check against the status data.

Finally a temperature logger (Hobo[®] H8 series) was placed at the thermostat to sample and record the temperature every 15 minutes. Some sites also received an outdoor temperature logger (Hobo[®] H8 Pro series) to record outdoor temperature as well (most of the subsequent analysis relied on weather station data, however).

Special consideration was needed for the two fully modulating furnaces in the study (Sites 28 and 32). Simply tracking gas-valve on/off status was not adequate for these because their output can be modulated between 40 and 100 percent of full output. The approach used was to leave these sites as the last for testing and monitoring installation, and then leave the Dent power monitoring equipment behind to record actual average waitage over one-minute intervals for these furnaces, in addition to tracking gas valve and air handler on/off status. One additional channel of the Dent loggers was also dedicated to recording the control voltage to the gas valve; this voltage varies from 6 to 18 VAC in proportion to the degree of modulation. The Dent loggers had sufficient on-board storage for about a month's worth of one-minute furnace waitage and gas valve control voltage data.

The data loggers and sensor wires were color coded so that the homeowners could replace the loggers as they filled up. Approximately once a month, each homeowner was mailed a new set of data loggers, along with a return envelope for the current loggers and a postcard to record the date and time of the swap (indoor temperature loggers were swapped only once over the course of monitoring). A few loggers were incorrectly configured, or not plugged in correctly, but these amounted to no more than 40 out of more than 750 data files received over the course of monitoring the 31 sites. In addition, some data loggers filled up before they could be swapped out, particularly the state loggers, which can hold a fixed number (about 1,000) of on/off cycles rather than data over a fixed amount of time. These data were accurate but incomplete. Considerable effort was spent identifying gaps in the data and removing the small amount of erroneous data from incorrectly configured loggers.

The monitoring equipment was installed at the sites over the latter part of February 2002, and monitoring officially continued through the end of August to capture the cooling season. Because some data loggers were not yet filled up and equipment was not completely removed until later in the fall, some data were obtained for the fall of 2002. No summer data was obtained from Site 5, because the homeowners left for the summer in early June. Fortunately, despite the late start of the study in the 2001/02 heating season, the coldest weather of the year occurred in early March just after the completion of monitoring installation. The furnaces were thus monitored over about a 100F° temperature range, from about -5°F to +95°F.

Monitoring — Data Reduction Protocol

Raw data from the monitoring was in the form of a stream of date/time stamps of status changes for the gas valves and air handlers, 90-second interval data for furnace amperage, and 15-minute interval data for indoor temperature. The bulk of the analysis for this report was conducted using daily summaries of these data. Total daily burner and blower hours and cycles were calculated from the status data, as were minimum, maximum, and median daily cycle lengths. These were merged with daily average furnace amperage and indoor temperature data, as well as with daily average outdoor temperatures obtained from each of four nearby NOAA weather stations. Days with less than 90 percent data recovery were discarded. Appendix F provides basic scatterplots of some of these variables.

The resulting dataset of daily summary data formed the basis for the regression models of daily operating hours and cycles described in detail in Appendix C. Essentially, these models provided a means of estimating operating hours and cycles as a function of outdoor temperature. When combined with a distribution of outdoor temperature, the models provide estimates of total operating hours and cycles over the course of a year or season.

Results

Overview

Although furnaces involve a number of components, the air handler is by far the most important when it comes to electricity use.² As will be shown later, the air handler typically accounted for 75 percent or more of the electricity consumed by the furnace in the study. The test data collected on the furnaces in the study confirm two primary ways in which ECM furnaces save air handler energy: 1) an ECM is inherently more efficient than a typical PSC air handler motor; and, 2) ECM-based air handlers can be operated over a much wider usable range of speeds than can typical four-speed PSC air handlers.

Both of these advantages can be seen graphically in Figure 2, which shows the characteristic curve of blower power draw versus airflow for each site in the study. Though differences in variables such as duct and filter resistance make each curve unique—and strict comparison between sites difficult—the ECM-based air handlers generally draw less power at a given airflow than the PSC-based air handlers. This is consistent with the notion that ECM blowers are inherently more efficient (Byrne, 2000).

Moreover, Figure 2 dramatically illustrates the wider airflow range available from the ECM-based air handlers. ³ In practical terms, this means that these furnaces can operate at far lower wattage in situations where less airflow is needed, such as continuous fan-only operation and reduced-output heating for furnaces with multistage firing.

This report examines differences between ECM and non-ECM furnaces in four basic operating modes: heating, cooling, fan-only operation, and standby. These modes and key results are described below.

Heating Mode

The study suggests that a typical non-ECM condensing furnace in Wisconsin will fire for a total of about 1,000 hours over the course of an average heating season, and consume about 800 kWh of electricity—most of which will be used to power the air handler. A typical multi-stage ECM furnace will mainly operate in a reduced low-fire mode, with its full firing capability used primarily to recover from thermostat setback periods. Although the ECM furnace will operate more total hours in heating mode (since it is producing less heat per hour in low-fire mode), it will do so with far lower electrical power requirement for the air handler: the result is that the ECM furnace will use about half the electricity in heating mode (400 kWh) over the course of an average heating season.

² Throughout this report, the term "air handler" refers to the furnace blower motor and fan assembly used to circulate air through the furnace and deliver heated air to the house.

³ Actually, many of the ECM furnaces are capable of higher airflows than shown. For the study, tests were conducted only up to the selected cooling speed based on the size of the central air conditioning system.




Figure 2: Blower power versus airflow curves for study furnaces.

Cooling Mode

In cooling operation, the furnace air handler provides airflow over the evaporator coil for the central air conditioning system to remove heat and circulate cooled air through the house. Airflow requirements in this mode are typically large, so the savings from ECM-based air handlers stem from their inherently higher operating efficiency. The study results suggest that a typical 2.5-ton air conditioner that is operated for 400 hours over an average Wisconsin cooling season will require 225 kWh of air handler energy from a non-ECM furnace and 155 kWh from an ECM furnace, for a difference of about 70 kWh. In addition, less air handler energy in the summer means less waste motor heat that must be removed by the air conditioner: this adds perhaps an additional 25 kWh to the cooling-mode savings for a typical ECM furnace.

Fan-Only Operation

Some homeowners choose to operate their furnace air handler continuously, regardless of the need for heating or cooling, to filter the air in the home or perhaps even out temperature variation around the home. Airflow requirements in these situations are low, but non-ECM furnaces are typically set up to deliver the heating-mode airflow when called upon for fan-only operation. The result is high air handler power requirement (typically about 500 Watts), and—over the more than 7,000 hours that would be typical for year-round continuous fan operation—more than 3,500 kWh of electricity consumption. As the study data show, however, a typical ECM furnace can operate at a very low airflow rate, and provide adequate air circulation for about 80 percent less air handler energy.

Standby Operation


Standby is what furnaces do when they are not being called upon for heating, cooling airflow, or continuous fanonly circulation. Except for furnaces that are called upon to provide continuous air circulation, most furnaces spend the vast majority of their time (typically more than 7,000 hour per year) in this mode drawing a small amount of power that adds five to ten percent to the total annual electricity use for the furnace. The study results indicate that ECM furnaces use more electricity than non ECM furnaces in standby, which reduces the savings from these furnaces by about 30 kWh typically.

The sections that follow cover each of the above operating modes in more detail. Final sections examine the geographic variation in the results, the impact of filter pressure drop on power requirements, and power factor measurements.

Heating Mode

Heating is the most complicated mode of operation for furnaces, involving the most components of the furnace, as well as ignition and shutdown sequences. Figure 3 shows electrical consumption over a heating cycle for one of the furnaces in the study (similar plots for all of the furnaces can be found in Appendix B).

Figure 3: Electrical profile of a typical heating cycle.



Though they differ in timing and in some of the details, the furnaces in the study all follow same basic sequence of operation for heating:

- 1. Upon receiving a call for heat from the thermostat, the combustion blower starts up.
- 2. When the system is satisfied that combustion airflow is adequate, the hot-surface igniter (HSI) is energized and after a short warm-up period the gas valve is opened, igniting the burners.
- 3. After a warm-up interval, the air handler starts up. At this point the furnace begins to deliver warm air to the house.
- 4. When the thermostat terminates the call for heat, the gas valve immediately closes, extinguishing the burner; after a short purge period, the combustion blower also shuts down.

5. After a pre-programmed period of scavenging heat from the furnace, the air handler shuts off, completing the heating cycle.

A heating cycle can be divided into three phases: startup, operating, and shutdown. The electricity consumed in the startup and shutdown phases is relatively constant from one heating cycle to the next, and hence is proportional to the number of heating cycles the furnace goes through. The total electricity consumed in the operating phase depends on how long the furnace is run. As the heating load on the home increases, both the number of cycles and the length of the heating cycle can be expected to increase. Analysis of the monitoring data collected on the furnaces in the study suggests that most of the increased run-time for furnaces comes from an increase in the number of cycles the furnace goes through rather than increases in the length of the cycle (see Appendices C and D).

Steady-State Power Draw

Figure 4 shows the overall power consumption of the furnaces in heating mode with both the burner and air handler in operation. It is readily apparent from this figure that the multi-stage ECM furnaces consume significantly less power in low-fire mode than do the single-stage non-ECM models. Some of this difference is no doubt due to the inherent efficiency advantage of the ECM blower, but much derives from the fact that the multi-stage ECM furnaces move considerably less air in low-fire mode. Since blower power is proportional to the cube of the airflow, even a modest reduction in airflow results in substantially lower blower power draw.

In high-fire mode, the multi-stage ECM furnaces in the study do not show as clear an advantage over the single-stage non-ECM furnaces in terms of power draw. The 60,000 Btu/hr models (Sites 3, 8 and 9) all show significantly lower power draw in high-fire mode compared to the non-ECM 60,000 Btu/hr sites (Sites 7, 26, 29, 20 and 23). When viewed in terms of blower wattage versus airflow, these furnaces are clearly set up to deliver less airflow at high-fire. But the 80- to 100-kBtu ECM furnaces draw about the same amount of power as the non-ECM furnaces in this size range.




Figure 4: Heating mode power draw.

Heating Speed Selection and Temperature Rise

Because air handler energy is a large part of the total power draw, the field selection of the heating blower speed at the time of installation can affect the power consumption of the furnace. The non-ECM furnaces in the study generally have four speed taps to choose from: low, medium-low, medium-high, and high. These furnaces were all set to either medium-low or medium-high, and most appear to be set at the factory default value.

Among the ECM furnaces, it is noteworthy that some are not field adjustable in terms of the heating mode blower speed. These furnaces sense actual airflow and attempt to achieve a preset target airflow. The two fully modulating furnaces can be field set for either a 50 or 65 F° temperature rise. The lower figure would correspond to a higher airflow rate, and vice versa. Both of the furnaces in the study were set for the 50 F° rise; when we tested the higher setting (for Site 28), blower wattage was reduced by about 50 percent.

Each furnace has a nameplate range for temperature rise (i.e. the difference between the supply and return air temperatures in steady-state operation)—typically 40 to 70 F°. Furnaces operating below the nameplate temperature rise are probably moving excessive air—and using excessive electricity—while those operating above the range risk premature heat exchanger failure. Tests on the furnaces in the study showed that dropping one speed tap setting from the default reduced airflow and blower wattage by about 10 percent on average.

Steady-state temperature rise was calculated for each furnace based on test data (see Appendix B). The measurement data suggest that low temperature rises (indicating excessive airflow) are more common than the reverse—12 of the furnaces in the study were below the nameplate range, and only three were above the nameplate range (Figure 5).




Figure 5: Extrapolated temperature rise.

*Calculated based on measured airflow and rated heat output (adjusted for difference between rated and observed heat input) However, the measurement data did not correspond well with the temperature rise calculated from the measured airflow and the estimated heat output of the furnaces. This second method generally predicted a higher temperature rise than was measured directly (Figure 5). It is possible that the single probes used to monitor air temperature on the supply side underestimated the average temperature of the overall air stream.

Heating Cycles and Hours of Operation

The monitoring data from the study allowed the development of models of daily hours of operation and number of heating cycles as a function of outdoor temperature. These models are needed to extrapolate the monitoring results to a full heating season and adjust the data to average weather conditions. (See Appendix C for more details on the modeling approach).

When modeled with Madison, Wisconsin weather data (which is close to the population-weighted average heating degree days for the state [WEB, 2002]), this exercise shows most furnaces in the study going through between 2,000 and 10,000 heating cycles per year with 500 to 1,500 burner-operating hours (Figure 6 and Figure 7).

The two furnaces with the lowest operating hours (Sites 30 and 14) are known to have substantial alternative heating sources in the home: the occupants at Site 30 rely mainly on a wood stove for space heat and use the furnace primarily as a means of distributing the wood heat throughout the house; the homeowner for Site 14 reported heavy use of a gas fireplace. Two other homes in the study had multiple heating systems, but showed operating hours that were not dissimilar to homes with a single heating system. Site 9 has in-floor hydronic heat in the basement. Site 8 has separate furnaces for each floor of the home (the monitored furnace served the first floor).

Hours of operation also depends on the relative sizing of the furnace in relation to the home's heating load, which in turn is a function of the size of the home, its thermal integrity, and the thermostat setpoint. Site 5 had by far the highest estimated operating hours; this site is also an older home with the highest measured average indoor temperature (see Appendix D). Indeed, three of the five older homes in the study occupy the top three slots in terms of estimated operating hours.

To get a better idea of the sizing of the furnaces in relation to the heating load of the homes, the modeled behavior of each furnace can be combined with knowledge of the gas consumption rate of the furnaces to estimate the percent of full furnace capacity at a given indoor/outdoor temperature difference. Figure 8 shows the results for an indoor/outdoor temperature difference of 90F°, which is within the 80-95 F° range specified (by region) by Wisconsin code (Comm 22.07). The results indicate that most of the furnaces in the study will run at only 40 to 60 percent of their full capacity under these conditions, and are thus about twice as big as needed to meet the daily heating load under these conditions. Since only one furnace in the study (Site 26) falls within the zone where 90 F° is the required design temperature differential, and the remainder fall in the zones where 80 to 85 F° design conditions are required, the results clearly demonstrate that furnaces are typically sized much larger than within 15% of design as required by Wisconsin code (Comm 22.12). Also, given that low-fire output for the two-stage furnaces in the study is typically about 65 percent of high-fire, it also means that these furnaces could meet the design heating load using just the low-fire mode of operation.

There is, however, another consideration in furnace sizing—setback recovery. Many of the homeowners in the study practiced temperature setbacks. As will be demonstrated later in this report, analysis of the time it takes to recover from the setback temperature (as a function of outdoor temperature) suggests that some furnaces would have quite long setback recovery periods under design conditions. From this standpoint, these furnaces are not over-sized.

Figure 6: Annual heating cycles.




Figure 7: Annual operating hours.




Figure 8: Percent of full capacity at design conditions.

Low/High-Fire Ratio for Two-Stage Furnaces

The two-stage furnaces in the study can operate in one of two heating stages: high-fire (100 percent of rated output), or low-fire, which is generally about 65 percent of full output. The extrapolated low- and high-fire proportions for the two-stage furnaces in the study over the course of an average heating season are shown in Figure 9. Nine of the 11 ECM two-stage furnaces are estimated to operate in low-fire mode 70 percent or more of their firing time, a finding that is generally consistent with product literature claims.

Two ECM furnaces in the study (Sites 3 and 8), however, operated in high-fire mode nearly all the time during the monitoring period. Both of these sites exhibited very long heating cycles (for reasons that are only partially understood), and the high-fire operation appears to be the result of how the staging control was affected by this behavior (which was not seen for the six other sites with this type of staging control but more typical firing cycle lengths). Moreover, as will be shown shortly, the two sites in question still had lower electricity consumption than similar-sized non-ECM furnaces despite operating in high-fire mode the majority of the time.




Figure 9: Low/High-fire proportions for two-stage furnaces.

Operation of Fully Modulating Furnaces

The two fully modulating furnaces in the study (both of the same make, though different sizes) are capable of operating anywhere between 40 and 100 percent of full output. Modulation of these furnaces is controlled by a special thermostat designed for this furnace model. Figure 10 shows the operation of the furnace over a typical day for one of the sites. The furnace operated at low output (drawing about 150 Watts) except when the temperature was being boosted to a higher setpoint. During these periods, the furnace gradually ramped up to high output (about 550 Watts) over the course of about 15 minutes, then ramped back down to low fire when the room temperature began to approach the setpoint.

Analysis of about a month's worth of one-minute interval data on the control voltage to the gas valve (which is proportional to the firing rate) indicates that the furnaces at these sites operate at a fairly low firing rate half or more of the time (Figure 11).

Site 28 (March 11) **Furnace Watts** Indoor Temp. (PF) Blower responding to HRV operation Hour of day gas flowing to furnace

Figure 10: Typical day of operation for a modulating furnace.





Figure 11: Distribution of output for modulating furnaces.




Annual Electricity Use in Heating Mode

As noted at the beginning of this section, furnaces use electricity during the startup, operating and shutdown phases of each heating cycle. When combined with the measurements of electricity consumption over the course of a heating cycle, the models of annual operating hours and cycles provide the basis for estimating annual electricity use by each furnace over a typical heating season. The data also allow this electricity use to be separated by furnace component and cycle phase.

Figure 12 shows estimates of the annual electricity consumption for each of the furnaces in the study. These estimates are obviously influenced by factors such as sizing, thermostat settings, and the use of auxiliary heat, all of which tend to cloud the comparison of ECM and non-ECM furnaces. For this reason, it is more instructive to look at the distribution of heating electricity use per therm of gas consumed (Figure 13). When viewed in this way, the two groups are clearly distinct, with the ECM furnaces mostly occupying the lower end of the distribution and the non-ECM furnaces at the upper end. The anomalous results for Site 17 appears to be due to misconfiguration of this three-zone system.⁴

The median ECM furnace in the study uses about 0.5 kWh per therm of gas in heating mode, which is about half that of the median non-ECM home. This suggests heating-mode savings of about 400 kWh per year for a typical older home with annual gas consumption of 800 therms.⁵





⁴ Based on feedback from this study, the homeowner brought a heating contractor in to look at the system, which resulted in a number of changes to the setup of the system that should substantially reduce electricity use by the furnace.

⁵ This level of gas usage is the average found from analysis of gas data for a sample of 97 Wisconsin homes built prior to 1994 with condensing furnaces in a recent characterization study of Wisconsin homes (Pigg and Nevius, 2000).




Figure 13: Annual electricity use per therm of gas consumed.

Heating Electricity Use — Field Results and GAMA Ratings

The estimates of annual electricity use per therm of gas consumption from the field results can be compared to rating data published by GAMA. The GAMA directory provides two published values for annual gas consumption and annual electricity consumption (Ef and Eae, respectively) under standard test conditions that can easily be combined to derive rating-based electricity use per therm.

Figure 14 compares the modeled estimates of annual heating electricity use per therm from the field data to the GAMA rating data. An number of observations can be made from this comparison. First, at a gross level there is a general correspondence between the two values; sites with low rated electricity use per therm (generally ECM models) tend to have low values from the field, and those with higher ratings have higher observed values. In fact, the data suggest that a simple discriminant of Eae/Ef = 6 (corresponding to 0.6 kWh per therm) can be used to distinguish ECM from non-ECM furnaces. (This discriminant may not be applicable to "southern" style furnaces that have proportionately larger blower motors to accommodate larger air conditioning systems.)

⁶ For this comparison, the field data were adjusted to remove differences between the measured and nominal gas input rates for the furnaces. The adjustments were generally less than 15 percent (see Appendix B).




Figure 14. Modeled versus rated heating kWh per therm.

Second, the data suggest that the rating data tend to underestimate the actual electricity use of the furnaces on average—but more so for ECM furnaces on a percentage basis. In three-quarters of the cases, the field data show more electricity use per therm than the rating data would indicate, but this blends the fact that 86 percent of the ECM furnaces (12 of 14) exceeded the rating value compared to 65 percent of the non-ECM furnaces (6 of 17). Because the ECM furnaces generally occupy the low end of the kWh-per-therm scale, the difference between the two groups is fairly large in percentage terms: the median ECM furnace uses 82 percent more electricity per therm than the rating data would indicate, compared to just three percent for the median non-ECM site.


Clearly, there are site-specific configuration and behavioral factors that can strongly affect heating electricity use per therm. Site 17 uses much more electricity than its rating data would suggest; this furnace was found to be misconfigured for much higher airflow than needed. Similarly the two sites that operated in high-fire mode most of the time (Sites 3 and 8) are somewhat on the high side in kWh per therm compared to their ratings.

The data also reveal how behavioral factors can influence electricity use for the ECM furnaces. Sites 21 and 31 have identical furnaces that operate under comparable static pressures and have about the same total gas consumption. Yet Site 31 uses about 60 percent more electricity per therm than Site 21. The explanation for this difference is that the homeowners at Site 31 practice substantial day and night thermostat setbacks, while the homeowners at Site 21 keep their thermostat at a constant setting. The setback practice at Site 31 translates into about 30 percent high-fire operation compared to less than five percent high-fire at Site 21. Since high-fire operation has five to six times the overall power draw of low-fire for these sites but consumes only about 50 percent more gas, the upshot is higher electricity use per therm for Site 31.

The data also suggest that differences between static pressure levels in the field and those used in the ratings may underlie some of the observed differences. The ASHRAE standard on which the rating data are based stipulates a minimum external static pressure of 0.2 inches water column (IWC) at the highest firing rate for furnaces in the 55,000 to 80,000 Btu/hr size range, and 0.23 IWC for furnaces with firing rates of 80,000 to 100,000 Btu/hr. Both of these values are considerably lower than the observed external static pressure among the furnaces in the study, which ranged from 0.24 to 1.0 IWC and averaged about 0.5 IWC. (The field measurements were also made downstream of the central air conditioning evaporator coil, which means that true external static pressure across the furnace cabinet is even higher.) These high static pressures are consistent with other field data (e.g., Phillips, 1998 and Proctor and Parker, 2000)

Figure 15. Percent deviation of heating electricity use per therm from rating value.

Deviation of heating kWh/therm from GAMA rating



External Static Pressure (IWC)*

*in high-fire heating operation

As Figure 15 shows, the data show some tendency for the discrepancy between measured and rated electricity use per therm to go in opposite directions for the two groups as static pressure increases: ECM furnaces use more as static pressure increases (though there is considerable scatter in the data) and non-ECM furnaces use less. This is consistent with the way these furnaces operate. Non-ECM furnaces operate at a fixed speed: as static pressure increases for these furnaces, airflow (and electricity use) declines. In contrast, the ECM furnaces in the study use a blower motor manufactured by General Electric that can sense airflow and adjust its speed accordingly. As static pressure increases on an ECM furnace, the blower motor compensates by running at a higher speed (and using more electricity) to continue to deliver the desired airflow.

If external static pressure under actual conditions is higher on average than those used in the rating procedures (as this and other studies suggest), the result would be to narrow somewhat the differences between ECM and non-ECM furnaces in electricity use per therm—though the ECM furnaces still clearly use considerably less electricity than the non-ECM models.

Electricity Use by Component and Operating Phase

Figure 16 shows how heating-mode electricity use is distributed between the inducer fan, the air handler and other components of each furnace. As could be expected, the air handler accounts for the bulk of the electricity use for all of the furnaces, typically accounting for about 80 percent of the total electricity use in non-ECM furnaces, and about 70 percent in ECM models. The ECM furnaces show a somewhat higher proportion of electricity use for "other" components: this is less a consequence of these components drawing more power than non-ECM furnaces than it is the result of much lower fan power, resulting in "other" representing a proportionally larger slice of the pie.

Similarly, Figure 17 breaks electricity into the three phases of operation for heating: startup (from the call for heat until the air handler starts), operating, and shutdown (from the end of the call for heat to air handler shutdown). Again, it is no surprise that the operating phase dominates, accounting for about 80 percent of the total on average. But the data suggest that there are conditions under which startup and shutdown electricity can exceed the operating electricity use. Less than half of the electricity for Site 1, for example, is used during steady-date operation. This site has the second shortest average firing cycle length in the study (about three minutes of firing per cycle), and it has a fairly long blower-off delay (two minutes). Thus, this furnace spends about a minute warming up, two minutes operating, and then two minutes shutting down. Site 17 also has a large proportion of its electricity use devoted to shutdown due to an unusually long blower-off delay (more than 7 minutes). Cycle lengths are discussed in the next section.

Figure 16: Heating-mode electricity use by component.





Figure 17: Heating-mode electricity use by cycle phase.



Cycling Behavior

As the preceding section shows, cycle length can affect electricity consumption. A certain amount of electricity is needed during the startup and shutdown phase of a heating cycle, so furnaces that cycle more frequently will use more electricity per therm of gas consumed.

Because of the way the data were collected, the study provides copious information on heating cycle length. We focus here on three summary statistics: the median and maximum daily firing time and the number of cycles per day. The median daily firing time is the middle value for firing length among all heating cycles in a given day and represents the length of a typical firing cycle for that day. The maximum daily firing time generally represents the setback recovery cycle for homes that practice thermostat setback. For many of the homes in the study, these values are a function of outdoor temperature; as outdoor temperature declines the median and maximum daily firing cycle length increases. For this reason, results shown below are normalized to a common outdoor temperature (see Appendix D).

Figure 18 shows the median firing cycle length for the study sites. Most furnaces in the study had typical firing cycle lengths between 5 and 15 minutes, but a few had relatively short cycles, and five sites had typical firing times that exceeded 20 minutes. As noted previously, the two, two-stage furnace sites with staging control issues are in this group. Thermostat deadband and placement as well as furnace sizing undoubtedly all play into the cycle length.

Figure 18: Median firing cycle length.





Figure 19: Typical daily thermostat setbacks.




Many of the homeowners in the study practiced thermostat setbacks, as Figure 19 shows (Appendix D contains more information about average indoor temperatures and time-of-day temperature profiles during the heating season). Analysis of the daily maximum heating cycle length—which normally represents the setback recovery period in homes where setback is practiced—shows a fairly wide range in setback recovery times under typical outdoor weather conditions (Figure 20). These recovery times are no doubt a function of both the depth of the setback and the sizing of the furnace in relation to the home's heating loads.

When the data on maximum daily firing cycle are extrapolated to design conditions (90 F° indoor/outdoor temperature difference), some sites appear to have very long setback recovery times (Figure 21). From this standpoint, these furnaces are not oversized. However, it can also be argued that if long setback recovery is an issue, homeowners should simply refrain from setting back the thermostat very much under extremely cold conditions.

Figure 20: Maximum daily firing cycle length under typical winter conditions.

Typical daily maximum firing cycle length (minutes)




*No setback practiced Normalized to 32°F outdoor temperature (see Appendix D)

Not shown: Site 13

Figure 21: Maximum firing cycle length at design conditions.

Daily maximum firing cycle length (hours) @ 90F° indoor/outdoor temperature difference



The number of heating cycles that a furnace goes through in a day is strongly correlated with outdoor temperature for most of the sites (see Appendix C). Indeed it appears that, for the most part, it is more the increase in the number of heating cycles rather than the length of the heating cycle that contributes to the increase in total furnace run time as the outdoor temperature drops.

For most sites, the number of heating cycles in a day is fairly linear in outdoor temperature (scatter plots for all sites in the study are provided in Appendix C). However a few sites exhibit a relationship like the one shown in Figure 22, where there is an apparent limit in the number of heating cycles that the furnace can go through during a day. The exact cause of this behavior is unknown, but may be due to limits imposed by certain thermostats on the number of cycles per hour.

In any event, when normalized to typical winter conditions, there is a fairly wide variation in the number of daily heating cycles across the sites (Figure 23). As with heating cycle length, this variation probably reflects differences in thermostat deadbands, the relative sizing of the furnaces, and details about thermostat placement.

Figure 22: Daily heating cycles versus outdoor temperature for one site.





Figure 23: Typical daily number of heating cycles.




Normalized to 32°F outdoor temperature (see Appendix C)

Blower-Off Delay

The delay period between the time the call for heat ends and the air handler blower shuts down also affects electricity use. Longer blower-off delays translate into more electricity use per therm of gas consumed, though less so for the ECM models, as these furnaces typically drop to their lowest airflow during the blower-off delay. All of the furnaces in the study have blower-off delays that are field configurable via DIP switches on the control board.

Figure 24 shows the blower-off delays measured for the furnaces in the study during testing. Most are between 90 and 150 seconds. The very long blower-off delay for Site 17 is symptomatic of a number of configuration issues at this site.

Figure 24: Blower-off delay.




Heating Season Temperature Control

When it comes to maintaining tight control on indoor temperature, the data suggest that nearly all of the furnaces in the study do a good job. This observation comes from analysis of temperature data recorded by sensors placed at the thermostat as part of the study. The analysis focused on the daily period between 7 pm and 9 pm, which was the time the thermostat was most likely to be maintaining a constant setting (changes in indoor temperature at the beginning and end of setback periods could otherwise cloud the analysis). Analysis of the temperature range recorded during this time period shows that at most of the sites the indoor temperature typically varied by less than 1F° (the resolution of the sensors used was about 0.7F°), though a few sites showed a typical swing of 2 F° (Figure 25). These statistics may underestimate the actual swing if the heating cycle period is such that the 15-minute interval at which the temperatures are recorded tends to be at the same point in the heating cycle. Nonetheless, even the maximum recorded temperature swing over the course of monitoring during these hours indicates less than a 3F° variation for most of the sites.

It is notable that there is no clear difference in temperature swing between the ECM and non-ECM furnaces. It is also noteworthy that three of the five sites with heating cycles that typically exceed 20 minutes in length (Sites 3, 8 and 11) are also in the group with wider temperature swings, suggesting that the thermostats for these systems have a wider deadband (although subsequent field checks for Sites 3 and 8 revealed that they were set for a nominal 1F° temperature swing).

Figure 25: Heating season indoor temperature swing.




Cooling Mode

Airflow and Operating Watts

In cooling mode, the air handler operates at a pre-set cooling speed. The near-universal guideline is that the air handler should deliver 400 cfm per ton of air conditioning capacity. In practice, most non-ECM furnaces are simply set to the highest available airflow (only two of the 17 non-ECM furnaces in the study were set otherwise). ECM furnaces on the other hand typically have DIP switches that the installer sets to match the air conditioning tonnage, and provide 400 cfm per ton of airflow.

As Figure 26 shows, most of the furnaces actually delivered airflow somewhere in the range of 350 to 450 cfm per ton of air conditioning capacity when operating at the cooling speed. However, there is a group of mostly non-ECM furnaces with more than 500 cfm per ton of airflow. With the exception of Site 26—which was already set at the lowest possible cooling speed—these are sites with smaller central air conditioning systems for which the high speed setting on the air handler provides too much air flow. Air handler power requirements would be reduced by 20 to 25 percent (roughly 100 to 140 Watts) if the cooling speed setting was set to provide as close to 400 cfm per ton as possible.

Figure 26: Airflow per ton of air conditioning capacity at cooling speed.



Not shown: Sites 6, 7, 13, 17, 28 and 30

Figure 27: Cooling-mode wattage versus airflow.

Cooling-mode Watts

1200 1000 800 Non-ECM furnace Non-ECM furnace 400 200 Airflow (cfm)

Figure 27 shows furnace wattage in cooling mode as a function of airflow. The data suggest that below about 4 tons of air conditioning (1600 cfm) ECM furnaces on average have lower power draw than non-ECM furnaces. Regression fits to the data suggest an average difference of about 175 Watts at 1000 cfm (2.5 tons) and 150 Watts at 1200 cfm (3 tons).

Operating Hours and Cooling-Mode Electricity Savings


Models of daily run-time as a function of outdoor temperature for each site (see Appendix C) show a wide range of predicted seasonal air-handler operating hours in cooling mode (Figure 28). This could be expected given the relatively discretionary nature of air conditioning use in Wisconsin.

However, if 400 hours is taken as a typical value for central air conditioning use, then ECM furnaces could be expected to yield 60 to 70 kWh of direct blower energy savings, based on the regression fits shown in Figure 27. Lower blower wattage also translates into less waste heat in the air stream to be removed by the air conditioning system. This additional electricity savings is estimated at about 20 to 25 kWh, bringing the overall estimate of ECM savings in cooling mode to 80 to 95 kWh per year for 2.5- and 3-ton air conditioning systems, respectively.⁷

⁷ For example, for a 10 SEER system: 60 kWh of direct blower electricity savings * 3,413 Btu per kWh / (10 Btu per watt * 1000 watts per kW) = 20.5 kWh indirect cooling electricity savings.

Figure 28: Annual cooling-mode hours.

Annual Blower Hours in Cooling mode



Not shown: Sites 5, 8, 10, 14, 17 and 28


Continuous-Fan Mode

Continuous-fan mode corresponds to setting the fan switch on most thermostats to "on" (rather than "auto"). People choose to run the air handler continuously for a variety of reasons, but chief among these are filtering out house dust and reducing temperature differences in the home. A minority of participants in the study actually operate their furnace in continuous-fan mode part or all of the year (Table 1), but we tested all of the furnaces in this mode regardless of the actual practice of the homeowner, and were thus able to model continuous-fan electricity use.

Table 1: Continuous-fan use by study participants.

Continuous-fan use	Number of sites 20 Sites		
Never			
All year long	5 Sites (Sites 4, 10, 17, 18, 20)		
Winter only	1 Sites (Sites 30)		
Summer only	2 Sites (Sites 13, 21)		
Ad hoc basis	3 Sites (Sites 8, 9, 14)		

Figure 29: Continuous-fan mode power draw.



*configured for speed other than factory default

There is a clear difference in capability between the ECM and non-ECM furnaces in the study in power draw in continuous-fan mode. All of the ECM furnaces have a separate (and field adjustable) continuous-fan speed setting that is generally factory-set for a very low airflow delivery (typically 500-600 cfm). In contrast, all but two of the non-ECM furnaces in the study ran at the heating speed when called upon for continuous-fan operation.

As could be expected, this means that the ECM furnaces generally draw considerably less power in continuous-fan mode than the non-ECM sites (Figure 29). The ECM furnaces mostly draw less than 200 Watts of continuous-fan power, with 100 Watts as a reasonable average value. In contrast, the non-ECM furnaces drew between 400 and 800 Watts, with 500 being a typical value.

Four ECM furnaces were found to be configured to higher continuous-fan speeds than the factory default. Site 2 is the most interesting example of these. Continuous-fan airflow for the furnace at this site is determined by the settings of three DIP switches immediately to the right of an identical bank of DIP switches that set the cooling airflow. The settings at this site were found to be the same as the cooling airflow settings (Figure 30). This resulted in about twice the continuous-fan airflow than would have been the case at the factory default (1,400 measure cfm, versus 700 cfm) and nearly six times the blower power draw (750 Watts, versus 130 Watts).




Figure 30: Continuous-fan and cooling airflow DIP switches for Site 2.

Whether the contractor who installed the furnace was confused about how to set the DIP switches or simply felt that a furnace should deliver the cooling-mode airflow in continuous-fan mode is not known. However, it can be said that the homeowner was not consulted on this. When told about this, the homeowner—who did not normally use continuous-fan mode—said he had been under the impression that his new furnace was supposed to circulate air more quietly, but found it to be noisy when he tried running it in fan-on mode.


Both of the two modulating furnaces (Sites 28 and 32)—which were installed by the same heating contractor—were also found to be set to higher than default settings for continuous-fan mode. This furnace model has a DIP switch that allows one to choose between two airflow settings. When tested at the lower setting (500 cfm), the Site 28 furnace drew only 93 Watts, compared to 280 Watts at the higher setting (800 cfm).

Hours of Operation and Savings

Continuous-fan mode hours are essentially all hours that the furnace is not operating in heating or cooling modes. The furnace models described in Appendix C predict thousands of hours of continuous-fan operation in this mode (Figure 31). Median run-time hours for the furnaces in the study were 7,400 for year-round operation, 3,500 for winter-only operation, and 2,000 for summer-only operation.

Using rounded median values for operating hours and wattage draws for ECM and non-ECM furnace in this mode, Table 2 shows estimates of electricity savings in continuous-fan mode.

Figure 31: Hours of operation in continuous-fan mode.






Table 2: Continuous-fan electricity use, by furnace type.

Continuous-Fan Mode Electricity Use (kWh)								
Season of Use	Non-ECM Furnace (median 500 Watts)	ECM Furnace (median 100 Watts)	Difference					
Year-Round (median 7,400 hours)	3,700	740	2,960					
Winter Only (median 3,500 hours)	1,750	350	1,400					
Summer Only (median 2,000 hours)	1,000	200	800					

Central Ventilation and Furnace Air Handler Operation

Central ventilation systems such as heat recovery ventilators (HRVs) are sometimes wired with an air handler interlock, meaning that whenever the HRV operates, the furnace air handler also operates at the continuous-fan speed. Ten sites in the study had central ventilation systems, but only four of these were interlocked with the furnace air handler. (Sites 16, 26, 28 and 32—interlocked HRV operation (on a 20-minute on, 40-minute off schedule) can be seen for Site 28 in Figure 10 on page 19.)

Homes with an interlocked central ventilation system will thus have higher furnace electricity use if they do not already practice continuous-fan operation. Estimating this additional electricity use is difficult though, because homeowner use of the systems can vary substantially (Pigg, 2002b).

Standby Power Consumption

All of the furnaces in the study consumed a small amount of power in standby mode. Standby power ranged from 4 to 13 Watts, with a median of 8 Watts (Figure 32). The ECM furnaces dominate the higher end of the distribution, presumably due to large and more complicated control circuitry. On average, the ECM furnaces consumed 4 Watts of standby power above that consumed by the non-ECM furnaces in the study.

Modeling of the furnaces in the study suggests that furnaces not running in continuous-fan mode have an average of about 7,500 hours per year of standby operation (Figure 33). This translates into additional electricity consumption of about 30 kWh per year in this mode for ECM furnaces in the study.

Figure 32: Standby mode power consumption.





Figure 33: Annual hours of standby mode.

Standby hours per year



Modeled for Madison, Wisconsin Assumes no continuous-fan operation

Summary of Electricity Use Results

Table 3 summarizes the preceding results based on typical values from the study. Two scenarios are shown: no continuous-fan use, and year-round continuous-fan operation. Both scenarios assume the presence of central air conditioning.

The results suggest that for the range of systems studied here, substituting an ECM furnace for a non-ECM furnace will save an average of about 465 kWh per year in homes that do not practice continuous-fan use, and about 3,455 kWh per year in homes that run the air handler continuously. At a current average electricity price of about 8 cents per kWh, this translates to \$36 annual electricity savings in the former scenario, and about \$270 annual savings in the latter.

Table 3: Summary of annual electricity use and ECM savings.

Mode of Operation	No continuous-fan use			Year-round continuous-fan use		
	Non-ECM	ECM	Difference	Non-ECM	ECM	Difference
Heating (kWh)	800	400	400	800	400	400
Cooling (kWh) ^b	225	155	70	225	155	70
Continuous-Fan (kWh)	0	0	0	3,700	740	2,960
Standby (kWh)	60	90	-30	0	0	0
Total (kWh)	1,085	645	440	4,725	1,295	3,430
ndirect AC (kWh)°			25			25
Overalf including indirect (kWh)			465			3,455

^aFor annual gas use of 800 therms.

^b For a 2.5-ton air conditioner with airflow of 1000 cfm and 400 hours of operation per year.

^eRepresents additional air conditioning electricity difference from reduced need to remove air handler waste heat.

Geographic Variation

The results presented thus far are based on modeling the operation of the furnaces in the study with Madison, Wisconsin weather data. At about 7,600 heating degree days per year, Madison is close to the population-weighted average heating degree days for the state (7,800 heating degree days; WEB, 2002).

To provide a better sense of how the results vary over the state, Table 4 shows the median percentage difference in selected estimates when the furnaces are modeled with weather data in other parts of the state (Figure 34). While there are substantial differences in the modeled energy use for heating and cooling, heating electricity use per therm is relatively invariant to location. Similarly, modeled continuous-fan and standby hours are not strongly affected by location.

Table 4: Median change in selected modeled values for other locations, relative to Madison, Wisconsin.

	Green Bay	Milwaukee	Lancaster	Eau Claire	Superior	Rhinelande
Heating				.		
Therms	+7.5%	-7.3%	+1.8%	+17.8%	+28.4%	+26.5%
Cycles	+6.9%	-5 .6%	+1.1%	+14.3%	+25.8%	+22.8%
burner hours	+7.8%	-7.9%	+2.0%	+18.9%	+29.2%	+27.8%
kWh	+7.7%	-7.6%	+1.9%	+18.4%	+28.8%	+27.3%
kWh/therm	0.0%	+0.1%	0.0%	-0.2%	-0.1%	-0.2%
Cooling						
Hours	-19.2%	+6.1%	+1.9%	-25.5%	-59.8%	-47.7%
kWh	-18.8%	+5.7%	+2.0%	-24.9%	-59.6%	-47.2%
Contfan hours	-0.4%	+0.7%	-0.3%	-1.3%	-1.7%	-1.9%
Standby hours	-0.4%	+0.8%	-0.3%	-1.5%	-2.0%	-2.1%




Figure 34: Location of weather stations used for modeling.

Filter Static Pressure Drop


As previously noted, the data from the study show higher electricity use with higher external static pressure for ECM furnaces. Moreover, the field measurements indicate that on average, about half of the total static pressure seen by the system is due to the pressure drop across the filter. This suggests that if filter static pressure can be reduced, the electricity use by ECM furnaces can be further reduced as well, since these furnaces compensate for high static pressure by increasing their speed and power.

Figure 35 shows the range of measured filter pressure drop normalized to two airflow levels that roughly correspond to low- and high-fire (and cooling) operation for a typical 80,000 Btu/hr furnace. There are five sites with noticeably higher pressure drops, but these do not appear to share common characteristics. Two of the sites use conventional ½ inch or 1 inch furnace filters, one (Site 28) uses a pleated media filter, one (Site 26) uses a washable filter, and one (Site 5) uses an electrostatic filter with a wire mesh pre-filter that was found to be extremely loaded.

If 0.05 IWC and 0.1 IWC are taken as the lowest easily achievable static pressure drop at these two airflows, then pressure drop across the median filter in the study could be reduced by about 0.05 IWC and 0.2 IWC, at 600 and 1200 cfm, respectively. Based on published performance data for one ECM furnace line, this could be expected to reduce air handler power requirements by about 10 Watts at the lower airflow rate, and by about 70 Watts at the higher rate for an ECM furnace, corresponding to perhaps a 10 percent reduction in total power requirements at both airflows.

Figure 35. Filter static pressure drop.

Filter static pressure drop (inches water column)



The above figures relate to the *median* furnace in the study. For a furnace with a high static pressure drop, such as Site 5, the savings from reducing the filter resistance (in this case by simply cleaning the mesh pre-filter) would be considerably higher. Based on the measurement data for Site 5 and the published performance data for the furnace, it appears that air handler power could be reduced by 40 to 60 percent by reducing the filter static pressure drop to a level comparable to the filters on the low end of the distribution.

Impact of ECM Furnaces on Gas Consumption

In theory, reducing blower electricity use will result in an increase in gas consumption during the heating season, because ECM furnaces have less waste blower heat, which would ordinarily somewhat offset the need for additional gas heat from the furnace. At least one field study (Gusdorf et al., 2003) has demonstrated as much when the furnace fan operates continuously throughout the heating season.

Gas consumption was not monitored for this study, so it is not possible to bring direct empirical data to bear on this question. The estimated typical 400 kWh electricity savings from ECMs in heating mode would translate into perhaps 15 therms of additional gas consumption at a typical gas efficiency for a condensing furnace. With continuous fan operation during the winter, this might rise to 65 therms.

However, the above figures assume that ECM and non-ECM furnaces have the same gas heating efficiency, which does not appear to be the case typically. The published heating efficiency (AFUE) for the 14 ECM furnaces in the study ranged from 92.5% to 95.0%, with a median of 94.1%. The 17 non-ECM furnaces had AFUE's that ranged from 92.0% to 92.5%, with a median of 92.2%. The difference between the median AFUE's for the two groups translates into about 16 therms less gas consumption for an ECM furnace with an annual heating load of 750 therms—enough to offset the calculated increase in gas consumption due to less waste electrical heat from an ECM furnace operating in heating mode. It is likely that a furnace operating in continuous-fan mode would still have a net increase in gas use, but the dollar savings to the consumer from reduced electricity use still overshadow any additional gas charges.

A Note on Power Factor

Although not a particular concern to consumers, power factor is of interest to utilities, which must size distribution systems to handle reactive as well as active power. Power factor measurements on the furnaces in the study showed that the ECM furnaces had somewhat lower power factors compared to non-ECM furnaces, except in standby mode. A more detailed compilation of power factor data can be found in Appendix B.

Table 5: Median measured power factor, by operating mode.

Operating Mode	ECM Furnaces	Non-ECM Furnaces
Heating	0.72 (low-fire) 0.68 (high-fire)	0.88
Cooling	0.63	0.81
Continuous Fan	0.69	0.87
Standby	0.62	0.40

Discussion

Results from this study are relevant from a variety of perspectives. The discussion that follows is organized around the following points of view:

- Wisconsin Focus on Energy program efforts
- National energy efficiency standards and program efforts
- Consumers
- Furnace contractors and distributors

Implications for Wisconsin Focus on Energy Program Efforts

First and foremost, the results from the study provide basic confirmation that multi-stage ECM furnaces do provide substantial electricity savings over conventional condensing furnaces. The savings are most dramatic in continuous-fan and heating modes, but are also apparent in cooling mode. Based on the small (and not necessarily representative) sample of homes covered by this study, the savings for a home in Madison, Wisconsin with typical gas consumption and air conditioning use appears to be about 450 kWh per year without continuous-fan operation, and more than 3,000 kWh per year with year-round continuous fan use. Peak demand savings are more difficult to discern from this study, but the results suggest that there are summer peak savings. Winter peak electricity demand is the most difficult to assess; many of the two-stage ECM furnaces will be operating in high-fire on a cold winter morning, and the data were most variable in this mode.

The above figures are meant to reflect the study results in a typical Wisconsin home. These may not be applicable to the population of participants in Focus programs that promote ECM furnaces if, for example, these participants use more or less gas, or have furnaces that are sized differently for their heating load.

Probably a larger source of uncertainty in estimates of savings due to program efforts to promote ECMs, however, lies on the behavioral side, which this study did not address. In particular, the average savings from a population of ECM furnaces is sensitive to the proportion of households that operate the furnace in continuous fan mode. Since the difference in savings between homes without continuous-fan use and those with year-round operation is so large, the average savings from blending these two is very sensitive to assumptions about the proportion of homes with continuous-fan use. If one assumes that 10 percent of homes practice year-round continuous-fan operation, then the overall average savings would be about 700 kWh per year (with half of the savings arising from homes with continuous-fan operation). Change this proportion to 20 percent, however, and the figure becomes 1,000 kWh per year, and continuous-fan homes represent two-thirds of the total.

In reality, the situation is more complicated than portrayed above. As the actual practices of the homeowners in this study demonstrate, some people practice year-round continuous-fan operation, but others do so only seasonally—or even on an ad hoc basis. Furthermore, some homeowners in new developments may practice continuous-fan operation temporarily to deal with ambient construction dust. Finally, other literature has alluded to a possible "takeback" effect; some people may purchase an ECM furnace precisely in order to operate their air handler continuously—in the absence of such a choice, they would not do so. All of these factors play into the average

impacts from programs to promote ECM furnaces; unfortunately, these were mostly outside the scope of this technical look at these furnaces. Additional research is needed to quantify these practices in the Wisconsin population. Such research could be undertaken in conjunction with the biennial Appliance Sales Tracking telephone survey conducted by the Energy Center of Wisconsin.

The study also provides insights for efforts to affect how furnaces are installed and configured, such as the Wisconsin Efficient Heating and Cooling Initiative. Although these are discussed in more detail below under "Contractors and Distributors," it is worth noting here that the study offers evidence that high static pressure reduces the savings from ECMs, since these furnaces compensate by increasing the blower power input. This suggests that efforts to influence furnace filter selection and maintenance as well as duct design (for new construction) in order to minimize the static pressure experienced by an ECM furnace could bear fruit in additional electricity savings. This suggests a need to better understand the pressure drop characteristics of different types and brands of furnace filters, as well as how static pressure changes over time as the filters become loaded.

Further, the study suggests a need to promote the practice of always setting continuous-fan speed to the lowest possible option. Doing so requires no testing or equipment, and in most cases involves no action on the part of the installer, since most furnaces are already configured in this way. However, that four out of fourteen ECM furnaces in the study were configured for higher continuous-fan operation suggests that some contractors wrongly believe that more is better when it comes to continuous-fan airflow. Also, installers failed to take advantage of a separate low-speed tap for continuous-fan operation for some models of non-ECM furnaces.

Implications for National Energy Efficiency Standards and Program Efforts

This study provides some insights of national relevance. First, this study confirms previous research demonstrating that in actual practice static pressures are considerably higher than those stipulated in standard rating procedures. The furnaces in this study averaged 0.44 IWC of static pressure drop across the furnace and evaporator coil at high fire, which is more than twice the 0.2 inches generally used in the standard test procedure for rating furnace efficiency (which does not include pressure drop across the AC coil). In cooling mode, the study furnaces averaged an even higher 0.50 inches of static pressure drop. This difference is the most likely explanation for the finding that actual furnace electricity use in heating mode for ECM furnaces is on average higher than rating data would suggest.

Second, the study suggests that 0.6 kWh of heating electricity use per therm of gas consumption (or 6 kWh per million BTU of gas input) represents a useful demarcation line between electrically efficient furnaces (i.e., ECM model) and less electrically efficient models. This dividing point neatly separates the ECM and non-ECM furnaces in the study both in terms of their rating based electricity use per therm of gas consumption and in terms of the field results

Third, the study indicates there would be some value in incorporating standby electricity use in national standards and program efforts. At a current 8 to 14 Watts, standby electricity use by furnaces exceeds that of many consumer electronic appliances, which typically have digital clocks and must sense inputs from infrared remotes. There is undoubtedly room for reduction in furnace standby electricity use with better control board design.

Finally, the study suggests that some fairly simple changes at the manufacturing level could have energy savings benefits even for non-ECM furnaces. For example, four non-ECM furnaces in the study had a separate speed tap lug for continuous-fan operation. This allows the air handler to run at the lowest speed setting in this mode independently of the speed selection for heating and cooling modes. Based on our test data, this could be expected to reduce continuous-fan electricity use by about 8 percent. However, none of the four study furnaces were field configured to make use of this feature, and the one heating contractor we spoke with who installs these furnaces stated he did not really understand its function. If the manufacturer were to simply plug the low speed tap wire into this lug at the factory, electricity use could be reduced by perhaps one percent on average across the units shipped by this manufacturer.

Implications for Consumers

This study clearly demonstrates that an ECM furnace is a "no brainer" for people who intend to operate their air handler continuously. With electricity savings on the order of \$275 or more per year, the additional cost of these furnaces can be recovered within a few short years.⁸ The extra cost of these furnaces is more difficult to justify solely on the basis of electricity savings for consumers who do not practice continuous-fan operation, but—with annual electricity savings of perhaps \$30 to \$40—the electricity savings are still worth considering.

Moreover, as a premium product, multi-stage ECM furnaces appear to offer comfort and noise advantages that may outweigh the electricity savings in the minds of many consumers. Though sound levels were not formally evaluated by this study, the ECM furnaces in the study were noticeably quieter in low-fire heating mode, which—as the study demonstrates—is the operating mode the majority of the time during the heating season.

Comfort was also not formally evaluated as a part of this study, but the data do document much lower airflow in low-fire heating mode for ECM furnaces, which could reasonably be expected to translate into fewer drafts from air handler operation. Though many ECM furnaces (indeed many new furnaces in general) are marketed as providing tighter control on temperature swings, the study did not reveal any clear difference in indoor temperature variation between ECM and non-ECM furnaces—though there are some limitations in our ability to measure such differences. The tightness with which indoor temperature is maintained is probably as much (or more) a function of the thermostat and its configuration as it is the type and model of furnace. Nonetheless, nearly all of the furnaces in the study showed a good ability to reduce temperature swings.

Implications for Heating Contractors and Furnace Distributors

Several field configuration lessons emerge from the data gathered for this study. First, the fact that some contractors are field configuring furnaces to operate at higher continuous-fan speeds than the factory default is troubling. Continuous-fan operation does not need high airflow; indeed higher airflow rates are more likely to create uncomfortable drafts in the home. And, from an energy efficiency perspective, higher airflow in continuous-fan mode wastes electricity. Even if the purchaser of a furnace does not intend to use continuous-fan operation, future occupants might do so, and it is unlikely that the initial configuration would be revisited. For all of these reasons, the

⁸ Anecdotal reports put the cost increment for a typical two-stage ECM furnace over a conventional condensing furnace at \$400 to \$600.

general rule should be to use the lowest possible speed setting for continuous-fan mode, as most ECM furnaces are factory configured to do.

It is not possible to know from this study why the furnaces in the study were set up for higher airflow in this mode, nor is it possible to measure the prevalence of the practice. Two of the four such ECM furnaces were installed by the same heating contractor, one may have been a case of misunderstanding of DIP switch settings, and in one case, the high continuous-fan airflow setting was part of a larger array of configuration issues with a complicated zoning control system. Nonetheless the incidence is high enough to suggest the need for contractor training and education in this regard.

Second, installers should be cognizant of the relationships between furnace sizing, temperature swing, and staging control for two-stage furnaces. Long heating cycle lengths due to undersizing or other factors may interfere with staging control algorithms and result in excessive high-fire operation and undesirable variation in indoor temperature.

Third, when it comes to the perennial issue of furnace sizing, the study indicates that although most are considerably oversized in terms of meeting design heating loads—even under conservative assumptions for design conditions—the study does lend credence to the argument that some over-sizing is needed for setback recovery. The majority of homeowners in the study practiced thermostat setbacks during the heating season—as do the majority of Wisconsin homeowners in general—and recovery periods even under average winter conditions were fairly long for some of the homes. In this vein, the multi-stage ECM furnaces appear to offer the best of both worlds: reduced cycling, airflow and electricity use to meet the basic heating load of the home, combined with the ability to produce higher output to boost the indoor temperature after a setback.

Limitations

As with any effort, there are limitations to this study. The more important of these are enumerated below:

- 1. Sample size. As with any detailed field study, budget constraints prevented studying a larger sample of homes. With small samples the probability increases of obtaining a sample that—purely by chance—deviates substantially from the population from which it was drawn. This so-called sampling uncertainty can be quantified. For example, the 90 percent confidence interval for the average difference between ECM and non-ECM furnaces in heating mode electricity use per therm of gas for the study sample is ± 0.1 kWh/therm. With the study finding that ECM furnaces use about 0.5 kWh/therm less than non-ECM furnaces, one can be 90 percent confident from a sampling error standpoint that the average difference in the population is somewhere between 0.4 and 0.6 kWh/therm. However, non-random sampling errors probably dominate in this case (see next item); hence the report eschews reporting confidence intervals like the one above.
- 2. Sample representativeness. There are a number of ways in which the study sample might differ from the population at large in ways that would not be mitigated by a larger sample. Most notably, a variety of furnaces were deliberately selected for study; the market share for particular brands may therefore be under- over over-represented. Also, the study is dominated by new homes, many of which participated in the Wisconsin Energy Star Homes program—though about half the Wisconsin furnace market is thought to be made up of replacement furnaces for older homes. Finally, homeowners willing to participate in the study might be different than those who are not willing to participate—for example, they might be more inclined to operate in continuous-fan mode.
- 3. Modeling uncertainty. The study relies on models of heating and cooling energy use as a function of outdoor temperature to translate variable weather conditions over part of a season to long-term seasonal averages. There is uncertainty in this process, arising in the choice of the models used, in the fitting process for the model coefficients, and in the application of long-term averages in the context of climate change. In terms of the functional form of the models, the data suggest that, for most of the sites in the study, the majority of the variation in heating and cooling-mode hours and cycles is explained by outdoor temperature. However, other factors such as humidity during the cooling season that were not included in the models might change the estimates somewhat. Finally, there is also uncertainty in average values such as power draw measured during testing. These values can change over time, for example as filters load. Comparison of results across the two rounds of testing suggests that most values were stable to within about 10 percent.

	:
	•
	•

References

ASHRAE. 1993. "Method of Testing for Annual Fuel Utilization Efficiency of Residential Central Furnaces and Boilers," ANSI/ASHRAE Standard 103-1993. American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc, Atlanta, Georgia.

Byrne, Jeanne. 2000. "Motors Matter," Home Energy Magazine, July/August 2000.

Gusdorf, J, M Swinton, E Entchev, C Simpson, and B Castellan. 2003. "The Impact of ECM furnace motors on natural gas use and overall energy use during the heating season of CCHT research facility." Institute for Research in Construction, NRCC-38443, www.nrc.ca/irc/ircpubs, January, 2003.

Palmiter, Larry and Paul Francisco, "A New Device for Field Measurement of Air Handler Flows," Proceedings of the 2000 American Council for an Energy Efficient Economy (ACEE) Summer Study on Energy Efficiency in Buildings, ACEEE, Washington, D.C.

Phillips, Bert. 1998. "Impact of Blower Performance on Residential Forced-Air Heating System Performance." ASHRAE Transactions, V. 104, Pt.1, American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc, Atlanta, Georgia.

Pigg, Scott and Monica Nevius. 2000. Energy and Housing in Wisconsin: A Study of Single-Family Owner-Occupied Homes. Energy Center of Wisconsin Research Report 199-1. Energy Center of Wisconsin, Madison, Wisconsin.

Pigg, Scott. 2002a. "Energy Savings from the Wisconsin Energy Star Homes Program," Energy Center of Wisconsin Research Report 211-1, Energy Center of Wisconsin, Madison, Wisconsin.

Pigg, Scott. 2002b. "Field Study of Ventilation in New Wisconsin Homes," Energy Center of Wisconsin Research Report 216-1, Energy Center of Wisconsin, Madison, Wisconsin.

Proctor, John, and Danny Parker. 2000. "Hidden Power Drains: Residential Heating and Cooling Fan Power Demand," Proceedings of the 2000 American Council for an Energy Efficient Economy (ACEEE) Summer Study on Energy Efficiency in Buildings, ACEEE, Washington, D.C.

Sachs, Harvey, Toru Kubo, Sandy Smith and Kalon Scott. 2002. "Residential HVAC Fans and Motors are Bigger than Refrigerators," Proceedings of the 2002 American Council for an Energy Efficient Economy (ACEEE) Summer Study on Energy Efficiency in Buildings, ACEEE, Washington, D.C.

Wisconsin Energy Bureau (WEB). 2002. Preliminary Wisconsin Energy Statistics — 2002. Wisconsin Department of Administration, Madison, Wisconsin (www.doa.state.wi.us).