

FILE

**Ohio Power Siting Board**

**Staff Investigation Report and Recommendation**

**Case No.:** 10-1452-EL-BNR

**Project:** Pleasant Valley – West Akron 138 Transmission Line  
Loop to Cleveland Clinic Data Center

**Applicants:** American Transmission Systems, Incorporated  
Cleveland Electric Illuminating Company

**Report Date:** 6 January 2011

**Automatic Approval Date:** 15 January 2011 (Construction Notice process)

**Waiver Request:** None

**Inspection Date(s):** 18 October 2010

**Staff Assigned:** J. O'Dell

**Summary of Staff Recommendations (see report text for discussion):**

Application: ☒ Approval    ☐ Disapproval    ☐ Approval with Conditions  
Waiver:        ☐ Approval    ☐ Disapproval    ☒ Not Applicable

**Summary of Staff Recommended Conditions (see report text for discussion):**

- None

**Projected Docket Closure Date (if automatically approved):** 31 May 2013

**Investigation Report**

**Project Description:** This project involves the installation of approximately 530 feet of 138 kV transmission line and three wood pole structures. The line is needed to provide electrical service to a new distribution substation for the Cleveland Clinic Data Center.

**Site Description:** No appreciable vegetative clearing is required. This project is located in the City of Brecksville, Cuyahoga County.

**Discussion/Comments/Concerns:** The construction of this project should pose only minimal negative social and ecological impacts.

This is to certify that the images appearing are an accurate and complete reproduction of a case file document delivered in the regular course of business.  
Technician \_\_\_\_\_ Date Processed \_\_\_\_\_

RECEIVED-DOCKETING DIV  
2011 JAN -6 AM 11:43  
PUCO