

LARGE FILING SEPERATOR SHEET

CASE NUMBER: 10-2586-EL-SSO

FILE DATE: JAN 19 2011

SECTION:

NUMBER OF PAGES: 200

DESCRIPTION OF DOCUMENT:

- exhibit part 1 :

This is to certify that the images appearing are an accurate and complete reproduction of a case file document delivered in the regular course of business.
Technician SHB Date Processed 1/19/11

FILE

PUCO EXHIBIT FILING

Date of Hearing: 1/13/2011

Case No. 10-2586-EL-SSO

PUCO Case Caption: Duke Energy - Ohio

Volume III

List of exhibits being filed:

Company Ex. 13

IEU - Ohio Ex. 8A, 9A, 10A and 11

FES Ex. 4

This is to certify that the images appearing are an
accurate and complete reproduction of a case file
document delivered in the regular course of business.
Technician SKB Date Processed 1/19/11

Reporter's Signature: Mary DePaolo Jones
Date Submitted: 1/19/2011

PUCO

2011 JAN 19 PM 12:10

RECEIVED-DOCKETING DIV

Duke Energy Ohio
Case No. 10-2586-EL-SSO
FES Third Set Interrogatories
Date Received: December 15, 2010

FES-INT-03-022

REQUEST:

State the total number of customers to whom You currently provide distribution service.

RESPONSE:

The Company provides distribution service to 683,236 customers as of October 2010.

PERSON RESPONSIBLE: James E. Ziolkowski

**Duke Energy Ohio
Case No. 10-2586-EL-SSO
FES Third Set Interrogatories
Date Received: December 15, 2010**

FES-INT-03-023

REQUEST:

Of the number You identify in response to Interrogatory No. 22, state the number of customers who are :

- a) residential customers;
- b) commercial customers; and
- c) industrial customers.

RESPONSE:

- a) residential customers: 606,940
- b) commercial customers: 67,532
- c) industrial customers: 2,262

PERSON RESPONSIBLE: James E. Ziolkowski

Duke Energy Ohio
Case No. 10-2586-EL-SSO
FES Third Set Interrogatories
Date Received: December 15, 2010

FES-INT-03-024

REQUEST:

Of the number You identify in response to Interrogatory No. 22, state the number of customers who are served under each of Your rate classifications and/or tariffs.

RESPONSE:

Sum of CUSTOMERS	CUSTOMER CLASS						
RATE	Commercial	Industrial	OPA	Residential	Street Lighting		Grand Total
DM	277	0	0	0	14	0	291
DP	35,641	723	2,017	0	0	13	38,394
DS	139	101	49	0	0	0	289
EH	16,451	1,399	1,330	0	0	0	19,180
GS	710	11	155	0	0	0	876
HS	277	2	61	0	0	11	351
OL	0	0	0	0	0	6	6
OR	0	0	0	0	0	0	0
OR	0	0	0	0	198	0	198
RS	13,512	0	19	606,705	0	0	620,236
SC	5	0	0	0	0	48	53
SE	60	0	0	0	0	306	366
SF	5	0	0	0	0	0	5
SL	387	0	0	0	0	1,833	2,220
SO	0	0	0	0	0	0	0
SS	0	0	0	0	0	0	0
SX	0	0	0	0	0	23	23
TD	0	0	0	0	23	0	23
TL	6	0	7	0	0	251	264
TS	4	26	4	0	0	0	34
UO	58	0	0	0	0	367	425
WS	0	0	2	0	0	0	2
Grand Total	67,532	2,262	3,644	606,940	2,858	0	663,236

Note:

GS is Rate GS-FL. SF is Rate SFL-ADPL. OR is Rate ORH. SO, SS, SX, and UO are all Rate UOLS (one of the lighting rates). WS is water pumping special contract. All other rates match the title of the tariff sheet.

PERSON RESPONSIBLE: James E. Ziolkowski

**Duke Energy Ohio
Case No. 10-2586-EL-SSO
FES Third Set Interrogatories
Date Received: December 15, 2010**

FES-INT-03-025

REQUEST:

State the current average annual and monthly kilowatt hour ("kWh") usage for each of the customer classes referenced in Interrogatory No. 23 and 24.

RESPONSE:

Attachment FES-INT-03-025 shows the kWh, number of customers, and calculated kWh per customer by month, rate, and customer class for each month of November 2009 through October 2010.

PERSON RESPONSIBLE: James E. Ziolkowski

COMPANY	1
SERV	E
STATUS	(A)

CUSTOMER C/PART	DATE	MONTH												Grand Total
		Nov-09	Dec-09	Jan-10	Feb-10	Mar-10	Apr-10	May-10	Jun-10	Jul-10	Aug-10	Sep-10	Oct-10	
COMMERCIAL	Sum of CUSTOMERS	327	210	283	308	371	520	440	471	440	294	211	277	3,920
	Sum of USAGE	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of USAGE	36,240	36,628	36,391	34,519	36,001	35,817	35,396	36,957	35,508	35,858	35,900	36,841	427,208
	Sum of KWH/CUSTOMER	34,101,417	40,773,406	47,992,211	42,254,423	40,542,406	36,489,170	34,992,312	45,298,377	60,609,686	62,009,569	47,362,810	38,360,691	508,906,907
	Sum of USAGE	988	1,147	1,338	1,224	1,128	1,119	977	1,259	1,412	1,459	1,319	1,077	11,931
	Sum of KWH/CUSTOMER	141	141	139	122	142	137	137	141	137	138	137	139	1,602
	Sum of USAGE	71,864,869	74,862,266	78,819,502	68,749,862	81,906,284	71,986,000	66,987,124	106,887,962	97,897,111	98,185,848	90,383,489	77,178,448	973,280,577
	Sum of KWH/CUSTOMER	593,629	593,629	551,219	429,522	570,619	539,825	485,414	787,829	714,877	711,482	659,754	583,241	6,565,500
	Sum of USAGE	13,922	16,815	18,686	16,148	18,862	16,612	16,612	18,859	16,800	16,700	16,773	16,481	200,308
	Sum of KWH/CUSTOMER	342,677,449	385,487,184	409,038,916	300,409,738	387,526,171	358,704,935	395,864,377	433,998,977	481,289,222	468,119,126	434,933,124	370,029,940	4,747,176,756
	Sum of USAGE	20,245	22,924	24,396	22,334	21,809	21,519	21,563	25,882	27,378	27,719	26,050	22,483	23,897
	Sum of KWH/CUSTOMER	708	711	699	668	720	714	712	712	712	714	712	710	6,650
	Sum of USAGE	3,091,272	5,349,437	7,848,591	7,143,797	6,878,332	3,219,266	2,699,434	32,113	15,479	6,833	21,340	2,594,928	37,736,887
	Sum of KWH/CUSTOMER	4,385	7,524	11,228	10,383	8,154	4,508	3,605	2,878	3,870	829	5,335	3,058	6,632
	Sum of USAGE	2,482,821	2,490,724	2,482,076	2,461,448	2,462,283	2,461,307	2,461,805	2,461,192	2,462,192	2,462,752	2,462,752	2,462,752	26,542,878
	Sum of KWH/CUSTOMER	8,726	8,752	8,782	8,751	8,885	8,857	8,856	8,856	8,826	8,826	8,881	8,891	8,824
	Sum of USAGE	68,109	69,650	68,245	66,551	75,929	70,188	70,099	70,337	69,842	69,208	69,572	69,969	630,500
	Sum of KWH/CUSTOMER	0	0	0	0	0	0	0	0	0	0	0	0	0
INDUSTRIAL	Sum of CUSTOMERS	1,228,233	1,235,540	1,228,405	1,181,301	1,231,823	1,224,069	1,204,524	1,234,271	1,212,057	1,209,828	1,208,624	1,202,894	14,857,978
	Sum of USAGE	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	13,305	13,510	13,300	12,825	13,659	13,331	13,337	13,463	13,470	13,552	13,550	13,573	180,422
	Sum of USAGE	6,877,994	8,104,678	10,078,418	8,822,801	8,767,747	7,327,399	6,114,549	7,189,864	7,093,304	8,043,304	6,788,184	6,253,500	91,189,462
	Sum of KWH/CUSTOMER	524	574	753	672	648	542	489	532	524	512	501	459	5,627
	Sum of USAGE	1,379	1,379	1,379	1,379	1,379	1,379	1,379	1,379	1,379	1,379	1,379	1,379	16,548
	Sum of KWH/CUSTOMER	228	278	278	278	278	278	278	278	278	278	278	278	3,348
	Sum of USAGE	40,084	39,688	40,410	40,084	40,084	37,204	39,890	38,890	38,890	38,890	38,890	38,890	470,905
	Sum of KWH/CUSTOMER	988	981	974	958	988	920	946	948	948	948	948	948	9,664
	Sum of USAGE	44,867	44,810	44,606	44,493	43,753	42,942	41,109	42,759	44,684	44,400	44,500	44,616	526,742
	Sum of KWH/CUSTOMER	11,164	11,153	11,153	11,123	10,933	10,861	10,276	9,652	9,939	9,850	9,906	9,903	9,938
	Sum of USAGE	136,414	136,414	141,011	136,872	140,796	134,903	136,503	136,503	136,503	136,503	136,503	136,503	1,846,027
	Sum of KWH/CUSTOMER	362	363	365	359	364	353	353	353	353	353	353	353	3,565
	Sum of USAGE	916	764	611	916	916	590	754	754	754	754	754	754	9,727
	Sum of KWH/CUSTOMER	4,844	4,844	4,844	4,844	4,844	4,844	4,844	4,844	4,844	4,844	4,844	4,844	58,128
	Sum of USAGE	807	807	807	807	807	807	807	807	807	807	807	807	8,007
	Sum of KWH/CUSTOMER	3,616,017	4,156,917	2,518,799	2,121,006	14,166,910	14,928,494	16,665,098	18,985,009	18,933,481	18,328,357	16,382,765	16,473,606	143,280,296
	Sum of KWH/CUSTOMER	904,504	1,039,220	928,099	707,022	3,541,833	3,732,124	4,164,000	4,248,752	4,233,395	4,088,089	4,088,191	4,618,402	3,046,697
	Sum of USAGE	50,958	54,363	54,244	54,543	57,384	59,770	57,993	57,844	58,086	59,048	58,833	63,143	687,817
	Sum of KWH/CUSTOMER	810	971	969	982	1,043	1,057	1,036	1,033	1,052	1,054	1,032	1,089	1,021
	Sum of USAGE	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	709	715	709	709	726	726	722	724	726	722	726	723	8,837
	Sum of USAGE	879,296	948,919	1,126,804	1,087,791	998,852	760,461	798,048	900,360	998,929	1,030,166	981,350	774,640	10,626,807
	Sum of KWH/CUSTOMER	868	1,327	1,582	1,519	1,317	1,048	922	1,256	1,362	1,439	1,321	1,071	1,285
	Sum of USAGE	73,033,339	73,175,220	77,738,820	80,844,725	85,780,813	73,030,006	77,681,181	82,871,557	85,832,866	86,312,885	83,840,662	78,624,784	938,717,534
	Sum of KWH/CUSTOMER	882,274	893,881	739,368	621,906	609,253	600,962	731,996	799,919	833,918	827,989	822,942	783,678	7,547,678
	Sum of USAGE	1,422	1,422	1,398	1,427	1,427	1,416	1,406	1,407	1,407	1,400	1,397	1,398	16,800
	Sum of KWH/CUSTOMER	98,313,174	100,338,463	97,010,974	95,483,302	97,954,020	99,258,620	98,639,850	108,966,677	114,331,917	116,136,175	111,832,175	102,554,336	1,239,321,663
	Sum of USAGE	87,860	70,364	68,343	69,442	68,223	70,096	70,342	78,170	81,282	82,957	80,052	73,305	73,305

COMPANY	1
SERV	E
STATUS	(A4)

CUSTOMER CREDIT	DATE	MONTH												Grand Total
		Nov-09	Dec-09	Jan-10	Feb-10	Mar-10	Apr-10	May-10	Jun-10	Jul-10	Aug-10	Sep-10	Oct-10	
EH	Sum of CUSTOMERS	11	11	11	11	11	11	11	11	11	11	11	11	86
	Sum of USAGE	-8,613	13,087	60,437	27,271	77,081	4,028	1,928					2,646	179,043
	Sum of KWH/CUSTOMER	-763	1,244	5,484	2,478	7,088	367	176					241	2,035
	Sum of CUSTOMERS	2	2	2	2	2	2	2	2	2	2	2	2	24
	Sum of USAGE	617	617	617	617	617	617	617	617	617	617	617	617	7,404
	Sum of KWH/CUSTOMER	309	309	309	309	309	309	309	309	309	309	309	309	3,838
	Sum of CUSTOMERS	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of USAGE	5,204	5,344	5,304	4,842	5,788	5,304	5,284	5,344	5,304	5,304	5,304	5,304	53,848
	Sum of KWH/CUSTOMER	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of CUSTOMERS	180,631	182,782	182,082	145,261	180,274	182,868	154,073	185,312	154,245	155,082	154,713	154,951	1,842,145
NS	Sum of USAGE	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of CUSTOMERS	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of USAGE	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of CUSTOMERS	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of USAGE	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of CUSTOMERS	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of USAGE	0	0	0	0	0	0	0	0	0	0	0	0	0
TS	Sum of KWH/CUSTOMER	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of CUSTOMERS	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of USAGE	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of CUSTOMERS	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of USAGE	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of CUSTOMERS	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of USAGE	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	0	0	0	0	0	0	0	0	0	0	0	0	0
UO	Sum of CUSTOMERS	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of USAGE	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of CUSTOMERS	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of USAGE	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of CUSTOMERS	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of USAGE	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of CUSTOMERS	0	0	0	0	0	0	0	0	0	0	0	0	0
DM	Sum of KWH/CUSTOMER	2,019	2,022	2,015	1,988	2,048	2,036	2,022	2,059	2,065	2,047	2,048	2,017	24,357
	Sum of CUSTOMERS	2,138,180	2,061,246	2,098,721	2,718,152	2,482,909	2,095,783	1,985,994	2,238,631	2,805,035	2,617,822	2,418,546	2,069,246	29,134,254
	Sum of USAGE	1,058	1,311	1,523	1,398	1,312	1,323	953	1,136	1,288	1,278	1,181	1,026	11,851
	Sum of KWH/CUSTOMER	52	52	52	44	55	49	49	49	49	49	49	49	599
	Sum of CUSTOMERS	38,976,509	31,942,722	34,058,302	27,881,058	31,209,718	28,607,315	26,892,838	52,515,575	50,845,738	43,484,395	43,080,007	36,702,527	448,885,262
	Sum of USAGE	788,779	614,283	655,756	628,850	557,318	583,823	590,875	1,071,787	1,033,270	887,059	878,184	749,133	748,958
	Sum of KWH/CUSTOMER	1,355	1,345	1,347	1,337	1,349	1,337	1,337	1,439	1,441	1,448	1,439	1,330	18,181
	Sum of CUSTOMERS	48,705,845	51,204,205	53,840,707	48,347,770	51,583,841	50,016,977	51,019,281	83,230,022	81,728,355	63,825,118	65,488,581	52,764,055	683,343,408
	Sum of USAGE	35,945	38,159	38,971	38,048	38,077	37,078	38,180	43,884	42,837	41,139	45,958	39,672	40,225
	Sum of KWH/CUSTOMER	4,830,186	5,848,683	5,858,951	5,231,803	7,254,258	4,846,846	4,688,868	4,510	4,590	4,878	4,500,739	4,804,287	48,804,287
GS	Sum of KWH/CUSTOMER	30,387	40,785	54,681	52,431	45,055	29,919	28,607	2,258				29,037	36,758
	Sum of CUSTOMERS	80	60	61	61	61	61	61	61	61	61	61	61	750
	Sum of USAGE	20,300	20,300	20,300	20,300	20,300	20,300	20,300	20,304	20,304	20,304	20,304	20,304	243,688
	Sum of KWH/CUSTOMER	338	338	338	338	338	338	338	338	338	338	338	338	304
	Sum of CUSTOMERS	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of USAGE	3,866	3,866	3,866	3,778	3,998	3,866	3,866	3,866	3,866	3,866	3,866	3,866	46,271
	Sum of KWH/CUSTOMER	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of CUSTOMERS	116,201	116,117	116,215	112,127	119,882	116,458	115,883	115,798	115,480	115,425	115,454	115,009	1,388,973
	Sum of USAGE	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	20	20	20	20	20	20	20	20	20	20	20	20	238
RS	Sum of CUSTOMERS	11,849	18,779	22,075	19,848	19,775	12,447	16,318	15,584	16,477	16,123	11,768	9,577	183,480
	Sum of USAGE	577	789	1,104	992	769	522	818	828	774	806	619	504	771
	Sum of KWH/CUSTOMER	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of CUSTOMERS	457	457	457	457	457	457	457	421	413	413	413	413	5,272
	Sum of USAGE	57	57	57	57	57	57	57	59	59	59	59	59	58
	Sum of KWH/CUSTOMER	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of CUSTOMERS	15,541,082	15,528,950	14,808,484	14,787,284	17,018,602	17,021,358	16,230,243	19,588,472	18,832,483	20,478,509	18,828,509	18,778,838	204,888,283
	Sum of USAGE	3,865,271	3,877,213	3,701,818	3,681,821	4,404,681	3,604,271	3,907,368	4,897,368	4,658,118	5,119,023	4,731,627	4,104,980	4,181,597
	Sum of KWH/CUSTOMER	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of CUSTOMERS	4,280	4,280	4,280	4,280	4,280	4,280	4,280	4,280	4,280	4,280	4,280	4,280	51,480
UO	Sum of KWH/CUSTOMER	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of CUSTOMERS	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of USAGE	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of CUSTOMERS	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of USAGE	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of CUSTOMERS	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of USAGE	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	0	0	0	0	0	0	0	0	0	0	0	0	0
WIS	Sum of CUSTOMERS	2	2	2	2	2	2	2	2	2	2	2	2	24
	Sum of USAGE	38,820	45,692	61,812	85,264	72,238	86,208	43,820	38,122	28,154	25,704	38,554	35,788	582,182
	Sum of KWH/CUSTOMER	18,410	24,286	30,936	33,182	28,118	48,103	21,910	19,061	14,077	12,852	18,277	17,889	26,874
	Sum of CUSTOMERS	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of USAGE	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of CUSTOMERS	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of USAGE	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of CUSTOMERS	0	0	0	0	0	0	0	0	0	0	0	0	0

COMPANY	1
SERV	E
STATUS	(all)

CUSTOMER C/RATE	Date	MONTH												Oct-10 Grand Total
		Nov-09	Dec-09	Jan-10	Feb-10	Mar-10	Apr-10	May-10	Jun-10	Jul-10	Aug-10	Sep-10	Oct-10	
Residential	Sum of CUSTOMERS	9	12	9	7	12	8	12	8	17	12	12	13	130
	Sum of USAGE	-306	0	0	0	0	0	0	0	0	0	0	0	396
	Sum of KWH/CUSTOMER	-34	0	0	0	0	0	0	0	0	0	0	0	3
	Sum of CUSTOMERS	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of USAGE	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of CUSTOMERS	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of USAGE	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of CUSTOMERS	0	0	0	0	0	0	0	0	0	0	0	0	0
Commercial	Sum of USAGE	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of CUSTOMERS	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of USAGE	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of CUSTOMERS	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of USAGE	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of CUSTOMERS	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of USAGE	0	0	0	0	0	0	0	0	0	0	0	0	0
Industrial	Sum of KWH/CUSTOMER	42,117	42,287	41,248	40,779	43,772	41,865	41,195	42,198	41,674	41,568	41,577	41,503	502,174
	Sum of CUSTOMERS	308,407	308,423	299,756	295,880	303,184	302,472	295,181	305,979	298,779	298,909	297,840	297,716	3,624,828
	Sum of KWH/CUSTOMER	208	208	207	183	202	202	186	186	186	200	189	186	2,344
	Sum of USAGE	458,488	753,876	1,180,513	911,917	859,582	488,097	380,907	470,582	514,776	534,735	460,542	331,752	7,332,678
	Sum of KWH/CUSTOMER	2,255	3,829	5,923	5,995	4,955	2,119	1,823	2,377	2,874	2,874	2,884	2,874	3,089
	Sum of CUSTOMERS	608,783	610,257	607,174	589,481	613,467	610,578	603,802	607,697	608,943	607,836	605,844	605,705	7,278,379
	Sum of USAGE	454,797,513	842,597,876	836,100,336	715,825,825	617,922,277	458,123,650	413,098,233	640,922,061	798,089,488	828,186,185	894,473,744	472,001,297	7,570,717,270
	Sum of KWH/CUSTOMER	750	1,053	1,276	1,214	1,007	750	884	1,055	1,207	1,384	1,146	778	1,040
	Sum of CUSTOMERS	151	161	151	43	258	151	151	151	151	151	151	151	1,812
	Sum of KWH/CUSTOMER	22,982	33,197	44,695	43,527	35,793	22,145	23,098	32,897	40,084	44,176	34,359	28,095	409,186
Special Lighting	Sum of KWH/CUSTOMER	1,094	1,581	2,317	1,979	1,828	1,056	1,003	1,482	1,821	1,821	1,582	1,244	1,588
	Sum of CUSTOMERS	4,358	4,208	4,208	4,208	4,786	4,786	4,807	4,984	4,658	4,658	4,726	4,703	54,089
	Sum of USAGE	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of CUSTOMERS	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of USAGE	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of CUSTOMERS	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of USAGE	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	0	0	0	0	0	0	0	0	0	0	0	0	0
Other	Sum of KWH/CUSTOMER	7,065	8,641	11,586	10,466	10,569	7,511	7,479	7,368	6,435	5,810	4,812	5,343	93,105
	Sum of CUSTOMERS	589	720	956	872	881	578	575	588	495	447	370	411	617
	Sum of USAGE	1	1	1	1	1	1	1	1	1	1	1	1	11
	Sum of KWH/CUSTOMER	100,680	107,280	112,800	135,800	121,800	111,120	99,120	105,840	103,680	108,720	77,570	77,570	1,187,080
	Sum of KWH/CUSTOMER	103,680	107,280	112,800	135,800	121,800	111,120	99,120	105,840	103,680	108,720	77,570	77,570	1,187,080
	Sum of CUSTOMERS	10	10	10	10	10	10	10	10	10	10	10	10	11
	Sum of USAGE	5,938	6,938	6,038	6,048	6,048	6,048	6,048	6,048	6,048	6,048	6,048	6,048	73,753
	Sum of KWH/CUSTOMER	594	594	594	594	594	594	594	594	594	594	594	594	6,005
	Sum of CUSTOMERS	6	6	6	6	6	6	6	6	6	6	6	6	78
	Sum of USAGE	77,467	77,467	77,467	77,467	77,467	77,467	77,467	77,467	77,467	77,467	77,467	77,467	829,604
Other	Sum of KWH/CUSTOMER	12,911	12,911	12,911	12,911	12,911	12,911	12,911	12,911	12,911	12,911	12,911	12,911	129,111
	Sum of CUSTOMERS	1,987	1,987	1,987	1,987	1,987	1,987	1,987	1,987	1,987	1,987	1,987	1,987	23,848
	Sum of USAGE	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of CUSTOMERS	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of USAGE	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of CUSTOMERS	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of USAGE	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	0	0	0	0	0	0	0	0	0	0	0	0	0
Other	Sum of KWH/CUSTOMER	1,700,185	1,700,343	1,700,185	1,700,185	1,700,185	1,700,185	1,700,185	1,700,185	1,700,185	1,700,185	1,700,185	1,700,185	20,402,378
	Sum of KWH/CUSTOMER	24,004	24,007	24,004	24,004	24,004	24,004	24,004	24,004	24,004	24,004	24,004	24,004	284,816
	Sum of CUSTOMERS	308	308	308	308	308	308	308	308	308	308	308	308	3,587
	Sum of USAGE	283,785	383,785	384,108	383,825	384,293	384,108	384,108	384,108	384,108	384,108	384,108	384,108	4,399,080
	Sum of KWH/CUSTOMER	1,884	1,887	1,887	1,887	1,887	1,887	1,887	1,887	1,887	1,887	1,887	1,887	22,287
	Sum of CUSTOMERS	3,010,283	3,011,141	3,025,768	3,028,820	3,022,130	3,019,694	3,023,148	3,021,793	3,019,448	3,021,148	3,024,286	3,027,445	36,236,786
	Sum of USAGE	1,813	1,813	1,813	1,813	1,813	1,813	1,813	1,813	1,813	1,813	1,813	1,813	2,827
	Sum of KWH/CUSTOMER	750	750	750	750	750	750	750	750	750	750	750	750	8,750
	Sum of CUSTOMERS	29	29	29	29	29	29	29	29	29	29	29	29	338
	Sum of KWH/CUSTOMER	396	396	396	396	396	396	396	396	396	396	396	396	4,752

COMPANY	1
SERV	1E
STATUS	(AU)

CUSTOMER OR RATE	Data	MONTH												Grand Total
		Nov-09	Dec-09	Jan-10	Feb-10	Mar-10	Apr-10	May-10	Jun-10	Jul-10	Aug-10	Sep-10	Oct-10	
Sum of CUSTOMERS	TL	254	254	254	254	254	254	254	254	254	254	254	254	3,037
Sum of USAGE		1,517,823	1,514,830	1,507,816	1,520,032	1,490,119	1,492,022	1,479,205	1,476,739	1,473,022	1,472,398	1,486,848	1,486,284	17,936,089
Sum of KWH/CUSTOMER		5,976	5,964	5,913	5,984	5,890	5,978	5,824	5,814	5,846	5,843	5,963	5,967	6,908
Sum of CUSTOMERS	UO	254	254	254	254	254	254	254	254	254	254	254	254	3,037
Sum of USAGE		1,198,529	1,190,231	1,190,436	1,192,109	1,197,064	603,016	1,795,698	1,198,873	1,199,407	1,198,742	1,200,870	1,222,969	14,395,602
Sum of KWH/CUSTOMER		4,086	4,035	4,035	4,037	4,032	1,958	5,029	3,865	3,867	3,515	3,497	3,389	3,753
Total Sum of CUSTOMERS		663,260	687,019	694,134	683,765	690,949	697,850	680,144	684,436	686,643	684,242	683,187	683,246	8,106,687
Total Sum of USAGE		1,435,023,136	1,708,002,928	1,507,378,305	1,863,019,258	1,745,862,688	1,488,654,652	1,433,474,790	1,562,227,634	2,026,937,653	2,089,282,818	1,974,385,860	1,517,181,895	20,767,669,366
Total Sum of KWH/CUSTOMER		2,102	2,468	2,468	2,468	2,467	2,165	2,108	2,221	2,987	3,028	2,749	2,221	26,874

**Duke Energy Ohio
Case No. 10-2586-EL-SSO
FES Third Set Interrogatories
Date Received: December 15, 2010**

FES-INT-03-026

REQUEST:

State the total number of customers to whom You currently provide distribution service and who take generation service from a competitive retail electric service supplier.

RESPONSE:

As of October 2010, there are 181,948 Duke Energy Ohio distribution customers taking service from a CRES provider.

PERSON RESPONSIBLE: James E. Ziolkowski

**Duke Energy Ohio
Case No. 10-2586-EL-SSO
FES Third Set Interrogatories
Date Received: December 15, 2010**

FES-INT-03-027

REQUEST:

Of the number You identify in response to Interrogatory No. 26 state the number of customers who are:

- a) Residential customers;
- b) Commercial customers; and
- c) Industrial customers.

RESPONSE:

- a) Residential: 153,480
- b) Commercial: 23,714
- c) Industrial: 1,212

There are also 2,732 OPA customers and 810 street lighting customers taking service from a CRES provider.

PERSON RESPONSIBLE: James E. Ziolkowski

Duke Energy Ohio
Case No. 10-2586-EL-SSO
FES Third Set Interrogatories
Date Received: December 15, 2010

FES-INT-03-029

REQUEST:

State the current average annual and monthly kWh usage for each of the customers classes referenced in Ineterrogatory Nos. 27 and 28.

RESPONSE:

Please see Attachment FES-INT-03-029.

PERSON RESPONSIBLE: James E. Ziolkowski

COMPANY	1
SERV	E
STATUS	Shopper

CUSTOMER ORIGIN	CUST	MONTH												Oct-10 Grand Total
		Nov-09	Dec-09	Jan-10	Feb-10	Mar-10	Apr-10	May-10	Jun-10	Jul-10	Aug-10	Sep-10	Oct-10	
Industrial	Sum of CUSTOMERS	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of USAGE	810	810	810	810	810	810	810	810	810	810	810	810	9,720
	Sum of KWH/CUSTOMER	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!
	Sum of CUSTOMERS	15	15	15	15	15	15	15	15	15	15	15	15	20
	Sum of USAGE	213,976,728	210,372,781	218,331,820	174,903,016	171,122,406	220,972,135	228,105,431	247,818,120	230,504,779	235,478,442	225,018,431	208,947,238	2,886,619,278
	Sum of KWH/CUSTOMER	14,265,115	14,024,853	13,845,745	15,900,350	15,949,526	12,988,181	13,043,069	12,131,936	12,383,444	11,842,970	10,447,362	13,105,490	
	Sum of CUSTOMERS	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of USAGE	316	316	316	316	316	316	316	316	316	316	316	316	10,431
	Sum of KWH/CUSTOMER	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!
	Sum of CUSTOMERS	0	0	0	0	0	0	0	0	0	0	0	0	0
ORA	Sum of USAGE	331	481	567	595	639	681	638	1,052	1,061	1,214	1,475	1,480	10,775
	Sum of KWH/CUSTOMER	465,478	711,157	985,880	854,488	905,533	949,882	901,708	1,164,908	1,283,922	1,410,048	1,862,278	1,835,703	13,184,969
	Sum of CUSTOMERS	11	17	16	20	26	27	27	31	31	38	45	45	338
	Sum of USAGE	5,295,886	8,110,875	8,521,830	11,843,017	14,076,859	13,894,914	15,275,503	38,233,988	36,107,315	35,983,898	42,175,363	35,882,113	268,300,430
	Sum of KWH/CUSTOMER	481,428	477,089	473,624	582,191	541,405	518,330	545,554	1,233,353	1,161,752	948,300	937,230	787,871	9,377
	Sum of CUSTOMERS	388	532	805	635	682	744	775	902	914	973	1,141	1,078	787,871
	Sum of USAGE	19,186,883	26,773,688	28,032,101	31,070,477	32,746,247	31,394,890	36,024,873	46,731,285	45,321,101	48,058,980	56,081,482	46,194,569	453,075,258
	Sum of KWH/CUSTOMER	49,401	50,228	47,887	48,580	48,014	45,692	46,493	51,808	49,585	50,431	49,914	42,852	43,318
	Sum of CUSTOMERS	30	83	88	73	79	82	80	80	80	80	80	80	590
	Sum of USAGE	1,883,013	4,380,872	8,001,874	5,895,367	5,354,658	3,803,182	3,854,089	1,270	-4,980	0	0	0	34,804,188
GS	Sum of KWH/CUSTOMER	52,767	69,539	86,879	80,800	97,780	43,941	42,823	636	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	53,356
	Sum of CUSTOMERS	1	7	7	7	7	7	7	7	7	7	7	7	10
	Sum of USAGE	10	1,363	1,063	1,363	1,363	1,363	1,363	1,363	1,363	1,363	1,363	1,363	16,598
	Sum of KWH/CUSTOMER	10	1,363	1,063	1,363	1,363	1,363	1,363	1,363	1,363	1,363	1,363	1,363	16,598
	Sum of CUSTOMERS	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of USAGE	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of CUSTOMERS	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of USAGE	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	0	0	0	0	0	0	0	0	0	0	0	0	0
OL	Sum of CUSTOMERS	21,446	38,750	43,874	42,334	48,777	50,064	51,771	54,656	54,330	55,753	57,829	58,679	595,332
	Sum of USAGE	453	5,767	7,089	5,093	5,093	5,093	7,087	6,182	4,524	4,928	966	1,015	49,019
	Sum of KWH/CUSTOMER	453	5,767	7,089	5,093	5,093	5,093	7,087	6,182	4,524	4,928	966	1,015	49,019
	Sum of CUSTOMERS	27	27	27	27	27	27	27	27	27	27	27	27	24
	Sum of USAGE	14	14	14	14	14	14	14	14	14	14	14	14	324
	Sum of KWH/CUSTOMER	14	14	14	14	14	14	14	14	14	14	14	14	324
	Sum of CUSTOMERS	1	1	1	1	1	1	1	1	1	1	1	1	23
	Sum of USAGE	1,150,887	1,092,304	1,092,304	930,841	1,018,439	9,211,868	7,150,977	9,687,462	9,428,919	15,227,787	18,926,509	16,779,636	89,589,661
	Sum of KWH/CUSTOMER	1,150,887	1,092,304	1,092,304	930,841	1,018,439	9,211,868	7,150,977	9,687,462	9,428,919	15,227,787	18,926,509	16,779,636	89,589,661
	Sum of CUSTOMERS	0	0	0	0	0	0	0	0	0	0	0	0	0
Residential	Sum of USAGE	453	5,767	7,089	5,093	5,093	5,093	7,087	6,182	4,524	4,928	966	1,015	49,019
	Sum of KWH/CUSTOMER	453	5,767	7,089	5,093	5,093	5,093	7,087	6,182	4,524	4,928	966	1,015	49,019
	Sum of CUSTOMERS	27	27	27	27	27	27	27	27	27	27	27	27	24
	Sum of USAGE	14	14	14	14	14	14	14	14	14	14	14	14	324
	Sum of KWH/CUSTOMER	14	14	14	14	14	14	14	14	14	14	14	14	324
	Sum of CUSTOMERS	1	1	1	1	1	1	1	1	1	1	1	1	23
	Sum of USAGE	1,150,887	1,092,304	1,092,304	930,841	1,018,439	9,211,868	7,150,977	9,687,462	9,428,919	15,227,787	18,926,509	16,779,636	89,589,661
	Sum of KWH/CUSTOMER	1,150,887	1,092,304	1,092,304	930,841	1,018,439	9,211,868	7,150,977	9,687,462	9,428,919	15,227,787	18,926,509	16,779,636	89,589,661
	Sum of CUSTOMERS	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of USAGE	453	5,767	7,089	5,093	5,093	5,093	7,087	6,182	4,524	4,928	966	1,015	49,019
DU	Sum of KWH/CUSTOMER	453	5,767	7,089	5,093	5,093	5,093	7,087	6,182	4,524	4,928	966	1,015	49,019
	Sum of CUSTOMERS	27	27	27	27	27	27	27	27	27	27	27	27	24
	Sum of USAGE	14	14	14	14	14	14	14	14	14	14	14	14	324
	Sum of KWH/CUSTOMER	14	14	14	14	14	14	14	14	14	14	14	14	324
	Sum of CUSTOMERS	1	1	1	1	1	1	1	1	1	1	1	1	23
	Sum of USAGE	1,150,887	1,092,304	1,092,304	930,841	1,018,439	9,211,868	7,150,977	9,687,462	9,428,919	15,227,787	18,926,509	16,779,636	89,589,661
	Sum of KWH/CUSTOMER	1,150,887	1,092,304	1,092,304	930,841	1,018,439	9,211,868	7,150,977	9,687,462	9,428,919	15,227,787	18,926,509	16,779,636	89,589,661
	Sum of CUSTOMERS	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of USAGE	453	5,767	7,089	5,093	5,093	5,093	7,087	6,182	4,524	4,928	966	1,015	49,019
	Sum of KWH/CUSTOMER	453	5,767	7,089	5,093	5,093	5,093	7,087	6,182	4,524	4,928	966	1,015	49,019
DS	Sum of CUSTOMERS	27	27	27	27	27	27	27	27	27	27	27	27	24
	Sum of USAGE	14	14	14	14	14	14	14	14	14	14	14	14	324
	Sum of KWH/CUSTOMER	14	14	14	14	14	14	14	14	14	14	14	14	324
	Sum of CUSTOMERS	1	1	1	1	1	1	1	1	1	1	1	1	23
	Sum of USAGE	1,150,887	1,092,304	1,092,304	930,841	1,018,439	9,211,868	7,150,977	9,687,462	9,428,919	15,227,787	18,926,509	16,779,636	89,589,661
	Sum of KWH/CUSTOMER	1,150,887	1,092,304	1,092,304	930,841	1,018,439	9,211,868	7,150,977	9,687,462	9,428,919	15,227,787	18,926,509	16,779,636	89,589,661
	Sum of CUSTOMERS	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of USAGE	453	5,767	7,089	5,093	5,093	5,093	7,087	6,182	4,524	4,928	966	1,015	49,019
	Sum of KWH/CUSTOMER	453	5,767	7,089	5,093	5,093	5,093	7,087	6,182	4,524	4,928	966	1,015	49,019
	Sum of CUSTOMERS	27	27	27	27	27	27	27	27	27	27	27	27	24
OL	Sum of KWH/CUSTOMER	14	14	14	14	14	14	14	14	14	14	14	14	324
	Sum of CUSTOMERS	1	1	1	1	1	1	1	1	1	1	1	1	23
	Sum of USAGE	1,150,887	1,092,304	1,092,304	930,841	1,018,439	9,211,868	7,150,977	9,687,462	9,428,919	15,227,787	18,926,509	16,779,636	89,589,661
	Sum of KWH/CUSTOMER	1,150,887	1,092,304	1,092,304	930,841	1,018,439	9,211,868	7,150,977	9,687,462	9,428,919	15,227,787	18,926,509	16,779,636	89,589,661
OA	Sum of CUSTOMERS	4	4	4	4	4	4	4	4	4	4	4	4	36
	Sum of USAGE	9,914	9,914	9,914	7,800	13,440	10,619	7,018	11,765	18,445	30,285	130,805	94,481	390,800
	Sum of KWH/CUSTOMER	1,732	2,478	3,888	1,863	3,360	1,770	1,166	1,981	3,231	3,906	2,504	2,504	2,504
	Sum of KWH/CUSTOMER	1,732	2,478	3,888	1,863	3,360	1,770	1,166	1,981	3,231	3,906	2,504	2,504	2,504

COMPANY	1
SERV	E
STATUS	Shopper

CUSTOMER	DATE	MONTH												Grand Total
		Jan-09	Feb-09	Mar-09	Apr-09	May-09	Jun-09	Jul-09	Aug-09	Sep-09	Oct-09	Nov-09		
Residential	Sum of CUSTOMERS	41,888	49,465	50,790	49,913	53,882	58,877	62,701	130,054	147,368	153,443	157,368	809,455	
	Sum of USAGE	35,532,656	54,046,010	72,733,366	61,704,458	57,511,147	70,059,466	90,059,458	183,042,043	192,663,574	137,820,431	1,068,934,934	8,094,334	
	Sum of KWH/CUSTOMER	796	1,100	1,432	1,228	1,068	1,190	1,432	1,392	1,332	898	6,777	1,182	
	Sum of CUSTOMERS	0	0	0	0	0	0	0	0	0	0	0	0	
	Sum of USAGE	0	0	0	0	0	0	0	0	0	0	0	0	
Street Lighting	Sum of KWH/CUSTOMER	0	0	0	0	0	0	0	0	0	0	0	0	
	Sum of USAGE	0	0	0	0	0	0	0	0	0	0	0	0	
	Sum of CUSTOMERS	168	201	201	308	373	437	609	946	1,103	1,103	1,103	6,068	
	Sum of KWH/CUSTOMER	0	0	0	0	0	0	0	0	0	0	0	0	
	Sum of USAGE	0	0	0	0	0	0	0	0	0	0	0	0	
Industrial	Sum of KWH/CUSTOMER	1	2	3	3	3	3	4	4	10	10	10	68	
	Sum of USAGE	840	2,174	5,061	4,341	3,017	1,328	2,595	4,815	4,815	4,202	36,025	643	
	Sum of KWH/CUSTOMER	840	1,087	1,887	1,447	1,006	443	488	648	462	383	420	1	
	Sum of CUSTOMERS	0	0	0	0	0	0	0	0	0	0	0	0	
	Sum of USAGE	0	0	0	0	0	0	0	0	0	0	0	0	
Government	Sum of KWH/CUSTOMER	1	2	2	2	2	2	2	2	2	2	2	2	
	Sum of USAGE	1,188	1,008	708	2,506	1,008	1,808	1,817	1,817	2,573	2,573	2,573	2,573	
	Sum of KWH/CUSTOMER	1,188	804	354	1,254	804	804	804	804	804	804	804	804	
	Sum of CUSTOMERS	0	0	0	0	0	0	0	0	0	0	0	0	
	Sum of USAGE	4,345	11,799	11,799	11,799	12,608	16,681	21,008	22,103	25,877	25,877	25,877	25,877	
Commercial	Sum of KWH/CUSTOMER	2	5	5	5	5	5	5	5	5	5	5	5	
	Sum of USAGE	21,278	35,253	35,253	35,253	35,253	43,382	51,803	57,780	958,807	854,807	854,807	854,807	
	Sum of KWH/CUSTOMER	10,639	7,051	7,051	7,051	7,051	8,678	10,273	11,556	57,120	57,120	57,120	57,120	
	Sum of CUSTOMERS	10	37	37	37	37	41	40	41	44	44	44	44	
	Sum of USAGE	23,303	52,169	52,169	52,169	52,169	58,187	66,198	80,332	80,332	84,407	84,407	84,407	
Public Works	Sum of KWH/CUSTOMER	2,300	1,411	1,411	1,411	1,590	1,494	1,859	1,859	1,918	1,918	1,918	1,918	
	Sum of USAGE	4,4	384	384	384	430	472	486	540	540	540	540	540	
	Sum of KWH/CUSTOMER	197,193	437,448	447,930	448,151	500,358	568,210	661,471	908,053	1,076,463	961,033	1,164,169	8,206,817	
	Sum of CUSTOMERS	5,482	1,110	1,143	1,135	1,164	1,200	1,261	1,382	1,556	1,700	2,000	1,527	
	Sum of USAGE	0	0	0	0	0	0	0	0	0	0	0	0	
Schools	Sum of KWH/CUSTOMER	0	0	0	0	0	0	0	0	0	0	0	0	
	Sum of USAGE	0	0	0	0	0	0	0	0	0	0	0	0	
	Sum of CUSTOMERS	0	0	0	0	0	0	0	0	0	0	0	0	
	Sum of KWH/CUSTOMER	0	0	0	0	0	0	0	0	0	0	0	0	
	Sum of USAGE	0	0	0	0	0	0	0	0	0	0	0	0	
Universities	Sum of KWH/CUSTOMER	12	17	17	22	32	43	43	43	43	43	43	43	
	Sum of USAGE	106,922	118,825	108,257	120,583	184,347	128,033	179,072	238,014	293,046	895,954	885,291	3,413,536	
	Sum of KWH/CUSTOMER	8,910	6,096	6,268	7,823	5,862	4,638	5,522	5,905	6,572	14,119	14,119	8,777	
	Sum of CUSTOMERS	14	30	30	34	53	63	68	68	68	68	68	68	
	Sum of USAGE	1,898	3,390	3,708	3,708	4,841	6,971	8,118	7,988	7,880	1,145,118	4,184,736	6,503,880	
Total	Sum of KWH/CUSTOMER	50,249	56,387	53,718	68,353	68,190	74,952	77,053	81,369	98,239	133,479	181,443	1,114,469	
	Sum of USAGE	487,861,800	686,814,248	682,084,248	677,982,198	728,137,612	728,137,612	753,868,102	961,173,928	959,588,102	1,126,681,126	1,126,681,126	9,873,311,813	
	Sum of KWH/CUSTOMER	9,804	10,278	11,278	9,715	9,715	9,715	11,318	11,318	11,318	11,318	11,318	9,873,311,813	
	Sum of CUSTOMERS	0	0	0	0	0	0	0	0	0	0	0	0	
	Sum of USAGE	0	0	0	0	0	0	0	0	0	0	0	0	

Duke Energy Ohio
Case No. 10-2586-EL-SSO
FES Third Set Interrogatories
Date Received: December 15, 2010

FES-INT-03-030

REQUEST:

State the total number of customers to whom You currently provide distribution service and who take generation service pursuant to Your current Standard Service Offer.

RESPONSE:

As of October 2010, there are 501,288 customers taking generation service pursuant to the Company's Standard Service Offer.

PERSON RESPONSIBLE: James E. Ziolkowski

**Duke Energy Ohio
Case No. 10-2586-EL-SSO
FES Third Set Interrogatories
Date Received: December 15, 2010**

FES-INT-03-031

REQUEST:

Of the number you identify in response to Interrogatory No. 30, state the number of customers who are:

- a) residential customers;
- b) commercial customers; and
- c) industrial customers.

RESPONSE:

- a) Residential: 453,460
- b) Commercial: 43,818
- c) Industrial: 1,050

There are also 912 OPA customers and 2,048 street lighting customers taking service under the Company's Standard Service Offer.

PERSON RESPONSIBLE: James E. Ziolkowski

Duke Energy Ohio
Case No. 10-2586-EL-SSO
FES Third Set Interrogatories
Date Received: December 15, 2010

FES-INT-03-032

REQUEST:

Of the number You identify in response to Interrogatory No. 30, state the number of customers who are served under each of Your rate classifications and/or tariffs.

RESPONSE:

Sum of CUSTOMERS	CUSTOMER CLASS					
RATE	Commercial	Industrial	OPA	Residential	Street Lighting	Grand Total
	277	0	0	14	0	291
DM	24,408	478	537		3	25,424
DP	22	21	4			47
DS	7,642	537	252			8,431
EH	514	9	47			570
GS	23	1	51		8	83
NS	0	0	0	0	5	5
OL	0	0	0	0	0	0
OR				162		162
RS	10,446		14	453,262		463,722
SC	5				33	38
SE	58				262	320
SF	5					5
SL	356				1,256	1,611
SO	0				0	0
SX					17	17
TD				22		22
TL	6		5		190	201
TS	1	6				7
UO	56	0	0	0	274	330
WS			2			2
Grand Total	43,818	1,050	912	453,460	2,048	501,288

Note:

GS is Rate GS-FL. SF is Rate SFL-ADPL. OR is Rate ORH. SO, SS, SX, and UO are all Rate UOLS (one of the lighting rates). WS is water pumping special contract. All other rates match the title of the tariff sheet.

PERSON RESPONSIBLE: James E. Ziolkowski

**Duke Energy Ohio
Case No. 10-2586-EL-SSO
FES Third Set Interrogatories
Date Received: December 15, 2010**

FES-INT-03-033

REQUEST:

State the current average annual and monthly kWh usage for each of the customers classes referenced in Interrogatory Nos. 31 and 32.

RESPONSE:

Please see Attachment FES-INT-03-033.

PERSON RESPONSIBLE: James E. Ziolkowski

COMPANY	1
SERV	E
STATUS	Non-Shopper

CUSTOMER CATE	Data	MONTH												OPI-101 GROSS Total
		Nov-08	Dec-08	Jan-09	Feb-09	Mar-09	Apr-09	May-09	Jun-09	Jul-09	Aug-09	Sep-09	Oct-09	
Commercial	Sum of CUSTOMERS	327	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of USAGE	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	327	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	327	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	327	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	327	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	327	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	327	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	327	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	327	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	327	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	327	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	327	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	327	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	327	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	327	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	327	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	327	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	327	0	0	0	0	0	0	0	0	0	0	0	0
Industrial	Sum of CUSTOMERS	327	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of USAGE	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	327	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	327	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	327	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	327	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	327	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	327	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	327	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	327	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	327	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	327	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	327	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	327	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	327	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	327	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	327	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	327	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of KWH/CUSTOMER	327	0	0	0	0	0	0	0	0	0	0	0	0

[illegible]

COMPANY	1
SERV	E
STATUS	Non-Shopper

CUSTOMER CREDIT	MONTH											
	Nov-09	Dec-09	Jan-10	Feb-10	Mar-10	Apr-10	May-10	Jun-10	Jul-10	Aug-10	Sep-10	Oct-10 Grand Total
Sum of CUSTOMERS	280	285	289	289	272	266	267	269	270	258	257	274
Sum of USAGE	1,193,531	1,188,838	1,186,730	1,188,488	1,192,123	598,047	1,787,550	1,190,587	1,191,527	53,622	64,451	-2,941,793
Sum of KWH/CUSTOMER	4,283	4,179	4,112	4,118	4,383	2,248	6,895	4,428	4,413	203	241	-10,726
Total Sum of CUSTOMERS	633,002	630,032	628,430	605,413	624,759	612,698	603,121	603,076	607,354	538,782	507,115	6,011,588
Total Sum of USAGE	986,358,221	1,121,238,033	1,275,291,958	1,085,327,080	994,969,161	760,516,740	878,522,143	900,753,895	1,027,841,828	942,851,686	727,574,235	618,873,621
Total Sum of KWH/CUSTOMER	1,468	1,760	2,039	1,789	1,893	1,241	1,457	1,494	1,720	1,749	1,435	1,037
												10,973,659,136
												10,973,659,136

**Duke Energy Ohio
Case No. 10-2586-EL-SSO
FES Third Set Interrogatories
Date Received: December 15, 2010**

FES-INT-03-034

REQUEST:

State the total number of customers to whom You project You will provide distribution service for each year of the first five years of the proposed MRO.

RESPONSE:

This information is not available, however, the Company does not expect the number of distribution customers to materially change from current levels.

PERSON RESPONSIBLE: James E. Ziolkowski

**Duke Energy Ohio
Case No. 10-2586-EL-SSO
FES Third Set Interrogatories
Date Received: December 15, 2010**

FES-INT-03-035

REQUEST:

Of the number You identify in response to Interrogatory No. 34, state the projected number of customers who will be:

- a) residential customers;
- b) commercial customers; and
- c) industrial customers.

RESPONSE:

Please see the response to FES-INT-03-034.

PERSON RESPONSIBLE: James E. Ziolkowski

**Duke Energy Ohio
Case No. 10-2586-EL-SSO
FES Third Set Interrogatories
Date Received: December 15, 2010**

FES-INT-03-036

REQUEST:

Of the number You identify in response to Interrogatory No. 34, state the projected number of customers who will be served under each of Your rate classifications and/or tariffs.

RESPONSE:

Please see the response to FES-INT-03-034.

PERSON RESPONSIBLE: James E. Ziolkowski

**Duke Energy Ohio
Case No. 10-2586-EL-SSO
FES Third Set Interrogatories
Date Received: December 15, 2010**

FES-INT-03-037

REQUEST:

State the projected average annual and monthly kWh usage for each of the customer classes referenced in Interrogatory Nos. 35 and 36.

RESPONSE:

Please see the response to FES-INT-03-034.

PERSON RESPONSIBLE: James E. Ziolkowski

**Duke Energy Ohio
Case No. 10-2586-EL-SSO
FES Third Set Interrogatories
Date Received: December 15, 2010**

FES-INT-03-038

REQUEST:

Of the total number of customers You identify in response to Interrogatory No. 34, state the number of such customers who You project will take generation service from a competitive retail electric service supplier for each year of the first five years of the proposed MRO.

RESPONSE:

Please see the response to FES-INT-03-034.

PERSON RESPONSIBLE: James E. Ziolkowski

**Duke Energy Ohio
Case No. 10-2586-EL-SSO
FES Third Set Interrogatories
Date Received: December 15, 2010**

FES-INT-03-039

REQUEST:

Of the number You identify in response to Interrogatory No. 38, state the projected number of customers who will be:

- a) residential customers;
- b) commercial customers; and
- c) industrial customers.

RESPONSE:

Please see the response to FES-INT-03-034.

PERSON RESPONSIBLE: James E. Ziolkowski

**Duke Energy Ohio
Case No. 10-2586-EL-SSO
FES Third Set Interrogatories
Date Received: December 15, 2010**

FES-INT-03-040

REQUEST:

Of the number You identify in response to Interrogatory No. 38, state the projected number of customers who will be served under each of Your rate classifications and/or tariffs.

RESPONSE:

Please see the response to FES-INT-03-034.

PERSON RESPONSIBLE: James E. Ziolkowski

**Duke Energy Ohio
Case No. 10-2586-EL-SSO
FES Third Set Interrogatories
Date Received: December 15, 2010**

FES-INT-03-041

REQUEST:

State the projected average annual and monthly kWh usage for each of the customer classes referenced in Interrogatory Nos. 39 and 40.

RESPONSE:

Please see the response to FES-INT-03-034.

PERSON RESPONSIBLE: James E. Ziolkowski

Duke Energy Ohio
Case No. 10-2586-EL-SSO
FES Third Set Interrogatories
Date Received: December 15, 2010

FES-INT-03-042

REQUEST:

Of the total number of customers You identify in response to Interrogatory No. 34, state the number of such customers who You project will take generation service pursuant to the proposed MRO for each year of the first five years of the proposed MRO.

RESPONSE:

Please see the response to FES-INT-03-034.

PERSON RESPONSIBLE: James E. Ziolkowski

**Duke Energy Ohio
Case No. 10-2586-EL-SSO
FES Third Set Interrogatories
Date Received: December 15, 2010**

FES-INT-03-043

REQUEST:

Of the number You identify in response to Interrogatory No. 42, state the projected number of customers who will be:

- a) residential customers;
- b) commercial customers; and
- c) industrial customers.

RESPONSE:

Please see the response to FES-INT-03-034.

PERSON RESPONSIBLE: James E. Ziolkowski

**Duke Energy Ohio
Case No. 10-2586-EL-SSO
FES Third Set Interrogatories
Date Received: December 15, 2010**

FES-INT-03-044

REQUEST:

Of the number You identify in response to Interrogatory No. 42, state the projected number of customers who will be served under each of Your rate classifications and/or tariffs.

RESPONSE:

Please see the response to FES-INT-03-034.

PERSON RESPONSIBLE: James E. Ziolkowski

Duke Energy Ohio
Case No. 10-2586-EL-SSO
FES Third Set Interrogatories
Date Received: December 15, 2010

FES-INT-03-045

REQUEST:

State the projected average annual and monthly kWh usage for each of the customer classes referenced in Interrogatory Nos. 43 and 44.

RESPONSE:

Please see the response to FES-INT-03-034.

PERSON RESPONSIBLE: James E. Ziolkowski

Duke Energy Ohio
Case No. 10-2586-EL-SSO
FES Third Set Production of Documents
Date Received: December 15, 2010

FES-POD-03-016

REQUEST:

All Documents You identified in response to the foregoing Interrogatories.

RESPONSE:

The responses provided to FES-INT-03-022 through FES-INT-03-033 are tabulations of billing data obtained from the Company's bill and revenue reporting system. There are no documents or additional data to be provided other than the tables are attachments that appear or are referenced in those responses.

PERSON RESPONSIBLE: James E. Ziolkowski

Duke Energy Ohio
Case No. 10-2586-EL-SSO
FES Third Set Production of Documents
Date Received: December 15, 2010

FES-POD-03-017

REQUEST:

All Documents You relied on in generating Your responses to the foregoing Interrogatories.

RESPONSE:

Please see the response to FES-POD-03-016.

PERSON RESPONSIBLE: James E. Ziolkowski

Duke Energy Ohio
Case No. 10-2586-EL-SSO
FES Third Set Production of Documents
Date Received: December 15, 2010

FES-POD-03-018

REQUEST:

All documents that reflect, relate or refer to projections, forecasts, estimates or calculations of the number of customers to whom You will provide distribution service and who will take generation service from a competitive retail electric service provider during the first five years of the proposed MRO.

RESPONSE:

There are no responsive documents.

PERSON RESPONSIBLE: James E. Ziolkowski

Duke Energy Ohio
Case No. 10-2586-EL-SSO
FES Third Set Production of Documents
Date Received: December 15, 2010

FES-POD-03-019

REQUEST:

All documents that reflect, relate or refer to projections, forecasts, estimates or calculations of the number of customers to whom You will provide distribution service and who will take generation service pursuant to the proposed MRO during the first five years of the proposed MRO.

RESPONSE:

There are no responsive documents.

PERSON RESPONSIBLE: James E. Ziolkowski



RGOS

Regional Generation Outlet Study

November 19, 2010

This page intentionally left blank.

Contents

1	Study Overview	1
1.1	RGOS Results Summary	1
1.2	Long-term Transmission Strategies	2
1.3	RGOS Candidate Multi-Value Projects	12
1.4	RGOS Results Summary	15
2	Scope	16
2.1	Stakeholder Study Participation	16
2.2	Stakeholder Survey Results	18
2.3	Wind Zone Development	18
2.4	Study Methodology	20
3	Renewable Energy Requirements	22
3.1	Renewable Portfolio Standards	22
4	Renewable Energy Zones Development	25
4.1	Wind Analysis	25
5	Regional Transmission Designs	30
5.1	Indicative Transmission Designs	30
5.2	Model Development	33
5.3	Analyses	37
6	Construction Cost Estimates	80
6.1	Estimating Assumptions	80
6.2	Transmission Scenario Overlay Cost Estimate Results	83
7	RGOS 2011 Candidate MVP Portfolio Selection	91
7.1	Candidate Multi-Value Project Identification Process	91
8	Going Forward	97
	Appendix 1: Site Selection Methodology	1
A1.1	Developing Wind Resource Datasets	1
A1.2	Generate Wind Plant Output	6
A1.3	Renewable Energy Zone Scenario Development	11
	Appendix 2: Midwest ISO Member State RPS Requirements	1
	Appendix 3: Indicative Transmission Design	1
A3.1	Local 345 kV	2
A3.2	Local 765 kV	4
A3.3	Combo (50/50) 345 kV	6
A3.4	Combo (50/50) 765 kV	6
A3.5	Combo (75/25) 345 kV	10
A3.6	Combo (75/25) 765 kV	12
A3.7	Regional 345 kV	14
A3.8	Regional 345 kV Optimized	15
A3.9	Regional 765 kV with DC	17
A3.10	Regional 765 kV with DC Optimized	18
A3.11	Regional 765 kV DC West	20
A3.12	Regional 765 kV DC West Optimized	21
A3.13	Regional 765 kV	23
A3.14	Regional 765 kV Optimized	24
	Appendix 4: Transmission Upgrades	Attached
A4.1	Native Voltage	
A4.2	Native Voltage with DC	
A4.3	765 kV	
	Appendix 5: Modeling Correction	Attached
A5.1	Native Voltage	
A5.2	Native Voltage with DC	
A5.3	765 kV	
	Appendix 6: Production Cost Model Summary Results	Attached
	Appendix 7: Native Voltage Transmission Detail Flow Information	Attached
	Appendix 8: 765 kV Transmission Detail Flow Information	Attached
	Appendix 9: Native Voltage with DC Transmission Detail Flow Information	Attached
	Appendix 10: Detailed Transmission Overlay Maps	Attached

Tables & Figures

Figure 1.2-1: RGOS Study Footprint.....	2
Figure 1.2-2: Zone Scenario Generation and Transmission Cost Comparison.....	3
Table 1.2-1: Summary of RGOS Overlay Physical Infrastructure.....	4
Table 1.2-2: 2010 Cost Summary - Construction (2010 USD in Millions).....	5
Table 1.2-3: Cost Summary - 2010 Levelized Annual Costs***.....	6
Table 1.2-4: Cost Summary - 2010 Annual Costs (\$/MWh***).....	7
Table 1.2-5: 2010 Adjusted Production Cost (APC) Savings (\$/MWh).....	8
Table 1.2-6: 2010 Net Total Cost Summary (\$/MWh).....	8
Figure 1.2-3: Native Voltage Transmission Overlay Strategy.....	9
Figure 1.2-4: 765 kV Transmission Overlay Strategy.....	10
Figure 1.2-5: Native Voltage with DC Transmission Overlay Strategy.....	11
Figure 1.3-1: Candidate MVP Strategy Development Venn Diagram.....	12
Figure 1.3-2: RGOS-identified Candidate Multi-Value Projects (Midwest ISO and PJM Lines Shown).....	13
Table 1.3-2: Candidate Multi-Value Projects.....	14
Figure 2.3-1: Renewable Energy Zone Locations.....	18
Table 2.3-1: Renewable Energy Zone Information (UMTDI Zone Selection B).....	19
Table 2.3-2: Renewable Energy Zone Information (non-UMTDI Zone Selections).....	19
Table 2.4-1: Key Assumptions for Economic Model Development.....	20
Figure 3.1-1: RPS Requirements within Midwest ISO Footprint.....	23
Table 3.1-1: 2015-2025 RPS Targets.....	24
Figure 4.1-1: Local Wind Zone Identification.....	27
Figure 4.1-2: Regional Wind Zone Identification.....	28
Figure 4.1-3: Combination Wind Zone Identification.....	28
Figure 5-1: Balancing Generation and Transmission Investment.....	30
Table 5.1-1: Transmission Line Cost Assumptions (2010 USD in Millions).....	31
Table 5.1-2: Indicative Transmission Costs (2010 USD in Millions Sorted by Total Cost).....	32
Figure 5.1-1: Zone Scenario Generation and Transmission Cost Comparison.....	33
Table 5.2-1: Renewable Energy Zone Information (UMTDI Zone Selections).....	35
Table 5.2-2: Renewable Energy Zone Information (non-UMTDI Zone Selections).....	36
Table 5.3-1: Native Voltage Overlay Information from Initial Energy Model Analysis.....	37
Figure 5.3-1: Native Voltage Indicative Overlay (Iteration 1).....	38
Figure 5.3-2: Native Voltage after Production Cost Modeling Optimization (Iteration 4).....	38
Table 5.3-2: Native Voltage Overlay Information from Initial Energy Model Analysis Annual APC Savings (2010 USD in Millions).....	39
Figure 5.3-3: 765 kV Indicative Overlay (Iteration 1).....	40
Figure 5.3-4: 765 kV Overlay after Production Cost Modeling Optimization (Iteration 4).....	40
Table 5.3-3: Native Voltage Overlay Information from Initial Energy Model Analysis.....	41
Figure 5.3-5: Native Voltage with DC Indicative Overlay.....	42
Figure 5.3-6: Native Voltage with DC Overlay after Production Cost Modeling Optimization.....	42
Table 5.3-4: Monitored Elements Metrics and Criteria.....	43
Table 5.3-5: Constraint Metrics and Criteria.....	44
Table 5.3-6: Power Flow Solution Criteria.....	46
Figure 5.3-7: Native Voltage Off-peak Analysis.....	46
Figure 5.3-8: Native Voltage with DC Off-peak Analysis.....	47
Figure 5.3-9: 765 Kv Off-peak Analysis.....	47
Figure 5.3-10: Native Voltage Peak Analysis.....	48
Figure 5.3-11: Native Voltage with DC Peak Analysis.....	48
Figure 5.3-12: 765 kV Peak Analysis.....	49
Table 5.3-7: Sub-200 kV Constraints.....	50
Table 5.3-8: Adjusted Production Cost Savings (2010 USD in Millions).....	51
Table 5.3-9: Load Cost Savings (2010 USD in Millions).....	52
Table 5.3-10: RGOS Wind Zone Energy Delivered.....	53
Table 5.3-11: Native Voltage Max Loading Summary.....	53
Table 5.3-12: 765 kV Max Loading Summary.....	54
Table 5.3-13: Native Voltage with DC Max Loading Summary.....	55
Table 5.3-14: Native Voltage Strategy Net State Interface Flow Summary (RGOS Lines Only).....	56
Figure 5.3-13: Native Voltage Strategy Net State Interface Duration Curves (RGOS Lines Only).....	56
Table 5.3-15: 765 kV Strategy Net State Interface Flow Summary (RGOS Lines Only).....	57
Figure 5.3-14: 765 kV Strategy Net State Interface Duration Curves (RGOS Lines Only).....	57
Table 5.3-16: Native Voltage with DC Strategy Net State Interface Flow Summary (RGOS Lines Only).....	58

Figure 5.3-15: Native Voltage with DC Strategy Net State Interface Duration Curves (RGOS Lines Only)	59
Table 5.3-17: Native Voltage Strategy State Interface Flow Summary (RGOS Lines Only)	59
Figure 5.3-16: Native Voltage Strategy State Interface Duration Curves (RGOS Lines Only)	60
Table 5.3-18: 765 kV Strategy State Interface Flow Summary (RGOS Lines Only)	61
Figure 5.3-17: 765 kV Strategy State Interface Duration Curves (RGOS Lines Only)	62
Table 5.3-19: Native Voltage with DC Strategy State Interface Flow Summary (RGOS Lines Only)	62
Figure 5.3-18: Native Voltage with DC Strategy State Interface Duration Curves (RGOS Lines Only)	63
Table 5.3-20: Base Case State Interface Summary (All Lines 230 kV and Greater)	64
Figure 5.3-19: Base Case State Interface Duration Curves (All Lines 230 kV and Greater)	65
Table 5.3-21: Native Voltage Strategy State Interface Summary (All Lines 230 kV and Greater)	65
Figure 5.3-20: Native Voltage Strategy State Interface Duration Curves (All Lines 230 kV and Greater)	66
Table 5.3-22: 765 kV Strategy State Interface Summary (All Lines 230 kV and Greater)	67
Figure 5.3-21: 765 kV Strategy State Interface Duration Curves (All Lines 230 kV and Greater)	68
Table 5.3-23: Native Voltage with DC Strategy State Interface Summary (All Lines 230 kV and Greater)	68
Figure 5.3-22: Native Voltage with DC Strategy State Interface Duration Curves (All Lines 230 kV and Greater)	70
Table 5.3-24: Future Scenario PAC Sector Average Weights	72
Figure 5.3-23: Indicative Robustness Testing Decision Tree Diagram	73
Figure 5.3-24: Indicative RGOS 765kV Plan Robustness Testing Results	76
Figure 5.3-25: Indicative RGOS Native Voltage Plan Robustness Testing Results	77
Figure 5.3-26: Indicative RGOS Native Voltage with DC Plan Robustness Testing Results	78
Table 5.3-25: RGOS Transmission Plan Cost and Benefit Comparison - 2025 USD in Millions	79
Table 5.3-26: RGOS Transmission Plan Comparison - Other Quantifiable Measures	79
Table 6.1-1: Line Mile Costs - \$M/mile (2010 USD)	80
Table 6.1-2: Substation Costs (2010 USD)	80
Table 6.1-3: Transformer Costs (2010 USD)	81
Table 6.1-4: Reactive Costs (2010 USD)	81
Table 6.1-5: Net Present Value Factors	81
Table 6.1-6: Net Present Capitalization Cost Factors	82
Table 6.2-1: Native Voltage (345 kV) 2010 Capital Costs	84
Table 6.2-2: Native Voltage (345 kV) 2010 Net Present Value	85
Table 6.2-3: 765 kV 2010 Capital Costs	86
Table 6.2-4: 765 kV 2010 Net Present Value	87
Table 6.2-5: Native DC 2010 Capital Costs	88
Table 6.2-6: Native DC 2010 Net Present Value	89
Table 6.2-7: Generation 2010 Net Present Value	90
Table 7.1-1: Renewable Portfolio Standard Requirements	92
Figure 7.1-1: Location of Midwest ISO Generation Interconnection Queue Requests	93
Figure 7.1-2: RGOS-Identified Candidate Multi-Value Projects	94
Figure 8-1: Proposed Midwest ISO Candidate Multi-Value Project Portfolio #1	97
Figure A1.1-1: Example of US Wind Resource Map	2
Figure A1.1-2: Site Selection Wind Development Area	2
Figure A1.1-3: Potential Sites for Onshore Site Selection by Capacity Factor	4
Figure A1.1-4: NREL Selected Site for Mesoscale Wind farm Modeling	5
Figure A1-5 NREL and RGOS Study Region Selected Sites	6
Table A1.2-1: Onshore Site Selection Capacity Factors by Year	7
Figure A1.2-1: Distribution of Site Capacity for all 1,513 Selected Onshore Sites	8
Figure A1.2-2: Minimum Power Output of the NREL Selected Sites for Each Year	9
Figure A1.2-3: Maximum Power Output of the NREL Selected Sites for Each Year	10
Table A1.3-1 Summary of Capacity Factor Metrics	11
Figure A1.3-1 Average Capacity Factor Metrics by State	12
Figure A1.3-2 Maximum Capacity Factor Metrics by State	12
Figure A1.3-3 Minimum Capacity Factor Metrics by State	13
Figure A1.3-4 Correlation of Wind to Load in the Midwest ISO	14
Figure A1.3-5: Correlation of Wind Ramp to Load Ramp	15
Figure A1.3-6: Correlation of Wind Sites to Distance	16
Table A2-1: Midwest ISO Region State RPS Requirements	1
Table A3.1-1: Local 345 kV Sum of Line Lengths (Miles)	2
Table A3.1-2: Local 345 kV Sum of Total Cost	2
Figure A3.1-1: RGOS Local 345 kV	3
Table A3.2-1: Local 765 kV Sum of Line Lengths (Miles)	4
Table A3.2-2: Local 765 kV Sum of Total Cost	4
Figure A3.2-1: RGOS Local 765 kV	5

Table A3.3-1: Combo (50/50) 345 kV Sum of Line Lengths (in Miles)	6
Table A3.3-2: Combo (50/50) 345 kV Sum of Total Cost	6
Figure A3.3-1: RGOS Combo (50/50) 345 kV	7
Table A3.4-1: Combo (50/50) 765 kV Sum of Line Lengths (in Miles)	8
Table A3.4-2: Combo (50/50) 765 Sum of Total Cost	8
Figure A3.4-1: RGOS Combo (50/50) 765 kV	9
Table A3.5-1: Combo (75/25) 345 kV Sum of Line Lengths (in Miles)	10
Table A3.5-2: Combo (75/25) 345 kV Sum of Total Cost	10
Figure A3.5-1: RGOS Combo (75/25) 345 kV	11
Table A3.6-1: Combo (75/25) 765 kV Sum of Line Lengths (in Miles)	12
Table A3.6-2: Combo (75/25) 765 kV Sum of Total Cost	12
Figure A3.6-1: RGOS Combo (75/25) 765 kV	13
Table A3.7-1: Regional 345 kV Sum of Line Lengths (in Miles)	14
Table A3.7-2: Regional 345 kV Sum of Total Cost	14
Table A3.8-1: Regional 345 kV Optimized Sum of Line Lengths (in Miles)	15
Table A3.8-2: Regional 345 kV Optimized Sum of Total Cost	15
Figure A3.8-1: RGOS Regional 345 kV (with Optimized)	16
Table A3.9-1: Regional 765 kV with DC Sum of Line Lengths (in Miles)	17
Table A3.9-2: Regional 765 kV with DC Sum of Total Cost	17
Table A3.10-1: Regional 765 kV with DC Optimized Sum of Line Lengths (in Miles)	18
Table A3.10-2: Regional 765 kV with DC Optimized Sum of Total Cost	18
Figure A3.10-1: RGOS Regional 765 kV with DC (with Optimized)	19
Table A3.11-1: Regional 765 kV DC West Sum of Line Lengths (in Miles)	20
Table A3.11-2: Regional 765 kV DC West Sum of Total Cost	20
Table A3.12-1: Regional 765 kV DC West Optimized Sum of Line Lengths (in Miles)	21
Table A3.12-2: Regional 765 kV DC West Optimized Sum of Line Lengths (in Miles) Sum of Total Cost	21
Figure A3.12-1: RGOS Regional 765 kV DC West (with Optimized)	22
Table A3.13-1: Regional 765 kV Sum of Line Lengths (in Miles)	23
Table A3.13-2: Regional 765 kV Sum of Total Cost	23
Table A3.14-1: Regional 765 kV Optimized Sum of Line Lengths (in Miles)	24
Table A3.14-2: Regional 765 kV Optimized Sum of Total Cost	24
Figure A3.14-1: RGOS Regional 765 kV Optimized	25

RGOS Team Members and Contributors

Midwest ISO RGOS Team Members

Jameson T. Smith
Jarred S. Miland
Jeanna Furnish
Ronghai Wang
Jianfeng Zhang

Ryan Pulkrabek
Laura Rauch
Matt Sutton
Khurram Ansari

Design Sub Team Contributors

Anita Sharma, AEP
Jon Riley, AEP
Manny Rahman, AEP
Scott Delfenderfer, Ameren Services Company
Pat Shanahan, ATC
Wenchun Zhu, ATC
Jared Alholinna, CAPX
Rhonda Peters, Clipper Windpower Development Company
Ron Szymczak, ComEd
Steve Porter, Dairyland Power Cooperative
Ed Kirschner, Duke Energy
Jeff Gindling, Duke Energy
Matt Schuerger, Energy Systems Consulting Services, LLC
Jay Goldman, Exelon Transmission Company
Ray Connolly, Exelon Transmission Company
Jennifer Easler, Iowa Office of Consumer Advocate
Larry Shi, Iowa Office of Consumer Advocate
Mark Kempker, IPL
Carlo Capra, ITC Holdings
Jeff Eddy, ITC Holdings
Bryan Rushing, LS Power Development, LLC
Rajesh Puchota, LS Power Development, LLC
Jeff Hart, MidAmerican Energy Company
Jim Swanson, MidAmerican Energy Company
Aruna Ranaweera, Midwest ISO
David Duebner, Midwest ISO
Digaunto Chatterjee, Midwest ISO
Scott Hoberg, Minnesota Power
George Sweazy, Minnesota Power
John Weber, Missouri River Energy Services
Jason Weiers, Otter Tail Power Company
Dan Balk, WAPA
Hamish Wong, Wisconsin Public Service Corporation
Dan Kline, Xcel Energy
Jason Standing, Xcel Energy
Jason Espeeth, Xcel Energy
Justin Michlig, Xcel Energy
Robert McKee, ATC

1 Study Overview

Renewable Portfolio Standards (RPS) passed by most Midwest ISO member states mandate meeting significant percentages of total electrical energy with renewable energy resources. To develop transmission portfolios fulfilling these requirements and meeting the objective function of achieving the lowest delivered dollar per MWh cost, Midwest ISO, with the assistance of state regulators and industry stakeholders, conducted the Regional Generator Outlet Study (RGOS).

1.1 RGOS Results Summary

During initial RGOS phases, analysis showed locating wind zones in a distributed manner throughout the system—as opposed to only locating the wind local to load or regionally where the best wind resources are located—results in a set of least-cost wind zones that help to reduce the delivered dollar per MWh cost needed to meet renewable energy requirements. From this earlier work, a combination of local and regional wind zones were identified and approved by the Upper Midwest Transmission Development Initiative (UMTDI). Further solidifying the validity of this methodology, the Midwest Governors' Association affirmed the method employed selecting these wind zones as the best approach to wind zone selection.

- RGOS determined the best fit solution to be a transmission overlay encompassing all Midwest ISO states, premised on a distributed set of wind zones, each with varying capacity factors and distances from load.

RGOS narrowed its focus to the development of three (3) transmission expansion scenarios to integrate wind from the designated zones: (1) a Native Voltage overlay that does not introduce new voltages such as 765kV in areas where they do not currently exist; (2) a 765 kV overlay allowing the introduction of 765 kV transmission throughout the study footprint; and (3) Native Voltage with DC transmission that allows for the expansion of DC technology within the study footprint.

- All three (3) transmission expansion scenarios meet respective state Renewable Portfolio Standards (RPS) requirements within the Midwest ISO footprint.
- The addition of renewable energy zones with the transmission overlays reduced the Midwest ISO load-weighted LMP between \$4.30 to \$4.90/MWh (2010 USD).
- The three (3) transmission overlay plans represent potential investment of \$16B to \$22B in 2010 USD in transmission over the next 20 years and consist of new transmission mileage of 6,400–8,000 miles.
- Total cost for the transmission overlays range from \$19/MWh to \$25/MWh. The cost of the wind generation is an additional \$72/MWh. However, the overlays and generation also produce Adjusted Production Cost (APC) savings of \$41/MWh to \$43/MWh within the Midwest ISO footprint, creating a net cost of \$49/MWh to \$54/MWh. This cost does not include the value associated with an additional \$20/MWh to \$22/MWh of APC savings which would accrue to the rest of the Eastern Interconnect as the result of the RGOS transmission overlays and generation.
- Analyses of these three (3) transmission plan alternatives through the RGOS study, along with additional analytics performed within Midwest ISO planning processes, have identified a sub-set qualifying as inputs into the Candidate Multi-Value Project (MVP) portfolio analysis.

Because of RGOS, Midwest ISO has identified the next, most immediate step to transmission investment: a set of robust Candidate MVPs designed to address current renewable energy mandates and the regional reliability needs of its members. Viable for near-term development, these projects represent \$5.8B (2010 USD) of capital investment, approximately \$4.4 billion in the Midwest ISO footprint with the remainder in PJM. These Candidate MVPs will serve as inputs into the 2011 Candidate MVP Portfolio analysis, the first of a cyclical set of MVP Portfolio analyses which will propose and evaluate transmission to meet a changing policy landscape. While none of the overlay scenarios—Native Voltage, 765 kV, Native Voltage with DC—has emerged as the definitive renewable energy transmission solution, it is important to note all selected Candidate MVPs are compatible with all three (3) transmission plans.

1.2 Long-term Transmission Strategies

All three (3) transmission plans were developed to provide reliable delivery of the RPS-identified levels of renewable energy. Reliable delivery assumptions are discussed within Section 5 and focus on transmission system constraints 200 kV and higher. Refer to Figure 1.2-1. The study region consists of Midwest ISO and neighboring facilities including MAPP, Commonwealth Edison, and American Electric Power.




Figure 1.2-1: RGOS Study Footprint

Because RGOS transmission plans impact MAPP and PJM systems, references to these neighboring systems are made whenever RGOS is discussed, the result of necessary assumptions regarding planning practices and strategic assessment. For example, a 765 kV grid logically connects into an already existing 765 backbone on the PJM system, but PJM references are not yet indicative of any projects in the PJM Regional Transmission Expansion Plan. Evaluation of overlays moving forward will continue to require coordination between impacted neighboring entities, including PJM, MAPP, SPP, and TVA.

1.2.1 Transmission Expansion Drivers

The Midwest ISO region observed two significant drivers for transmission expansion: (1) state RPS mandates; and (2) associated generation in the Midwest ISO Generation Interconnection Queue (GIQ). For more detailed information regarding state RPS mandates and goals, refer to section 3 and Appendix 2 of this document. The second major driver for transmission expansion is the Midwest ISO Generation Interconnection Queue (GIQ), which—as of the end of July 2010—held approximately 64,500 MWe of wind requests. After careful examination of the inherently complex issues involved, Midwest ISO staff and stakeholders determined the GIQ process would not be an efficient means for building a cost-effective transmission system either immediately, over the next 5–10 year period or in the foreseeable future beyond that time-frame.

1.2.2 Indicative Zone Selection Rationale

Several different generation siting options were analyzed during previous phases of RGOS. This analysis focused on the relative benefits of local generation, which typically requires less transmission to be delivered to major load centers, and regional generation, which can be located where wind energy is the strongest. A total of fourteen (14) generation siting options were developed, with options ranging from purely local generation siting, purely regional generation siting, or a combination of local and regional generation siting. Transmission overlays were then developed with Transmission Owners (TOs) on a high-level, indicative basis for each generation siting option. Capital costs for each generation siting option and its associated high-level transmission overlay were calculated and plotted against each other to determine the relative cost of each generation siting approach. Refer to Figure 1.2-2.




Figure 1.2-2: Zone Scenario Generation and Transmission Cost Comparison

It was determined the least cost approach to generation siting is a methodology containing a combination of local and regional wind generation locations, as shown by the white area on Figure 1.2-2. This was the approach affirmed by the Midwest Governors' Association as the best approach to wind zone selection.

For greater detail regarding the indicative transmission results, design, and optimization, refer to sections 4.1.1, 5.1, and Appendix 3 of this document. Also refer to section 9.1 of the Midwest ISO Transmission Expansion Plan (MTEP) 2009, which more fully describes the rationale driving zone scenario generation.

1.2.3 Comparative Analysis

During the study process, the RGOS group focused on the development of three (3) transmission expansion scenarios mentioned in the previous section: (1) a Native Voltage overlay that does not introduce new technology or voltages in the area; (2) a 765 kV overlay allowing the introduction of 765 kV transmission throughout the study footprint; and (3) Native Voltage with DC transmission that allows for the expansion of DC technology within the study footprint. Refer to Table 1.2-1, which describes the physical characteristics of the three (3) overlay scenarios. It shows how the number of new lines, total line miles, acres of right-of-way, river crossings, and substations differ between scenarios. It also breaks down each scenario geographically between Midwest ISO, PJM, and Total study footprint. Joint/DC represents AC and DC transmission projects that may constitute shared costs between Midwest ISO and PJM.

The data reveals, for example, that the Native Voltage scenario requires more new lines, more line miles, and more substations than the 765 kV overlay for the total study footprint but does, however, require less acres of right-of-way.

Table 1.2-1: Summary of RGOS Overlay Physical Infrastructure

Overlay	Purview	# of New Lines	Line Miles	Acres of Right of way	River Crossings	Substations
Native	Total	122	6,795	128,637	7	139
	Midwest ISO	107	5,938	109,248	7	119
	PJM	13	685	13,197	0	20
	Joint/DC	2	173	4,192	0	0
765	Total	90	6,412	138,612	7	124
	Midwest ISO	69	5,029	104,582	7	94
	PJM	17	1,047	23,891	0	30
	Joint/DC	4	336	8,139	0	0
Native DC	Total	113	8,033	150,094	7	132
	Midwest ISO	98	5,340	100,917	7	101
	PJM	17	836	16,289	0	21
	Joint/DC	1	1,857	32,887	0	10

* Right-of-way widths used in Calculation: 230 kV-100ft ; 345 kV-160ft; Dbl Ckt 345 kV-160ft; 765 kV-200 ft

Refer to Table 1.2-2, which describes the costs to build new transmission and generation for the three (3) overlay scenarios. Transmission costs were calculated by multiplying line mileage by cost per mile, with cost per mile differentiated by state. These calculations also included substations, transformers, and related infrastructure. Construction cost estimates also attempted to include the regulatory permitting process. The table categorizes these factors by Native Voltage, 765 kV, and Native Voltage with DC scenarios, as well as Midwest ISO, PJM, and Joint/DC geographies.

Based on these factors, RGOS produced total overlay estimates of \$16.3 billion (2010 USD) for the Native Voltage system, \$20.2 billion for 765 kV, and \$21.9 billion for the Native Voltage with DC scenario for the RGOS study footprint.

Generation costs were calculated by multiplying the total amount of RPS required MW by construction cost estimates of \$2 million per MW. This cost, at \$58.1 billion (2010 USD), does not vary between scenarios.

Table 1.2-2: 2010 Cost Summary - Construction (2010 USD In Millions)

Category	Geographic Purview	Native Voltage	765 kV	Native Voltage with DC
Transmission	Total	\$16,301	\$20,249	\$21,544
	Midwest ISO	\$13,865	\$15,098	\$12,882
	PJM	\$1,962	\$4,198	\$2,138
	Joint/DC*	\$484	\$955	6,744
Generation	Total	\$58,100	\$58,100	\$58,100
	Midwest ISO	\$44,737	\$44,737	\$44,737
	PJM	\$13,363	\$13,363	\$13,363
	Joint/DC*	\$ -	\$ -	\$ -
Total	Total	\$74,401	\$78,349	\$79,644
	Midwest ISO	\$58,602	\$59,836	\$57,399
	PJM	\$15,315	\$17,559	\$15,501
	Joint/DC*	\$484	\$955	\$6,744

Refer to Table 1.2-3, which describes 2010 Levelized Annual Costs, which are the total revenue requirements (2010 USD) for the three (3) scenarios. Revenue requirements refer to the total annualized costs for the new transmission and generation. These levelized annual costs are determined through application of proxy Attachment O of the Midwest ISO FERC tariff. Table 1.2-3 breaks these factors down by Native Voltage, 765 kV, and Native Voltage with DC (Native DC) scenarios, and Midwest ISO, PJM, and Joint/DC geographies.

RGOS found total study footprint annual levelized costs vary between \$1.7 billion per year for Native Voltage, to \$2.1 for 765 kV, to \$2.2 for Native Voltage with DC (Native DC), with generation annual costs at \$4.9 billion.

Table 1.2-3: Cost Summary - 2010 Levelized Annual Costs***

Category	Geographic Parview	Native Voltage	765 kV	Native DC
Transmission	Total	\$1,606	\$2,064	\$2,168
	Midwest ISO	\$1,410	\$1,537	\$1,304
	PJM	\$209	\$424	\$227
	Joint/DC*	\$57	\$102	\$656
Generation	Total	\$6,334	\$6,334	\$6,334
	Midwest ISO	\$4,931	\$4,931	\$4,931
	PJM	\$1,402	\$1,402	\$1,402
	Joint/DC*	\$ -	\$ -	\$ -
Total	Total	\$8,019	\$8,397	\$8,621
	Midwest ISO	\$6,361	\$6,469	\$6,236
	PJM	\$1,612	\$1,826	\$1,630
	Joint/DC*	\$57	\$102	\$656

Table 1.2-4 describes 2010 Annual Costs \$/MWh, which takes total costs from Table 1.2-3 and presents total costs as a per MWh value. This calculation is based on 88.6 TWh of energy delivered from renewable energy zones. Table 1.2-4 describes transmission and generation costs for the modeled RGOS renewable wind zone energy.

These are not incremental costs; rather, these are a comparative measure of total MWh cost if wind served as the only energy source relative to RGOS wind and transmission. This table indicates transmission costs for the modeled RGOS renewable energy wind zone delivered would be \$19, \$23, or \$25 per MWh based on the addition of the various RGOS transmission overlays in the Midwest ISO footprint. On the generation side, MWh cost would increase to \$72/MWh for all scenarios. It should be understood that the wind and the subsequent transmission have impacts on the entire system being served. This includes providing additional potential reliability benefits to the system for the transmission additions, as well as providing reductions in the production costs on the system. Within this study, only adjusted production costs were given a value to compare to the costs. Because costs are added to the system infrastructure as a direct result to the renewable energy zones to meet RPS requirements, the energy delivered from those zones was used as a common denominator for the per unit comparison.

Table 1.2-4: Cost Summary – 2010 Annual Costs (\$/MWh^{***})

Category	Geographic Purview	Native Voltage	765 kV	Native DC
Transmission	Total	\$19	\$23	\$25
	Midwest ISO	\$16	\$17	\$15
	PJM	\$2	\$5	\$3
	Joint/DC*	\$1	\$1	\$7
Generation	Total	\$72	\$72	\$72
	Midwest ISO	\$56	\$56	\$56
	PJM	\$16	\$16	\$16
	Joint/DC*	\$0	\$0	\$0
Total	Total	\$91	\$95	\$98
	Midwest ISO	\$72	\$73	\$70
	PJM	\$18	\$21	\$18
	Joint/DC*	\$1	\$1	\$7

* Joint/DC represents AC and DC transmission projects that may constitute shared costs between Midwest ISO and PJM. Note, too, there is one AC project: the Pioneer 765 kV project in Indiana. The rest represent DC projects.

** Transmission costs include line and substation cost estimates

*** Levelized annual costs determined through application of proxy Attachment O calculation to determine annual revenue requirements

**** Calculation based on energy delivered from renewable energy zones: 88.6 TWh (each overlay effectively delivered the same amount of energy)

Adding wind to the system reduces energy costs. This benefit is captured through the adjusted production cost calculated by dividing total production cost savings by total MWh. Refer to Table 1.2-5, which describes regional per MWh adjusted production savings based on 88.6 TWh of RGOS wind zone delivered energy. Adjusted cost savings within the Midwest ISO footprint for Native Voltage, 765 kV, and Native Voltage with DC (Native DC) scenarios would be \$41/MWh, \$43/MWh, and \$43/MWh (2010 USD), respectively.

Table 1.2-5: 2010 Adjusted Production Cost (APC) Savings (\$/MWh)

Entity	Native Voltage	765 kV	Native DC
Midwest ISO	\$41	\$43	\$42
Midwest ISOMAPP	\$56	\$57	\$57
Midwest ISOMAPP/PJM	\$62	\$63	\$63
Eastern Interconnect	\$62	\$63	\$63

Table 1.2-6 summarizes net cost. Subtracting 2010 MWh Adjusted Production Cost (APC) benefits from 2010 installed costs results in the following net costs per MWh of delivered RGOS wind zone energy.

Table 1.2-6: 2010 Net Total Cost Summary (\$/MWh)

Entity	Native Voltage	765 kV	Native DC
Midwest ISO	\$49	\$52	\$54
Midwest ISOMAPP	\$35	\$37	\$39
Midwest ISOMAPP/PJM	\$29	\$32	\$33
Eastern Interconnect	\$29	\$32	\$33

When analyzing the information presented in Tables 1.2-1–1.2-4, it is important to note while overall metrics show some disparity among plans, the Native Voltage and 765 kV overlays are very similar when looking solely at Midwest ISO-only impacts. It is more problematic, however, when comparing either of these two (2) overlays to the Native Voltage with DC option since DC transmission costs are not categorized as solely Midwest ISO or solely PJM because the lines start in one system and terminate in the other.

1.2.4 Native Voltage Overlay

The Native Voltage solution focuses on transmission development that does not introduce a new voltage class within areas. This means areas with 345 kV transmission as the native Extra High Voltage (EHV) transmission must be limited to a maximum of 345 kV transmission for new infrastructure expansion. However, those areas with existing 765 kV transmission would be allowed to expand 765 kV infrastructure. Refer to Figure 1.2-3, which depicts the Native Voltage transmission solution meeting the RGOS design criteria. For a large (42 in. x 36 in.), detailed version of the Native Voltage overlay, refer to Appendix 10, attached.




Figure 1.2-3: Native Voltage Transmission Overlay Strategy

As currently designed, the Native Voltage transmission overlay has the lowest construction cost. Although Native Voltage has more line miles than the 765 kV overlay, it requires fewer acres of right-of-way. When considering Midwest ISO alone, although the economic metrics of the Native Voltage overlay may not be as attractive as the metrics for the 765 kV overlay, Native Voltage requires about \$1,200M less in capital investment to construct. The Native Voltage plan, like the two other transmission overlays, achieves the reliability objectives of the study. However, this plan does not extend as far south as the other two plans. This is part of the reason the other plans have higher construction/capital costs.

The Native Voltage strategy does have some risks and benefits. If renewable energy mandates are increased within the study footprint, or if there is an increased need for exports, additional transmission may need to be constructed. This would likely require additional right-of-way and more miles of transmission line when compared to the 765 kV and Native Voltage with DC overlays. In the long-term, this may result in escalating costs and environmental impacts that are not accounted for in this study. However, the Native Voltage Overlay has less dependence on the future transmission expansion plans of neighbors. By not introducing new voltages, the Native Voltage strategy readily integrates into the existing Midwest ISO system and may allow for quicker construction and better sequencing with other overlay components compared with the 765 kV overlays. Additionally, this strategy possibly puts less cost at risk if actual wind requirements of the Midwest ISO states are determined to be lower than the amount of wind included in the RGOS study—a determination not yet made. This risk will be minimized by carefully sequencing the construction of whichever overlay is chosen.

1.2.5 765 kV Overlay

The 765 kV solution emphasizes the development of transmission that introduces a new voltage class to much of the RGOS footprint. Figure 1.2-4 depicts the 765 kV transmission solution meeting RGOS design criteria. For a large (42 in. x 36 in.), detailed version of the 765 kV overlay, refer to Appendix 10, attached.




Figure 1.2-4: 765 kV Transmission Overlay Strategy

The 765 kV overlay results in Adjusted Production Cost (APC) savings greater than the Native Voltage overlay. The 765 kV overlay also uses less line miles of transmission lines than the Native Voltage overlay, although the 765 kV overlay does require more acres of right-of-way due to the wider right-of-way needed for 765 kV transmission. However, in the Midwest ISO portion of the overlay, the comparison of transmission costs, mileage, and acreage may favor the 765 kV plan.

Selecting 765 kV as an overall strategy also holds risks. For example, system development may not be achievable without cooperation among the transmission expansion strategies of two RTO regions; e.g., investment in 765 kV construction within Midwest ISO may be more heavily dependent upon the investment of the 765 kV grid within the western PJM region than the Native Voltage overlay. Proper coordination of development within Midwest ISO is also an important consideration. Transmission built in the western portion of the footprint to 765 kV standards may default to 345 kV transmission operation if eastern portions of the Midwest ISO footprint do not commit to the same 765 kV development in the same time-frame, resulting in potential cost risk. Finally, introducing 765 kV into new portions of the footprint will require costs associated with the learning curve required for the development and management necessitated by a new voltage type in the system.

Adopting a 765 kV strategy does, however, offer a number of benefits. For example, the 765 kV overlay demonstrates the need for less miles of transmission than the miles of transmission required by Native Voltage to deliver the same amount of renewable energy. If wind development in the region continues to increase over the future—and it is reasonable to expect this would be a continuing trend—the 765 kV overlay will reduce the amount of environmental impact caused by transmission construction. Although the current 765 kV plan has the potential to create better interconnection access to areas to the south and Southeast of Midwest ISO, additional refinement of the 765 kV plan that results in the same geographical footprint access as the current Native Voltage design could further reduce the line mileage of the strategy while also reducing total costs.

1.2.6 Native Voltage with DC Overlay

The Native Voltage with DC solution focuses on the development of transmission that introduces a new voltage class to much of the RGOS study footprint. Figure 1.2-5 shows the Native Voltage with DC transmission solution that meets RGOS design criteria. For a large (42 in. x 36 in.), detailed version of the Native Voltage with DC overlay, refer to Appendix 10, attached.




Figure 1.2-5: Native Voltage with DC Transmission Overlay Strategy

The Native Voltage with DC overlay provides benefits to the system—reducing, for example, the amount of AC transmission needed by allowing energy to be gathered in the western region of the study footprint and delivered to points to the east while avoiding potential impacts on the underlying systems. This scenario demonstrates that the crossing under Lake Michigan has the potential to reduce land-based transmission within Wisconsin and along the southern shores of Lake Michigan. Like 765 kV, Native Voltage with DC accesses part of the footprint that the Native Voltage strategy would not.

Land-based High Voltage Direct Current (HVDC) transmission was modeled as conventional HVDC. However, there are other options for the DC design available for future analysis that may provide for operational benefit that could not be captured through this study. For example, HVDC-Voltage Source Control (VSC) provides real power flow control beyond generator dispatch at full range of capability where conventional has limitations at lightly loaded schedules. In addition, HVDC-VSC has voltage control capability independent of the real power flow on the line, whereas conventional design reactive support is dependent on the real power flow. Finally, it is more functional in being able to interconnect at more intermediate locations compared to conventional HVDC which limits intermediate interconnection points.

Unfortunately the costs of adding DC to the system are rather high compared to the AC alternatives at shorter distance needs, and the entries to tap the lines are much more expensive and less integrated than providing AC paths across the system. However, it is difficult to eliminate DC transmission as an option for bulk energy delivery from renewable energy areas across long distances because of not-yet-evaluated option values. Proper evaluation of these other metrics along with improved design of what type of HVDC as well as interconnection locations could improve the case for long-distance DC energy delivery.

1.3 RGOS Candidate Multi-Value Projects

Although RGOS focused on the development of holistic system solutions meeting long-term needs for the integration of renewable resources into the transmission system, it is important to identify an initial group of projects that are compatible with the three overlays that provide a practical first step towards meeting the renewable resource requirements. Midwest ISO staff has developed an analytical framework to identify the best potential transmission projects. These RGOS-identified projects will require more detailed analysis. Because a Midwest ISO long-range transmission expansion strategy has not yet been determined and was not within the scope of RGOS analysis, it is important Candidate Multi-Value Projects (MVPs) not pre-determine Midwest ISO long-range strategic aims and equally important Candidate MVPs prove compatible with all potential strategies.

Refer to the Venn diagram in Figure 1.3-1 conceptualizing RGOS Candidate Multi-Value Project (MVP) selection.




Figure 1.3-1: Candidate MVP Strategy Development Venn Diagram

1.3.1 Identifying RGOS Candidate Multi-Value Projects

The RGOS inputs into the Candidate Multi-Value Projects (MVPs) portfolio were identified by means of the steps outlined below. Please note other studies were considered in collecting the final Candidate MVP portfolio; not all projects in that portfolio are derived from the RGOS study effort. For greater detail regarding the steps comprising the Candidate MVP identification process, refer to section 7 of this document. For a summary of the future ramifications of Candidate MVP portfolio identification, refer to section 8.

- Step 1: Identify useful corridors common to multiple Midwest ISO studies.
- Step 2: Identify RPS timing needs and synchronize with generation interconnection queue locations.
- Step 3: Evaluate constructability of transmission.

An initial set of transmission projects was identified using the inspection steps listed above. These transmission projects served as an input into the overall Candidate MVP portfolio described in section 7.1. The selected Candidate MVPs are compatible with RGOS-developed overlays and provide potential value for other needs identified within the transmission system. Refer to Figure 1.3-2, which depicts Candidate MVPs from the RGOS analysis. Estimated cost for this RGOS Candidate MVP set is approximately \$5.8 Billion, with \$4.4 billion of that amount within Midwest ISO borders.




Figure 1.3-2: RGOS-identified Candidate Multi-Value Projects
 (Midwest ISO and PJM Lines Shown)

The numbered list shown in Table 1.3-1, below, corresponds to the Candidate MVP identifiers depicted in Figure 1.3-2 on the previous page.

Table 1.3-2: Candidate Multi-Value Projects

ID	Candidate MVP	Estimated Installed Cost (2010 USD in millions)
1	Big Stone to Brookings 345 kV line	150
2	Brookings to Twin Cities 345 kV line	700
3	Lakefield Junction to Mitchell County 345 kV line constructed at 765 kV specifications	600
4	North LaCrosse to North Madison to Cardinal, Dubuque to Spring Green to Cardinal 345 kV lines	811
5	Sheldon to Webster to Hazleton 345 kV line	458
6	Ottumwa to Adair to Thomas Hill, Adair to Palmyra 345 kV lines	295
7	Palmyra to Meredosia to Pawnee, Ipava to Meredosia 345 kV lines	345
8	Sullivan to Meadow Lake to Greentown to Blue Creek 765 kV line	908
9	Collins to Kewanee to Pontiac to Meadow Lake 765 kV line	984
10	Michigan Thumb 345 kV transmission loop	510
11	Davis Besse to Beaver 345 kV line	71

The RGOS effort encompassed not only Midwest ISO but also immediate neighbors within PJM. This broadening of the study footprint resulted in development of transmission overlays that also include transmission within the PJM footprint. However, for purposes of Candidate Multi Value Project (MVP) evaluation, only Midwest ISO projects are included.

1.4 RGOS Results Summary

RGOS provides industry stakeholders and policy makers with a regional planning perspective identifying potential investment opportunities and demonstrating the integration of renewable energy policies into electrical system development. The purpose of RGOS has been to explore long-term transmission strategies ensuring study defined reliability objectives in delivery of renewable energy as well as RPS compliance. Aside from developmental considerations and regulatory concerns, determining a long-term transmission expansion strategy also serves to frame and define near-term needs. With these factors in mind, RGOS contributors considered the following when formulating viable long-term transmission strategies:

- **Performance:** Does the proposed strategy perform well under a variety of future scenarios?
- **Developmental Considerations:** Noting many of the more reliable wind resources reside far from large electrical load centers and lack adequate long-distance transmission lines, what is the expectation for further long-term development of wind resources within Midwest ISO?
- **Time Constraints:** Can finalizing a single, long-term strategy decision be deferred long enough to allow continued testing of important assumptions without jeopardizing legal requirements and renewable investment or risking the potential for stranded investment?

The best fit solution is a transmission overlay encompassing all Midwest ISO states, premised on a distributed set of wind zones, each with varying capacity factors and distances from load.

Midwest ISO cannot currently recommend a long-term transmission development strategy employing Native Voltage, 765 kV, or Native Voltage with DC. All three plans meet study objectives. Costs and benefits vary between scenarios, but not significantly. Methodologies for analyzing performance under a variety of possible futures require continued development along with determining 'options value' for each strategy. Detailed construction design analysis is still required.

No consensus exists regarding the amount of renewable generation ultimately needed to comply with current and future RPS mandates. Predictions vary. Some assert a much higher level of wind generation will be required than those included in RGOS analyses while others, equally confident, claim a lower amount. Regardless of the long-term uncertainty engendered by expansion or reduction of renewable energy standards, states within the Midwest ISO system will need new transmission to meet current and near-term renewable energy requirements, to ensure reliable operation of the transmission grid, and to facilitate the generation interconnection queue process. Midwest ISO will continue to work with policy makers and industry stakeholders to determine a strategy for transmission development within the footprint.

Because of RGOS, Midwest ISO has identified the next, most immediate step to transmission investment: a set of robust Candidate Multi-Value Projects (MVPs) meeting current renewable energy mandates and the regional reliability needs of its members.

The best fit solution is a transmission overlay encompassing all Midwest ISO states, premised on a distributed set of wind zones, each with varying capacity factors and distances from load.

2 Scope

2.1 Stakeholder Study Participation

Stakeholders reviewed and contributed to RGOS throughout the study process. A Technical Review Group (TRG), composed of regulators, transmission owners, renewable energy developers, and market participants, met monthly with Midwest ISO engineers to provide input, feedback, and guidance. Composed of a smaller group of experienced transmission engineers, a Design Subteam (DST) met bi-weekly to review detailed results. RGOS reported regularly to the Midwest ISO Planning Advisory Committee (PAC) and Planning Subcommittee (PSC). RGOS transmission planners also conferred with the Upper Midwest Transmission Development Initiative (UMTDI), a group of Governor-appointed representatives from Wisconsin, Iowa, Minnesota, South Dakota, and North Dakota.

2.2 Stakeholder Survey Results

In 2008, at the onset of Phase I of the RGOS study, a stakeholder survey was completed for the states of Illinois, Iowa, Minnesota, and Wisconsin. The purpose of the survey was to determine the renewable energy requirements; i.e., the Renewable Portfolio Standards (RPS), of the various Load Serving Entities (LSEs) in those states. The results were published in the RGOS Phase I Executive Summary Report¹. Likewise, another survey was performed during the summer 2009 to update RGOS Phase I information and to gather LSE renewable requirements from the remaining Midwest ISO states. The surveys also included the PJM members Commonwealth Edison (CE) and American Electric Power (AEP).

This inquiry sought detailed information regarding the plan of each company to meet the requirements of their particular RPS or goal. Each State also received a survey for their perspective. The survey results provided specific and current information on the RPS and wind assumptions within the RGOS study area, such as the following:

- Identifying the RPS mandates and respective plans by each LSE, by state
- Determining how and to what extent each LSE intends to utilize wind generation to meet its RPS obligations
- Calculating the energy projections of each LSE for each year under its RPS

The information obtained from these surveys was vital in determining the amount of renewable energy and capacity to study. Not all the LSE's responded to the survey resulting in some data being determined through a similar survey by the Organization of Midwest States (OMS) Cost Allocation and Regional Planning (CARP) Working Group.

¹ RGOS Phase I Executive Summary Report

Table 3.2-1 below summarizes the results of the RGOS survey, identifying total and net renewable energy requirements, existing and planned renewable energy, and the net renewable capacity for 2027. Table 3.2-1 also identifies the amount (in percent) of each state's RPS expected to be served by wind energy. The 'Total Energy Required' column is the net requirement after applying the "% of RPS by Wind" percentages. As can be seen in Table 3.2-1, some states have more existing renewable energy than required by their respective mandates or goals. Existing renewables were only counted towards the requirements of the respective state in which these renewables originate; thus, an excess of existing wind in one state was not counted towards the requirements in another state. In Iowa, for example, it was not fully known where an excess of that state's existing renewable energy is being supplied. Confining source to state also reduced the risk of double counting if an LSE is fulfilling part of its requirements by deriving some of its renewable energy from another state.

Table 2.2-1: RGOS Survey Results

State	% of RPS by Wind	Total Energy Required (GWh)	Existing & Planned (GWh)	Net Needs (GWh)	Wind Zoned Capacity (MW)
IA	100%	348	10,272	-	4,650
IL	75%	17,906	5,006	12,297	2,200
IN	-	-	2,263	-	1,000
MI	92%	7,684	366	7,518	3,150
MN	96%	22,766	6,929	15,857	3,875
MO	90%	6,591	439	6,152	1,000
MT	-	-	-	-	400
OH	100%	26,244	3	26,241	5,075
WI	53%	14,630	1,869	12,671	2,325
ND	-	1,463	4,752	-	2,325
SD	-	1,294	626	668	2,325
Total	-	99,136	39,216	61,496	28,325
RTO					
Midwest ISO	-	76,707	32,165	62,028	21,562
PJM	-	20,428	1,050	19,378	6,743

Note the following:

- "Existing & Planned" refers to wind farms or other qualifying renewable energy source currently in operation or holding a signed Generator Interconnection Agreement.
- The Wisconsin RPS is 10% of energy served from renewable; however, it has been adjusted to 25% per direction from the State of Wisconsin.
- Several sources were considered in order to determine the most up-to-date levels of Existing and Planned renewable energy within the study footprint. Those sources included LSE surveys, Midwest ISO Operations data, and data compiled from the SMARTtransmission² study.

² SMARTtransmission

2.3 Wind Zone Development

A key assumption of the RGOS study has been the amount and location of wind energy zones modeled within the study footprint. Wind energy zone development was based on stakeholder surveys focusing on expected renewable energy needs over the next 20 years and how much of that need is expected to be met with wind generation.

During RGOS I and RGOS II wind zone development, Midwest ISO staff provided for consideration multiple energy zone configurations that met renewable energy requirements. In this process, study participants identified capital costs associated with generation capacity as well as capital costs associated with indicative transmission that would help deliver the energy to the system. In both RGOS I and II efforts, the most expensive energy delivery options were those options relying solely on the best regional wind source areas (with higher amounts of transmission needed) or those options relying solely on the best local wind source areas (with higher amounts of generation capital required).

As a result of RGOS I and RGOS II zone development efforts as well as interaction with regulatory bodies such as the Upper Midwest Transmission Development Initiative (UMTDI) and various state agencies within Midwest ISO, a set of renewable energy zones was selected. These zones represent the intention of state governments to source some renewable energy locally while also using the higher wind potential areas within the Midwest ISO market footprint. Zone selection was based on a number of potential locations developed by the Midwest ISO utilizing mesoscale wind data supplied by the National Renewable Energy Laboratory (NREL) of the US Department of Energy. Wind zones distributed across the region (1) reflecting local development trends and requirements; or (2) occupying the best regional wind locations, results in a set of distributed wind zones best balancing renewable energy requirements and overall system costs.

Refer to Figure 2.3-1, which depicts this selected set of renewable energy zones, and to Table 2.3-1 and Table 2.3-2, which furnish zone-by-zone UMTDI and non-UMTDI selections, respectively.




Figure 2.3-1: Renewable Energy Zone Locations

Table 2.3-1: Renewable Energy Zone Information (UMTDI Zone Selection B)

Zone	State	CF	Nameplate (MW)	Energy Output (GWh)	Zone	State	CF	Nameplate(MW)	Energy Output (GWh)
IA-B	IA	0.366	775	2466	MN-L	MN	0.349	775	2369
IA-F	IA	0.362	775	2456	ND-G	ND	0.424	775	2879
IA-G	IA	0.354	775	2403	ND-K	ND	0.373	775	2532
IA-H	IA	0.367	775	2492	ND-M	ND	0.359	775	2437
IA-I	IA	0.356	775	2417	SD-H	SD	0.364	775	2907
IA-J	IA	0.327	775	2220	SD-J	SD	0.407	775	2763
MN-B	MN	0.393	775	2666	SD-L	SD	0.399	775	2709
MN-E	MN	0.382	775	2593	WI-B	WI	0.266	775	1806
MN-H	MN	0.368	775	2488	WI-D	WI	0.263	775	1821
MN-K	MN	0.334	775	2298	WI-F	WI	0.276	775	1874

Table 2.3-2: Renewable Energy Zone Information (non-UMTDI Zone Selections)

Zone	State	CF	Nameplate (MW)	Energy Output (GWh)	Zone	State	CF	Nameplate(MW)	Energy Output (GWh)
IL-A	IL	0.310	550	1494	MI-I	MI	0.269	350	794
IL-B	IL	0.296	550	1436	MO-A	MO	0.358	500	1606
IL-F	IL	0.300	550	1446	MO-C	MO	0.330	500	1446
IL-K	IL	0.262	550	1214	MT-A	MT	0.432	400	1614
IN-E	IN	0.311	500	1362	OH-A	OH	0.272	725	1727
IN-K	IN	0.281	500	1276	OH-B	OH	0.271	725	1721
MI-A	MI	0.264	300	684	OH-C	OH	0.280	725	1775
MI-B	MI	0.274	500	1200	OH-D	OH	0.282	725	1800
MI-C	MI	0.298	500	1306	OH-E	OH	0.285	725	1820
MI-D	MI	0.281	500	1231	OH-F	OH	0.281	725	1765
MI-E	MI	0.272	500	1191	OH-I	OH	0.407	725	2586
MI-F	MI	0.270	500	1183					

The capacity factors used in Table 2.3-1 and Table 2.3-2 are weighted capacity factors (CFs) developed as part of RGOS Phase I analysis. For further information regarding CF calculations, refer to section 9 of MTEP09 and the RGOS Phase I Executive Summary Report. In selecting renewable energy zones, a general methodology was used:

1. UMTDI B zones from the RGOS Phase I were used for the western footprint to meet local needs.
2. Michigan would meet all of its energy needs within the state of Michigan in accordance with state legislation.
3. Ohio, Missouri, and Illinois would meet 50% of their needs with respective in-state resources to reflect state legislation and the desire for local development.
4. UMTDI group B zones, Montana, and Indiana were used to meet the remaining renewable energy needs of Ohio, Missouri, and Illinois.
5. Target energy from renewable energy zones was 81,406 GWh.

2.4 Study Methodology

There were three (3) primary steps utilized in the development of the transmission overlays. These steps include both production cost and Power Flow analysis, with each technique providing its own value to the process. The starting point of this analysis was the indicative transmission developed during RGOS Phase I and Phase II studies in 2008 and 2009. For more information regarding this development process, again refer to MTEP09 report, Section 9.

2.4.1 Production Cost Analysis

Power Flow reliability analysis was conducted using a production cost model as a starting point. This starting point analyzed the energy flow on the system and reduced the indicative transmission to a limited level of transmission to achieve economic energy flow. Production cost modeling uses a limited list of reliability constraints for analysis, and therefore should not be considered an optimal solution without reliability model analysis.

The production cost model included the transmission infrastructure contained within the RGOS peer-reviewed 2019 Power Flow model. The initial production cost analysis was based on the Organization of Midwest ISO States (OMS) Cost Allocation and Regional Planning (CARP) developed Business as Usual with High Demand and Energy Case. Refer to Table 2.4-1, which posits the primary assumptions associated with the development of this case.

Table 2.4-1: Key Assumptions for Economic Model Development

Uncertainty	Value
Demand Source	Module E 2009 Submittal
Demand Growth	1.6% Annual Escalation
Energy Growth	2.19% Annual Escalation
Natural Gas Cost (2010 Henry Hub)	\$6.22/MBtu
Carbon Cost/Cap	No Cap nor Cost applied
Reserve Target	15% of Midwest ISO Coincident Peak Demand

Note each overlay was compared to a base run that included new wind zone generation without additional transmission beyond 2019 base case assumptions. The base run included typical flowgates, and was not screened for additional flowgates that might have the potential to severely restrict RPS wind injections resulting in 'dump' energy.

The production cost model uses an event file to perform contingencies and system monitoring. This event file was updated with 'local' contingencies to capture wind effects, and contains Midwest ISO and NERC flowgates. These flowgates will not show the outlet issues associated with the zones. To add relevant constraints to the modeling, Midwest ISO staff utilized the Power Flow Analysis Tool (PAT).

2.4.2 Linear Power Flow Analysis

The reduced amount of transmission developed through the production cost analysis of the indicative transmission designs was then added to the off-peak (70% of peak load), shoulder Power Flow model. Linear analysis on the off-peak shoulder model identified additional reliability constraints that were addressed. The bulk of the reliability analysis fell within the off-peak shoulder case work effort.

Once all selected criteria violations were identified and solutions proposed, plans were analyzed using an on-peak model as well as a light load (40% of peak load) model.

MTEP09 Power Flow models were used in the development of the 2019 peak and off-peak models. These models were created within the Midwest ISO Model On Demand database and include 2019 summer peak load cases, which were then modified to produce the 2019 off-peak model used in the analysis. The MTEP10 Power Flow model was used to create the light load model employed in analysis. The external representation used for the MTEP models are the NERC ERAG MMWG models. The latest MRO models were used to update non-Midwest ISO Midwest Reliability Organization (MRO) data. Midwest ISO system updates were added through the stakeholder process. Neighboring utility updates were provided by SPP, TVA, and PJM.

The 2019 model contains all projects moving to MTEP Appendix A or Appendix B as well as those MTEP Appendix B projects identified with a "Planned" status designation. Given the uncertainty of their respective status, those projects in MTEP Appendices B and C not moving to MTEP Appendix A in the current planning cycle will be removed or not incorporated in RGOS models. Designing RGOS (or any) transmission system dependent on projects not confirmed for development or potentially destined for replacement by an alternative project would adversely impact the final set of transmission projects.

NERC Category A, B and C events were used in Power Flow analysis. A comprehensive Category C evaluation was not performed. Category C events were limited to select events greater than 230 kV supplied by stakeholders, and double branch contingencies within a bus of each zone's outlet facilities were used. Category C events were tested for energy zone outlet restriction and for potential cascading events. These cascading events were defined as situations in which transmission facilities experience a maximum loading of 125% or higher, as compared to the facility's emergency ratings. All elements greater than 100 kV were monitored during analysis. However, only elements greater than 200 kV in violation were addressed for solutions. All other elements were identified and included within the evaluation of the overlays.

It is understood that evaluating the system reliability for violations on the 230 kV system and above misses constraints on the lower voltage system. This may result in the understatement of the wind curtailment within the economic models as well as the amount of transmission that must be considered for full reliability modeling impact. However, it is a functional screen of the impacts caused by the injection of new resources on the system. Future evaluation of an overall strategy may need to assess the lower voltage concerns in its final decision on the proper transmission expansion strategy for the Midwest ISO footprint.

2.4.3 AC Power Flow Analysis

AC Power Flow analysis was performed on the same peak, off-peak, and light load models used in the linear flow analysis by employing an AC Power Flow solution with the same contingency files used in linear Power Flow work. This analysis helped identify an approximation for reactive and capacitive support on the system, improving the accuracy of cost estimates and providing a more holistic solution to stated RGOS objectives.

2.4.4 Study Objective Change

Initially, the RGOS study was commissioned to develop and analyze multiple transmission overlay solutions that would meet the desire to deliver the RPS requirements in a reliable and economically conscientious way. It was expected that the study would identify a single strategy that would guide transmission investment for the next 20 years. However, during the development and analytics of the

overlays, it was determined by Midwest ISO staff and management that none of the overlays stood out as the proper strategy to push forward for all future EHV transmission development.

Because an overall strategy for future transmission development was deemed inappropriate at this time, the RGOS study focused on transmission projects identified within the study that facilitate RPS requirements throughout the study footprint while not predetermining a long-term transmission investment strategy.

3 Renewable Energy Requirements

The bulk of the generation expansion within the RGOS study footprint will consist of resources that will be required to meet legislated renewable energy requirements and goals. Based on RGOS survey results and the current construct of the Midwest ISO Generation Interconnection Queue (GIQ), wind will be relied upon to meet the majority of the requirements. Therefore, the RGOS study focused on the development of a transmission system that would help facilitate the wind contribution to the renewable energy requirements.

3.1 Renewable Portfolio Standards

The Midwest ISO region observed two significant drivers for transmission expansion: (1) state RPS mandates; and (2) associated generation in the Midwest ISO Generation Interconnection Queue (GIQ).

Some states within the Midwest ISO purview; i.e., Montana, Minnesota, Wisconsin, Iowa, Missouri, Illinois, Michigan, Ohio, and Pennsylvania, currently have RPS mandates that require varying percentages of electrical energy be met from renewable energy resources. North Dakota and South Dakota do not have an RPS but do have renewable goals. Kentucky and Indiana currently have neither RPS mandates nor goals. RPS mandates vary from state to state in specific requirements and implementation timing but generally start at or around 2010 and continue into the next decade. Refer to Figure 3.1-1.




Figure 3.1-1: RPS Requirements within Midwest ISO Footprint

The second major driver for transmission expansion is the Midwest ISO Generation Interconnection Queue (GIQ), which—as of the end of July 2010—held approximately 64,500 MWe of wind requests. After careful examination of the inherently complex issues involved, Midwest ISO staff and stakeholders determined the GIQ process would not be an efficient means for building a cost-effective transmission system over the next 5–10 year period or in the foreseeable future beyond that time-frame.

Each state has specific requirements associated with RPS mandates and goals. Most of the legislated mandates within the study footprint come to maturity between 2015 and 2025. Refer to Table 3.1-1 for a summary of the percentages of energy to be served over time, by year.

Table 3.1-1: 2016–2025 RPS Targets

Year	Wind Energy (%)	Solar Energy (%)	Hydro Energy (%)	Geothermal Energy (%)	Biomass Energy (%)	Other Energy (%)	Renewable Energy (%)	Non-Renewable Energy (%)	Total Energy (%)	CO2 Emissions (MMT)	
2015	10.00%	12.00%	18.00%	10.00%	10.00%	3.50%	5.00%	15.00%	5.50%	10.00%	105
2016	10.00%	17.00%	25.00%	11.50%	10.00%	4.50%	5.00%	15.00%	6.00%	10.00%	105
2017	10.00%	17.00%	25.00%	13.00%	10.00%	5.50%	5.00%	15.00%	6.50%	10.00%	105
2018	10.00%	17.00%	25.00%	14.50%	10.00%	6.50%	10.00%	15.00%	7.00%	10.00%	105
2019	10.00%	17.00%	25.00%	16.00%	10.00%	7.50%	10.00%	15.00%	7.50%	10.00%	105
2020	10.00%	20.00%	30.00%	17.50%	10.00%	8.50%	10.00%	15.00%	8.00%	10.00%	105
2021	10.00%	20.00%	30.00%	19.00%	10.00%	9.50%	15.00%	15.00%	8.00%	10.00%	105
2022	10.00%	20.00%	30.00%	20.50%	10.00%	10.50%	15.00%	15.00%	8.00%	10.00%	105
2023	10.00%	20.00%	30.00%	22.00%	10.00%	11.50%	15.00%	15.00%	8.00%	10.00%	105
2024	10.00%	20.00%	30.00%	23.50%	10.00%	12.50%	15.00%	15.00%	8.00%	10.00%	105
2025	10.00%	25.00%	30.00%	25.00%	10.00%	12.50%	15.00%	15.00%	8.00%	10.00%	105

For a tabular breakdown of respective state RPS requirements, refer to Appendix 2 of this document.

4 Renewable Energy Zones Development

4.1 Wind Analysis

Significant work was performed in 2008 and 2009 relating to wind data development and analysis for the RGOS Phase I study, completed in 2009. This work was essential to the RGOS Phase I effort and carried over into further development of renewable resources for current RGOS study work. No consistent source for geographically disparate wind data existed within the RGOS study region at the start of the study. Although basic wind speed information has been available for many years, factors such as wind speed, for example, leave too many unanswered assumptions for the purposes of a detailed statistical and economic study. Other factors include—but are not limited to—wind power output, time correlation with load, turbine class used, terrain, weather, and available capacity. Although data from existing wind farms in the Midwest ISO region could have been used, there were limitations to this data, such as size and quantity, geographic diversity, output history, and future technology or turbine classes.

As identified in the RGOS Phase I Executive Summary Report³, the Generation Interconnection Queue (GIQ) was not, of itself, an appropriate identifier for wind resources to perform this study. As reported in the RGOS Phase I report in July 2008, the Midwest ISO Queue had 350 wind interconnection requests totaling 67,000 MW, and the PJM Queue had 42,400 MW of wind, of which 27,000 MW was in the RGOS study region. This totaled over 94,000 MW of wind generation which could have been used during the RGOS study. Impartially selecting a subset of queued projects to meet identified state renewable energy requirements without detailed wind data would have been difficult.

Several additional issues made using GIQ data problematic, to include:

- Queue requests for wind had increased in locations with an RPS, which could potentially bias zones towards states with RPS and against potentially higher capacity factor sites in states that do not have such mandates, such as North and South Dakota, and Indiana.
- The location of generation interconnection requests were potentially biased by other criteria not related to the wind capacity factor, such as the generators' location in relation to available transmission, wind turbine transportation, and financing. However, it was recognized that most of the wind interconnection requests do occur in the high wind areas, and that this would be accounted for in any statistical analysis of wind potential in the region.

Midwest ISO worked with the National Renewable Energy Laboratory (NREL) throughout 2007 and early 2008 in a collaborative effort with the Joint Coordinated System Plan (JCSP) and was aware NREL would be performing the Eastern Wind Integration and Transmission Study (EWITS), a comprehensive study of wind in the Eastern Interconnect. In March 2008, NREL engaged AWS Truewind to develop a set of wind resource and plant output data for the eastern United States for EWITS. The statement of work identified five (5) technical tasks to developing high resolution wind power output data in 10-minute increments for years 2004, 2005, and 2008. The methods used and results achieved are described in the following sections. The final results and a study report are available on the NREL website at <http://wind.nrel.gov/public/EWITS>.

³ RGOS Phase I Executive Summary Report

4.1.1 Renewable Energy Zone Scenario Development

The information gathered in performing the metrics work discussed in Section 4.1 was used to identify an appropriate weighting system for developing the renewable energy zones. The renewable energy zones were developed on a state-by-state basis taking advantage of the highest eleven (11) year average capacity factor sites in each state. Selected sites were lumped together to achieve an energy zone that had an approximate capacity of 2,400 MW, while maximizing the overall capacity factor of the energy zone. Many energy zones were developed for each state in this manner. Based on the metrics, weighted values were created and used to rank the zones. The four (4) weighted measures and their weighting are as follows, where on-peak hours are 8AM-10PM, afternoon on-peak hours are 3PM-6PM, and summer months are June, July, and August:

- **Weighted Capacity Factor (CF)**
 - 11-Year average CF 50%
 - 3-Year average CF 10%
 - On-peak CF 10%
 - Afternoon On-peak CF 10%
 - Summer On-peak CF 10%
 - Summer Afternoon On-peak CF 10%
- **Distance to Load Center**
- **Weighted Variability**
 - Variance of hourly wind output 25%
 - Standard Deviation 25%
 - Average hourly ramp-up 25%
 - Average hourly ramp-down 25%
- **Distance to Infrastructure**
 - Distance to existing transmission (>300 kV) 33.3%
 - Distance to Railroads 33.3%
 - Distance to major highways 33.3%

For each renewable energy zone developed, weighted metrics were calculated as a composite of the selected sites in that zone. The weighted capacity factor was converted to a \$/MWh value based on a capacity of 750MW from each zone and a cost of \$2M/MW for wind turbines. Distance-to-load center values were calculated by taking the distance from each selected site to the nearest large load center. Distance to infrastructure was used to help select zones that may otherwise have a similar metrics score to another zone, by giving preference to a zone close to existing infrastructure. Proximity to major railroads and highways aids in the delivery and construction of necessary substations and wind farms.

Wind zones were created in each state once a process methodology was established. Even though North Dakota, South Dakota, and Indiana do not have RPS mandates in accordance with RGOS scope, they do have extensive wind resources and thus were used to provide possible renewable energy to the study. In order to establish local versus regional energy sources—again per study scope—energy zone scenarios were created, each concentrating on local to load center wind (with most of the renewable energy zones located within each state, respectively), remote to load center wind (utilizing higher capacity factors and transporting the wind as needed) and a local and remote combination. A ranking was applied to the four (4) measures described in the last section to create a score from 0-100 for each energy zone. Appropriate renewable energy zones were selected for each scenario based on those rankings. For renewable energy zones in the western part of the footprint, the Upper Midwest Transmission Development Initiative (UMTDI) Zone Scenario B was used.

For each scenario, the top ranking zones were selected as sites for renewable generation until the needed amount of MWh's was sufficient to meet the RPS requirements. Since higher capacity factor areas produce more energy, the regional scenarios had fewer zones than the local scenarios.

The results of this work are shown in Figures 4.1-1–4.1-3, which depict the three (3) scenarios: local, regional, and combination, including the UMTDI Zone Scenario B.




Figure 4.1-1: Local Wind Zone Identification




Figure 4.1-2: Regional Wind Zone Identification




Figure 4.1-3: Combination Wind Zone Identification

To provide for a full range of opportunities in meeting various RPS and goal requirements, these three (3) renewable energy zone scenarios were adjusted to create two (2) additional scenarios. These five (5) scenarios include the following:

- **Local:** In the Local scenario, renewable energy requirements and goals will be met with resources located within the same state as the load.
- **Regional:** In the Regional scenario, renewable energy requirements and goals will be met with resources located in the highest ranking renewable energy zones regardless of respective zone location relative to the RGOS II load. This scenario will utilize the high capacity factor zones recommended by UMTDI from RGOS I.
- **Regional Optimized:** The Regional scenario results in capacity in excess of what is needed to at least cover the renewable requirements/goals. In the optimized case, the capacity in some zones is reduced to the extent there are just enough resources to cover renewable energy requirements/goals.
- **Combination:** In the Combination scenario, renewable energy requirements and goals will be met with a combination of resources located within the RGOS II states and those outside RGOS II states with the highest ranking. Emphasis will be given to state requirements to locate part or all of their resources used to meet renewable energy requirements and goals within those states. Also, distance to load centers will be given more emphasis when determining zones than in the Regional scenario.
- **Combination 75/25:** In this scenario, 75% of RGOS requirements are met with resources in the UMTDI zones and 25% of RGOS requirements are met within the remaining states.

5 Regional Transmission Designs

The goal of the Regional Generation Outlet Study (RGOS) is to develop transmission projects that will facilitate the state renewable energy mandates in the Midwest ISO footprint. The process used to meet this goal consists of detailed transmission design analysis to determine a transmission system that meets RGOS reliability objectives while delivering energy from the generation zones. Refer to Figure 5-1.




Figure 5-1: Balancing Generation and Transmission Investment

5.1 Indicative Transmission Designs

As in the RGOS Phase I, once candidate renewable energy zone scenarios were established for study, the next step was to design an indicative transmission system for those zones to connect to the grid and deliver energy to load. There were many different transmission designs that could be utilized to achieve this goal, all of which had different costs and benefits associated with them. The purpose of the Indicative Transmission Design phase of the study was to analyze these different alternatives and to quantify costs and benefits of these alternatives. These costs and benefits would then be used to provide information to select a final set of energy zones.

Indicative transmission designs were created with stakeholders by means of a design workshop. Stakeholders, specifically experienced transmission planners from the region, and Midwest ISO staff developed the different transmission alternatives for economic analysis. The process consisted of developing an assumption set to guide the indicative development process, understanding the various renewable energy zone scenarios, and finally developing an indicative set of transmission that could potentially supply the renewable energy. The indicative transmission was developed without the use of system modeling or analysis; rather, the task was achieved by harnessing the collective knowledge of workshop participants, all experienced transmission planners. Again, the point of the exercise was to develop transmission that could "indicatively" provide a solution.

5.1.1 Assumption Set

An assumption set was established by the stakeholders to develop the indicative transmission portfolios and apply costs to them. The indicative transmission portfolios were developed without the benefit of transmission simulations; i.e. Power Flow, so a consistent assumption set had to be employed to compare the transmission portfolio of one energy zone scenario against another.

The primary assumption for the indicative transmission development was that the system would be considered self-healing. It would not depend on the underlying system in the indicative design phase. For this work, Surge Impedance Loading (SIL) ratings were used for new transmission lines. This eliminated the need for Power Flow analysis in the indicative stage since a 'self-healing' plan minimized the impact of new transmission on the existing system. Actual analysis of Power Flow was planned for the conceptual transmission design phase to evaluate the underlying system impacts and would use normal and emergency line ratings. 750 MW of capacity would be exploited from each zone. Other assumptions included the approximate range of capacity for 345 kV and 765 kV transmission using SIL as a limiter. Note economic parameters were also developed for calculating the cost of the transmission. Refer to Table 5.1-1, which shows the capital costs applied to the transmission.

Table 5.1-1: Transmission Line Cost Assumptions used within Indicative Work Efforts (2010 USD in Millions)

KV	MD OR	IA	WI	IL	MO	IN	MI	OH PA
345	2	1.5	2.5	2	1	1.8	1.8	2
2-345	2.5	2.1	3	2.6	1.5	2.3	2.3	2.5
500	3.5							
765	4.8	4.2	4.8	4.2	4.2	4.4	3.6	4
400	0	0	0	0	0	0	0	0
800	2.2	2.2	2.2	2.2	2.2	2.2	2.2	2.2

Note wind generation at \$2/MW was used for the wind turbine capital costs.

5.1.2 Indicative Transmission Results

Given the five (5) renewable energy zone scenarios, several indicative transmission overlays were created using 345 kV, 765 kV, and DC transmission options. For additional details regarding Indicative Transmission Design, refer to Appendix 3, which shows the transmission and renewable energy zone maps for the various overlays. Financial results are shown in Table 5.1-2.

Table 5.1-2: Indicative Transmission Costs (2010 USD In Millions Sorted by Total Cost)

Voltage (kV)	Zone Scenario	Generation	Transmission	Total
345	Combination 75/25	\$82,300	\$18,601	\$80,901
345	Combination	\$85,300	\$18,601	\$83,901
765	Combination 75/25	\$82,300	\$25,193	\$87,493
765	Combination	\$85,300	\$25,192	\$80,492
765	Regional Optimized	\$80,800	\$30,428	\$81,228
765/DC	Regional Optimized	\$80,800	\$33,981	\$84,781
765	Regional	\$88,900	\$30,428	\$97,328
765/DC	Regional	\$88,900	\$33,981	\$100,881
765/DC	Regional Optimized	\$80,800	\$47,855	\$108,655
345	Local	\$91,400	\$18,291	\$110,691
345	Regional Optimized	\$80,800	\$51,260	\$112,060
765	Local	\$91,400	\$22,553	\$113,953
765/DC	Regional	\$88,900	\$47,855	\$114,755
345	Regional	\$88,900	\$51,260	\$118,160

As can be seen from Table 5.1-2, all four (4) Combination scenarios demonstrated the lowest overall cost alternative. The "Bathtub Curve" for these scenarios can be seen in Figure 5.1-1 (also refer to section 5 of this document). Hence, a Combination set of zones was selected as the basis for moving forward to select a final set of renewable energy zones. Feeding into the final zone selection for each scenario were other state requirements in addition to energy. For example, the State of Michigan requires the state RPS be served 100% internally to the state. In Ohio, the requirement is 50%, and Illinois has a preference defined in its requirements for local wind. As a result, Missouri, Illinois, and Ohio renewable energy zones were selected based on at least 50% of the wind requirements being served within that respective state. Input on the final zones was gathered from Midwest Governors Association (MGA), the Upper Midwest Transmission Development Initiative (UMTDI), and from stakeholders—including non-Midwest ISO, PJM members Commonwealth and American Electric Power.




Figure 5.1-1: Zone Scenario Generation and Transmission Cost Comparison

For greater detail regarding indicative transmission results, design, and optimization, refer to Appendix 3 of this document. Also refer to Midwest ISO Transmission Expansion Plan (MTEP) 2009, which more fully describes the rationale driving zone scenario origination.

5.2 Model Development

5.2.1 Power Flow Model Creation

The majority of the transmission design analysis was conducted on a MTEP09 series 2019 summer peak model. This model was developed via the MTEP09 model building effort with considerable stakeholder review. It was used for two sets of analyses: a summer off-peak analysis and a summer peak analysis. For the summer off-peak analysis, the base transmission model was modified to create a shoulder-peak (70% load level) Power Flow model for the RGOS I system analysis in mid-2009 and sent to the stakeholders for additional review. Both the summer peak and summer off-peak models were updated for

the full RGOS analysis effort in early 2010 and sent to the stakeholders for a final review. A list of the major transmission upgrades made to this model since the RGOS I study effort is included in the public folder located at:

<http://mtep.midwestiso.org/mtep10/RGOS/report/Appendices4-6.zip>

And includes the following MS Excel .xlsx spreadsheet files:

- A4_1_Native Voltage.xlsx
- A4_2_Native Voltage with DC.xlsx
- A4_3_765 kV.xlsx

A secondary set of analyses were performed on a light load model. This model was converted from a MTEP10 series 2015 light load scenario to a 2019 light load scenario. The model, in addition to being developed and reviewed through the MTEP model building effort, was also provided to the stakeholders for additional review. A list of the major modeling corrections made to this model is also included in the public folder identified above and includes the following MS Excel .xlsx spreadsheet files:

- Modeling Corrections - 765 Modeling Documentation.xlsx
- Modeling Corrections - NV with DC Modeling Documentation.xlsx
- Modeling Corrections - NV wo DC Modeling Documentation.xlsx

External transmission system representation in the MTEP series models was provided by the Eastern Interconnection Reliability Assessment Group (ERAG) Multi-Regional Modeling Working Group (MMWG) North American Electric Reliability Corporation (NERC) models, except for the non-Midwest ISO MRO members, where the latest Midwest Reliability Organization (MRO) models were used. Commonwealth Edison and American Electric Power (AEP) supplied system updates directly to the RGOS study effort for their respective transmission systems. The base MTEP models included all transmission projects moving to MTEP Appendix A or B as well as Appendix B and C projects with a status of Planned. Prior to the start of the RGOS work, any projects in Appendix B or C that were not moving to Appendix A in the MTEP10 planning cycle and have a voltage class greater than 300 kV were removed from the model. These projects could have a significant impact on the transmission network. As such, given the level of uncertainty on whether the projects will be constructed or not, it was determined that designing the RGOS transmission system dependent on these projects adds additional uncertainty to the final RGOS transmission portfolio.

5.2.2 Generation

As part of the MTEP10 model building process, a Regional Merit Dispatch (RMD) was created to aid in dispatching the Midwest ISO generation fleet for the various MTEP10 Power Flow models. This RMD was used to dispatch the wind zones into all the models used for the RGOS analysis. Commonwealth Edison supplied a generation dispatch for its system to enable the wind zones in its control area, and the generation in American Electric Power (AEP) was scaled down to enable the dispatch of the wind zones in its control area. Further information on RMD may be found in the MTEP10 report Appendix E1. Additionally, only existing generators and generators with an executed generator interconnection agreement were included in the Power Flow model.

Consistent with Midwest ISO Planning Subcommittee practices, generation from the energy zones was dispatched to the system at 90% and 20% of capacity for all zones in the shoulder-peak and peak models, respectively. No wind was dispatched in the light load model. Existing and planned wind generation already in the model was dispatched at this same level, respectively, for each model. Data analysis shows load levels between 40% and 80% of peak load, wind output can randomly vary from 0%–80%. The wind levels chosen for analysis represent a majority of the worst case conditions for each scenario—although it could be argued a light load, 90% wind output model should be considered to capture all the worst case scenarios. This light load, high-wind analysis, while initially part of the RGOS effort, was deferred due to time constraints.

Refer to Tables 5.2-1 and 5.2-2, which show the modeled capacity of each wind zone. It is important to note each zone was designed for a potential capacity of up to 2400 MWe even though transmission was not designed for that level of injection. Wind generation in the Midwest ISO footprint was delivered (sunk) to the Midwest ISO market. Generators in the Illinois Commonwealth Edison area are delivered to Commonwealth Edison (PJM), and the wind zones located in American Electric Power (AEP) were sunk to other AEP generation.

Table 5.2-1: Renewable Energy Zone Information (UMTDI Zone Selections)

Zone	State	Nameplate (MW)	Modeled Capacity		
			Off-peak (MW)	Peak (MW)	Light Load (MW)
IA-B	IA	775	698	155	0
IA-F	IA	775	698	155	0
IA-G	IA	775	698	155	0
IA-H	IA	775	698	155	0
IA-I	IA	775	698	155	0
IA-J	IA	775	698	155	0
MN-B	MN	775	698	155	0
MN-E	MN	775	698	155	0
MN-H	MN	775	698	155	0
MN-K	MN	775	698	155	0
MN-L	MN	775	698	155	0
ND-G	ND	775	698	155	0
ND-K	ND	775	698	155	0
ND-M	ND	775	698	155	0
SD-H	SD	775	698	155	0
SD-J	SD	775	698	155	0
SD-L	SD	775	698	155	0
WI-B	WI	775	698	155	0
WI-D	WI	775	698	155	0

Table 5.2-2: Renewable Energy Zone Information (non-UMTDI Zone Selections)

Zone	State	Nameplate (MW)	Modeled Capacity		
			Off-peak (MW)	Peak (MW)	Light Load (MW)
IL-A	IL	550	495	110	0
IL-B	IL	550	495	110	0
IL-F	IL	550	495	110	0
IL-K	IL	550	495	110	0
IN-E	IN	500	450	100	0
IN-K	IN	500	450	100	0
MI-A	MI	300	270	60	0
MI-B	MI	500	450	100	0
MI-C	MI	500	450	100	0
MI-D	MI	500	450	100	0
MI-E	MI	500	450	100	0
MI-F	MI	500	450	100	0
MI-I	MI	350	315	70	0
MO-A	MO	500	450	100	0
MO-C	MO	500	450	100	0
MT-A	MT	400	360	80	0
OH-A	OH	725	652.5	145	0
OH-B	OH	725	652.5	145	0
OH-C	OH	725	652.5	145	0
OH-D	OH	725	652.5	145	0
OH-E	OH	725	652.5	145	0
OH-F	OH	725	652.5	145	0
OH-I	OH	725	652.5	145	0

5.3 Analyses

5.3.1 Initial Energy Model Results

The first transmission analytical step of the RGOS process was the evaluation of the combination ('Combo') indicative overlays with the selected RGOS zones in a production cost model. The analysis consisted of four (4) iterations of PROMOD runs that reduced the indicative overlays that delivered energy and showed utilization of the transmission lines identified in the overlays. Through this process, the RGOS study was able to reduce the inherent overbuild of the indicative work to a set of transmission that provided energy flow based on modeled flowgates, delivered the renewable energy zones, and provided a starting point for the more detailed Power Flow work.

The primary metric to reduce overlay transmission was line utilization. Within the first iteration, all transmission segments with peak line flow less than 20% of the rated limit were removed from the overlay. Iterations 2 and 3 removed all transmission loaded less than 30% of the rated limit was also removed. Iteration 4 removed additional under-utilized transmission while using engineering judgment to ensure overlay circuits were not radial and made general sense in system configuration.

5.3.1.1 Native Voltage Overlay

The Native Voltage overlay saw significant reduction in the process of eliminating under-utilized transmission. Between iteration 1 and iteration 4, 128 line segments and autotransformers were removed from the overlay, reducing the high-level generic cost of the overlay used in this stage of the analysis from \$18 billion to \$10.3 billion. With better engineering judgment on the interconnection of the renewable energy zones, wind curtailment improved with the refinement. However, adjusted production cost savings also decreased—but not at the same rate as the cost to add the transmission to the system. Refer to Table 5.3-1, which provides more detail on the outputs of the energy model iterations.

Table 5.3-1: Native Voltage Overlay Information from Initial Energy Model Analysis

Iteration	Rough Costs (2009 \$M)	20% LARR (2009 \$M)	APC Savings (annual) 2019 \$M			Wind Curtailment ^{**}
			Midwest ISO	RGOS	Eastern Interconnect	
1	18,024	3,606	609	749	718	0.84%
2	16,677	3,335	614	758	718	0.85%
3	9,697	1,939	459	567	547	2.42%
4	10,269	2,054	487	602	558	0.71%

* Costs represent 345 @\$1.5/M, 345-2 @\$2.0/M, 765 @\$3.0/M and a 25% adder for station costs
 ** 10.44% Wind Curtailment prior to indicative transmission additions

Refer to Figures 5.3-1 and 5.3-2, which show the overlay at the beginning and end of the energy model refinement.




Figure 5.3-1: Native Voltage Indicative Overlay (Iteration 1)




Figure 5.3-2: Native Voltage after Production Cost Modeling Optimization (Iteration 4)

5.3.1.2 765 kV Overlay

The 765 kV overlay saw significant reduction in the process of eliminating under-utilized transmission. Between Iteration 1 and Iteration 4, 124 line segments and autotransformers were removed from the overlay. This reduced the high-level generic cost, used in this stage of the analysis, of the overlay from \$23.8 billion to \$15.6 billion. With better engineering judgment on the interconnection of the renewable energy zones, the wind curtailment improved with the refinement. However, adjusted production cost savings also decreased but not at the same rate as the cost required to add the transmission to the system. Refer to Table 5.3-2, which furnishes more detail on the outputs of the energy model iterations.

**Table 5.3-2: Native Voltage Overlay Information from Initial Energy Model Analysis
 Annual APC Savings (2019 USD in Millions)**

Iteration	Rough Costs (2009 \$M)*	20% ARR (2009 \$M)	Midwest SO	RGOS	Eastern Interconnect	Wind Curtailment**
1	23,752	4,750	702	926	887	0.89%
2	21,781	4,356	701	922	884	0.90%
3	16,960	3,392	669	924	883	0.14%***
4	15,564	3,113	556	785	737	0.10%

* Costs represent 345 @\$1.5M, 345-2@\$2.0M, 765 @\$3.0M and a 25% adder for station costs
 ** 10.44% Wind Curtailment prior to indicative transmission additions
 *** Primary reduction result of moving some of the wind zones to an indicative overlay station

Refer to Figures 5.3-3 and 5.3-4, which depict the overlay at the beginning and end of the energy model refinement.




Figure 5.3-3: 765 kV Indicative Overlay (Iteration 1)




Figure 5.3-4: 765 kV Overlay after Production Cost Modeling Optimization (Iteration 4)

5.3.1.3 Native Voltage with DC Overlay

The Native Voltage with DC overlay saw significant reduction in the process of eliminating under-utilized transmission. Between Iteration 1 and Iteration 4, 123 line segments and autotransformers were removed from the overlay, reducing the high-level generic cost of the overlay used in this stage of the analysis from \$23.5 billion to \$16.1 billion. With better engineering judgment on the interconnection of the renewable energy zones, the wind curtailment improved with refinement. However, adjusted production cost savings also decreased but not at the same rate as the cost required to add the transmission to the system. Refer to Table 5.3-3, which offers more detail on the outputs of the energy model iterations.

Table 5.3-3: Native Voltage Overlay Information from Initial Energy Model Analysis

Iteration	Rough Costs (2009 \$M)*	2011 ARR (2009 \$M)	APC Savings (annual) 2019 \$M			Wind Curtailment**
			Midwest ISO	RGOS	Eastern Interconnect	
1	23,524	4,705	734	986	965	0.85%
2	22,457	4,491	734	989	996	0.85%
3	14,654	2,931	673	925	927	0.32%
4	16,109	3,222	734	1023	1035	0.04%

* Costs represent 345 @\$1.5/M, 345-2 @\$2.0/M, 766 @\$3.0/M and a 25% adder for station costs and a cost of \$5.5B for the DC transmission

** 10.44% Wind Curtailment prior to indicative transmission additions

Refer to Figures 5.3-5 and 5.3-6, which show the overlay at the beginning and end of the energy model refinement process.




Figure 5.3-5: Native Voltage with DC Indicative Overlay




Figure 5.3-6: Native Voltage with DC Overlay after Production Cost Modeling Optimization

5.3.2 Power Flow Analysis Set-up

A set of monitored and contingent elements was created and constraints were defined prior to beginning Power Flow analysis. Voltage and thermal design criteria from each Transmission Owner were applied during the analysis. Voltage limitations were set through the monitored element file and thermal ratings of elements were taken from the Power Flow case. More details on the monitored, contingent elements, and constraint parameters are discussed below.

5.3.2.1 Monitored Elements

The study footprint included the entire Midwest ISO footprint, along with the footprints of American Electric Power, Commonwealth Edison, and MAPP. Overloads identified outside of the study footprint were evaluated for their impact; all constraints outside the footprint with a meaningful cause and material impact on the RGOS footprint were mitigated. All elements greater than 100 kV were monitored during analysis, but the primary focus of the study was overloads on transmission elements with a voltage of 230 kV or higher. More details on the monitored elements are shown in Table 5.3-4, below.

Table 5.3-4: Monitored Elements Metrics and Criteria

Metric	Criteria
Thermal Monitoring	<ol style="list-style-type: none"> 1. System intact 2. All transmission with thermal loadings over 90% of the normal rating (Rate A) was monitored during the analysis. 3. Category B Contingencies: <ol style="list-style-type: none"> a. All transmission with thermal loadings over 90% of the emergency rating (Rate B) was monitored during the analysis. 4. Category C Contingencies: <ol style="list-style-type: none"> a. All transmission with thermal loadings over 125% of the emergency rating (Rate B) was monitored during the analysis.
Voltages	<ol style="list-style-type: none"> 1. System intact 2. All voltages greater than or less than the TO thresholds were monitored during the analysis.

5.3.2.2 Contingency Set-Up

NERC Category A and B events were used for the primary RGOS analysis, including the blanket outage of any 200 kV or higher facilities as well as the implementation of the contingency files provided throughout the MTEP study process. Selected Category C events were also analyzed in the analysis. These events include the double outage of lines surrounding each wind zone, and they also included the 'critical few' double outage contingencies provided by stakeholders. The contingency files used were from the MTEP10 reliability study and consistent with NERC, regional, state, and local planning criteria. These contingency files were screened for compatibility with each model, any discrepancies resolved.

5.3.2.3 Constraint Criteria

All 200 kV or higher transmission with overloads was identified as a constraint and appropriate mitigation was taken. More details on the specific constraint mitigation for each portion of the analysis are shown in Table 5.3-5, below.

Table 5.3-5: Constraint Metrics and Criteria

Metric	Criteria
Thermal Monitoring	<ol style="list-style-type: none"> 1. System Intact: 2. All 200 kV+ transmission with thermal loadings over 100% of the normal rating (Rate A) was considered a constraint. 3. Category B Contingencies: <ol style="list-style-type: none"> a. All 200 kV+ transmission with thermal loadings over 100% of the emergency rating (Rate B) was considered a constraint. 4. Category C Contingencies: <ol style="list-style-type: none"> a. All 200 kV+ transmission with thermal loadings over 125% of the emergency rating (Rate B) was considered a constraint.
Voltages	All voltages on a 200 kV+ buses that were greater than or less than the TO thresholds were considered constraints.

5.3.3 NERC Transmission Planning Standards

North American Reliability Corporation (NERC) Transmission Planning standards TPL-001-0, TPL-002-0, and TPL-003-0 specify system performance requirements for the Bulk Electric System (>100 kV) under system intact (Category A), single element events (Category B), and multiple element events (Category C) for a variety of system conditions. Transmission planners must analyze and design the system to meet these system performance requirements or face monetary penalties. The standards specify the type of events to be analyzed and the system performance required for the different categories of events. System intact performance has the most restrictive performance requirements for voltage levels and thermal loadings on equipment. Single element events, loss of any single line or transformer or generator or shunt, must result in system performance within applicable voltage limits and thermal ratings. There should be no loss of load on the system not directly involved in the event. The system must also be stable, with no cascading outages. For multiple element outages, the system must be within limits, stable, and with no cascading outages. However, system adjustments including controlled loss of load or firm transfers are allowed to mitigate contingent performance issues associated with Category C events.

The intent of the RGOS effort was to examine system performance, with NERC TPL standards as a reliability guideline, to determine transmission upgrades to provide system intact and contingent performance standards. The focus of reliability study efforts was fixed on providing adequate capacity to deliver power and energy from wind energy zones.

Refer to Table 5.3-6. NERC Category A, B, and select C events were used in Power Flow analysis. The category C events applied to greater than 230 kV events as supplied by stakeholders, and bus double branch contingencies within a bus of each zone's outlet facilities was used. Category C events tested for energy zone outlet restriction and for potential cascading events. These cascading events were defined as situations in which transmission facilities experience a maximum loading of 125% or higher, as compared to the facility's emergency ratings. All elements greater than 100 kV were monitored during analysis while only elements greater than 200 kV in violation were addressed for solutions. All other elements were identified. NERC and regional entity (RE) planning criteria were applied. Transmission Owners' voltage and thermal design criteria were applied.

Table 5.3-6: Power Flow Solution Criteria

Metric	Criteria
Thermal Monitoring	<ol style="list-style-type: none"> 1. System intact 2. Thermal loadings over normal rating (Rate A). All transmission with thermal loadings between 90% and 100% of normal rating will be identified and noted and considered when comparing portfolios. 3. Contingent 4. Thermal overloads over emergency (Rate B). All transmission with thermal loadings between 90% and 100% of emergency rating will be identified and noted and considered when comparing portfolios.
Thermal Overload	<ol style="list-style-type: none"> 1. System intact 2. All transmission greater than 200 kV with thermal loadings greater than 100% of normal rating will be addressed for solution. 3. All transmission less than 200 kV with thermal loadings greater than 100% of normal rating will be identified and noted and considered when comparing portfolios. 4. Contingent 5. All transmission greater than 200 kV with thermal loadings greater than 100% of emergency rating will be addressed for solution. 6. All transmission less than 200 kV with thermal loadings greater than 100% of emergency rating will be identified and noted and considered when comparing portfolios.
High Voltage	<ol style="list-style-type: none"> 1. System intact 2. Voltages greater than TO thresholds will be addressed for solution on buses greater than 200 kV. All other buses will be identified and noted. 3. Contingent 4. Voltages greater than TO thresholds will be addressed for solution on buses greater than 200 kV. All other buses will be identified and noted and considered when comparing portfolios.
Low Voltage	<ol style="list-style-type: none"> 1. System intact 2. Voltages less than TO thresholds will be addressed for solution on buses greater than 200 kV. All other buses will be identified and noted and considered when comparing portfolios. 3. Contingent 4. Voltages less than TO thresholds will be addressed for solution on buses greater than 200 kV. All other buses will be identified and noted and considered when comparing portfolios.

5.3.4 Off-peak Linear Analysis Results

The primary analysis was performed on a 2019, summer off-peak model. This model was chosen due to the likelihood of a high wind output during summer off-peak conditions. This analysis began with the transmission determined in the energy analysis, and it continued in a highly iterative fashion, with between 80 and 110 iterations were performed on each of the Native Voltage, Native Voltage with DC, and 765 kV scenarios. It also contained several different phases, as discussed below. Each of the phases was conducted in an iterative manner, with the transmission refinement relying heavily upon reruns of the Category A, B, and C analyses.

- Category A and B (System Intact and N-1) analysis focused upon the identification and mitigation of 200 kV and above Category A and B constraints. A large amount of transmission was added to the model during this period, with the end result being a system without an 200 kV and above constraints under system intact or single contingency conditions.
- Category C (N-2) analysis is based upon the results of the Category A and B analysis. It focused on potentially cascading system events, which were simulated in the model as any transmission element which has a 125% or greater loading under a Category C event.
- Transmission refinement/optimization was conducted to ensure that the transmission design was not overbuilt. It analyzed the transmission added through the energy and previous off-peak analysis to determine that the lines proposed were used and useful. If any line was found to be lightly loaded, it was removed from the model, and analyses were conducted to ensure that no new constraints occurred without the line.

These analyses resulted in a set of new transmission for each scenario that resolved all the thermal overloads on the system under peak conditions. This transmission was then used as an input for later analysis. Refer to Figures 5.3-7–5.3-8.




Figure 5.3-7: Native Voltage Off-peak Analysis




Figure 5.3-8: Native Voltage with DC Off-peak Analysis




Figure 5.3-9: 765 Kv Off-peak Analysis

Figure 8.3-10: Native Voltage Peak Analysis




Figure 5.3-11: Native Voltage with DC Peak Analysis




Figure 5.3-12: 765 kV Peak Analysis

5.3.5.2 Light Load Sensitivity Analyses Results

Light load sensitivity analyses were conducted to ensure system reliability with a full transmission buildout, without the support of wind from the wind zones. In particular, this scenario was designed to determine and mitigate any reactive (voltage) constraints which may occur due to the large reactive impact of the lightly loaded new transmission that was added during the off-peak and peak analyses. Light load analysis began with the transmission from the final peak sensitivity and relied upon AC analysis to determine any new thermal or voltage constraints.

5.3.6 Final Off-peak AC Analysis Results

The final step taken during RGOS Power Flow analysis was to run an off-peak AC analysis using transmission developed through the light load sensitivity. Final off-peak AC analysis had two (2) functions:

1. To test the transmission additions added in the peak and light load sensitivity analyses to ensure these additions did not create any reliability violations under off-peak conditions. This provided a final check, under a scenario with the highest wind output, ensuring RGOS plans were not harmful.
2. To find and resolve any lingering voltage violations.

After final off-peak analysis was completed, RGOS transmission scenarios were finalized and economic analyses were performed on each of the scenarios.

5.3.7 Lower Voltage Constraints

Refer to Table 5.3-7. Although RGOS analyses mitigated all constraints on the 200 kV and above transmission system, it did not explicitly attempt to mitigate constraints on the transmission system below 200 kV. These constraints were eliminated from the RGOS scope to minimize the study timeline and—due to the high level of Transmission Owner interaction—mitigate these lower voltage issues. All transmission constraints would require mitigation prior to any transmission plan or prior to any portion of a transmission plan being moved to MTEP Appendix A for approval and subsequent construction.

Although thermal analysis did not mitigate all sub-200 kV constraints, it did identify and track these constraints throughout the process. The first iteration of the Power Flow analysis, performed on the off-peak model with indicative transmission added from the final energy analysis, contained between 166 and 228 sub-200 kV overloaded lines, depending on scenario. After the final transmission scenarios had been developed and applied to the models, the off-peak model had 76–190 sub-200 kV overloaded lines. These final constraints would have to be mitigated prior to any RGOS plan being moved to MTEP Appendix A.

Table 5.3-7: Sub-200 kV Constraints

Scenario	Initial Sub 200 kV Constraints	Final Sub 200 kV Constraints
Native Voltage	228	190
Native Voltage with DC	147	76
765 kV	166	127

5.3.8 Energy Model Results

The production cost model is also used to evaluate the different strategies refined within the Power Flow reliability work effort. The information in this section was derived from the evaluating the transmission overlays as of the end of the off-peak reliability analysis. Because of this, transmission added because of light load or peak analyses are not included in this production cost model evaluation.

The production cost simulation models reliability at a high level. Unlike Power Flow analysis, which can simulate all possible system contingencies, the production cost model focuses solely upon those contingencies provided by the user that will have significant re-dispatch effects. Within this analysis, contingencies related to RGOS zones were not modeled as completely as the contingencies that may have resulted from adding the new overlay transmission. It is also important to note the events modeled focus primarily on the 230 kV and above transmission system. The ultimate effects of contingency limitations are there are unknown costs and benefits due to re-dispatch that have not yet been explored.

5.3.8.1 Cost Savings

RGOS focuses on the addition of incremental wind to meet the RPS requirements throughout the study footprint and the transmission that facilitates the delivery of the energy. By adding the wind to the system without any RGOS transmission, a reduction in adjusted production costs is recognized within the study footprint as well as some of the defined neighboring regions. This reduction is the result of adding low-cost energy to the system. This can be seen in column 2 of Table 5.3-8, which represents the change in adjusted production cost savings compared to a model that does not include RGOS wind or transmission. Adding the different transmission strategies shows additional benefit can be achieved within the study footprint.

Table 5.3-8: Adjusted Production Cost Savings (2010 USD in Millions)

Pool	+ RGOS Wind	Wind+Native	Wind+765	Wind+Native DC
PJM	\$560	\$527	\$512	\$500
MISO	\$3,265	\$3,664	\$3,767	\$3,747
TVASUB	(\$16)	(\$20)	(\$26)	(\$18)
MAPPCOR	\$1,222	\$1,293	\$1,317	\$1,339
SPP	(\$34)	(\$36)	(\$17)	\$25
SERCNI	\$6	\$15	\$18	\$6
IMO	\$11	\$19	\$21	\$24
MHEB	(\$14)	(\$7)	(\$6)	\$3
NYISO	(\$13)	(\$8)	(\$14)	(\$13)
RGOS (no mapp)	\$3,805	\$4,220	\$4,317	\$4,304
Eastern Int	\$4,966	\$5,446	\$5,571	\$5,613

Another metric that can be taken from the production cost model is load cost savings. In Table 5.3-9, it can be seen costs to load reduce with the addition of RGOS wind in most modeled regions, and then reduce even more with the addition of transmission to the system. This potential benefit is recognized more within the RGOS study footprint. However, other regions benefit from the greater availability of cheaper generation due to a greater abundance of low-cost energy within the study footprint.

Table 5.3-9: Load Cost Savings (2010 USD in Millions)

Pool	+ RGOS Wind	Wind+Native	Wind+765	Wind+Native DC
PJM	\$665	\$1,769	\$1,984	\$2,021
MISO	\$1,688	\$2,170	\$2,283	\$2,021
TVASUB	\$212	\$307	\$296	\$360
MAPPOR	\$1,776	\$1,591	\$1,405	\$1,168
SPP	\$41	(\$3)	(\$68)	\$125
SERCNI	\$57	\$279	\$290	\$502
IMO	\$104	\$145	\$201	\$205
MHEB	\$50	\$28	\$22	\$5
NYISO	(\$38)	(\$14)	(\$12)	(\$17)
RGOS (no mapp)	\$2,291	\$3,352	\$3,533	\$3,228
Eastern Int	\$4,754	\$6,274	\$6,404	\$6,409

5.3.8.2 RGOS Zone Energy Delivered

RGOS modeled an incremental 28 GW of wind within the study footprint to meet aggregate RPS requirements assumed within the study, resulting in modeling of 88.5 TWh of energy to be delivered to the system. Refer to Table 5.3-10, which shows approximately 8% of the wind was curtailed when adding RGOS-only wind. Curtailment occurred at locational Marginal Prices (LMP) of -\$40 defined within the model. The curtailment is a result of LMPs being suppressed due to modeled constraints on the system. It is expected this curtailment may be less than what actually should have been seen because of the lack of appropriately modeled constraints around the wind zones and bulk delivery paths. Refer to Table 5.3-10, which shows this curtailment of RGOS energy zones disappears when RGOS transmission is added to the system.

Table 5.3-10: RGOS Wind Zone Energy Delivered

Overlay	Installed RGOS Wind Zone		Delivered Energy (MWh)	Curtailment
	Nameplate (MW)	Modeled Energy (MWh)		
Base Case (wind added with no transmission)	28,325	88,560,920	81,417,776	8.07%
Native Voltage	28,325	88,560,920	88,533,050	0.03%
765 kV	28,325	88,560,920	88,560,920	0.00%
Native with DC	28,325	88,560,920	88,560,920	0.00%

5.3.8.3 Overlay Line Utilization Summary

Because the production model analyzes every hour within the modeled year, flow information on each of the modeled RGOS lines can be identified. Tables 5.3-11–5.3-13 summarize the max instantaneous loading of the RGOS lines identified in each overlay strategy. This loading is identified as a percentage of the stated rating within the tables. Also, these loadings represent system intact loadings. Because of this, some lines identified within the power flow analysis are primarily needed for reliability and thus load poorly under system intact conditions. More detailed information on each line can be found in the spreadsheet identified as Appendix 6: Production Cost Model Summary Results.

Table 5.3-11: Native Voltage Max Loading Summary

Utilization	Voltage (kV) & Rating (MW)		
	230 kV 340 MW	345 kV 1600 MW	765 kV 5000 MW
Total Lines	4	134	6
Loading at or above 20%	2	123	5
Loading at or above 30%	1	95	2
Loading at or above 40%	1	47	1
Loading at or above 50%	0	27	0

Table 5.3-11: Native Voltage Max Loading Summary

Utilization	Voltage (kV) & Rating (MW)		
	230 kV 340 MW	345 kV 1600 MW	765 kV 5000 MW
Loading at or above 60%	0	10	0
Loading at or above 70%	0	4	0
Loading at or above 80%	0	1	0
Loading at or above 90%	0	0	0
Loading at or above 100%	0	0	0

Table 5.3-12: 765 kV Max Loading Summary

Utilization	Voltage (kV) & Rating (MW)	
	345 kV 1600 MW	765 kV 5000 MW
Total Lines	62	34
Loading at or above 20%	52	34
Loading at or above 30%	31	30
Loading at or above 40%	19	26
Loading at or above 50%	11	14
Loading at or above 60%	3	7
Loading at or above 70%	0	3
Loading at or above 80%	0	3
Loading at or above 90%	0	0
Loading at or above 100%	0	0

Table 5.3-13: Native Voltage with DC Max Loading Summary

Utilization	Voltage (kV) & Rating (MW)			
	345 kV 1600 MW	765 kV 5000 MW	DC 1600	DC 6400
Total Lines	92	8	1	2
Loading at or above 20%	83	9	1	2
Loading at or above 30%	56	6	1	2
Loading at or above 40%	44	5	1	2
Loading at or above 50%	32	3	1	2
Loading at or above 60%	18	2	1	2
Loading at or above 70%	11	2	1	2
Loading at or above 80%	6	1	1	2
Loading at or above 90%	5	0	1	2
Loading at or above 100%	2	0	1	2

5.3.8.4 Interface Flow Summary

Hundreds of lines and autotransformers were modeled for RGOS-developed strategies. More detailed information can be found in Appendix 7: Native Voltage Transmission Detail Flow Information for the Native Voltage strategy; Appendix 8: 765 kV Transmission Detail Flow Information for the 765 kV strategy; and Appendix 9: Native Voltage with DC Transmission Detail Flow Information for the Native Voltage with DC strategy.

Another way to summarize the impact of RGOS transmission strategies is to conceptualize the flow of energy over defined interfaces. For purposes of this study, interfaces were defined as transmission lines crossing state boundaries. Table 5.3-14 provides information for the net energy flow within states containing RGOS lines that cross state borders for the Native Voltage overlay strategy.

Table 5.3-14: Native Voltage Strategy Net State Interface Flow Summary (RGOS Lines Only)

State(s)	Max Export (MW)	Max Import (MW)	# of Hours Exporting	# of Hours Importing
Dakotas Net	1,962	-489	8,376	380
IA Net	2,039	-633	7,729	1,028
IL Net	1,887	-2,546	3,779	4,974
IN Net	329	-2,052	202	8,555
MN Net	919	-2,031	1,399	7,354

Table 5.3-14: Native Voltage Strategy Net State Interface Flow Summary (RGOS Lines Only)

State(s)	Max Export (MW)	Max Import (MW)	# of Hours Exporting	# of Hours Importing
MO Net	1,213	-412	7,571	1,180
MT Net	223	-298	3,047	5,627
OH Net	889	-1,612	898	7,857
WI Net	1,974	-1,079	6,560	2,175

Figure 5.3-13 provides the net energy duration curve for each of the states previously identified with the modeled Native Voltage overlay. Referencing Table 5.3-14 and Figure 5.3-13, it can be seen areas with higher incremental wind penetration tend to be net exporters while states with more load and less wind capability tend to be net importers.




Figure 5.3-13: Native Voltage Strategy Net State Interface Duration Curves (RGOS Lines Only)

Table 5.3-15 and Figure 5.3-14 represent net state energy information for the 765 kV strategy overlay. It is evident more energy flows on the lines with the 765kV overlay than with the Native Voltage overlay. This should be expected because of the higher ratings and lower impedance of 765 kV transmission lines.

Table 5.3-15: 765 kV Strategy Net State Interface Flow Summary (RGOS Lines Only)

State(s)	Max Export (MW)	Max Import (MW)	# of Hours Exporting	# of Hours Importing
Dakotas Net	2,925	-872	8,351	405
IA Net	3,935	-1,401	8,121	639
IL Net	1,752	-8,447	929	7,830
IN Net	1,424	-3,552	537	8,222
MN Net	2,637	-2,184	6,932	1,822
MO Net	4,308	-2,003	7,154	1,604
MT Net	215	-297	2,915	5,789
OH Net	2,073	-3,479	701	8,058
WI Net	2,438	-2,019	5,430	3,326




Figure 5.3-14: 765 kV Strategy Net State Interface Duration Curves (RGOS Lines Only)

Table 5.3-16 and Figure 5.3-15 show net state energy information for the Native Voltage with DC transmission strategy. The purpose of DC transmission across the RGOS study footprint is to deliver high levels of energy across the system with minimal impact on existing transmission that it (DC transmission) bypasses. Because of the source and sink locations of the DC lines, the Dakotas, Minnesota, and Iowa see a high impact for net state export while Ohio experiences large imports due to most of the DC transmission sinking within Ohio state boundaries.

**Table 5.3-16: Native Voltage with DC Strategy Net State Interface Flow Summary
 (RGOS Lines Only)**

	Max Export (MW)	Max Import (MW)	# of Hours Exporting	# of Hours Importing
Dakotas Net	3,628	-249	8,704	56
IA Net	5,774	-610	8,450	309
IL Net	1,646	-3,622	3,566	5,194
IN Net	-81	-1,806	0	8,760
MI Net	2,485	-3,129	1,321	7,439
MN Net	4,793	-1,290	8,134	625
MO Net	1,100	-1,125	4,437	4,317
MT Net	241	-264	3,627	5,050
OH Net	2,614	-10,222	491	8,269
WI Net	1,600	-1,600	6,970	1,790




Figure 5.3-15: Native Voltage with DC Strategy Net State Interface Duration Curves (RGOS Lines Only)

To show in greater detail where energy is actually flowing, the following tables and figures show specific state-to-state RGOS line energy flow information. Max power flow and number of positive hours represent "from" to "to" flow while the min power flow and number of negative hours represent the opposite.

Table 5.3-17 and Figure 5.3-16 show the bulk of the energy flow tends to go west to east in the Native Voltage overlay study footprint.

Table 5.3-17: Native Voltage Strategy State Interface Flow Summary (RGOS Lines Only)

Interface	Max Power Flow (MW)	Min Power Flow (MW)	# of Hours Positive	# of Hours Negative
Dak to IA	400	-337	4,759	3,959
Dak to MN	2,042	-298	8,485	272
IA to IL	760	-466	7,835	911
IA to MO	438	-687	4,201	4,517
IA to WI	566	-100	8,674	81
IL to IN	2,060	-166	8,753	6
IN to OH	1,612	-888	7,857	898
MN to IA	980	-1,408	4,515	4,233

Table 5.3-17: Native Voltage Strategy State Interface Flow Summary (RGOS Lines Only)

Interface	Max Power Flow (MW)	Min Power Flow (MW)	# of Hours Positive	# of Hours Negative
MN to WI	462	-284	8,433	322
MO to IL	716	-462	7,802	941
MT to Dak	223	-296	3,047	5,627
NE to IA	42	-157	436	8,240
WI to IL	2,204	-741	8,440	316

* Positive numbers represent flows from A to B (Dakotas to MN) while negative numbers represent flow from B to A (MN to Dakotas).




Figure 5.3-16: Native Voltage Strategy State Interface Duration Curves (RGOS Lines Only)

As previously noted, the 765 kV overlay shows many of the same characteristics of the Native Voltage but at higher capacity levels. Table 5.3-18 and Figure 5.3-17 provide energy flow information for this strategy.

Table 5.3-18: 765 kV Strategy State Interface Flow Summary (RGOS Lines Only)

Interface	Max Power Flow (MW)	Min Power Flow (MW)	# of Hours Positive	# of Hours Negative
Dak to MN	2,943	-795	8,218	537
IA to IL	4,103	-993	8,623	137
IA to MO	2,056	-2,639	5,163	3,595
IA to WI	2,773	-372	8,698	63
IL to IN	3,545	-2,021	8,254	506
IN to OH	3,479	-2,073	8,068	701
MN to IA	5,097	-2,468	7,841	917
MO to IL	525	-256	7,417	1,301
MO to IN	2,440	-922	8,194	564
MT to Dak	215	-297	2,915	5,789
WI to IL	3,795	-1,750	8,423	336

* Positive numbers represent flows from A to B (Dakotas to MN) while negative numbers represent flow from B to A (MN to Dakotas).




Figure 5.3-17: 768 kV Strategy State Interface Duration Curves (RGOS Lines Only)

Table 5.3-19 and Figure 5.3-18 represent energy flow information for the Native Voltage with DC overlay. Because the DC overlay interconnects into the existing system at only a few points, new state interfaces are developed—the Illinois to Ohio interface, for example. It can also be seen some interface characteristics are different because of where the DC interconnects. For example, the general flow of energy goes from Missouri to Illinois in other overlays. However, with the DC line tying to the system south of a St. Louis in Illinois, the general energy flow of that interface flows from Illinois to Missouri.

Table 5.3-19: Native Voltage with DC Strategy State Interface Flow Summary (RGOS Lines Only)

Interface	Max Power Flow	Min Power Flow	# of Hours Positive	# of Hours Negative
Dak to MN	3,768	-322	8,681	79
IA to IL	6,400	0	8,308	0
IA to MO	324	-822	572	8,166
IL to IN	1,721	-131	8,750	10
IL to OH	8,000	0	8,397	0
IN to OH	493	-687	3,810	5,127
MN to IA	1,664	-1,496	4,531	4,225
MN to IL	6,400	0	8,300	0

Table 5.3-19: Native Voltage with DC Strategy State Interface Flow Summary (RGOS Lines Only)

Interface	Max Power Flow	Min Power Flow	# of Hours Positive	# of Hours Negative
MO to IL	552	-1,180	1,120	7,633
MT to Dak	241	-284	3,627	5,050
OH to MI	2,141	-1,968	4,167	4,569
WI to MI	1,600	-1,600	6,970	1,790

* Positive numbers represent flows from A to B (Dakotas to MN) while negative numbers represent flow from B to A (MN to Dakotas).




Figure 5.3-18: Native Voltage with DC Strategy State Interface Duration Curves (RGOS Lines Only)

To demonstrate a more integrated look of the impact of the RGOS lines added to the system, the following tables and figures show the interface energy flow summary from state-to-state with RGOS lines as well as existing transmission of 230 kV and greater.

Table 5.3-20 and Figure 5.3-19 represent the state interface flow of the base case. The base case is defined as adding RGOS energy zones to the existing transmission system without adding additional RGOS transmission.

Table 5.3-20: Base Case State Interface Summary (All Lines 230 kV and Greater)

INTERFACE	Max Power Flow (MW)	Min Power Flow (MW)	# of Hours Positive	# of Hours Negative
DK-MHEB	550	-500	1,968	6,771
IA-IL	1,098	-991	6,822	1,931
IA-MO	816	-776	5,194	3,538
IA-NE	1,850	-1,944	5,140	3,615
IA-SD	1,064	-880	4,395	4,350
IL-IN	6,383	-4,308	8,013	748
IL-KT	1,189	-165	8,738	21
IL-MO	1,897	-1,873	4,467	4,290
IN-OH	7,040	-3,390	8,084	695
MI-IN	3,981	-2,355	6,625	2,130
MI-OH	2,599	-1,921	6,571	2,186
MN-DAK	553	-1,514	254	8,504
MN-IA	1,248	-1,670	4,969	3,762
MN-MHEB	834	-855	26	8,734
MN-WI	2,258	-734	8,698	62
OH-PA	1,924	-3,745	2,556	6,198
WI-IL	1,314	-1,682	7,084	1,675
WI-MI	333	-77	8,243	478

* Positive numbers represent flows from A to B (Dak to MHEB) while negative numbers represent flow from B to A (MHEB to Dak).




Figure 5.3-19: Base Case State Interface Duration Curves (All Lines 230 kV and Greater)

Table 5.3-21 and Figure 5.3-20 represent the interface information for the Native Voltage overlay with existing transmission added. The impact of adding transmission to one or some of the interfaces may also have an effect on the energy flows of unaltered interfaces.

Table 5.3-21: Native Voltage Strategy State Interface Summary (All Lines 230 kV and Greater)

INTERFACE	Max Power Flow (MW)	Min Power Flow (MW)	# of hours Positive	# of Hours Negative
DK-MHES	467	-481	1,790	6,952
IA to WI	566	-100	8,675	81
IA-IL	2,245	-1,407	7,865	890
IA-MO	1,000	-1,321	5,293	3,464
IA-NE	1,859	-1,756	4,458	4,297
IA-SD	909	-1,224	2,889	5,885
IL-IN	8,729	-3,806	8,499	261
IL-KT	1,195	-182	8,724	36
IL-MO	2,136	-2,814	3,050	5,704

Table 5.3-21: Native Voltage Strategy State Interface Summary (All Lines 230 kV and Greater)

INTERFACE	Max Power Flow (MW)	Min Power Flow (MW)	# of Hours Positive	# of Hours Negative
IN-OH	7,882	-2,385	8,531	229
MI-IN	4,148	-2,336	6,302	2,455
MI-OH	2,754	-2,093	6,435	2,323
MN-DAK	811	-3,834	420	8,340
MN-IA	1,481	-2,201	4,789	3,967
MN-MHEB	788	-907	29	8,731
MN-WI	2,881	-1,184	8,684	98
OH-PA	1,989	-3,875	3,258	5,497
WI-IL	4,337	-2,141	8,259	501
WI-MI	341	-70	8,355	370

* Positive numbers represent flows from A to B (Dak to MHEB) while negative numbers represent flow from B to A (MHEB to Dak).




Figure 5.3-20: Native Voltage Strategy State Interface Duration Curves (All Lines 230 kV and Greater)

As mentioned previously, the 765 kV system shows those interfaces with new transmission have higher energy flow impacts than those with the Native Voltage overlay. This can be seen in Table 5.3-22 and Figure 5.3-21.

Table 5.3-22: 765 kV Strategy State Interface Summary (All Lines 230 kV and Greater)

Interface	Max Power Flow (MW)	Min Power Flow (MW)	# of Hours Positive	# of Hours Negative
Dak-MHEB	544	-473	1,476	7,275
IA-IL	5,158	-1,598	8,437	320
IA-MO	2,569	-3,191	5,363	3,395
IA-NE	1,620	-1,467	4,314	4,432
IA-SD	651	-811	3,745	5,001
IA-WI	2,773	-372	8,698	63
IL-IN	11,088	-4,908	8,490	269
IL-KT	1,204	-252	8,716	44
IL-MO	2,258	-2,323	3,995	4,763
IN-OH	12,019	-4,880	8,423	336
MI-IN	4,004	-2,478	5,533	3,225
MI-OH	2,694	-2,277	6,044	2,714
MN-DAK	1,140	-4,299	396	8,363
MN-IA	5,931	-3,450	7,444	1,318
MN-MHEB	819	-902	24	8,736
MN-WI	2,422	-633	8,684	76
MO-IN	2,440	-922	8,194	564
OH-PA	2,453	-3,720	4,027	4,730
WI-IL	4,884	-2,688	8,247	512
WI-MI	343	-71	8,333	393

* Positive numbers represent flows from A to B (Dak to MHEB) while negative numbers represent flow from B to A (MHEB to Dak).




Figure 5.3-21: 765 kV Strategy State Interface Duration Curves (All Lines 230 kV and Greater)

The DC transmission in the Native Voltage with DC overlay shows much of the same impacts with the existing system as without. Native Voltage with DC continues to demonstrate the transfer of large amounts of energy but also shows that selection of locations for the DC terminals can change characteristics of the energy flow across the system. This change in characteristics can be seen on the Iowa and Minnesota interface and the Missouri to Illinois interface. Refer to Table 5.3-23 and Figure 5.3-22.

Table 5.3-23: Native Voltage with DC Strategy State Interface Summary
(All Lines 230 kV and Greater)

Interface	Max Power Flow (MW)	Min Power Flow (MW)	# of Hours Positive	# of Hours Negative
DK-MNEB	444	-512	638	8,114
IA-IL	7,508	-1,073	8,448	311
IA-MO	741	-1,687	1,254	7,501
IA-NE	1,048	-2,626	638	8,120
IA-SD	908	-852	8,432	2,322
IL-IN	7,732	-4,287	6,880	1,800
IL-KT	1,263	-233	8,689	68

**Table 5.3-23: Native Voltage with DC Strategy State Interface Summary
 (All Lines 230 kV and Greater)**

Interface	Max Power Flow (MW)	Min Power Flow (MW)	# of Hours Positive	# of Hours Negative
IL-MO	3,276	-1,663	6,451	2,304
IL-OH	8,000	0	8,397	0
IN-OH	6,085	-2,977	7,712	1,046
MI-IN	4,813	-3,098	5,020	3,735
MI-OH	4,775	-2,806	6,619	2,138
MN-DAK	716	-5,530	103	8,657
MN-IA	1,854	-2,688	2,013	6,737
MN-IL	6,400	0	8,300	0
MN-MHEB	922	-903	23	8,737
MN-WI	2,119	-1,137	8,233	527
OH-PA	2,309	-3,885	3,974	4,784
WI-IL	1,599	-2,213	3,259	5,500
WI-MI	1,819	-1,855	7,081	1,879

* Positive numbers represent flows from A to B (Dak to MHEB) while negative numbers represent flow from B to A (MHEB to Dak).




Figure 5.3-22: Native Voltage with DC Strategy State Interface Duration Curves
(All lines 230 kV and Greater)

5.3.9 Sensitivity Analysis for RGOS Plans - Robustness Testing

With intensive stakeholder collaboration taking place under the Technical Review Group (TRG), three (3) distinct long-term transmission expansion scenarios have been developed to meet state renewable energy standards and goals encompassing the entire study footprint, as discussed in section 5. In parallel with RGOS study process, a collaborative effort on robust business case development has been undertaken through the MTEP10 planning process to enable a more holistic value assessment of transmission projects or portfolios. The sensitivity analysis for the three (3) RGOS plans has been performed within the context of the MTEP process to facilitate the business case development for new transmission.

The primary focus of sensitivity analysis effort is to determine the total values of the three (3) proposed transmission plans by means of a robustness testing process. To perform robustness testing, each of the three transmission solutions is assessed against a set of value measures across a broad range of plausible future scenarios. As a result, robustness testing under multiple futures provides additional quantifiable benefits to ensure a more complete evaluation on the performance of the three (3) transmission scenarios, and aid in identifying the best-fit long-term strategy which will result in the least future regrets regardless of policy decisions.

Recognizing the need for consideration of additional value measures and further methodology development in transmission business case analysis, the overall benefits of the three long-term strategies identified through the robustness testing process are indicative and are subject to change depending on the assumptions made to quantify the identified value measures and additional value measure inclusion. Without further development of value measure methodology including both financially quantifiable measures and non-financial measures, it will be premature to determine the overall comparative benefits of the RGOS transmission plans and select the definitive long-term strategy. However, with the substantial amount of valuable information resulting from sensitivity analysis, it allows policy makers and stakeholders to recognize that there is a broader set of values beyond satisfying public policy needs to support the implementation of regional plans.

5.3.9.1 Future Scenario Selection and Weights

The Planning Advisory Committee Process (PAC) developed an array of future scenarios (Futures). RGOS used the following:

- **S1: CARP Business As Usual with high Demand and Energy Growth Rates:** Considered the status quo scenario, with a quick recovery from the economic downturn in demand and energy projections. This future scenario models the power system as it exists today with reference values and trends with the exception of demand and energy growth rates.
- **S2: CARP Federal RPS:** Requires that 20% of the energy consumption in the Eastern Interconnect come from renewable resources by 2025. State mandates are the same as those modeled in the Business as Usual Future and any additional renewable energy is met with wind to satisfy the 20% renewable energy requirement.
- **S4: CARP Federal RPS, Carbon Cap and Trade, Smart Grid and Electric Cars:** Combines the impact of multiple future policy scenarios into one future. Smart grid is modeled within the demand growth rate. It is assumed that an increased penetration of smart grid will lower the overall growth of demand. Electric vehicles are modeled within the energy growth rate. Electric vehicles are assumed to increase off-peak energy usage and as such increase the overall energy growth rate.
- **S8: PAC Business as Usual with Mid-Low Demand and Energy Growth Rates:** Considered the status quo future scenario and continues the economic downturn-affected growth in demand, energy, and inflation rates.
- **S10: PAC Carbon Cap and Trade with Nuclear:** Models a declining cap on future CO2 emissions with an aggressive nuclear build out as carbon neutral resources.

The flexibility provided by the multi-dimensional scenario planning analysis allows a more complete robustness analysis around the long-term transmission plans. The weighting of the futures and how a transmission plan performs based on the assigned weights must be taken into account in order to more accurately select the appropriate strategy. To achieve this end, Planning Advisory Committee (PAC) sectors were requested to provide weights for the selected futures based on the possibility of each future relative to the others. The straight sector average weights assigned to each future are tabulated in Table 5.3-24.

Table 5.3-24: Future Scenario PAC Sector Average Weights

Future Scenarios	Weights
S8: PAC Business as Usual Mid-Low D+E	34%
S2: CARP Federal RPS Future	26%
S10: PAC Carbon Future - Carbon Cap with Nuclear	15%
S1: CARP Business as Usual with high growth rate for D+E	14%
S4: CARP Federal RPS + Carbon Cap + Smart Grid + Electric Cars	11%

5.3.9.2 Robustness Testing Process and Value Measures

As illustrated in Figure 5.3-23, robustness testing involves a comprehensive value assessment for transmission solutions utilizing a decision tree based methodology. To perform robustness testing, each transmission solution is tested across multiple future scenarios which it might not be designed for. The value of the transmission for each given future is then evaluated and quantified against a complete set of value measures. By applying the assigned future weights to the values derived from each future, the overall weighted average value is determined for each transmission solution. The ultimate goal of robustness testing is to identify the preferred transmission strategy that can provide the best value under most, if not all, future outcomes in order to minimize the risk associated with the various uncertainties surrounding policy discussions.

The Midwest ISO utilizes PROMOD IV[®], a commercial production cost model, to evaluate potential economic benefits of transmission plans. Production cost model simulations are performed with and without each developed transmission scenario. Taking the difference between these two (2) simulation results provides the economic benefits associated with each specific plan.




Figure 5.3-23: Indicative Robustness Testing Decision Tree Diagram

As a key component of transmission value assessment, the following financially quantifiable measures have been considered for making comparisons on the performance of the three (3) RGOS plans:

- a. **Adjusted Production Cost Savings** where total annual generation production costs include fuel, variable operations and maintenance (O&M) and start up costs, and are adjusted with off-system purchases and sales. The off-system purchases and sales are quantified using load weighted LMP and gen weighted LMP respectively. Adjusted production cost savings can be achieved through reduction of transmission congestion costs and more efficient generation resource utilization.
- b. **Load Cost Savings** where load cost represents the annual load payments, measured by projections in hourly load weighted LMP. Load cost savings and adjusted production cost savings are essentially two alternative benefit measures to address the single type of economic value and are not additive measures. Load cost savings is not used to calculate the total value of the RGOS plans in MTEP10.
- c. **Capacity Loss Savings** where capacity losses represent the amount of capacity required to serve transmission losses during the system peak hour. The intent is to capture the value of reducing the amount of capacity reserves that are required to maintain system reliability. The avoided capacity investment due to loss reduction is quantified using a generic overnight construction cost of \$950,000 per MW.
- d. **Capacity Savings Due to Planning Reserve Margin Reduction:** The intent of this measure is to capture the value associated with transmission plans by potentially lowering the overall Planning Reserve Margin requirement through congestion relief. Recognizing a relatively small reduction in reserve requirement would allow a significant amount of benefits to accrue, this measure is under consideration for inclusion in future evaluation of transmission plans/portfolios.
- e. **Carbon Emission Reduction Cost Savings:** To address carbon reduction legislation in some future scenarios, a certain cost on carbon is placed combined with uneconomic coal retirement deployment to achieve the high level carbon reductions. The cost of carbon is modeled in a way to only impact the unit dispatch as a penalty and exclude the costs associated with carbon emissions from production costs. The benefits of carbon emission reduction are additive to the adjusted production cost savings described above. The corresponding carbon cost modeled in each scenario is used to quantify the dollar value of carbon emission reductions.
- f. **Generation Revenue Due to Wind Curtailment Reduction:** With the new transmission corridors to access the remote wind resources, the curtailment level of wind energy is minimized substantially, particularly for the futures with aggressive RPS requirements. The revenue is quantified using annual generation weighted LMP for the RGOS footprint as an estimate. The intent of this measure is only to provide a standalone value associated with wind curtailment reduction and is not included in the overall value calculation, as this value is embedded in adjusted production cost savings described above.

Robustness testing for the three (3) long-term strategies has been focused on financially quantifiable measures as a starting point. There are other benefit measures including qualitative and risk factors that need to be taken into account to provide a more thorough analysis and allow a more complete value to be captured through the robust business case development process. Midwest ISO will continue to collaborate with stakeholders on further development of value measures as an ongoing effort in the next few planning cycles.

5.3.9.3 RGOS Transmission Plan Value Assessment Results

From the aforementioned list of financially quantifiable measures, only the mutually exclusive or additive measures were used to calculate the total value of RGOS transmission plans to avoid overstating the value of the plans. The straight sum of adjusted production cost savings, capacity loss savings and carbon emission reduction cost savings were used to determine the value of each plan for a given future scenario. Although the capacity savings due to PRM reduction is additive, it has not been evaluated due to time constraints. The overall aggregated financially quantifiable value for each RGOS plan is then determined by applying the PAC-assigned future weights to the value derived for each future. The total financially quantifiable value results for the three (3) RGOS plans are indicative, subject to change depending on the assumptions made to quantify the identified value measures and additional value measure inclusion. In general, the additive financially quantifiable benefits are considered for transmission value assessment. However, for the potential market efficiency projects, the RECBII economic benefit metric, a blend of 70% adjusted project cost benefit and 30% load cost savings, is still in place for transmission value evaluation. Specifically, the financially quantifiable value of each RGOS transmission plan was determined as follows:

Value of transmission plan (per future) = Sum of values of financially quantifiable measures

= Adjusted production cost savings + Capacity loss savings + Carbon emission reductions⁴

Value of transmission plan (overall) = Sum of value of the plan per future * future weights

= 34%*Scenario 8 + 15%*Scenario 10 + 14%*Scenario 1 + 26%*Scenario 2 + 11%*Scenario 4

For each RGOS transmission plan, the value of each individual financially quantifiable measure under each given future, the total value per future and the overall weighted value are succinctly illustrated through the decision tree diagrams in Figures 5.3-24–5.3-26.

⁴ The capacity savings due to PRM reduction is additive and is under development for inclusion in the total value evaluation.

Looking at the results, a wide range of potential benefits are achieved across the five (5) selected futures. Based on the robustness analysis process described above, the three RGOS plans are expected to bring an annual weighted financially quantifiable benefits ranging from \$1,064 million to \$1,830 million in year 2025 for RGOS study footprint. It is important to reiterate that values derived in this section are indicative and have only been used for the purpose of performance comparison among the three (3) long-term transmission strategies.




Figure 5.3-24: Indicative RGOS 765kV Plan Robustness Testing Results⁶

⁶ The RGOS transmission plans are still in development and the plan version used for robustness testing is as of May 25, 2010. All the results illustrated in the diagram are 2025 annual benefits and are calculated for RGOS study footprint.




Figure 5.3-25: Indicative RGOS Native Voltage Plan Robustness Testing Results⁶

⁶ The RGOS transmission plans are still in development and the plan version used for robustness testing is as of May 28, 2010. All the results illustrated in the diagram are 2025 annual benefits and are calculated for RGOS study footprint.




Figure 5.3-26: Indicative RGOS Native Voltage with DC Plan Robustness Testing Results⁷

⁷ The RGOS transmission plans are still in development and the plan version used for robustness testing is as of May 26, 2010. All the results illustrated in the diagram are 2023 annual benefits and are calculated for RGOS study footprint.

Table 5.3-25 summarizes the annual costs, financially quantifiable values, and benefit-to-cost ratios associated with each of the three (3) RGOS transmission plans. It shows the Native with DC option provides the highest benefit-to-cost ratio based on an annual analysis in year 2025. However, before determining an overall definitive long-term transmission strategy, an expanded business case analysis has to be in place with consideration of a more complete list of value measures. Each RGOS plan has its own risks and other pertinent factors that may significantly impact the way the preferred long-term strategy is identified, as described in section 1.

Table 5.3-25: RGOS Transmission Plan Cost and Benefit Comparison - 2025 USD in Millions

Transmission Plan Options	2025 Annual Transmission Cost ⁹	2025 Annual Total Financially Quantifiable Value ¹⁰	2025 B/C Ratio
RGOS 765kV	4,684	1,408	0.30
RGOS Native	3,816	1,084	0.28
RGOS Native With DC	4,868	1,830	0.38

Table 5.3-26 shows results of some additional quantifiable benefits, not necessarily financially quantifiable, that can be incorporated into the decision-making process. Moving forward, Midwest ISO will continue to refine the list of value measures and develop a methodology to better utilize non-financially quantifiable value measures, as well as ensure extensive stakeholder involvement throughout the process.

Table 5.3-26: RGOS Transmission Plan Comparison – Other Quantifiable Measures

Transmission Plan Options	Acres of Right of Way	Hourly Transmission Utilization (%)
RGOS 765kV	136,637	17%
RGOS Native	126,637	16%
RGOS Native With DC	150,084	21%

⁹ Annual cost in 2025\$ is calculated using 18.3% the Midwest ISO annual average charge rate based 2010 attachment O and 3% escalation rate. The RGOS plans are assumed to be in service at 2019. It is important to note that the cost estimates are used for benefit-to-cost ratio calculation only.

¹⁰ The total financially quantifiable value numbers are indicative and are subject to change depending on the assumptions on how to quantify the identified value measures and additional value measure development.

¹¹ The benefit-to-cost ratios are indicative and calculated using 2025 annual values only, not present values. The results are only intended to provide the comparison between transmission plans relative to each other.

¹² The percentage of hourly new transmission utilization is calculated for the CARPBAU future only, using the straight average of the hourly flows on the new RGOS transmission lines divided by the ratings.

6 Construction Cost Estimates

6.1 Estimating Assumptions

Cost of construction assumptions were developed through the study stakeholder process. Several assumptions were used to determine both capital and present value costs associated with the generation and transmission overlays developed. Table 6.1-1 and Table 6.1-2 summarize capital expenditures. Not shown in the tables is the cost for wind generation, which is \$2M per MW (2010 USD).

Table 6.1-1: Line Mile Costs - \$/Mile (2010 USD)

KV	IA	IL	IN	MI	MN	MO	MT	ND	OH	SD	WI
345	\$1.6	\$1.5	\$2.0	\$1.8	\$1.8	\$0.9	\$1.4	\$1.4	\$2.0	\$1.4	\$2.1
2-345	\$2.3	\$2.0	\$2.0	\$2.7	\$2.5	\$2.3	\$1.9	\$1.9	\$2.0	\$1.9	\$2.7
500	\$2.1	\$1.8	\$1.8	\$0.0	\$2.4	\$1.8	\$1.8	\$1.8	\$1.8	\$1.8	\$2.8
765	\$3.2	\$2.8	\$2.8	\$3.6	\$3.5	\$3.2	\$2.8	\$2.8	\$2.8	\$2.8	\$4.0
230	\$0.75	\$0.75	\$0.75	\$0.75	\$0.75	\$0.75	\$0.75	\$0.75	\$0.75	\$0.75	\$0.75
161	\$0.5	\$0.5	\$0.5	\$0.5	\$0.5	\$0.5	\$0.5	\$0.5	\$0.5	\$0.5	\$0.5
138	\$0.5	\$0.5	\$0.5	\$0.5	\$0.5	\$0.5	\$0.5	\$0.5	\$0.5	\$0.5	\$0.5
115	\$0.5	\$0.5	\$0.5	\$0.5	\$0.5	\$0.5	\$0.5	\$0.5	\$0.5	\$0.5	\$0.5
DC (OH)	\$2.2	OH - Overhead Construction									
DC (Mar)	\$3.0	Mar - Marine									

Table 6.1-2: Substation Costs (2010 USD)

KV	# Bays	(\$M)
115	2	\$9.0
138	2	\$9.0
161	2	\$9.0
230	2	\$9.0
345	2	\$11.8
765	2	\$25.1
DC Station +/- 800 KV - BI-Pole, 6400 MW		\$549.0
DC Station +/- 400 KV - BI-Pole 1000 MW		\$340.0
Two bays (3 CBs)		

Table 6.1-3: Transformer Costs (2010 USD)

kV	(\$M)
765/345	\$28.2
765/161	\$20.7
765/138	\$20.7
765/115	\$20.7
345/230	\$6.5
345/161	\$5.7
345/138	\$5.7
345/115	\$5.7
Note 765 Transformers include on-site spare.	

Table 6.1-4: Reactive Costs (2010 USD)

kV	(\$M MVAR)
345	\$0.0224
765	\$0.0560

Other factors used in developing capital costs included using a 50% multiplier for additions to existing substations. Existing substations were costed at half the price of a new substation unless more than two (2) bays were added, in which case no multiplier was applied. All transmission rebuilds were priced as new construction and a 1.1 multiplier was applied to all line mileages to account for adjustments in right-of-way calculations. River crossing costs included \$14.0M (2010 USD) for each crossing of the Mississippi River and \$7.0M for the Missouri River. Cost factors used to perform net present value calculations are shown in Tables 6.1-5 and 6.1-6.

Table 6.1-5: Net Present Value Factors

Value Factor	Generation	Transmission
Income Tax Rate	40.0%	40.0%
Inflation Rate	3.0%	3.0%
Book Life	20	40
Salvage	0	0

Table 6.1-5: Net Present Value Factors

Value Factor	Generation	Transmission
Tax Life	15	15
Discount Rate	7.0%	7.0%
O&M (% of Investment)	0.20%	0.20%

Table 6.1-6: Net Present Capitalization Cost Factors

Capitalization	Rate of Fund	Cost of Fund
Bonds	50.00%	6.00%
Preferred	0.00%	7.50%
Common	50.00%	13.38%
Short Term Debt	0.00%	5.00%

6.2 Transmission Scenario Overlay Cost Estimate Results

Cost values were calculated on three levels, 2010 Capital, 2010 Levelized Annual and 2010 \$/MWh (2010 USD) for generation and each of the three transmission overlays, Native Voltage (345 kV), 765 kV and Native DC. Capital costs represent the dollar amount if an entire overlay was built and paid for today. The levelized annual cost represents an equal payment to be made each year for the life of the respective overlay if the overlay was financed via typical utility options (represented by Table 6.2-1). A \$/MWh value was calculated by dividing the 2010 levelized annual costs by the total annual delivered wind energy from the renewable energy zones.

Important in these calculations was the disbursement of capital dollars across the future investment horizon. An overlay of this magnitude will be constructed across several years. When that money will be spent is not yet known, so assumptions must be made. The assumption used is that the earliest investment would be in 2015 and the latest would be 2025. As noted in Section 1.4 Starter Projects, a set of initial transmission projects have been identified. The total costs for these initial projects were spread over the 2015-2018 horizon. Remaining overlay costs were then equally apportioned through 2025 for each overlay, respectively. For generation investment, the generation capital was rationed from 2015 through 2025 based on RPS requirements.

Line miles and substation costs were calculated on a state-by-state basis as well as Midwest ISO vs PJM. Transmission lines that had end point substations in both the Midwest ISO were considered a Midwest ISO investment and likewise for PJM. Some costs however, such as AC lines where the end substations were in different RTO's were calculated as Joint transmission investment. DC transmission and substations were calculated on a state-by-state basis, however, were also labeled as Joint with respect to Midwest ISO vs PJM.

Refer to Tables 6.2-1 to 6.2-7 on the following pages, which provide a detailed capital cost and net present value summary.

Table 6.2-1: Native Voltage (345 kV) 2010 Capital Costs

[illegible]

Table 6.2-2: Native Voltage (345 kV) 2010 Net Present Value

New or Replacement Requirements (2010 \$M)									
Capital Costs as of 2010 (USD \$M)									
Year	Midwest BDO	PJM	Joint	Total	Midwest BDO	PJM	Joint	Total	
2015	\$1,047	\$257	\$121	\$1,424	\$1,382	\$339	\$160	\$1,880	
2016	\$1,047	\$257	\$121	\$1,424	\$1,330	\$326	\$154	\$1,810	
2017	\$1,047	\$257	\$121	\$1,424	\$1,280	\$314	\$148	\$1,742	
2018	\$1,047	\$257	\$121	\$1,424	\$1,233	\$302	\$142	\$1,677	
2019	\$1,382	\$132	\$0	\$1,515	\$1,587	\$150	\$0	\$1,717	
2020	\$1,382	\$132	\$0	\$1,515	\$1,508	\$144	\$0	\$1,652	
2021	\$1,382	\$132	\$0	\$1,515	\$1,452	\$139	\$0	\$1,591	
2022	\$1,382	\$132	\$0	\$1,515	\$1,397	\$134	\$0	\$1,531	
2023	\$1,382	\$132	\$0	\$1,515	\$1,346	\$129	\$0	\$1,474	
2024	\$1,382	\$132	\$0	\$1,515	\$1,296	\$124	\$0	\$1,419	
2025	\$1,382	\$132	\$0	\$1,515	\$1,247	\$119	\$0	\$1,366	
Total	\$13,865	\$1,852	\$484	\$16,301	\$16,036	\$2,219	\$604	\$17,859	
Levelized Annual Cost					\$1,419	\$209	\$97	\$1,686	
					\$18.0	\$2.4	\$0.6	\$19.0	
					\$20000				

Table 6.2-3: 765 kV 2010 Capital Costs

Transmission Type		A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	R	S	T	U	V	W	X	Y	Z	Total
New AC Transmission		\$3,582	\$2,208	\$1,115	\$222	\$1,924	\$1,732	\$52	\$1,477	\$885	\$722	\$1,313	\$15,322															
	Midwest ISO	\$3,582	\$478	\$10	\$222	\$1,924	\$1,514	\$52	\$1,477	\$375	\$722	\$1,284	\$11,629															
	PJM	\$0	\$1,514	\$415	\$0	\$0	\$215	\$0	\$0	\$558	\$0	\$0	\$2,735															
	Joint	\$0	\$215	\$557	\$0	\$0	\$0	\$0	\$0	\$3	\$0	\$45	\$555															
Upgraded AC Transmission		\$357	\$112	\$0	\$0	\$0	\$5	\$0	\$18	\$0	\$337	\$150	\$552															
	Midwest ISO	\$157	\$112	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$159	\$150	\$555															
	PJM	\$201	\$0	\$0	\$0	\$0	\$5	\$0	\$18	\$0	\$177	\$0	\$404															
	Joint	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0															
Total AC Transmission		\$3,939	\$2,318	\$1,115	\$222	\$1,924	\$1,741	\$52	\$1,495	\$885	\$1,059	\$1,453	\$15,314															
	Midwest ISO	\$3,755	\$558	\$10	\$222	\$1,924	\$1,514	\$52	\$1,477	\$375	\$682	\$1,415	\$12,217															
	PJM	\$201	\$1,514	\$415	\$0	\$0	\$225	\$0	\$18	\$558	\$177	\$0	\$3,142															
	Joint	\$0	\$215	\$557	\$0	\$0	\$0	\$0	\$0	\$3	\$0	\$45	\$555															
DC Transmission (Joint)		\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0															
River Creekside (Midwest ISO)		\$14	\$14	\$0	\$0	\$14	\$7	\$0	\$14	\$0	\$0	\$14	\$77															
AC Substations		\$435	\$715	\$214	\$145	\$554	\$344	\$41	\$447	\$379	\$205	\$345	\$3,555															
	Midwest ISO	\$435	\$105	\$50	\$145	\$554	\$344	\$41	\$447	\$101	\$205	\$345	\$2,505															
	PJM	\$0	\$512	\$154	\$0	\$0	\$0	\$0	\$0	\$275	\$0	\$0	\$1,054															
DC Substations (Joint)		\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0															
Total		\$4,405	\$3,049	\$1,329	\$357	\$2,522	\$2,052	\$54	\$1,505	\$1,344	\$1,253	\$1,523	\$20,249															
	Midwest ISO	\$4,207	\$705	\$50	\$357	\$2,522	\$1,955	\$54	\$1,505	\$475	\$1,055	\$1,775	\$15,055															
	PJM	\$201	\$2,125	\$552	\$0	\$0	\$225	\$0	\$18	\$555	\$177	\$0	\$4,155															
	Joint	\$0	\$215	\$557	\$0	\$0	\$0	\$0	\$0	\$3	\$0	\$45	\$555															
	DC	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0															

Table 6.2-4: 765 KV 2010 Net Present Value

Capital Costs in 2010 USD (\$M)					NPV of Revenue Requirements (2019 \$M)				
Year	Midwest ISO	PJM	Joint	Total	Midwest ISO	PJM	Joint	Total	
2015	\$1,047	\$257	\$121	\$1,424	\$1,382	\$339	\$180	\$1,880	
2016	\$1,047	\$257	\$121	\$1,424	\$1,330	\$326	\$154	\$1,810	
2017	\$1,047	\$257	\$121	\$1,424	\$1,280	\$314	\$148	\$1,742	
2018	\$1,047	\$257	\$121	\$1,424	\$1,239	\$302	\$142	\$1,677	
2019	\$1,559	\$453	\$67	\$2,079	\$1,767	\$613	\$76	\$2,366	
2020	\$1,559	\$453	\$67	\$2,079	\$1,700	\$494	\$73	\$2,268	
2021	\$1,559	\$453	\$67	\$2,079	\$1,637	\$476	\$71	\$2,183	
2022	\$1,559	\$453	\$67	\$2,079	\$1,576	\$458	\$68	\$2,101	
2023	\$1,559	\$453	\$67	\$2,079	\$1,517	\$441	\$65	\$2,023	
2024	\$1,559	\$453	\$67	\$2,079	\$1,460	\$424	\$63	\$1,947	
2025	\$1,559	\$453	\$67	\$2,079	\$1,408	\$408	\$61	\$1,874	
Total	\$15,099	\$4,198	\$655	\$20,249	\$16,287	\$4,494	\$1,081	\$21,982	
				Levelized Annual Cost					
				\$899/M	\$17.4	\$4.8	\$1.2	\$23.3	

Table 6.2-6: Native DC 2010 Capital Costs

Transmission Type		A	B	C	D	E	F	G	H	I	J	Total	
New AC Transmission		\$1,967	\$1,271	\$735	\$1,013	\$1,906	\$383	\$62	\$1,894	\$1,279	\$928	\$361	\$12,070
	Midwest ISO	\$1,967	\$681	\$255	\$1,013	\$1,906	\$383	\$62	\$1,894	\$419	\$828	\$861	\$10,140
	PJM	\$0	\$500	\$480	\$0	\$0	\$0	\$0	\$0	\$687	\$0	\$0	\$1,667
	Joint	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$273	\$0	\$0	\$273
Upgraded AC Transmission		\$0	\$128	\$20	\$108	\$0	\$0	\$0	\$0	\$40	\$0	\$397	\$592
	Midwest ISO	\$0	\$111	\$20	\$108	\$0	\$0	\$0	\$0	\$0	\$0	\$397	\$537
	PJM	\$0	\$15	\$0	\$0	\$0	\$0	\$0	\$0	\$40	\$0	\$0	\$55
	Joint	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0
Total AC Transmission		\$1,967	\$1,397	\$755	\$1,123	\$1,906	\$383	\$62	\$1,894	\$1,319	\$928	\$1,148	\$12,682
	Midwest ISO	\$1,967	\$792	\$275	\$1,123	\$1,906	\$383	\$62	\$1,894	\$419	\$828	\$1,148	\$10,677
	PJM	\$0	\$605	\$480	\$0	\$0	\$0	\$0	\$0	\$627	\$0	\$0	\$1,712
	Joint	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$273	\$0	\$0	\$273
DC Transmission (Joint)		\$1,079	\$719	\$637	\$121	\$299	\$639	\$0	\$0	\$239	\$11	\$121	\$3,935
River Crossings (Midwest ISO)		\$14	\$14	\$0	\$0	\$14	\$7	\$0	\$14	\$0	\$0	\$14	\$77
AC Substations		\$170	\$356	\$127	\$209	\$161	\$112	\$46	\$448	\$397	\$105	\$124	\$2,334
	Midwest ISO	\$170	\$286	\$68	\$287	\$161	\$112	\$46	\$448	\$121	\$105	\$124	\$1,908
	PJM	\$0	\$88	\$69	\$13	\$0	\$0	\$0	\$0	\$286	\$0	\$0	\$426
DC Substations (Joint)		\$546	\$412	\$0	\$170	\$275	\$0	\$0	\$0	\$686	\$275	\$170	\$2,536
Total		\$3,778	\$2,899	\$1,719	\$1,713	\$2,926	\$1,042	\$86	\$2,144	\$2,631	\$1,319	\$1,577	\$21,544
	Midwest ISO	\$2,180	\$1,074	\$343	\$1,408	\$2,082	\$602	\$86	\$2,144	\$540	\$1,033	\$1,286	\$12,682
	PJM	\$0	\$894	\$639	\$13	\$0	\$0	\$0	\$0	\$893	\$0	\$0	\$2,138
	Joint	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$273	\$0	\$0	\$273
	DC	\$1,628	\$1,131	\$837	\$291	\$644	\$639	\$0	\$0	\$626	\$286	\$291	\$6,471

Table 6.2-6: Native DC 2010 Net Present Value

NPV of Revenue Requirements (2010 \$M)									
Capital Costs in 2010 USD (\$M)									
Year	Midwest MO	PJM	JointDC	Total	Midwest MO	PJM	JointDC	Total	
2015	\$1,047	\$267	\$121	\$1,434	\$1,362	\$330	\$180	\$1,872	\$1,460
2016	\$1,047	\$267	\$121	\$1,434	\$1,330	\$328	\$154	\$1,812	\$1,810
2017	\$1,047	\$267	\$121	\$1,434	\$1,280	\$314	\$148	\$1,742	\$1,742
2018	\$1,047	\$267	\$121	\$1,434	\$1,233	\$303	\$142	\$1,677	\$1,677
2019	\$1,211	\$160	\$804	\$2,264	\$1,372	\$180	\$1,014	\$2,566	\$2,566
2020	\$1,211	\$160	\$804	\$2,264	\$1,321	\$173	\$976	\$2,470	\$2,470
2021	\$1,211	\$160	\$804	\$2,264	\$1,271	\$167	\$939	\$2,377	\$2,377
2022	\$1,211	\$160	\$804	\$2,264	\$1,224	\$161	\$904	\$2,288	\$2,288
2023	\$1,211	\$160	\$804	\$2,264	\$1,178	\$156	\$870	\$2,203	\$2,203
2024	\$1,211	\$160	\$804	\$2,264	\$1,134	\$149	\$838	\$2,121	\$2,121
2025	\$1,211	\$160	\$804	\$2,264	\$1,082	\$143	\$806	\$2,041	\$2,041
Total	\$12,662	\$2,136	\$8,744	\$21,544	\$13,616	\$2,408	\$8,950	\$23,175	\$23,175
				Levelized Annual Cost					
					\$1,304	\$227	\$666	\$2,197	\$2,197
				\$22,000	\$14.7	\$2.6	\$7.4	\$24.7	\$24.7

Table 6.2-7: Generation 2010 Net Present Value

Capital Expenditures (2010 USD \$M)					NPV of Expected Requirements (2010 \$M)				
Year	Midwest MO	PJM	Total	Midwest MO	PJM	Total			
2015	\$22,305	\$3,990	\$26,295	\$28,386	\$5,074	\$33,434			
2016	\$3,136	\$1,007	\$4,144	\$3,898	\$1,233	\$5,073			
2017	\$2,550	\$794	\$3,344	\$3,005	\$936	\$3,941			
2018	\$2,847	\$1,055	\$4,002	\$3,343	\$1,187	\$4,540			
2019	\$1,394	\$435	\$2,230	\$1,622	\$912	\$2,435			
2020	\$2,826	\$1,082	\$3,921	\$2,973	\$1,148	\$4,122			
2021	\$3,871	\$871	\$4,741	\$3,917	\$881	\$4,797			
2022	\$1,520	\$1,154	\$2,675	\$1,481	\$1,124	\$2,608			
2023	\$1,549	\$1,183	\$2,734	\$1,483	\$1,109	\$2,593			
2024	\$1,586	\$1,210	\$2,797	\$1,431	\$1,082	\$2,524			
2025	\$1,851	\$172	\$1,223	\$914	\$140	\$1,053			
Total	\$44,737	\$13,363	\$58,100	\$62,244	\$14,858	\$77,098			
Levelized Annual Cost							\$489/kWh		
Native Voltage							\$55.6	\$71.5	
765 kV							\$55.7	\$71.5	
Native DC							\$55.7	\$71.5	

7 RGOS 2011 Candidate MVP Portfolio Selection

Although RGOS focused on the development of holistic system solutions meeting long-term needs for the integration of renewable resources into the transmission system, it is important to identify an initial group of projects that are compatible with the three overlays that provide a practical first step towards meeting the renewable resource requirements. Midwest ISO staff has developed an analytical framework to identify the best potential transmission projects. These RGOS-identified projects will require additional, more detailed analysis. Because a Midwest ISO long-range transmission expansion strategy has not yet been determined and was not within the analytical scope of this study, it is important to note that the potential transmission projects do not pre-determine Midwest ISO long-range strategic aims. It is also important to note that these transmission projects prove compatible with all potential strategies.

7.1 Candidate Multi-Value Project Identification Process

The RGOS inputs into the Candidate Multi-Value Projects (MVPs) portfolio were identified by means of the process outlined below. Please note that other studies were considered in collecting the Candidate MVP portfolio; not all of the projects in that portfolio are from the RGOS study effort.

Step 1: Identify useful corridors common to multiple Midwest ISO studies.

Corridors represent general paths for transmission that do not discriminate between voltages or potential intermediate connection points. Studies to be considered when identifying corridors include the following:

- Regional Generation Outlet Study overlay development results
- Generation Interconnection studies:
 - Definitive Planning Phase (DPP)
 - System Planning and Analysis (SPA)
- MTEP related studies:
 - MTEP Appendix B and C projects, which address future reliability concerns
 - Top congested flowgate studies
 - Cross-border top congested flowgate studies
 - Narrowly constrained areas

Step 2: Identify RPS timing needs and synchronize with Generation Interconnection Queue (GIQ) locations.

Refer to Table 7.1-1, which shows renewable portfolio requirements starting in 2015. All states within Midwest ISO with RPS mandates or load-serving entity goals are listed.

Table 7.1-1: Renewable Portfolio Standard Requirements

Year	WI	MN (w/o Xcel)	Xcel MN	IL	MI	OH	MO	MT	PA	SD	ND	IA
	(Of Energy Served)											(MW)
2015	10.0%	12.0%	18.0%	10.0%	10.0%	3.5%	5.0%	15.0%	5.5%	10.0%	10.0%	105
2016	10.0%	17.0%	25.0%	11.5%	10.0%	4.5%	5.0%	15.0%	6.0%	10.0%	10.0%	105
2017	10.0%	17.0%	25.0%	13.0%	10.0%	5.5%	5.0%	15.0%	6.5%	10.0%	10.0%	105
2018	10.0%	17.0%	25.0%	14.5%	10.0%	6.5%	10.0%	15.0%	7.0%	10.0%	10.0%	105
2019	10.0%	17.0%	25.0%	16.0%	10.0%	7.5%	10.0%	15.0%	7.5%	10.0%	10.0%	105
2020	10.0%	20.0%	30.0%	17.5%	10.0%	8.5%	10.0%	15.0%	8.0%	10.0%	10.0%	105
2021	10.0%	20.0%	30.0%	19.0%	10.0%	9.5%	15.0%	15.0%	8.0%	10.0%	10.0%	105
2022	10.0%	20.0%	30.0%	20.5%	10.0%	10.5%	15.0%	15.0%	8.0%	10.0%	10.0%	105
2023	10.0%	20.0%	30.0%	22.0%	10.0%	11.5%	15.0%	15.0%	8.0%	10.0%	10.0%	105
2024	10.0%	20.0%	30.0%	23.5%	10.0%	12.5%	15.0%	15.0%	8.0%	10.0%	10.0%	105
2025	10.0%	25.0%	30.0%	25.0%	10.0%	12.5%	15.0%	15.0%	8.0%	10.0%	10.0%	105

Locations of generation interconnection queue requests to the Midwest ISO transmission system can be seen in Figure 7.1-1. This map represents wind queue locations as of the end of July, 2010.




Figure 7.1-1: Location of Midwest ISO Generation Interconnection Queue Requests

Step 3: Evaluate constructability of transmission.

Construction dynamics possibly requiring longer lead times for projects include the following:

- Interstate transmission coordination
- River crossings
- Commonsense coordination of projects; i.e., a group of lines may not make sense until another group is constructed first
- Midwest ISO/PJM cross-border projects

Certain projects may have shorter lead times; for example, when stringing second circuits on "existing" double circuit capable transmission structures.

7.1.1 RGOS-identified Candidate Multi-Value Projects

An initial set of transmission projects was identified using the inspection steps described in section 1, and served as an input into the design of the overall Candidate MVP portfolio. Selected Candidate MVPs are compatible with RGOS-developed overlays and provide potential value for other needs identified within the transmission system, such as congestion relief and mitigation of reliability concerns. Refer to Figure 7.1-2, which depicts Candidate MVPs from the RGOS analysis. Estimated cost for this RGOS Candidate MVP set is approximately \$5.8 Billion (2010 USD), \$4.4 billion of which is within Midwest ISO borders.




Figure 7.1-2: RGOS-identified Candidate Multi-Value Projects

The following numbered list corresponds to the numbered identifiers in Figure 7.1-2 and furnishes additional details on the rationale guiding specific Candidate MVP selection.

1. **Big Stone to Brookings 345 kV line (2010 estimated installed cost: \$150M):** This line provides access to and collection from renewable energy areas located in the eastern South Dakota portion of the Buffalo Ridge area. This corridor is identified in all RGOS overlays at the 345 kV voltage level. The corridor is also compatible with current Generation Interconnection Queue (GIQ) locations.
2. **Brookings to Twin Cities 345 kV line (2010 estimated installed cost: \$700M):** This line, as approved by the Minnesota Public Utilities Commission, delivers energy from the Buffalo Ridge area to a major load center in the Twin Cities and beyond. This 345 kV project also provides collection points for renewable energy, as well as reliability benefits. This corridor is identified in all RGOS overlay scenarios, although at different voltage levels. Proceeding with 345 kV construction does not negate a long-range 765 kV transmission expansion strategy. The 765 kV strategy can be adjusted to accommodate this selection.

3. **Lakefield Junction to Mitchell County 345 kV line constructed at 765 kV specifications (2010 estimated installed cost: \$600M):** This line provides for an additional West to East path for energy delivery from the Buffalo Ridge area. This corridor has been identified in all of the RGOS overlays, as well as in other studies such as the Top Congested Flowgate analysis in the 2009 MTEP process and recent GIQ SPA analysis. This corridor is also compatible to collect resources associated with current GIQ locations. By developing this corridor using 765 kV construction, all potential long-term strategies remain viable.
4. **North LaCrosse to North Madison to Cardinal, Dubuque to Spring Green to Cardinal 345 kV lines (2010 estimated installed cost: \$811M):** The development of these corridors will provide for the continuation and extension of the west to east transmission path to provide more areas with greater access to the high wind areas within the Buffalo Ridge and beyond. These corridors are compatible with the RGOS overlays as well as other studies such as the GIQ SPA and DPP studies. These projects can be well-integrated regardless of the long-range transmission expansion strategy adopted by Midwest ISO; e.g., Native Voltage, 765 kV, and 345 kV plus DC.
5. **Sheldon to Webster to Blackhawk to Hazleton 345 kV line (2010 estimated installed cost: \$458M):** This set of transmission projects provides both a collection of renewable energy in high wind areas and an additional west to east transmission path for delivery of energy to other parts of the study footprint. This combination of collection and delivery is compatible with the RGOS overlays (with proper adjustments made) and has shown to be compatible with corridors identified within the GIQ SPA studies.
6. **Ottumwa to Adair to Thomas HM, Adair to Palmyra 345 kV lines (2010 estimated installed cost: \$296M):** This set of transmission is compatible with the all RGOS overlays and provides access to quality wind resources within the Midwest ISO footprint in Missouri. This corridor development provides an additional north to south path and begins a new west to east transmission path for energy delivery across the footprint.
7. **Palmyra to Meredosia to Pawnee, Ipava to Meredosia 345 kV lines (2010 estimated installed cost: \$348M):** This transmission is compatible with the RGOS overlays and provides access to quality Illinois wind potential located within the Midwest ISO footprint. These lines provide reliability support to the Ipava area with the new 345 kV connections. It also continues the new west to east path that will help bridge some of the market constraints across Illinois.
8. **Sullivan to Meadow Lake to Greentown to Blue Creek 765 kV line (2010 estimated installed cost: \$908M):** 765 kV transmission is native to Indiana. This transmission plan is part of the 765 kV overlay but can also be compatible with the other overlays such as the 345 kV lines discussed previously. This transmission provides access to the wind potential in the Benton County area of Indiana and provides an additional west to east energy delivery route. Both Midwest ISO and PJM generation interconnection queues include potential resources in this area. It will also provide the completion of a 765 kV loop within Indiana to help mitigate some of the market constraints associated with the existing Rockport to Jefferson 765 kV line. A similar line was identified as a potential solution to constraints associated with the Southwest Indiana generation energy delivery. Note a version of this project was previously proposed as a joint project between PJM and Midwest ISO. Because of this, costs may be split between Midwest ISO and PJM and would—in the event of a joint project undertaking—also require a coincident PJM analysis.

9. **Collins to Kewanee to Pontiac to Meadow Lake 765 kV line (2010 estimated installed cost: \$964M):** 765 kV transmission is native to the PJM system in northern Illinois and Indiana. This corridor is identified primarily within the 765 kV overlay. However, it does have corridor compatibility within the other overlays. As previously discussed, Native Voltage and Native Voltage with DC transmission can both be adjusted appropriately to provide compatibility with any of the strategies. This line provides a second EHV path from the Chicago area to the east. It also provides a potential solution to the Wilton to Dumont related constraints that provides three (3) of the top 20 historical top congested flowgates within the Midwest ISO market. With the increasing pressure of wind within the Midwest ISO and the PJM portion of Illinois, specifically the Kewanee area, this transmission line will help release known and projected congestion associated with the transmission systems along Lake Michigan's southern shore.
10. **Michigan Thumb 345 kV transmission loop (2010 estimated installed cost: \$810M):** This loop was evaluated under an Out-of-Cycle process for inclusion in MTEP10 Appendix A and approved by the Midwest ISO Board of Directors (BOD) in its August meeting. This accelerated review was required to meet the near-time needs of the Michigan renewable energy mandate. This transmission is compatible with all of the strategies within the RGOS analysis and gives access to a high wind potential area within Michigan.
11. **Davis Besse to Beaver 345 kV line (2010 estimated installed cost: \$71M):** This transmission provides access to and delivery of wind energy potential located around the shores of Lake Erie within Ohio. There is GIQ generation in the area and the transmission is identified within all of the RGOS-developed transmission strategies.

8 Going Forward

RGOS provides industry stakeholders and policy makers with a regional planning perspective identifying potential investment opportunities and demonstrating the integration of renewable energy policies into electrical system development. The purpose of the RGOS transmission development effort has been to explore long-term transmission strategies ensuring study-defined reliability objectives in delivery of renewable energy as well as compliance with RPS mandates encompassing states within the study footprint.

No consensus exists regarding the amount of renewable generation ultimately needed to comply with current and future RPS mandates. Some assert a much higher level of wind generation will be required than those included in RGOS analyses while others claim a lower amount. Regardless of the long-term uncertainties engendered by expansion or reduction of renewable energy standards, states within the Midwest ISO system will need new transmission to meet current and near-term renewable energy requirements, ensure reliable operation of the transmission grid, relieve current and projected areas of congestion, and facilitate the generation interconnection queue process.

As a result of the RGOS effort, Midwest ISO has identified the next, most immediate step to transmission investment: a set of robust Candidate Multi-Value Projects (MVPs) meeting current renewable energy mandates and the regional reliability needs of its members. This Candidate MVP project portfolio, comprised of results from RGOS, multiple congestion studies, and numerous generation interconnection studies, will undergo rigorous analysis as a first step towards a regional transmission plan to meet the policy driven needs of the states in the Midwest ISO footprint.




Figure 8-1: Proposed Midwest ISO Candidate Multi-Value Project Portfolio #1

Candidate MVP portfolio analysis is designed to be a fluid, adaptable, and dynamic planning approach based upon the concept of providing a high level of benefits relative to project cost under a number of different future possibilities, culminating in a regional plan that reliably and efficiently delivers value to load. In the MTEP11 study cycle, this portfolio will be thoroughly evaluated to ensure project value and to confirm system reliability with all Candidate MVPs included, with a goal of moving any applicable projects to MTEP Appendix A as MVPs. In 2012 and subsequent years, Candidate MVP portfolio analyses will continue to develop portfolios addressing long-term system value drivers and needs.

A Candidate MVP portfolio has been identified by analyzing transmission needs from multiple transmission and economic studies, which include the following:

- RGOS
- Studies conducted in the generation interconnection process
- Congestion studies such as the Top Congested Flowgate Study and the Cross Border Congested Flowgate Study
- MTEP reliability studies

Transmission solutions from these studies were evaluated for comparability and ability to be built within the near-term. These projects will continue to be evaluated in more detail into 2011, both to ensure project robustness and to confirm system reliability with inclusion of the Candidate MVP portfolio. This analysis was previously referred to as "Starter Project" analysis, but nomenclature was modified to further align its evaluation with the July 15th cost allocation filing at FERC.

Candidate MVP analyses will be used to find the total value of the portfolio of proposed projects, and using reliability and economic analyses, to determine if these projects are eligible for MVP cost allocation. To ensure total value of the projects is accurately captured, Midwest ISO will continue to refine and develop the set of metrics and methodology used to evaluate the total value of a portfolio of projects in the robustness testing step discussed in section 4. This refinement will take place with heavy stakeholder involvement through such forums as the Planning Advisory Committee (PAC) and the Planning Subcommittee (PS).

Appendix 1: Site Selection Methodology

A1.1 Developing Wind Resource Datasets

In this task, high resolution (2km x 2km) mesoscale wind data was developed for years 2004, 2005, and 2006 in 10-minute intervals at various hub heights. Mesoscale is a term used to describe a three dimensional numerical weather model. AWS Truewind determined the best mesoscale model and configuration to use for developing its high resolution wind resource dataset by testing and validating a number of potential modeling configurations. The validation covered one full year of simulations and compared the results with actual wind measurements from ten measurement sites throughout the study region. Results of this model included, temperature, pressure, wind speed, wind direction, wind density, turbulent kinetic energy at five heights, specific humidity, incoming long-wave and short-wave radiation and precipitation. With a validated mesoscale wind dataset it was then possible to model power output for various wind farm configurations at various hub heights.

A1.1.1 Site Selection Process

The goal of this task was to identify potential wind sites in the study region, both on-shore and off-shore, with a combined total rated capacity of at least 3,000 gigawatts (GW). An additional task, through a selection process, was to identify a subset of those wind sites totaling 600,000 megawatts (MW) from which to develop a wind database.

Providing a consistent set of resource estimates for ranking and selecting sites required the preparation of a seamless map of 11-year average wind speeds at 80 meters height for the EWTS region. A representative example wind speed map is shown in Figure A1.1-1. The map has been rendered using Ventyx Velocity Suite¹² and is a representation of wind resources across the United States. The data was compiled from both state and regional sources; thus, level of detail may vary. The scale ranges from Class 1 winds under 12.5 mph to Class 7 winds over 19.7 mph. This image is displayed at 500-meter resolution. While the EWTS and JCSP study regions were the same, wind data was not produced for entirety of the study regions because of time and cost considerations, plus lack of potential wind sites. The map in Figure A1.1.-2 shows the site selection wind development area.

¹² Ventyx®, Velocity Suite® 2006




Figure A1.1-1: Example of US Wind Resource Map




Figure A1.1-2: Site Selection Wind Development Area

Using the 11-year average wind speed at 80 meters, a map of the estimated net capacity factor for a composite IEC Class 2 wind turbine was then created.

These maps are created using Geographic Information System (GIS) software, which allows the spatial representation of the data on a map in unique layers. In addition to capacity factor, other layers such as land area, topography, lakes, rivers, cities, metropolitan areas, state and federal lands, airports, slope, etc. were utilized. Using the capacity factor map and an assumption for how many wind turbines could be placed in a specified area allows estimation of total potential wind capacity and energy in the Eastern United States. Any areas where it is undesirable or impossible for wind turbines to be located were excluded from consideration. With a capacity factor map layer combined with an exclusion map layer, the net potential wind development could be determined for the study region. Maps of exclusion areas to apply to the site selection process were created and the various criteria are listed below.

- Maps Layers from the USGS National Land Cover Database (2001):
 - Open Water
 - 200m buffer of Developed Low Intensity
 - 500m buffer of Developed Medium Intensity
 - 500m buffer of Developed High Intensity
 - Woody Wetlands
 - Emergent Herbaceous Wetland
- Map Layers from the ESRI data base:
 - Parks
 - Parks Detailed
 - Federal Lands (non - public)
 - 10,000ft buffer of small airports (all hub sizes)
 - 20,000ft buffer of large airports (hub sizes medium and large)
- Map Layers from the Conservation Biology Institute:
 - GPACT value of 1, 2, 7 & 8 (Typically these are managed areas, public and private)
- Map Layers from Other Sources:
 - Slopes greater than 20%
 - Areas outside the study region

Several methodologies were used to further prioritize the potential wind farms. The AWS Truewind site-screening program builds wind farms one grid cell at a time with 2km x 2km resolution, adding grids to the farm until an exclusion area boundary is met. A wind farm produced could be as small as 2km x 2 km or extremely large in rural areas. It was therefore necessary to specify a minimum and maximum size wind farm to ensure reasonable site sizes. In addition, to ensure geographic diversity within the sites, if two sites in an area were adjacent the program selected the site with the highest capacity factor and excluded the other. Thus the model logically reduces the amount of wind capacity identified to something less than the total potential capacity. Even this reduction methodology does not reduce the amount of wind sites to the specified 3,000 GW of capacity targeted as the capacity to use in the site selection process. In addition, if the program were to select the top 3,000 GW of wind sites, these sites would then all be in the central part of the country, which is less than ideal. Using previous wind studies and the work done by the JCSP, NREL identified target amounts of wind capacity within each state. These combined methodologies produced over 7800 sites totaling over 3,000 GW of rated capacity. Mesoscale wind data was applied to potential sites identified from this list.

Refer to Figure A1.1-3.




Figure A1.1-3 Potential Sites for Onshore Site Selection by Capacity Factor

From the 7,856 sites in site selection list, NREL identified 1,513 sites totaling 651,091 MW, for AWS Truewind to apply the three (3) years of 10-minute mesoscale wind data. These 1,513 sites are referred to as the "selected sites". These sites are shown in Figure A1.1-4.



Figure A1.1-4 NREL Selected Site for Mesoscale Wind farm Modeling

The NREL-selected sites with the mesoscale wind modeling are available in on the NREL website for years 2004, 2005, and 2006. Throughout this process, Midwest ISO worked with NREL, reviewing data and providing feedback. Having modeled wind in the past; reviewed numerous wind studies; worked with stakeholders, wind developers, state regulators; conducted the JCSP study, and with a need for wind data in ongoing studies and future studies, Midwest ISO was in a unique position to provide feedback and review the data.

From this reviewing process, Midwest ISO identified an additional need outside of the scope of the original request of AWS Truewind. Midwest ISO performed a gap analysis of the wind sites selected and identified additional sites where it wanted mesoscale wind data developed. NREL was able to work with AWS Truewind to incorporate these additional sites, and the data is included on the NREL website. Refer to Figure A1.1-5.



Figure A1-5 NREL and RGOS Study Region Selected Sites

A1.2 Generate Wind Plant Output

A detailed explanation of the procedure to calculate the wind plant output is on the NREL website. AWS Truewind ran a simulation model to convert the mesoscale wind data to the selected sites. Blended power curves were then created and used to calculate the power output of each site. The International Electrotechnical Commission (IEC) 1 and 2 curves were based on a composite of three commercial turbines (GE, Vestas, Gamesa brands). The IEC 3 curve was based on two turbines (GE 1.5xle and Gamesa G80). The IEC 1 and 2 turbines were assumed to have a hub height of 80 m and the IEC 3 turbine 100 m.

A single text file for the output was created for each site. The output included 10-minute simulated wind speed at 80 and 100 meters, with power outputs for IEC class 1 and 2 at 80 meters and IEC class 3 at 100 meters. All outputs were time stamped to Greenwich Mean Time (GMT). In addition, the program selected the most appropriate IEC class based on the maximum mean speed within the site adjusted for air density, for the specific year of study. Since the data was developed for years 2004, 2005, and 2006, the selected turbine class could vary in different years. All turbines in the plant were the same type (1, 2 or 3) as determined from the average wind speed with an adjustment for site altitude. The power output for the selected IEC class is provided in the last column of the file. A header is provided for each site identifying the site number, its rated capacity, the selected IEC class, and the losses for each turbine class. The 10-minute data may be converted to hourly data by taking the average output for each hour. This methodology was accomplished by Midwest ISO and NREL in their studies.

A1.2.1 Forecasts and One Minute Samples

AWS Truewind produced hourly forecasts for three different time horizons: next-day, six-hour, and four-hour for use in hourly production modeling. In addition, they developed one minute samples of wind generation. The procedures are described in depth in the documentation on the NREL website.

A1.2.2 Wind Statistics

- Onshore Site Selection:
 - 7,856 sites considered with a capacity of 3,086,915 MW.
 - Range of selected sites 11 year average capacity factor is 18.2% to 49.0%, the average capacity factor is 33.0 %.
- Mesoscale Data containing the following:
 - Data in Greenwich Mean Time (GMT)
 - 10-minute data for years 2004, 2005, 2006
 - Power output for IEC 1 & 2 turbines at 80 meters and IEC 3 turbines at 100 meters
 - Wind speeds at 80 and 100 meters
 - Max capacity, preferred turbine type and losses provided for each site
 - Onshore NREL Selected Sites
 - 1,326 sites selected by NREL with a capacity of 580,763 MW

Table A1.2-1: Onshore Site Selection Capacity Factors by Year

CF Year	Annual	Minimum	Maximum
2004 Capacity Factor	36.9%	2.4%	81.7%
2005 Capacity Factor	36.3%	2.4%	80.9%
2006 Capacity Factor	37.4%	4.2%	82.1%
3 Year Average Capacity Factor	36.9%	3.0%	81.5%

- Onshore Midwest Additional Sites:
 - 167 additional sites selected by the Midwest ISO with a capacity of 70,328 MW
 - 1,513 total sites totaling 651,091 MW with mesoscale wind data developed
 - Three (3) Year Annual, Min & Max capacity factor for all 1,513 sites of 36.6, 2.3% and 82.5%

Refer to Figure A1.2-1, which shows the distribution of all selected sites by rated capacity. The bulk of the sites fall between 200 MW and 600 MW in size. A small number of "megsites" with rated capacities exceeding 1000 MW were also chosen. All of the megasites are located in the Great Plains.




Figure A1.2-1: Distribution of Site Capacity for all 1,513 Selected Onshore Sites

The following figures represent the minimum and maximum system wind for the NREL sites for each year of mesoscale data. To understand and visualize the mesoscale data, Midwest ISO created thematic maps which represented the power output for the eastern interconnect in a color coded map corresponding to the wind power. To illustrate the hourly variance of wind, multiple images were created and combined into 'wind movies' for 2004, 2005, and 2006. These movies represent the mesoscale hourly power output of the NREL selected sites.

The data is presented as per unit power output with red having a value of 0.9 and dark blue with a value of 0.0. These movies are available to download at the following website: <http://www.icastudy.org/>. The Figures A1.2-2 and A1.2-3 showing minimum and maximum system wind were taken from the wind movie.




Figure A1.2-2: Minimum Power Output of the NREL Selected Sites for Each Year




Figure A1.2-3: Maximum Power Output of the NREL Selected Sites for Each Year

A1.3 Renewable Energy Zone Scenario Development

A1.3.1 Wind Analysis

Several capacity factor metrics were calculated to analyze the wind data to determine the appropriate measures for ranking the renewable energy zones. The purpose for examining the various capacity factor metrics was to first answer questions about the variability and timing of wind production and also to determine if there were areas where wind energy performed better. A statistical analysis of the data had to be performed to be able to questions such as the following:

- Is using the three year average capacity factor enough or should the capacity factor for each year be considered a separate criteria?
- How is a site treated which may have a lower capacity factor than another site but tends to produce more energy during on-peak hours?
- Does wind really blow more in the evening than during the day?

To provide answers, a range of statistics was created based on time and applied to each site. The various capacity factor metrics are described in Table A1.3-1, below.

Table A1.3-1 Summary of Capacity Factor Metrics

Metric	Capacity Factor (CF) Metric
11 Year CF	CF based on 11 year average wind speed at 80m
2004 CF	CF for 2004
2005 CF	CF for 2005
2006 CF	CF for 2006
3 Year CF	Average CF for 2004, 2005 and 2006
On-peak CF	3 year CF for hours between 6am to 10pm EST
Afternoon On-peak CF	3 year CF for hours between 3pm to 6pm EST
Summer On-peak CF	3 year CF on-peak hours for June, July and August
Summer Aft On-peak CF	3 year CF for afternoon on-peak hours for June, July & August
Off-peak CF	3 year CF for hours between 10pm to 6am EST

Figures A.3-1 through A.3-3 provide an overview of some of the capacity factor metrics per state. The off-peak average capacity factors were higher than the on-peak and significantly higher than the summer afternoon on-peak hours. A linear relationship can be seen between the average capacity factors and their changes for the different metrics. Spikes or dips in the data indicate the average capacity factors in a given state performed better or worse relative to the other states. This is seen in the afternoon on-peak hours with a slight dip for Missouri and a slight increase for Indiana.




Figure A1.3-1 Average Capacity Factor Metrics by State




Figure A1.3-2 Maximum Capacity Factor Metrics by State




Figure A1.3-3 Minimum Capacity Factor Metrics by State

Some other metrics developed for analysis include correlation of wind to load, ramp, and correlation of wind sites to distance from each other. The following figures demonstrate some of the results from this work.

Figure A1.3-4 represents the wind output correlation to load for Midwest ISO. A correlation of 1.0 is a perfect correlation, meaning load and wind exactly match each other. A correlation of 0.0 represents no correlation, meaning that load and wind act completely independent of each other. The correlation values demonstrate that there was not a strong correlation between wind output and load. In other words, one cannot generally expect a specific wind output based on load levels. However, in general, wind output is typically higher during off-peak hours as opposed to on-peak hours (when load is less) as shown in the previous figures. Similar results hold true on a state by state basis for all the states in Midwest ISO.




Figure A1.3-4 Correlation of Wind to Load in the Midwest ISO

Hourly ramping of the wind was calculated by looking at the delta of wind output from one hour to the next. A distribution of these values was created and a correlation to load ramp was calculated. As expected, the correlations were relatively close to zero and insignificant. Refer to Figure A.3-5 for results from Iowa (IA), Illinois (IL), Minnesota (MN), and Wisconsin (WI).




Figure A1.3-5: Correlation of Wind Ramp to Load Ramp

Figure A1.3-6 represents the correlation of individual sites to each other. The green line represents distance separation east to west, the blue line north to south. The figure demonstrates that as the distance between two sites becomes large, the correlation of the wind at those two sites reduces. In other words, the further apart two sites are, the less likely they will have similar wind profiles. This is an obvious expectation since two (2) sites located next to each other would be expected to have similar capacity factor characteristics.




Figure A1.3-6: Correlation of Wind Sites to Distance

Appendix 2: Midwest ISO Member State RPS Requirements

Refer to Table A2-1. The following information, derived from the US Department of Energy's National Renewable Energy Laboratory (NREL) Database of State Incentives for Renewables & Efficiency, highlights general aspects of various state Renewable Portfolio Standards (RPS) legislation within the Midwest ISO purview. The information can be found at <http://www.dsireusa.org/>.

Note the Ohio mandate is defined differently from most other states. The Ohio mandate focuses on an alternative energy mandate that can include resources such as clean coal and nuclear capacity. The total state mandate is 25% by 2024. However, it has been expressed in this report as that portion that meets the renewable technology minimum of 12.5% by 2024. Note, too, the Pennsylvania mandate is similar to the Ohio mandate, focusing not only on renewable resources but also alternative technologies such as Integrated Gasification Combined Cycle (IGCC). The entire Pennsylvania mandate is approximately 18% of energy served. However, for the purposes of this study, only the Tier I portion of the mandate emphasizing renewable resources is referenced.

Table A2-1: Midwest ISO Region State RPS Requirements

State	Applicable Sectors	Eligible Resources	Technology Minimum	DSIRE Reference Web Address
Wisconsin	Municipal Utility, Investor-Owned Utility, Rural Electric Cooperative	Solar Water Heat, Solar Space Heat, Solar Thermal Electric, Solar Thermal Process Heat, Photovoltaics, Landfill Gas, Wind, Biomass, Hydroelectric, Geothermal Electric, Geothermal Heat Pumps, Municipal Solid Waste, Solar Light Pipes, Solar Pool Heating, Anaerobic Digestion, Tidal Energy, Wave Energy, Fuel Cells using Renewable Fuels, Geothermal Direct-Use	None	http://www.dsireusa.org/incentives/incentives.cfm?incentive_type=1&state=WI
Minnesota	Municipal Utility, Investor-Owned Utility, Rural Electric Cooperative	Solar Thermal Electric, Photovoltaics, Landfill Gas, Wind, Biomass, Hydroelectric, Municipal Solid Waste, Hydrogen, Co-Firing, Anaerobic Digestion	Wind or Solar (Coal only): 20% by 2020; maximum of 1% from solar	http://www.dsireusa.org/incentives/incentives.cfm?incentive_type=1&state=MN
Illinois	Investor-Owned Utility, Retail Supplier	Solar Thermal Electric, Photovoltaics, Landfill Gas, Wind, Biomass, Hydroelectric, Biodiesel, Eligible Efficiency Technologies	Wind (GULF): 75% of annual requirement (18.75% of sales in compliance year 2024-2025); Wind (ARES): 50% of annual requirement (15% of sales in compliance year 2024-2025); PV (AR): 6% of annual requirement in compliance year 2015-2016 and thereafter (1.5% of total sales in compliance year 2024-2025)	http://www.dsireusa.org/incentives/incentives.cfm?incentive_type=1&state=IL

Table A2-1: Midwest ISO Region State RPS Requirements

State	Applicable Sectors	Eligible Technologies	Technology Minimum	DSIRE Reference Web Address
Michigan	Municipal Utility, Investor-Owned Utility, Rural Electric Cooperative, Retail Supplier	Solar Thermal Electric, Photovoltaics, Landfill Gas, Wind, Biomass, Hydroelectric, Geothermal Electric, Municipal Solid Waste, CHP/Cogeneration, Coal-Fired w/CCS, Gasification, Anaerobic Digestion, Tidal Energy, Wave Energy, Eligible Efficiency Technologies	None	http://www.dsireusa.org/incentives/incentives.cfm?incentive_code=MI168&w=1&ee=1
Ohio	Investor-Owned Utility, Retail Supplier	Solar Thermal Electric, Photovoltaics, Landfill Gas, Wind, Biomass, Hydroelectric, Geothermal Electric, Fuel Cells, Municipal Solid Waste, Waste Heat, Energy Storage, Clean Coal, Advanced Nuclear, Anaerobic Digestion, Microturbines, Eligible Efficiency Technologies	Renewables: 12.5% by 2024 (includes solar-electric minimum) Solar-Electric: 0.5% by 2024	http://www.dsireusa.org/incentives/incentives.cfm?incentive_code=OH148&w=1&ee=1
Missouri	Investor-Owned Utility	Solar Thermal Electric, Photovoltaics, Landfill Gas, Wind, Biomass, Municipal Solid Waste, Anaerobic Digestion, Small Hydroelectric, Fuel Cells using Renewable Fuels	Solar-Electric: 2% of annual requirement (0.5% of sales in 2021)	http://www.dsireusa.org/incentives/incentives.cfm?incentive_code=MO083&w=1&ee=1
Montana	Investor-Owned Utility, Retail Supplier	Solar Thermal Electric, Photovoltaics, Landfill Gas, Wind, Biomass, Hydroelectric, Geothermal Electric, Anaerobic Digestion, Fuel Cells using Renewable Fuel	None	http://www.dsireusa.org/incentives/incentives.cfm?incentive_code=MT115&w=1&ee=1
Pennsylvania	Investor-Owned Utility, Retail Supplier	Solar Water Heat, Solar Space Heat, Solar Thermal Electric, Solar Thermal Process Heat, Photovoltaics, Landfill Gas, Wind, Biomass, Hydroelectric, Geothermal Electric, Fuel Cells, Geothermal Heat Pumps, Municipal Solid Waste, CHP/Cogeneration, Waste Coal, Coal Mine Methane, Coal Gasification, Anaerobic Digestion, Other Distributed Generation Technologies, Eligible Efficiency Technologies	Tier 1 ~5% by compliance year 2020-2021 (includes PV minimum); Tier 2: 10% by compliance year 2020-2021; PV: 0.5% by compliance year 2020-2021	http://www.dsireusa.org/incentives/incentives.cfm?incentive_code=PA089&w=1&ee=1
South Dakota (Goal)	Municipal Utility, Investor-Owned Utility, Rural Electric Cooperative	Solar Thermal Electric, Photovoltaics, Landfill Gas, Wind, Biomass, Hydroelectric, Geothermal Electric, Municipal Solid Waste, Hydrogen, Electricity Produced from Waste Heat, Anaerobic Digestion, Eligible Efficiency Technologies	None	http://www.dsireusa.org/incentives/incentives.cfm?incentive_code=SD082&w=1&ee=1
North Dakota (Goal)	Municipal Utility, Investor-Owned Utility, Rural Electric Cooperative	Solar Thermal Electric, Photovoltaics, Landfill Gas, Wind, Biomass, Hydroelectric, Geothermal Electric, Hydrogen, Electricity from Waste Heat, Anaerobic Digestion	None	http://www.dsireusa.org/incentives/incentives.cfm?incentive_code=ND042&w=1&ee=1
Iowa	Utility	Solar Thermal Electric, Photovoltaics, Landfill Gas, Wind, Biomass, Hydroelectric, Municipal Solid Waste, Anaerobic Digestion	None	http://www.dsireusa.org/incentives/incentives.cfm?incentive_code=IA018&w=1&ee=1

Appendix 3: Indicative Transmission Design

This Appendix depicts and describes the indicative transmission overlays resulting from formulation of five (5) renewable energy zone scenarios. Also refer to section 5 of this document, which provides greater detail on design process background and results. These scenarios include the following:

- **Local:** In the Local scenario the renewable energy requirements and goals will be met with resources located within the same state as the load.
- **Regional:** In the Regional scenario renewable energy requirements and goals will be met with resources located in the highest ranking renewable energy zones regardless of the zones location relative to the RGOS II load. This scenario will utilize the high capacity factor zones recommended by UMTDI from RGOS I.
- **Regional Optimized:** The Regional scenario results in capacity in excess of what is needed to at least cover the renewable requirements/goals. In the optimized case the capacity in some zones reduced such that there is just enough resources to cover the requirements/goals.
- **Combination 50/50:** In the Combination scenario renewable energy requirements and goals will be met with a combination of 50% of the resources located within the eastern states (RGOS II) and 50% from the western states (RGOS I/UMTDI). Emphasis will be given to state requirements to locate part or all of their resources used to meet renewable energy requirements and goals within those states.
- **Combination 75/25:** This scenario is similar to Combination 50/50 except that 75% of the renewable energy requirements will be met from the west states (RGOS I/UMTDI).

The following tables and charts depict results from the indicative transmission workshop whereby the renewable energy zone scenarios above were used to develop indicative transmission overlays to serve the energy and capacity from each scenario. This work was accomplished using several transmission build-out possibilities that included 345 kV, 765 kV, and DC. Each of the various scenarios has a table showing transmission mileage, a table listing transmission capital costs, and a map depicting the transmission overlay.

A3.1 Local 345 kV

Refer to Tables A3.1-1 and A3.1-2.

Table A3.1-1: Local 345 kV Sum of Line Lengths (Miles)

Type (kV)	States								Total Line Length
	IA	IL	IN	MI	MN Dak	MO	OH PA	WI	
345	1001	999	188	271	230	611	228	880	4408
765				195			268		462
2-345	454	236	187		2701		59	136	3775
Grand Total	1455	1237	376	466	2931	611	554	1016	8846

Table A3.1-2: Local 345 kV Sum of Total Cost

Type (kV)	States								Grand Total
	IA	IL	IN	MI	MN Dak	MO	OH PA	WI	
345	\$1,501	\$1,999	\$339	\$488	\$460	\$611	\$455	\$2,201	\$8,054
765				\$702			\$1,070		\$1,772
2-345	\$953	\$616	\$431		\$6,753		\$148	\$406	\$9,309
Grand Total	\$2,454	\$2,616	\$770	\$1,189	\$7,212	\$611	\$1,673	\$2,606	\$19,136

Generation

MW of Capacity
 45,708

Cost (M\$)
 \$91,400.00

Total Costs (2010 USD in Millions)

Transmission \$19,135

Generation \$91,400

Transformers

Substations

Reactors

Total \$110,535

Refer to Figure A3.1-1.




Figure A3.1-1: RGOS Local 345 kV

A3.2 Local 765 kV

Refer to Tables A3.2-1 and A3.2-2.

Table A3.2-1: Local 765 kV Sum of Line Lengths (Miles)

Type (kV)	States								Total Line Length
	IA	IL	IN	MI	MN/Dak	MO	OH/PA	WI	
345	1001	1005	110	198	230	811	228	880	4260
765		432	398	319			289		1416
2-345	454	238			2701			135	3528
Grand Total	1455	1674	506	516	2931	811	498	1016	9284

Table A3.2-2: Local 765 kV Sum of Total Cost

Type (kV)	States								Grand Total
	IA	IL	IN	MI	MN/Dak	MO	OH/PA	WI	
345	\$1,501	\$2,008	\$198	\$353	\$460	\$611	\$455	\$2,201	\$7,788
765		\$1,816	\$1,741	\$1,148			\$1,074		\$5,779
2-345	\$953	\$618			\$6,753			\$405	\$8,730
Grand Total	\$2,454	\$4,443	\$1,939	\$1,802	\$7,213	\$611	\$1,529	\$2,606	\$22,298

Generation

MW of Capacity Cost (M\$)
 46,780 \$91,408.00

Total Costs (2010 USD (in Millions))

Transmission	\$22,298
Generation	\$91,400
Transformers	
Substations	
Reactors	
Total	\$113,898

Refer to Figure A3.2-1.




Figure A3.2-1: RGOS Local 765 kV

A3.3 Combo (50/50) 345 kV

Refer to Tables A3.3-1 and A3.3-2.

Table A3.3-1: Combo (50/50) 345 kV Sum of Line Lengths (In Miles)

Type (kV)	States								Total Line Length
	IA	IL	IN	MI	MN/Dak	MO	OH/PA	WI	
345	1162	997	241	198	230	486		880	4192
765			59	165			155		379
2-345	464	152	254		2701		94	135	3790
Grand Total	1616	1148	555	361	2931	486	249	1016	8381

Table A3.3-2: Combo (50/50) 345 kV Sum of Total Cost

Type (kV)	States								Grand Total
	IA	IL	IN	MI	MN/Dak	MO	OH/PA	WI	
345	\$1,743	\$1,993	\$434	\$353	\$480	\$486		\$2,201	\$7,670
765			\$261	\$593			\$621		\$1,474
2-345	\$953	\$394	\$585		\$6,753		\$234	\$406	\$9,325
Grand Total	\$2,696	\$2,387	\$1,279	\$946	\$7,212	\$486	\$855	\$2,606	\$18,470

Generation

MW of Capacity

32,650

Cost (M\$)

\$85,300.00

Total Costs (2010 USD in Millions)

Transmission \$18,470

Generation \$85,300

Transformers

Substations

Reactors

Total \$83,770

Refer to Figure A3.3-1.




Figure A3.3-1: RGOS Combo (50/50) 345 kV

A3.4 Combo (50/50) 765 kV

Refer to Tables A3.4-1 and A3.4-2.

Table A3.4-1: Combo (50/50) 765 kV Sum of Line Lengths (in Miles)

Type (kV)	States								Total Line Length
	IA	IL	IN	MI	MN Dak	MO	OH PA	WI	
345	443	772	93	196	33	277		826	2642
765	650	505	280	319	1166	324	237	162	3623
2-345	197				1338		59	21	1615
Grand Total	1290	1276	363	515	2537	601	296	1011	7886

Table A3.4-2: Combo (50/50) 765 Sum of Total Cost

Type (kV)	States								Grand Total
	IA	IL	IN	MI	MN Dak	MO	OH PA	WI	
345	\$664	\$1,543	\$168	\$353	\$66	\$277		\$2,070	\$5,141
765	\$2,731	\$2,121	\$1,144	\$1,146	\$5,597	\$1,361	\$947	\$776	\$15,826
2-345	\$414				\$3,348		\$147	\$62	\$3,970
Grand Total	\$3,810	\$3,664	\$1,312	\$1,502	\$8,008	\$1,638	\$1,094	\$2,808	\$24,937

Generation

MW of Capacity Cost (M\$)
 32,650 \$65,390.00

Total Costs (2010 USD in Millions)

Transmission	\$24,937
Generation	\$65,300
Transformers	
Substations	
Reactors	
Total	\$90,237

Refer to Figure A3.4-1.




Figure A3.4-1: RGOS Combo (50/60) 765 kV

A3.5 Combo (75/25) 345 kV

Refer to Tables A3.5-1 and A3.5-2.

Table A3.5-1: Combo (75/25) 345 kV Sum of Line Lengths (in Miles)

Type (kV)	States								Total Line Length
	IA	IL	IN	MI	MN/Dak	MO	OH/PA	WI	
345	1182	997	241	196	230	488		880	4192
765			59	185			155		379
2-345	454	152	254		2701		94	135	3790
Grand Total	1616	1148	555	381	2931	488	249	1016	8381

Table A3.5-2: Combo (75/25) 345 kV Sum of Total Cost

Type (kV)	States								Grand Total
	IA	IL	IN	MI	MN/Dak	MO	OH/PA	WI	
345	\$1,743	\$1,993	\$434	\$353	\$460	\$486		\$2,201	\$7,670
765			\$261	\$593			\$621		\$1,474
2-345	\$953	\$394	\$685		\$6,753		\$234	\$408	\$9,325
Grand Total	\$2,696	\$2,387	\$1,279	\$946	\$7,212	\$486	\$855	\$2,609	\$18,476

Generation

MW of Capacity Cost (M\$)
 31,160 \$62,300.00

Total Costs (2016 USD in Millions)

Transmission	\$18,470
Generation	\$62,300
Transformers	
Substations	
Reactors	
Total	\$80,770

Refer to Figure A3.5-1.




Figure A3.5-1: RGOS Combo (75/25) 345 kV

A3.6 Combo (75/25) 765 kV

Refer to Tables A3.6-1 and A3.6-2.

Table A3.6-1: Combo (75/25) 765 kV Sum of Line Lengths (in Miles)

Type (kV)	States								Total Line Length
	IA	IL	IN	MI	MN/Dak	MO	OH/PA	WI	
345	443	772	93	196	33	277		828	2642
765	650	505	260	319	1166	324	237	162	3623
2-345	197				1336		59	21	1815
Grand Total	1290	1277	353	515	2537	601	296	1011	7890

Table A3.6-2: Combo (75/25) 765 kV Sum of Total Cost

Type (kV)	States								Grand Total
	IA	IL	IN	MI	MN/Dak	MO	OH/PA	WI	
345	\$664	\$1,543	\$166	\$353	\$66	\$277		\$2,070	\$5,141
765	\$2,731	\$2,121	\$1,144	\$1,148	\$5,597	\$1,361	\$947	\$776	\$15,826
2-345	\$414				\$3,346		\$147	\$52	\$3,970
Grand Total	\$3,810	\$3,664	\$1,312	\$1,502	\$9,009	\$1,638	\$1,094	\$2,900	\$24,937

Generation

MW of Capacity	Cost (M\$)
31,168	\$62,306.00

Total Costs (2010 USD in Millions)

Transmission	\$24,937
Generation	\$62,300
Transformers	
Substations	
Reactors	
Total	\$87,237

Refer to Figure A3.6-1.




Figure A3.6-1: RGOS Combo (75/25) 765 kV

A3.7 Regional 345 kV

Refer to Tables A3.7-1 and A3.7-2.

Table A3.7-1: Regional 345 kV Sum of Line Lengths (in Miles)

Type (kV)	States								Total Line Length
	IA	IL	IN	MI	MN Dak	MO	OH PA	WI	
345	887	889	39	198	214	488		797	3488
765	150				67		269		487
2-345	729	152			3439			288	4808
400								80	80
800	335	532	489		280	229	363	103	2332
Grand Total	2161	1553	528	198	4809	716	632	1247	10973

Table A3.7-2: Regional 345 kV Sum of Total Cost

Type (kV)	States								Grand Total
	IA	IL	IN	MI	MN Dak	MO	OH PA	WI	
345	\$1,330	\$1,739	\$71	\$363	\$427	\$488		\$1,993	\$6,399
765	\$631				\$324		\$1,076		\$2,031
2-345	\$1,532	\$394			\$8,598			\$859	\$11,382
400								\$887	\$887
800	\$3,159	\$7,225	\$7,131		\$3,039	\$1,716	\$8,854	\$1,437	\$30,561
Grand Total	\$6,652	\$9,358	\$7,202	\$363	\$12,388	\$2,201	\$7,930	\$6,176	\$61,280

Generation

MW of Capacity Cost (M\$)
33,460 \$66,900.00

Total Costs (2010 USD in Millions)

Transmission \$51,200
Generation \$66,900
Transformers
Substations
Reactors

Total \$118,100

A3.8 Regional 345 kV Optimized

Refer to Tables A3.8-1 and A3.8-2.

Table A3.8-1: Regional 345 kV Optimized Sum of Line Lengths (in Miles)

Type (kV)	States								Total Line Length
	IA	IL	IN	MI	MN Dak	MO	OH PA	WI	
345	887	888	39	198	214	486		797	3488
765	150				67		268		487
2-345	729	152			3439			288	4608
400								60	60
800	335	532	489		280	229	363	103	2332
Grand Total	2101	1563	528	198	4000	715	632	1247	10073

Table A3.8-2: Regional 345 kV Optimized Sum of Total Cost

Type (kV)	States								Grand Total
	IA	IL	IN	MI	MN DAK	MO	OH PA	WI	
345	\$1,330	\$1,739	\$71	\$353	\$427	\$486		\$1,993	\$6,399
765	\$631				\$324		\$1,076		\$2,031
2-345	\$1,532	\$394			\$5,508			\$869	\$11,382
400								\$867	\$867
800	\$3,159	\$7,225	\$7,131		\$3,039	\$1,718	\$6,854	\$1,437	\$30,561
Grand Total	\$6,652	\$9,358	\$7,202	\$353	\$12,398	\$2,201	\$7,930	\$6,176	\$51,289

Generation

MW of Capacity Cost (M\$)
 30,400 \$60,800.00

Total Costs (2010 USD in Millions)

Transmission	\$51,289
Generation	\$60,800
Transformers	
Substations	
Reactors	
Total	\$112,089

Refer to Figure A3.8-1.




Figure A3.8-1: RGOS Regional 345 kV (with Optimized)

A3.9 Regional 765 kV with DC

Refer to Tables A3.9-1 and A3.9-2.

Table A3.9-1: Regional 765 kV with DC Sum of Line Lengths (In Miles)

Type (kV)	States								Total Line Length
	IA	IL	IN	MI	MN/Dak	MO	OH/PA	WI	
345	350	781	39	196	32	277		842	2517
765	651	505	354	319	1656	324	317	148	4274
2-345	337				1232			21	1590
400								60	60
800	166	297	437		280	222	3	101	1506
Grand Total	1804	1683	830	515	3300	823	330	1172	9947

Table A3.9-2: Regional 765 kV with DC Sum of Total Cost

Type (kV)	States								Grand Total
	IA	IL	IN	MI	MN/Dak	MO	OH/PA	WI	
345	\$624	\$1,563	\$71	\$353	\$63	\$277		\$2,105	\$4,957
765	\$2,735	\$2,121	\$1,559	\$1,148	\$7,948	\$1,361	\$1,269	\$706	\$18,850
2-345	\$707				\$3,080			\$62	\$3,849
400								\$687	\$687
800	\$1,577	\$4,286	\$4,594		\$3,038	\$1,699	\$2,426	\$1,434	\$19,057
Grand Total	\$6,644	\$7,970	\$6,224	\$1,802	\$14,126	\$3,337	\$3,696	\$4,197	\$47,800

Generation

MW of Capacity Cost (M\$)
 33,450 \$66,900.00

Total Costs (2018 USD in Millions)

Transmission \$47,800
 Generation \$66,900

Transformers

Substations

Reactors

Total \$114,500

A3.10 Regional 765 kV with DC Optimized

Refer to Tables A3.10-1 and A3.10-2.

Table A3.10-1: Regional 765 kV with DC Optimized Sum of Line Lengths (in Miles)

Type (kV)	States								Total Line Length
	IA	IL	IN	MI	MN Dak	MO	OH PA	WI	
345	350	781	39	196	32	277		842	2517
765	651	505	354	319	1656	324	317	148	4274
2-345	337				1232			21	1590
400								60	60
800	166	297	437		280	222	3	101	1506
Grand Total	1804	1683	830	615	3208	823	320	1172	9647

Table A3.10-2: Regional 765 kV with DC Optimized Sum of Total Cost

Type (kV)	States								Grand Total
	IA	IL	IN	MI	MN Dak	MO	OH PA	WI	
345	\$524	\$1,563	\$71	\$353	\$63	\$277		\$2,105	\$4,957
765	\$2,735	\$2,121	\$1,559	\$1,148	\$7,948	\$1,361	\$1,269	\$706	\$16,850
2-345	\$707				\$3,080			\$62	\$3,849
400								\$687	\$687
800	\$1,577	\$4,266	\$4,594		\$3,039	\$1,699	\$2,426	\$1,434	\$19,057
Grand Total	\$6,544	\$7,970	\$6,224	\$1,502	\$14,129	\$3,337	\$3,696	\$6,197	\$47,600

Generation

MW of Capacity
 30,400

Cost (M\$)
 \$60,800.00

Total Costs (2010 USD in Millions)

Transmission	\$47,600
Generation	\$60,800
Transformers	
Substations	
Reactors	
Total	\$108,400

Refer to Figure A3.10-1.




Figure A3.10-1: RGOS Regional 765 kV with DC (with Optimized)

A3.11 Regional 765 kV DC West

Refer to Tables A3.11-1 and A3.11-2.

Table A3.11-1: Regional 765 kV DC West Sum of Line Lengths (in Miles)

Type (kV)	States								Total Line Length
	IA	IL	IN	MI	MN/Dak	MO	OH/PA	WI	
345	350	755	39	196	32	277		842	2491
765	410	495	393	319	1169		317		3102
2-345	337				1232			21	1590
400								60	60
800	166	166			260	222		99	934
Grand Total	1263	1416	432	516	2712	499	317	1022	8176

Table A3.11-2: Regional 765 kV DC West Sum of Total Cost

Type (kV)	States								Grand Total
	IA	IL	IN	MI	MN/Dak	MO	OH/PA	WI	
345	\$524	\$1,509	\$71	\$353	\$63	\$277		\$2,105	\$4,903
765	\$1,723	\$2,077	\$1,728	\$1,148	\$5,610		\$1,269		\$13,555
2-345	\$707				\$3,080			\$62	\$3,849
400								\$667	\$667
800	\$1,577	\$2,768			\$3,039	\$1,699		\$1,429	\$10,531
Grand Total	\$4,532	\$6,374	\$1,798	\$1,502	\$11,791	\$1,976	\$1,269	\$4,463	\$33,726

Generation

MW of Capacity Cost (M\$)
33,450 \$66,900.00

Total Costs (2010 USD in Millions)

Transmission \$33,726
Generation \$66,900
Transformers
Substations
Reactors

Total \$100,626

A3.12 Regional 765 kV DC West Optimized

Refer to Tables A3.12-1 and A3.12-2.

Table A3.12-1: Regional 765 kV DC West Optimized Sum of Line Lengths (in Miles)

Type (kV)	States								Total Line Length
	IA	IL	IN	MI	MN/Dak	MO	OH/PA	WI	
345	350	755	39	198	32	277		842	2491
765	410	486	393	319	1169		317		3102
2-345	337				1232			21	1590
400								60	60
800	168	166			280	222		99	934
Grand Total	1263	1416	432	516	2712	499	317	1022	8176

Table A3.12-2: Regional 765 kV DC West Optimized Sum of Line Lengths (in Miles) Sum of Total Cost

Type (kV)	States								Grand Total
	IA	IL	IN	MI	MN/Dak	MO	OH/PA	WI	
345	\$524	\$1,509	\$71	\$353	\$63	\$277		\$2,105	\$4,903
765	\$1,723	\$2,077	\$1,728	\$1,148	\$5,810		\$1,269		\$13,555
2-345	\$707				\$3,080			\$62	\$3,849
400								\$687	\$687
800	\$1,577	\$2,788			\$3,039	\$1,699		\$1,429	\$10,531
Grand Total	\$4,532	\$6,374	\$1,798	\$1,502	\$11,791	\$1,976	\$1,269	\$4,483	\$33,728

Generation

MW of Capacity
30,400

Cost (M\$)
\$60,800.00

Total Costs (2010 USD in Millions)

Transmission	\$33,728
Generation	\$60,800
Transformers	
Substations	
Reactors	
Total	\$94,528

Refer to Figure A3.12-1.




Figure A3.12-1: RGOS Regional 765 kV DC West (with Optimized)

A3.13 Regional 765 kV

Refer to Tables A3.13-1 and A3.13-2.

Table A3.13-1: Regional 765 kV Sum of Line Lengths (in Miles)

Type (kV)	States								Total Line Length
	IA	IL	IN	MI	MN/Dak	MO	OH/PA	WI	
345	350	781	39	198	32	277		842	2517
765	651	834	411	319	1656	324	317	148	4060
2-345	337				1232			21	1589
400								60	60
Grand Total	1338	1615	450	515	2918	601	317	1071	8827

Table A3.13-2: Regional 765 kV Sum of Total Cost

Type (kV)	States								Grand Total
	IA	IL	IN	MI	MN/Dak	MO	OH/PA	WI	
345	\$524	\$1,583	\$71	\$353	\$63	\$277		\$2,106	\$4,957
765	\$2,735	\$3,503	\$1,807	\$1,148	\$7,948	\$1,361	\$1,269	\$706	\$20,480
2-345	\$707				\$3,079			\$62	\$3,849
400								\$687	\$687
Grand Total	\$3,967	\$5,086	\$1,877	\$1,502	\$11,090	\$1,638	\$1,269	\$3,763	\$36,173

Generation

MW of Capacity Cost (M\$)
 33,488 \$66,900.00

Total Costs (2010 USD in Millions)

Transmission	\$30,173
Generation	\$66,900
Transformers	
Substations	
Reactors	
Total	\$97,073

A3.14 Regional 765 kV Optimized

Refer to Tables A3.14-1 and A3.14-2.

Table A3.14-1: Regional 765 kV Optimized Sum of Line Lengths (in Miles)

Type (kV)	States								Total Line Length
	IA	IL	IN	MI	MN Dak	MO	OH PA	WI	
345	350	781	39	196	32	277		842	2517
765	851	834	411	319	1656	324	317	148	4860
2-345	337				1232			21	1589
400								60	60
Grand Total	1338	1615	460	515	2919	601	317	1071	8827

Table A3.14-2: Regional 765 kV Optimized Sum of Total Cost

Type (kV)	States								Grand Total
	IA	IL	IN	MI	MN Dak	MO	OH PA	WI	
345	\$524	\$1,563	\$71	\$353	\$63	\$277		\$2,105	\$4,957
765	\$2,735	\$3,503	\$1,807	\$1,148	\$7,948	\$1,361	\$1,289	\$708	\$20,480
2-345	\$707				\$3,079			\$62	\$3,849
400								\$687	\$687
Grand Total	\$3,967	\$5,066	\$1,877	\$1,502	\$11,090	\$1,638	\$1,289	\$3,763	\$30,173

Generation

MW of Capacity
 30,400

Cost (M\$)
 \$80,800.00

Total Costs (2010 USD in Millions)

Transmission \$30,173

Generation \$80,800

Transformers

Substations

Reactors

Total \$80,973

Refer to Figure A3.14-1.




Figure A3.14-1: RGOS Regional 765 kV Optimized

**Duke Energy Ohio
Case No. 10-2586-EL-SSO
IEU Supplemental First Set Production of Documents
Date Received: November 17, 2010**

IEU-SUPP-POD-03-005 CONFIDENTIAL

REQUEST:

Please provide any documents identified in response to Interrogatory No. 10.

RESPONSE:

CONFIDENTIAL PROPRIETARY TRADE SECRET

See Confidential Attachment IEU-Second- Supp-POD-03-005 (l): Transaction Review Committee White Paper - February (Draft)

See Confidential Attachment IEU-Second- Supp-POD-03-005 (m): Market Capacity

See Attachment IEU-Second- Supp-POD-03-005 (n): MISO Report Describing Future Transmission Expansion Projects and Costs;

See Confidential Attachment IEU-Second- Supp-POD-03-005 (o): Analysis of RTO Realignment

1. Original Base Case
2. Base Case FE STIP
3. Base Case FE 2012
4. Base Case FE STIP 2012\$ [REDACTED]
5. Base Case FE STIP \$2012 [REDACTED]

See Confidential Attachment IEU-Second- Supp-POD-03-005 (p): Draft of May Whitepaper dated April 30, 2010;

See Confidential Attachment IEU-Second- Supp-POD-03-005 (q): Draft of May Whitepaper dated May 7, 2010;

See Confidential Attachment IEU-Second- Supp-POD-03-005 (r): Draft of Whitepaper Appendix dated January 8, 2010.

PERSON RESPONSIBLE: Lee Barrett

Ten Points	40.00%
After Ten W/ACT	9.20%

[illegible]

Tax Rate	40.00%
After Tax WAGE	0.28%

[illegible]

Tax Rate	40.00%
After Tax WACC	0.35%

[illegible]

Tax Rate	40.00%
After Tax WACC	9.39%

[illegible]



139 East Fourth Street, R. Main 1212
P.O. Box 960
Cincinnati, Ohio 45201-0960
Tel: 513-287-4337
Fax: 513-287-4385
dianne.kuhnell@duke-energy.com

Dianne B. Kuhnell
Senior Paralegal

8

RTO
checks

VIA OVERNIGHT MAIL

December 31, 2010

All Counsel of Record

Re: Duke Energy Ohio 10-2586-EL-SSO

Dear Counsel:

Enclosed is a CD that contains the CONFIDENTIAL documents as an attachment response to IEU-SUPP-POD-03-005(s). Please note these documents are being produced pursuant to an executed confidentiality agreement. Because of the volume of information being provided, we have downloaded these documents onto an enclosed CD for ease of review.

We believe these to be the remainder of the documents pertaining to this IEU Production of Documents request. Included as requested in these documents are drafts of all analyses performed.

Should you have any questions, please call me at 513-287-4337.

Very truly yours,

Dianne Kuhnell
Senior Paralegal

Enclosures

cc: All counsel of record having executed a Confidentiality Agreement (w/encl.)

Duke Energy Ohio
Case No. 10-2586-EL-SSO
IEU Supplemental First Set Production of Documents
Date Received: November 17, 2010

IEU-SUPP-POD-03-005 (s) CONFIDENTIAL

REQUEST:

Please provide any documents identified in response to Interrogatory No. 10.


RESPONSE:

CONFIDENTIAL PROPRIETARY TRADE SECRET


See Confidential Attachment IEU-Second- Supp-POD-03-005 (s) being sent on CD: Drafts of Analyses.

PERSON RESPONSIBLE: Lee Barrett


Figure 1 – 2012/2013 Rest of RTO Clearing Price




Appendix 1 – Forecasted Rest of RTO Pricing
with and without DEO (Legacy CGE Generation & Load)
\$/ MW-Day



10 Year & 15 NPV from Incremental RPM Revenues (2012 Dollars) (in \$ millions)



Appendix 2 – 10 Year NPV Annualized (2012 Dollars) (in \$ millions)



TRE S0203

IEU-Ohio Ex.

10a



139 East Fourth Street, R.Main1212
P.O. Box 960
Cincinnati, Ohio 45201-0960
Tel: 513-287-4337
Fax: 513-287-4385
dianne.kuhnell@duke-energy.com

Dianne B. Kuhnell
Senior Paralegal

VIA OVERNIGHT MAIL

December 31, 2010

All Counsel of Record

Re: Duke Energy Ohio 10-2586-EL-SSO

Dear Counsel:

Enclosed is a CD that contains the CONFIDENTIAL documents as an attachment response to IEU-SUPP-POD-03-005(s). Please note these documents are being produced pursuant to an executed confidentiality agreement. Because of the volume of information being provided, we have downloaded these documents onto an enclosed CD for ease of review.

We believe these to be the remainder of the documents pertaining to this IEU Production of Documents request. Included as requested in these documents are drafts of all analyses performed.

Should you have any questions, please call me at 513-287-4337.

Very truly yours,

Dianne Kuhnell
Senior Paralegal

Enclosures

cc: All counsel of record having executed a Confidentiality Agreement (w/encl.)