

FILE

Ohio Power Siting Board

Staff Investigation Report and Recommendation

RECEIVED-DOCKETING DIV
2011 FEB -3 PM 3:21
PUCO

Case No.: 10-1149-EL-BLN

Project: Bayshore-Maclean-Lemoyne 138 kV Transmission Line
Reconductoring and Intermediate Structure Placement

Applicant: American Transmission Systems, Inc.

Report Date: 3 February 2011

Automatic Approval Date: 12 February 2011 (Letter of Notification process)

Waiver Request: None

Inspection Date(s): 1 & 20 September 2010

Staff Assigned: J. O'Dell & D. Rostofer

Summary of Staff Recommendations (see report text for discussion):

Application: ☒ Approval ☐ Disapproval ☐ Approval with Conditions
Waiver: ☐ Approval ☐ Disapproval ☒ Not Applicable

Summary of Staff Recommended Conditions (see report text for discussion):

- Applicant shall obtain all required easements prior to the start of construction.

Projected Docket Closure Date (if automatically approved): 31 May 2013

Investigation Report

Project Description: This project involves the reconductoring of approximately 2.8 miles of one circuit of the double circuit Bayshore-Maclean-Lemoyne 138 kV transmission line. The existing configuration utilizes steel lattice towers. Intermediate wood pole structures are needed to support the new larger conductors. These new intermediate poles would typically be placed in the mid-span area between towers. The project is required to reduce potential circuit-overloads, simplify switching activities and to increase overall reliability.

Site Description: The project is entirely confined within an existing transmission line r-o-w. Land use is primarily agricultural, with a short segment traversing along the edge and through the corner of a suburban residential community. This project is located in Troy Township, Wood County.

This is to certify that the images appearing are an accurate and complete reproduction of a case file document delivered in the regular course of business.
Technician *MM* Date Processed FEB 03 2011

Discussion/Comments/Concerns: The Applicant originally received approval to reconductor this line under a Construction Notice (ref: 08-1028-EL-BNR). Due to design changes, the Applicant subsequently filed this Letter of Notification. The Applicant is in the process of requesting withdrawal of the Construction Notice, as this project would replace the earlier filing. No significant vegetative clearing is required. The construction of this project should pose only minimal negative social and ecological impacts.