

**Case No. 11-1142-EL-REN**  
**Ayer-Tony-KY-PV-2.3KW Residence**  
**Staff Interrogatories – Initial Set**

Question 1: In section I.1 you list the expected annual capacity factor (%) as 0.1313. Did you mean 13.13 % or 0.1313 %? What is the correct capacity factor?

(Note: Capacity factor = Projected annual gross generation / (nameplate capacity x 8760)

Capacity factor = 2760 kWh (from section G.4d) / (2.3 kW (from section G.4a) x 8760) = 0.137 or 13.7 %.)

Answer 1: The correct capacity factor is 13.7%.

**This foregoing document was electronically filed with the Public Utilities**

**Commission of Ohio Docketing Information System on**

**4/15/2011 9:40:32 AM**

**in**

**Case No(s). 11-1142-EL-REN**

Summary: Response to staff interrogatories electronically filed by Mr. Dan Yonkin on behalf of Ayer, Tony