## **BEFORE THE**



## PUBLIC UTILITIES COMMISSION OF OHIO

In the Matter of the Application of Duke Energy Ohio, Inc., for an Adjustment to Rider AMRP Rates to Recover Costs Incurred in 2010.	) ) )	Case No. 10-2788-GA-RDR
In the Matter of the Application of Duke Energy Ohio, Inc. for Tariff Approval.	)	Case No. 10-2789-GA-ATA

## SUBMISSION OF LATE-FILED EXHBIT BY DUKE ENERGY OHIO, INC.

In an Opinion and Order issued May 4, 2011, the Public Utilities Commission of Ohio (Commission) approved a Stipulation and Recommendation ("Stipulation") that established Duke Energy Ohio, Inc.'s (Duke Energy Ohio) Accelerated Main Replacement Program (AMRP) rates effective May 6, 2011.<sup>1</sup> The Stipulation further provided:

The Parties agree that Duke Energy Ohio will file with the Commission a late filed exhibit ("Exhibit") that will memorialize the methodology by which the Company will calculate maintenance savings associated with the replacement of larger than 12 inch diameter pipe that serves as an offset to the AMRP Rider rate that customers will be asked to pay.<sup>2</sup>

On July 1, 2011, Duke Energy Ohio and the Office of the Ohio Consumers' Counsel and the Staff of the Public Utilities Commission of Ohio (collectively, the Parties) jointly submitted a

This is to cortally that the images of a case file accurate and complete reproduction of a case file document delivered in the regular course of business rechnician Date Processed AIG 15 7011

<sup>&</sup>lt;sup>1</sup> Duke Energy Ohio AMRP, Sheet No. 65 (May 6, 2011).

<sup>&</sup>lt;sup>2</sup> Stipulation at 6 (April 8, 2011).

motion requesting an extension within which to provide the late-filed exhibit and the Attorney Examiner granted the motion on July 14, 2011. Subsequently, the Parties have met and resolved remaining issues. As a result of the Parties resolution of the remaining issues, Duke Energy Ohio hereby submits the attached exhibit that provides a methodology for calculating maintenance savings associated with the replacement of larger than 12-inch diameter cast iron and bare steel pipe.

Duke Energy Ohio respectfully requests that the Commission accept this exhibit as part of the record in this matter.

Respectfully submitted,

DUKE ENERGY OHIO, INC.

Amy B. Spiller (0047277) Deputy General Counsel

Elizabeth H. Watts (0031092) (Counsel of Record)

Associate General Counsel

155 East Broad Street, 21st Floor

Columbus, Ohio 43215 Phone: 614-222-1330

Fax: 614-222-1337

Elizabeth. Watts@duke-energy.com

## **Certificate of Service**

I hereby certify that a true and accurate copy of the foregoing has been served upon the following parties via electronic mail on this 12th day of August, 2011.

Challetti H. (Koll)

Steven L. Beeler Assistant Attorney General Public Utilities Section 180 East Broad Street, 6<sup>th</sup> Floor Columbus, OH 43215-3793 steven.beeler@puc.state.oh.us

Larry S. Sauer Office of the Ohio Consumers' Counsel 10 West Broad Street, Suite 1800 Columbus, Ohio 43215-3485 sauer@occ.state.oh.us

	2011	2012	2013	2014	2015
Small Diameter Guaranteed Savings	\$475,152	\$612,696	\$662,712	\$734,610	\$847,146
Proposed Large Diameter Guaranteed Savings		\$6,877	\$27,508	\$55,016	\$82,524
Accumulated Total	\$475,152	\$619,573	\$690,220	\$789,626	\$929,670

368 Total Leaks over 10 years for 33 miles 33.5 Miles of large diameter main 10 Years of data 1.1 Leaks/mile/year