

October 3, 2012

Ms. Betty McCauley  
Director, Administration Department  
Secretary to the Commission  
Docketing Division  
The Public Utilities Commission of Ohio  
180 East Broad Street  
Columbus, OH 43215-3793

PUCO

2012 OCT -4 AM 10:00

RECEIVED-DOCKETING DIV

**Letter of Notification**  
**Davis Besse-Hayes 345 kV Transmission Line**  
**Construction Project**  
**Case No. 12-2466-EL-BLN**

Dear Ms. McCauley:

In accordance with Rule 4906-1-11, American Transmission Systems, Incorporated ("ATSI"), transmit one (1) original and eleven (11) copies of the enclosed Letter of Notification for the above captioned project. In this project, ATSI is proposing to install approximately 30 miles of 954 kmil 48/7 ACSR conductor in an existing open arm position on steel lattice towers and installing one new transmission structure. The project starts at the Davis Besse Substation and extends east to the proposed new Hayes Substation. ATSI has proposed the installation of the Hayes Substation in an application submitted to the Board on July 31, 2012 in Docket No. 11-4711-EL-BSB. That application proposes a Preferred Site and an Alternate Site for the Hayes Substation. The Project area is located in an existing transmission corridor extending in Carroll and Salem Townships, Ottawa County; Rice, Riley and Townsend Townships, Sandusky County; Margaretta and Perkins Township, Erie County, Ohio.

Please be advised of the following:

a) Name and address of the applicants:

American Transmission Systems, Incorporated  
76 South Main Street  
Akron, Ohio 44308

b) Name of proposed facilities:

Davis Besse-Hayes 345 kV Transmission Line Construction Project

This is to certify that the images appearing are an  
accurate and complete reproduction of a case file  
document delivered in the regular course of business  
Technician [Signature] Date Processed OCT 04 2012

c) Location of proposed facilities:

The Project area is located in an existing transmission corridor extending in Carroll and Salem Townships, Ottawa County; Rice, Riley and Townsend Townships, Sandusky County; Margaretta and Perkins Township, Erie County, Ohio.

d) Description of proposed facilities:

The Project involves installing approximately 30 miles of 954 kcmil 48/7 ACSR conductor in an existing open arm position on steel lattice towers. Additionally, one new transmission structure will be installed.

e) Applicant's representative:

Scott M. Humphrys  
Transmission Specialist  
Energy Delivery Transmission and Substation Design  
FirstEnergy Service Company  
76 South Main Street  
Akron, OH 44308-1890

We have provided a copy of the Letter of Notification by certified mail, with return receipt requested, to each official of the political subdivisions immediately affected by the proposed project as listed in the attached Exhibit 1. Copies of the transmittal letters addressed to the local government representatives of Carroll and Salem Townships, Ottawa County; Rice, Riley and Townsend Townships, Sandusky County; Margaretta and Perkins Township, Erie County, Ohio are enclosed for your file.

After docketing this filing, please return one time-stamped copy of the Letter of Notification for our records to us in the enclosed envelope. Should staff of the Ohio Power Siting Board desire further information or discussion of this submittal, please contact me at (330) 384-2526.

Sincerely,



Scott M. Humphrys  
Transmission Specialist  
Energy Delivery Transmission and Substation  
Design  
FirstEnergy Service Company

Attachments

October 3, 2012

The Honorable James. M. Sass  
Ottawa County Commissioner  
315 Madison Street Room 103  
Port Clinton, OH 43452

**Letter of Notification**  
**Davis Besse-Hayes 345 kV Transmission Line**  
**Construction Project**  
**Case No. 12-2666-EL-BLN**


Dear Mr. Sass,

In the above captioned project, American Transmission Systems, Incorporated ("ATSI") a subsidiary of FirstEnergy Corp., is proposing to install approximately 30 miles of new conductor on an existing open arm position on steel lattice towers. Additionally, one new transmission structure will be installed. The Project area is located in an existing transmission corridor extending in Carroll and Salem Townships, Ottawa County; Rice, Riley and Townsend Townships, Sandusky County; Margaretta and Perkins Township, Erie County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Transmission Specialist  
Energy Delivery Transmission and Substation  
Design  
FirstEnergy Service Company

Attachment

October 3, 2012

The Honorable Steven M. Arndt  
Ottawa County Commissioner  
315 Madison Street Room 103  
Port Clinton, OH 43452

**Letter of Notification**  
**Davis Besse-Hayes 345 kV Transmission Line**  
**Construction Project**  
**Case No. 12- -EL-BLN**


Dear Mr. Arndt,

In the above captioned project, American Transmission Systems, Incorporated ("ATSI") a subsidiary of FirstEnergy Corp., is proposing to install approximately 30 miles of new conductor on an existing open arm position on steel lattice towers. Additionally, one new transmission structure will be installed. The Project area is located in an existing transmission corridor extending in Carroll and Salem Townships, Ottawa County; Rice, Riley and Townsend Townships, Sandusky County; Margaretta and Perkins Township, Erie County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Transmission Specialist  
Energy Delivery Transmission and Substation  
Design  
FirstEnergy Service Company

Attachment

October 3, 2012

The Honorable Mark Stahl  
Ottawa County Commissioner  
315 Madison Street Room 103  
Port Clinton, OH 43452

**Letter of Notification**  
**Davis Besse-Hayes 345 kV Transmission Line**  
**Construction Project**  
**Case No. 12- -EL-BLN**


Dear Mr. Stahl,

In the above captioned project, American Transmission Systems, Incorporated ("ATSI") a subsidiary of FirstEnergy Corp., is proposing to install approximately 30 miles of new conductor on an existing open arm position on steel lattice towers. Additionally, one new transmission structure will be installed. The Project area is located in an existing transmission corridor extending in Carroll and Salem Townships, Ottawa County; Rice, Riley and Townsend Townships, Sandusky County; Margaretta and Perkins Township, Erie County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Transmission Specialist  
Energy Delivery Transmission and Substation  
Design  
FirstEnergy Service Company

Attachment

October 3, 2012

Mr. David A. Brunkhorst P.E., P.S.  
Ottawa County Engineer  
315 Madison Street Room 106  
Port Clinton, OH 43452

**Letter of Notification**  
**Davis Besse-Hayes 345 kV Transmission Line**  
**Construction Project**  
**Case No. 12-      -EL-BLN**


Dear Mr. Brunkhorst,

In the above captioned project, American Transmission Systems, Incorporated ("ATSI") a subsidiary of FirstEnergy Corp., is proposing to install approximately 30 miles of new conductor on an existing open arm position on steel lattice towers. Additionally, one new transmission structure will be installed. The Project area is located in an existing transmission corridor extending in Carroll and Salem Townships, Ottawa County; Rice, Riley and Townsend Townships, Sandusky County; Margaretta and Perkins Township, Erie County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Transmission Specialist  
Energy Delivery Transmission and Substation  
Design  
FirstEnergy Service Company

Attachment

October 3, 2012

Ottawa County Regional Planning  
Commission  
315 Madison Street Room 107  
Port Clinton, OH 43452

**Letter of Notification**  
**Davis Besse-Hayes 345 kV Transmission Line**  
**Construction Project**  
**Case No. 12- -EL-BLN**


To Whom It May Concern:,

In the above captioned project, American Transmission Systems, Incorporated ("ATSI") a subsidiary of FirstEnergy Corp., is proposing to install approximately 30 miles of new conductor on an existing open arm position on steel lattice towers. Additionally, one new transmission structure will be installed. The Project area is located in an existing transmission corridor extending in Carroll and Salem Townships, Ottawa County; Rice, Riley and Townsend Townships, Sandusky County; Margaretta and Perkins Township, Erie County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Transmission Specialist  
Energy Delivery Transmission and Substation  
Design  
FirstEnergy Service Company

Attachment

October 3, 2012

Mr. Donald L. St. Clair, Chair  
Carroll Township Trustees  
11080 W. Toussant East Road  
Oak Harbor, OH 43449

**Letter of Notification**  
**Davis Besse-Hayes 345 kV Transmission Line**  
**Construction Project**  
**Case No. 12-        -EL-BLN**


Dear Mr. St. Clair,

In the above captioned project, American Transmission Systems, Incorporated ("ATSI") a subsidiary of FirstEnergy Corp., is proposing to install approximately 30 miles of new conductor on an existing open arm position on steel lattice towers. Additionally, one new transmission structure will be installed. The Project area is located in an existing transmission corridor extending in Carroll and Salem Townships, Ottawa County; Rice, Riley and Townsend Townships, Sandusky County; Margareta and Perkins Township, Erie County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Transmission Specialist  
Energy Delivery Transmission and Substation  
Design  
FirstEnergy Service Company

Attachment



October 3, 2012

Mr. John S. Verb  
Carroll Township Trustee  
11080 W. Toussant East Road  
Oak Harbor, OH 43449

**Letter of Notification**  
**Davis Besse-Hayes 345 kV Transmission Line**  
**Construction Project**  
**Case No. 12- -EL-BLN**


Dear Mr. Verb,

In the above captioned project, American Transmission Systems, Incorporated ("ATSI") a subsidiary of FirstEnergy Corp., is proposing to install approximately 30 miles of new conductor on an existing open arm position on steel lattice towers. Additionally, one new transmission structure will be installed. The Project area is located in an existing transmission corridor extending in Carroll and Salem Townships, Ottawa County; Rice, Riley and Townsend Townships, Sandusky County; Margaretta and Perkins Township, Erie County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Transmission Specialist  
Energy Delivery Transmission and Substation  
Design  
FirstEnergy Service Company

Attachment

October 3, 2012

Mr. Richard J. Keiser  
Carroll Township Trustee  
11080 W. Toussant East Road  
Oak Harbor, OH 43449

**Letter of Notification**  
**Davis Besse-Hayes 345 kV Transmission Line**  
**Construction Project**  
**Case No. 12- -EL-BLN**


Dear Mr. Keiser,

In the above captioned project, American Transmission Systems, Incorporated ("ATSI") a subsidiary of FirstEnergy Corp., is proposing to install approximately 30 miles of new conductor on an existing open arm position on steel lattice towers. Additionally, one new transmission structure will be installed. The Project area is located in an existing transmission corridor extending in Carroll and Salem Townships, Ottawa County; Rice, Riley and Townsend Townships, Sandusky County; Margareta and Perkins Township, Erie County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Transmission Specialist  
Energy Delivery Transmission and Substation  
Design  
FirstEnergy Service Company

Attachment

October 3, 2012

Ms. Jessica E. Brough  
Carroll Township Fiscal Officer  
11080 W. Toussant East Road  
Oak Harbor, OH 43449

**Letter of Notification**  
**Davis Besse-Hayes 345 kV Transmission Line**  
**Construction Project**  
**Case No. 12-        -EL-BLN**


Dear Ms. Brough,

In the above captioned project, American Transmission Systems, Incorporated ("ATSI") a subsidiary of FirstEnergy Corp., is proposing to install approximately 30 miles of new conductor on an existing open arm position on steel lattice towers. Additionally, one new transmission structure will be installed. The Project area is located in an existing transmission corridor extending in Carroll and Salem Townships, Ottawa County; Rice, Riley and Townsend Townships, Sandusky County; Margareta and Perkins Township, Erie County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Transmission Specialist  
Energy Delivery Transmission and Substation  
Design  
FirstEnergy Service Company

Attachment

October 3, 2012

Mr. Richard C. Lenke, Chair  
Salem Township Trustees  
11650 W. Portage River South Road  
Oak Harbor, OH 43449

**Letter of Notification**  
**Davis Besse-Hayes 345 kV Transmission Line**  
**Construction Project**  
**Case No. 12-       -EL-BLN**


Dear Mr. Lenke,

In the above captioned project, American Transmission Systems, Incorporated ("ATSI") a subsidiary of FirstEnergy Corp., is proposing to install approximately 30 miles of new conductor on an existing open arm position on steel lattice towers. Additionally, one new transmission structure will be installed. The Project area is located in an existing transmission corridor extending in Carroll and Salem Townships, Ottawa County; Rice, Riley and Townsend Townships, Sandusky County; Margaretta and Perkins Township, Erie County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Transmission Specialist  
Energy Delivery Transmission and Substation  
Design  
FirstEnergy Service Company

Attachment

October 3, 2012

Mr. Victor A. Harder  
Salem Township Trustee  
11650 W. Portage River South Road  
Oak Harbor, OH 43449

**Letter of Notification**  
**Davis Besse-Hayes 345 kV Transmission Line**  
**Construction Project**  
**Case No. 12- -EL-BLN**


Dear Mr. Harder,

In the above captioned project, American Transmission Systems, Incorporated ("ATSI") a subsidiary of FirstEnergy Corp., is proposing to install approximately 30 miles of new conductor on an existing open arm position on steel lattice towers. Additionally, one new transmission structure will be installed. The Project area is located in an existing transmission corridor extending in Carroll and Salem Townships, Ottawa County; Rice, Riley and Townsend Townships, Sandusky County; Margareta and Perkins Township, Erie County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Transmission Specialist  
Energy Delivery Transmission and Substation  
Design  
FirstEnergy Service Company

Attachment

October 3, 2012

Mr. Charles E. Shultz  
Salem Township Trustee  
11650 W. Portage River South Road  
Oak Harbor, OH 43449

**Letter of Notification**  
**Davis Besse-Hayes 345 kV Transmission Line**  
**Construction Project**  
**Case No. 12- -EL-BLN**


Dear Mr. Shultz,

In the above captioned project, American Transmission Systems, Incorporated ("ATSI") a subsidiary of FirstEnergy Corp., is proposing to install approximately 30 miles of new conductor on an existing open arm position on steel lattice towers. Additionally, one new transmission structure will be installed. The Project area is located in an existing transmission corridor extending in Carroll and Salem Townships, Ottawa County; Rice, Riley and Townsend Townships, Sandusky County; Margaretta and Perkins Township, Erie County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Transmission Specialist  
Energy Delivery Transmission and Substation  
Design  
FirstEnergy Service Company

Attachment

October 3, 2012

Ms. Susan L. Perrin  
Salem Township Fiscal Officer  
11650 W. Portage River South Road  
Oak Harbor, OH 43449

**Letter of Notification**  
**Davis Besse-Hayes 345 kV Transmission Line**  
**Construction Project**  
**Case No. 12- -EL-BLN**


Dear Ms. Perrin,

In the above captioned project, American Transmission Systems, Incorporated ("ATSI") a subsidiary of FirstEnergy Corp., is proposing to install approximately 30 miles of new conductor on an existing open arm position on steel lattice towers. Additionally, one new transmission structure will be installed. The Project area is located in an existing transmission corridor extending in Carroll and Salem Townships, Ottawa County; Rice, Riley and Townsend Townships, Sandusky County; Margaretta and Perkins Township, Erie County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Transmission Specialist  
Energy Delivery Transmission and Substation  
Design  
FirstEnergy Service Company

Attachment

October 3, 2012

The Honorable Terry L. Thatcher,  
President Sandusky County Commissioners  
622 Croghan Street  
Fremont, OH 43420

**Letter of Notification**  
**Davis Besse-Hayes 345 kV Transmission Line**  
**Construction Project**  
**Case No. 12- -EL-BLN**

Dear Mr. Thatcher,

In the above captioned project, American Transmission Systems, Incorporated ("ATSI") a subsidiary of FirstEnergy Corp., is proposing to install approximately 30 miles of new conductor on an existing open arm position on steel lattice towers. Additionally, one new transmission structure will be installed. The Project area is located in an existing transmission corridor extending in Carroll and Salem Townships, Ottawa County; Rice, Riley and Townsend Townships, Sandusky County; Margaretta and Perkins Township, Erie County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Transmission Specialist  
Energy Delivery Transmission and Substation  
Design  
FirstEnergy Service Company

Attachment



October 3, 2012

The Honorable Danny L. Polter  
Sandusky County Commissioner  
622 Croghan Street  
Fremont, OH 43420

**Letter of Notification**  
**Davis Besse-Hayes 345 kV Transmission Line**  
**Construction Project**  
**Case No. 12- -EL-BLN**


Dear Mr. Polter,

In the above captioned project, American Transmission Systems, Incorporated ("ATSI") a subsidiary of FirstEnergy Corp., is proposing to install approximately 30 miles of new conductor on an existing open arm position on steel lattice towers. Additionally, one new transmission structure will be installed. The Project area is located in an existing transmission corridor extending in Carroll and Salem Townships, Ottawa County; Rice, Riley and Townsend Townships, Sandusky County; Margaretta and Perkins Township, Erie County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Transmission Specialist  
Energy Delivery Transmission and Substation  
Design  
FirstEnergy Service Company

Attachment

October 3, 2012

The Honorable Matt Damschroder  
Sandusky County Commissioner  
622 Croghan Street  
Fremont, OH 43420

**Letter of Notification**  
**Davis Besse-Hayes 345 kV Transmission Line**  
**Construction Project**  
**Case No. 12-        -EL-BLN**


Dear Mr. Damschroder,

In the above captioned project, American Transmission Systems, Incorporated ("ATSI") a subsidiary of FirstEnergy Corp., is proposing to install approximately 30 miles of new conductor on an existing open arm position on steel lattice towers. Additionally, one new transmission structure will be installed. The Project area is located in an existing transmission corridor extending in Carroll and Salem Townships, Ottawa County; Rice, Riley and Townsend Townships, Sandusky County; Margareta and Perkins Township, Erie County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Transmission Specialist  
Energy Delivery Transmission and Substation  
Design  
FirstEnergy Service Company

Attachment

October 3, 2012

Mr. James R. Moyer P.E., P.S.  
Sandusky County Engineer  
622 Croghan Street  
Fremont, OH 43420

**Letter of Notification**  
**Davis Besse-Hayes 345 kV Transmission Line**  
**Construction Project**  
**Case No. 12-        -EL-BLN**


Dear Mr. Moyer,

In the above captioned project, American Transmission Systems, Incorporated ("ATSI") a subsidiary of FirstEnergy Corp., is proposing to install approximately 30 miles of new conductor on an existing open arm position on steel lattice towers. Additionally, one new transmission structure will be installed. The Project area is located in an existing transmission corridor extending in Carroll and Salem Townships, Ottawa County; Rice, Riley and Townsend Townships, Sandusky County; Margaretta and Perkins Township, Erie County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Transmission Specialist  
Energy Delivery Transmission and Substation  
Design  
FirstEnergy Service Company

Attachment

October 3, 2012

Mr. John Wiley  
Sandusky County Regional Planning Director  
108 South Park Avenue  
Fremont, OH 43420

**Letter of Notification**  
**Davis Besse-Hayes 345 kV Transmission Line**  
**Construction Project**  
**Case No. 12-        -EL-BLN**


Dear Mr. Wiley,

In the above captioned project, American Transmission Systems, Incorporated ("ATSI") a subsidiary of FirstEnergy Corp., is proposing to install approximately 30 miles of new conductor on an existing open arm position on steel lattice towers. Additionally, one new transmission structure will be installed. The Project area is located in an existing transmission corridor extending in Carroll and Salem Townships, Ottawa County; Rice, Riley and Townsend Townships, Sandusky County; Margareta and Perkins Township, Erie County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Transmission Specialist  
Energy Delivery Transmission and Substation  
Design  
FirstEnergy Service Company

Attachment

October 3, 2012

Mr. William C. Lamalie, Chair  
Rice Township Trustees  
110 County Road 119  
Fremont, OH 43420

**Letter of Notification**  
**Davis Besse-Hayes 345 kV Transmission Line**  
**Construction Project**  
**Case No. 12- -EL-BLN**


Dear Mr. Lamalie,

In the above captioned project, American Transmission Systems, Incorporated ("ATSP") a subsidiary of FirstEnergy Corp., is proposing to install approximately 30 miles of new conductor on an existing open arm position on steel lattice towers. Additionally, one new transmission structure will be installed. The Project area is located in an existing transmission corridor extending in Carroll and Salem Townships, Ottawa County; Rice, Riley and Townsend Townships, Sandusky County; Margaretta and Perkins Township, Erie County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Transmission Specialist  
Energy Delivery Transmission and Substation  
Design  
FirstEnergy Service Company

Attachment

October 3, 2012

Mr. Donald E. Atkinson  
Rice Township Trustee  
110 County Road 119  
Fremont, OH 43420

**Letter of Notification**  
**Davis Besse-Hayes 345 kV Transmission Line**  
**Construction Project**  
**Case No. 12-      -EL-BLN**


Dear Mr. Atkinson,

In the above captioned project, American Transmission Systems, Incorporated ("ATSI") a subsidiary of FirstEnergy Corp., is proposing to install approximately 30 miles of new conductor on an existing open arm position on steel lattice towers. Additionally, one new transmission structure will be installed. The Project area is located in an existing transmission corridor extending in Carroll and Salem Townships, Ottawa County; Rice, Riley and Townsend Townships, Sandusky County; Margaretta and Perkins Township, Erie County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Transmission Specialist  
Energy Delivery Transmission and Substation  
Design  
FirstEnergy Service Company

Attachment

October 3, 2012

Mr. Timothy J. King  
Rice Township Trustee  
110 County Road 119  
Fremont, OH 43420

**Letter of Notification**  
**Davis Besse-Hayes 345 kV Transmission Line**  
**Construction Project**  
**Case No. 12- -EL-BLN**

Dear Mr. King,

In the above captioned project, American Transmission Systems, Incorporated ("ATSI") a subsidiary of FirstEnergy Corp., is proposing to install approximately 30 miles of new conductor on an existing open arm position on steel lattice towers. Additionally, one new transmission structure will be installed. The Project area is located in an existing transmission corridor extending in Carroll and Salem Townships, Ottawa County; Rice, Riley and Townsend Townships, Sandusky County; Margaretta and Perkins Township, Erie County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Transmission Specialist  
Energy Delivery Transmission and Substation  
Design  
FirstEnergy Service Company

Attachment

October 3, 2012

Ms. Kathleen M. Roosen  
Rice Township Fiscal Officer  
110 County Road 119  
Fremont, OH 43420

**Letter of Notification**  
**Davis Besse-Hayes 345 kV Transmission Line**  
**Construction Project**  
**Case No. 12-        -EL-BLN**


Dear Ms. Roosen,

In the above captioned project, American Transmission Systems, Incorporated ("ATSI") a subsidiary of FirstEnergy Corp., is proposing to install approximately 30 miles of new conductor on an existing open arm position on steel lattice towers. Additionally, one new transmission structure will be installed. The Project area is located in an existing transmission corridor extending in Carroll and Salem Townships, Ottawa County; Rice, Riley and Townsend Townships, Sandusky County; Margaretta and Perkins Township, Erie County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Transmission Specialist  
Energy Delivery Transmission and Substation  
Design  
FirstEnergy Service Company

Attachment



October 3, 2012

Mr. David W. Sachs, Chair  
Riley Township Trustees  
3093 State Route 142  
Fremont, OH 43420

**Letter of Notification**  
**Davis Besse-Hayes 345 kV Transmission Line**  
**Construction Project**  
**Case No. 12-        -EL-BLN**


Dear Mr. Sachs,

In the above captioned project, American Transmission Systems, Incorporated ("ATSI") a subsidiary of FirstEnergy Corp., is proposing to install approximately 30 miles of new conductor on an existing open arm position on steel lattice towers. Additionally, one new transmission structure will be installed. The Project area is located in an existing transmission corridor extending in Carroll and Salem Townships, Ottawa County; Rice, Riley and Townsend Townships, Sandusky County; Margaretta and Perkins Township, Erie County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Transmission Specialist  
Energy Delivery Transmission and Substation  
Design  
FirstEnergy Service Company

Attachment

October 3, 2012

Mr. John W. Antesberger  
Riley Township Trustee  
3093 State Route 142  
Fremont, OH 43420

**Letter of Notification**  
**Davis Besse-Hayes 345 kV Transmission Line**  
**Construction Project**  
**Case No. 12-        -EL-BLN**


Dear Mr. Antesberger,

In the above captioned project, American Transmission Systems, Incorporated ("ATSI") a subsidiary of FirstEnergy Corp., is proposing to install approximately 30 miles of new conductor on an existing open arm position on steel lattice towers. Additionally, one new transmission structure will be installed. The Project area is located in an existing transmission corridor extending in Carroll and Salem Townships, Ottawa County; Rice, Riley and Townsend Townships, Sandusky County; Margareta and Perkins Township, Erie County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Transmission Specialist  
Energy Delivery Transmission and Substation  
Design  
FirstEnergy Service Company

Attachment

October 3, 2012

Mr. Gary L. Overmyer  
Riley Township Trustee  
3093 State Route 142  
Fremont, OH 43420

**Letter of Notification**  
**Davis Besse-Hayes 345 kV Transmission Line**  
**Construction Project**  
**Case No. 12- -EL-BLN**


Dear Mr. Overmyer,

In the above captioned project, American Transmission Systems, Incorporated ("ATSI") a subsidiary of FirstEnergy Corp., is proposing to install approximately 30 miles of new conductor on an existing open arm position on steel lattice towers. Additionally, one new transmission structure will be installed. The Project area is located in an existing transmission corridor extending in Carroll and Salem Townships, Ottawa County; Rice, Riley and Townsend Townships, Sandusky County; Margaretta and Perkins Township, Erie County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Transmission Specialist  
Energy Delivery Transmission and Substation  
Design  
FirstEnergy Service Company

Attachment

October 3, 2012

Mr. Joseph A. Halbeisen  
Riley Township Fiscal Officer  
3093 State Route 142  
Fremont, OH 43420

**Letter of Notification**  
**Davis Besse-Hayes 345 kV Transmission Line**  
**Construction Project**  
**Case No. 12-        -EL-BLN**


Dear Mr. Halbeisen,

In the above captioned project, American Transmission Systems, Incorporated ("ATSI") a subsidiary of FirstEnergy Corp., is proposing to install approximately 30 miles of new conductor on an existing open arm position on steel lattice towers. Additionally, one new transmission structure will be installed. The Project area is located in an existing transmission corridor extending in Carroll and Salem Townships, Ottawa County; Rice, Riley and Townsend Townships, Sandusky County; Margaretta and Perkins Township, Erie County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Transmission Specialist  
Energy Delivery Transmission and Substation  
Design  
FirstEnergy Service Company

Attachment

October 3, 2012

Ms. Jean F. Leber, Chair  
Townsend Township Trustee  
1560 County Road 310  
Clyde, OH 43410

**Letter of Notification**  
**Davis Besse-Hayes 345 kV Transmission Line**  
**Construction Project**  
**Case No. 12-      -EL-BLN**


Dear Ms. Leber,

In the above captioned project, American Transmission Systems, Incorporated ("ATSI") a subsidiary of FirstEnergy Corp., is proposing to install approximately 30 miles of new conductor on an existing open arm position on steel lattice towers. Additionally, one new transmission structure will be installed. The Project area is located in an existing transmission corridor extending in Carroll and Salem Townships, Ottawa County; Rice, Riley and Townsend Townships, Sandusky County; Margaretta and Perkins Township, Erie County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Transmission Specialist  
Energy Delivery Transmission and Substation  
Design  
FirstEnergy Service Company

Attachment

October 3, 2012

Mr. Bruce L. Meggit  
Townsend Township Trustee  
5625 State Route 412  
Vickery, OH 43464

**Letter of Notification**  
**Davis Besse-Hayes 345 kV Transmission Line**  
**Construction Project**  
**Case No. 12- -EL-BLN**


Dear Mr. Meggit,

In the above captioned project, American Transmission Systems, Incorporated ("ATSI") a subsidiary of FirstEnergy Corp., is proposing to install approximately 30 miles of new conductor on an existing open arm position on steel lattice towers. Additionally, one new transmission structure will be installed. The Project area is located in an existing transmission corridor extending in Carroll and Salem Townships, Ottawa County; Rice, Riley and Townsend Townships, Sandusky County; Margareta and Perkins Township, Erie County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Transmission Specialist  
Energy Delivery Transmission and Substation  
Design  
FirstEnergy Service Company

Attachment

October 3, 2012

Mr. Jeffrey M. Miller  
Townsend Township Trustee  
1737 N. County Road 268  
Vickery, OH 43464

**Letter of Notification**  
**Davis Besse-Hayes 345 kV Transmission Line**  
**Construction Project**  
**Case No. 12-       -EL-BLN**


Dear Mr. Miller,

In the above captioned project, American Transmission Systems, Incorporated ("ATSI") a subsidiary of FirstEnergy Corp., is proposing to install approximately 30 miles of new conductor on an existing open arm position on steel lattice towers. Additionally, one new transmission structure will be installed. The Project area is located in an existing transmission corridor extending in Carroll and Salem Townships, Ottawa County; Rice, Riley and Townsend Townships, Sandusky County; Margaretta and Perkins Township, Erie County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Transmission Specialist  
Energy Delivery Transmission and Substation  
Design  
FirstEnergy Service Company

Attachment

October 3, 2012

Ms. Cathy A. Bales  
Townsend Township Fiscal Officer  
2739 County Road 306  
Vickery, OH 43464

**Letter of Notification**  
**Davis Besse-Hayes 345 kV Transmission Line**  
**Construction Project**  
**Case No. 12- -EL-BLN**


Dear Ms. Bales,

In the above captioned project, American Transmission Systems, Incorporated ("ATSI") a subsidiary of FirstEnergy Corp., is proposing to install approximately 30 miles of new conductor on an existing open arm position on steel lattice towers. Additionally, one new transmission structure will be installed. The Project area is located in an existing transmission corridor extending in Carroll and Salem Townships, Ottawa County; Rice, Riley and Townsend Townships, Sandusky County; Margaretta and Perkins Township, Erie County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Transmission Specialist  
Energy Delivery Transmission and Substation  
Design  
FirstEnergy Service Company

Attachment



October 3, 2012

The Honorable William J. Monaghan  
President, Erie County Commissioners  
2900 Columbus Avenue P.O. Box 1180  
Sandusky, OH 44871

**Letter of Notification**  
**Davis Besse-Hayes 345 kV Transmission Line**  
**Construction Project**  
**Case No. 12- -EL-BLN**


Dear Mr. Monaghan,

In the above captioned project, American Transmission Systems, Incorporated ("ATSI") a subsidiary of FirstEnergy Corp., is proposing to install approximately 30 miles of new conductor on an existing open arm position on steel lattice towers. Additionally, one new transmission structure will be installed. The Project area is located in an existing transmission corridor extending in Carroll and Salem Townships, Ottawa County; Rice, Riley and Townsend Townships, Sandusky County; Margaretta and Perkins Township, Erie County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Transmission Specialist  
Energy Delivery Transmission and Substation  
Design  
FirstEnergy Service Company

Attachment

October 3, 2012

The Honorable Pat Shenigo  
Erie County Commissioners  
2900 Columbus Avenue P.O. Box 1180  
Sandusky, OH 44871

**Letter of Notification**  
**Davis Besse-Hayes 345 kV Transmission Line**  
**Construction Project**  
**Case No. 12- -EL-BLN**


Dear Mr. Shenigo,

In the above captioned project, American Transmission Systems, Incorporated ("ATSI") a subsidiary of FirstEnergy Corp., is proposing to install approximately 30 miles of new conductor on an existing open arm position on steel lattice towers. Additionally, one new transmission structure will be installed. The Project area is located in an existing transmission corridor extending in Carroll and Salem Townships, Ottawa County; Rice, Riley and Townsend Townships, Sandusky County; Margaretta and Perkins Township, Erie County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Transmission Specialist  
Energy Delivery Transmission and Substation  
Design  
FirstEnergy Service Company

Attachment

October 3, 2012

The Honorable Thomas M. Ferrell, Jr.  
Erie County Commissioners  
2900 Columbus Avenue P.O. Box 1180  
Sandusky, OH 44871

**Letter of Notification**  
**Davis Besse-Hayes 345 kV Transmission Line**  
**Construction Project**  
**Case No. 12-        -EL-BLN**


Dear Mr. Ferrell,

In the above captioned project, American Transmission Systems, Incorporated ("ATSI") a subsidiary of FirstEnergy Corp., is proposing to install approximately 30 miles of new conductor on an existing open arm position on steel lattice towers. Additionally, one new transmission structure will be installed. The Project area is located in an existing transmission corridor extending in Carroll and Salem Townships, Ottawa County; Rice, Riley and Townsend Townships, Sandusky County; Margaretta and Perkins Township, Erie County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Transmission Specialist  
Energy Delivery Transmission and Substation  
Design  
FirstEnergy Service Company

Attachment

October 3, 2012

Mr. Steve Poggiali, Director  
Erie County Regional Planning Commission  
2900 Columbus Avenue  
Sandusky, OH 44870

**Letter of Notification**  
**Davis Besse-Hayes 345 kV Transmission Line**  
**Construction Project**  
**Case No. 12-        -EL-BLN**


Dear Mr. Poggiali,

In the above captioned project, American Transmission Systems, Incorporated ("ATSI") a subsidiary of FirstEnergy Corp., is proposing to install approximately 30 miles of new conductor on an existing open arm position on steel lattice towers. Additionally, one new transmission structure will be installed. The Project area is located in an existing transmission corridor extending in Carroll and Salem Townships, Ottawa County; Rice, Riley and Townsend Townships, Sandusky County; Margaretta and Perkins Township, Erie County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Transmission Specialist  
Energy Delivery Transmission and Substation  
Design  
FirstEnergy Service Company

Attachment

October 3, 2012

Mr. John D. Farschman, P.E., P.S.  
Erie County Engineer  
2700 Columbus Avenue  
Sandusky, OH 44870

**Letter of Notification**  
**Davis Besse-Hayes 345 kV Transmission Line**  
**Construction Project**  
**Case No. 12- -EL-BLN**


Dear Mr. Farschman,

In the above captioned project, American Transmission Systems, Incorporated ("ATSI") a subsidiary of FirstEnergy Corp., is proposing to install approximately 30 miles of new conductor on an existing open arm position on steel lattice towers. Additionally, one new transmission structure will be installed. The Project area is located in an existing transmission corridor extending in Carroll and Salem Townships, Ottawa County; Rice, Riley and Townsend Townships, Sandusky County; Margaretta and Perkins Township, Erie County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Transmission Specialist  
Energy Delivery Transmission and Substation  
Design  
FirstEnergy Service Company

Attachment

October 3, 2012

Mr. Gary P. Pooch, Chair  
Margaretta Township Trustees  
114 N. Main Street P.O. Box 278  
Castalia, OH 44824

**Letter of Notification**  
**Davis Besse-Hayes 345 kV Transmission Line**  
**Construction Project**  
**Case No. 12- -EL-BLN**


Dear Mr. Pooch,

In the above captioned project, American Transmission Systems, Incorporated ("ATSI") a subsidiary of FirstEnergy Corp., is proposing to install approximately 30 miles of new conductor on an existing open arm position on steel lattice towers. Additionally, one new transmission structure will be installed. The Project area is located in an existing transmission corridor extending in Carroll and Salem Townships, Ottawa County; Rice, Riley and Townsend Townships, Sandusky County; Margaretta and Perkins Township, Erie County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Transmission Specialist  
Energy Delivery Transmission and Substation  
Design  
FirstEnergy Service Company

Attachment

October 3, 2012

Mr. Timothy E. Reisterer  
Margaretta Township Trustee  
114 N. Main Street P.O. Box 278  
Castalia, OH 44824

**Letter of Notification**  
**Davis Besse-Hayes 345 kV Transmission Line**  
**Construction Project**  
**Case No. 12- -EL-BLN**


Dear Mr. Reisterer,

In the above captioned project, American Transmission Systems, Incorporated ("ATSI") a subsidiary of FirstEnergy Corp., is proposing to install approximately 30 miles of new conductor on an existing open arm position on steel lattice towers. Additionally, one new transmission structure will be installed. The Project area is located in an existing transmission corridor extending in Carroll and Salem Townships, Ottawa County; Rice, Riley and Townsend Townships, Sandusky County; Margaretta and Perkins Township, Erie County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Transmission Specialist  
Energy Delivery Transmission and Substation  
Design  
FirstEnergy Service Company

Attachment

October 3, 2012

Mr. A. Joe Bias, Jr.  
Margaretta Township Trustee  
114 N. Main Street P.O. Box 278  
Castalia, OH 44824

**Letter of Notification**  
**Davis Besse-Hayes 345 kV Transmission Line**  
**Construction Project**  
**Case No. 12- -EL-BLN**


Dear Mr. Bias,

In the above captioned project, American Transmission Systems, Incorporated ("ATSI") a subsidiary of FirstEnergy Corp., is proposing to install approximately 30 miles of new conductor on an existing open arm position on steel lattice towers. Additionally, one new transmission structure will be installed. The Project area is located in an existing transmission corridor extending in Carroll and Salem Townships, Ottawa County; Rice, Riley and Townsend Townships, Sandusky County; Margaretta and Perkins Township, Erie County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Transmission Specialist  
Energy Delivery Transmission and Substation  
Design  
FirstEnergy Service Company

Attachment



October 3, 2012

Ms. Mary Ann Lindsley  
Margaretta Township Fiscal Officer  
114 N. Main Street P.O. Box 278  
Castalia, OH 44824

**Letter of Notification**  
**Davis Besse-Hayes 345 kV Transmission Line**  
**Construction Project**  
**Case No. 12-      -EL-BLN**


Dear Ms. Lindsley,

In the above captioned project, American Transmission Systems, Incorporated ("ATSI") a subsidiary of FirstEnergy Corp., is proposing to install approximately 30 miles of new conductor on an existing open arm position on steel lattice towers. Additionally, one new transmission structure will be installed. The Project area is located in an existing transmission corridor extending in Carroll and Salem Townships, Ottawa County; Rice, Riley and Townsend Townships, Sandusky County; Margaretta and Perkins Township, Erie County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Transmission Specialist  
Energy Delivery Transmission and Substation  
Design  
FirstEnergy Service Company

Attachment

October 3, 2012

Mr. Jeffrey L. Ferrell, Chair  
Perkins Township Trustees  
5420 Milan Road  
Sandusky, OH 44870

**Letter of Notification**  
**Davis Besse-Hayes 345 kV Transmission Line**  
**Construction Project**  
**Case No. 12-      -EL-BLN**


Dear Mr. Ferrell,

In the above captioned project, American Transmission Systems, Incorporated ("ATSI") a subsidiary of FirstEnergy Corp., is proposing to install approximately 30 miles of new conductor on an existing open arm position on steel lattice towers. Additionally, one new transmission structure will be installed. The Project area is located in an existing transmission corridor extending in Carroll and Salem Townships, Ottawa County; Rice, Riley and Townsend Townships, Sandusky County; Margaretta and Perkins Township, Erie County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Transmission Specialist  
Energy Delivery Transmission and Substation  
Design  
FirstEnergy Service Company

Attachment

October 3, 2012

Mr. Timothy D. Coleman  
Perkins Township Trustee  
5420 Milan Road  
Sandusky, OH 44870

**Letter of Notification**  
**Davis Besse-Hayes 345 kV Transmission Line**  
**Construction Project**  
**Case No. 12-        -EL-BLN**


Dear Mr. Coleman,

In the above captioned project, American Transmission Systems, Incorporated ("ATSI") a subsidiary of FirstEnergy Corp., is proposing to install approximately 30 miles of new conductor on an existing open arm position on steel lattice towers. Additionally, one new transmission structure will be installed. The Project area is located in an existing transmission corridor extending in Carroll and Salem Townships, Ottawa County; Rice, Riley and Townsend Townships, Sandusky County; Margaretta and Perkins Township, Erie County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Transmission Specialist  
Energy Delivery Transmission and Substation  
Design  
FirstEnergy Service Company

Attachment

October 3, 2012

Mr. Michael J. Printy  
Perkins Township Trustee  
5420 Milan Road  
Sandusky, OH 44870

**Letter of Notification**  
**Davis Besse-Hayes 345 kV Transmission Line**  
**Construction Project**  
**Case No. 12-      -EL-BLN**


Dear Mr. Printy,

In the above captioned project, American Transmission Systems, Incorporated ("ATSI") a subsidiary of FirstEnergy Corp., is proposing to install approximately 30 miles of new conductor on an existing open arm position on steel lattice towers. Additionally, one new transmission structure will be installed. The Project area is located in an existing transmission corridor extending in Carroll and Salem Townships, Ottawa County; Rice, Riley and Townsend Townships, Sandusky County; Margaretta and Perkins Township, Erie County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Transmission Specialist  
Energy Delivery Transmission and Substation  
Design  
FirstEnergy Service Company

Attachment

October 3, 2012

Ms. Jane Gildenmeister  
Perkins Township Fiscal Officer  
5420 Milan Road  
Sandusky, OH 44870

**Letter of Notification**  
**Davis Besse-Hayes 345 kV Transmission Line**  
**Construction Project**  
**Case No. 12- -EL-BLN**


Dear Ms. Gildenmeister,

In the above captioned project, American Transmission Systems, Incorporated ("ATSI") a subsidiary of FirstEnergy Corp., is proposing to install approximately 30 miles of new conductor on an existing open arm position on steel lattice towers. Additionally, one new transmission structure will be installed. The Project area is located in an existing transmission corridor extending in Carroll and Salem Townships, Ottawa County; Rice, Riley and Townsend Townships, Sandusky County; Margaretta and Perkins Township, Erie County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Transmission Specialist  
Energy Delivery Transmission and Substation  
Design  
FirstEnergy Service Company

Attachment