

FILE



76 South Main Street
Akron, Ohio 44308

1-800-646-0400

November 2, 2012

Mr. Klaus Lambeck, Chief
Facilities, Siting & Environmental Analysis Division
Ohio Power Siting Board
Public Utilities Commission of Ohio
180 East Broad Street
Columbus, OH 43215-3793

RECEIVED-DOCKETING DIV
2012 NOV -6 PM 5:09
PUCO

Letter of Notification
East Akron-Sammis 138 kV Transmission Line Connection
to the Utica East Ohio Midstream Substation Project
Case No. 12-2912-EL-BLN

Dear Mr. Lambeck,

American Transmission Systems, Incorporated ("ATSI"), a subsidiary of FirstEnergy Corp., today under separate cover, has filed with the Public Utilities Commission of Ohio, Docketing Division, the subject Letter of Notification ("LON"). Copies of the LON are enclosed for your information.

In this project, ATSI is proposing to install a connection from the existing East Akron-Sammis 138 kV Transmission Line to the new Utica East Ohio Midstream Substation. The project includes looping the East Akron-Sammis 138 kV Transmission Line approximately 265 feet to the new Hagan Substation, installing the Hagan Substation and extending an approximately 1,850 foot long 138 kV single circuit tap to the new Utica East Ohio Midstream Substation. To connect the proposed transmission line loop to Hagan Substation, three (3) wood pole structures will be installed and five (5) wood pole structures will be installed from the new Hagan substation to the customer's Utica East Ohio Midstream Substation. The Project is located near the intersection of Township Highway 841 and County Highway 644 in Hanover Township, Columbiana County, Ohio. ATSI will request expedited processing for the Letter of Notification.

Should the Ohio Power Siting Board desire further information or discussion of this submittal, please contact me at (330) 384-4564.

Sincerely,

John T. Toth
Supervisor, Power Line Siting
Energy Delivery Transmission and
Substation Design
FirstEnergy Service Company

Attachments
cc: J. O'Dell (OPSB)

This is to certify that the images appearing are an accurate and complete reproduction of a case file document delivered in the regular course of business
Technician _____ Date Processed NOV 06 2012