

FILE

FirstEnergy[®]

20
76 South Main Street
Akron, Ohio 44308

1-800-646-0400

November 8, 2012

Ms. Barcy F. McNeal
Secretary
Docketing Division
The Public Utilities Commission of Ohio
180 East Broad Street
Columbus, OH 43215-3793

RECEIVED-DOCKETING DIV
2012 NOV -9 PM 1:25
PUCO

Letter of Notification
Evergreen – Niles 138 kV Transmission
Line Reconductor Project
Case No. 12- -EL-BLN

2938

Dear Ms. McNeal:

In accordance with Rule 4906-11-01, American Transmission Systems, Incorporated ("ATSI"), a FirstEnergy Corp. subsidiary, transmit one (1) original and eleven (11) copies of the enclosed Letter of Notification for the above captioned Project. In this Project, ATSI is proposing to rebuild and reconductor approximately 3.07 miles of the existing Evergreen-Niles 138 kV Transmission Line between the existing Evergreen Substation, located at 2401 Main Avenue SW and Structure 4780, located near 6107 Highland Avenue, Warren Ohio.

The Project area is located near the intersection of Burnett East Road and County Road 67 (Main Ave. SW), in Warren, Trumbull County, Ohio.

Please be advised of the following:

a) Name and address of the applicants:

American Transmission Systems, Incorporated
76 South Main Street
Akron, Ohio 44308

b) Name of proposed facilities:

Evergreen – Niles 138 kV Transmission Line
Reconductor Project

This is to certify that the images appearing are an accurate and complete reproduction of a case file document delivered in the regular course of business
Technician le Date Processed NOV 09 2012

c) Location of proposed facilities:

The Project area is located near the intersection of Burnett East Road and County Road 67 (Main Ave. SW), in Warren, Trumbull County, Ohio.

d) Description of proposed facilities;

The Project involves reconductoring approximately 3.07 miles of the Evergreen – Niles 138 kV Transmission Line. The transmission line will be reconducted with 795 ACSR 26/7. As part of the Project, four wood pole structures will be replaced with four two – pole wood structures and an additional four two – pole wood intermediate structures will be installed within the transmission line.


e) Applicant's representative:

John T. Toth
Siting Supervisor
Energy Delivery Transmission and Substation Design
FirstEnergy Service Company
76 South Main Street
Akron, OH 44308

After docketing this filing, please return one time-stamped copy of the Letter of Notification for our records to us in the enclosed envelope. We have provided a copy of the Letter of Notification by certified mail, with return receipt requested, to each official of the political subdivisions immediately affected by the proposed project as listed in the attached Exhibit 1. Copies of the transmittal letters addressed to the local government representatives of the City of Warren, Village of Lordstown, Warren Township, and Trumbull County are enclosed for your file.

Should the Ohio Power Siting Board desire further information or discussion of this submittal, please contact me at (330) 384-4564.

Sincerely,



John T. Toth
Supervisor, Power Line Siting
Energy Delivery Transmission and
Substation Design
FirstEnergy Service Company

Attachments

**EXHIBIT 1: OFFICIALS SERVED COPY OF LON
Evergreen – Niles 138 kV Transmission
Line Reconductor Project
Case No. 12- -EL-BLN**

Trumbull County

The Honorable Frank S. Fuda
President, Trumbull County Commissioner
160 High Street NW, 5th Floor
Warren, Ohio 44481

The Honorable Paul E. Heltzel
Trumbull County Commissioner
160 High Street NW, 5th Floor
Warren, Ohio 44481

The Honorable Daniel E. Polivka
Trumbull County Commissioner
160 High Street NW, 5th Floor
Warren, Ohio 44481

Ms. Paulette A. Godfrey
Clerk/Interim Administrator, Trumbull
County Commissioners
160 High Street NW, 5th Floor
Warren, Ohio 44481

Mr. Lewis Kostoff
Chairman, Trumbull County Planning
Commission
347 N. Park Avenue
Warren, OH 44481

Mr. William Miller
Director, Trumbull County Planning
Commission
347 N. Park Avenue
Warren, OH 44481

Mr. Randy Smith, P.E., P.S
Trumbull County Engineer
650 North River Road, N.W.
Warren, OH 44483

City of Warren

Mr. William Franklin
Mayor, City of Warren
391 Mahoning Avenue N.W.
Warren, OH 44483

Mr. Robert Dean
President of Council, City of Warren
391 Mahoning Avenue N.W.
Warren, OH 44483

Village of Lordstown

Mr. Arno Hill
Mayor, Village of Lordstown
1455 Salt Springs Road
Warren, OH 44481

Mr. William Blank
Clerk, Village of Lordstown
1455 Salt Springs Road
Warren, OH 44481

Mr. Michael Sullivan
Council President, Village of Lordstown
1455 Salt Springs Road
Warren, OH 44481

**American Transmission Systems, Incorporated
Evergreen – Niles 138 kV Transmission Line
Reconductor Project**

Warren Township

Ms. Terry Ambrose
Chairwoman, Warren Township Trustees
3765 W. Market Street
Leavittsburg, OH 44430

Ms. Kay Anderson
Vice Chairwoman, Warren Township
Trustees
3765 W. Market Street
Leavittsburg, OH 44430

Ms. Cheryl Ranttila Zaben
Warren Township Trustees
3765 W. Market Street
Leavittsburg, OH 44430

Ms. Debra D'Orio
Fiscal Officer, Warren Township
3765 W. Market Street
Leavittsburg, OH 44430

November 8, 2012

The Honorable Frank S. Fuda
President, Trumbull County Commissioner
160 High Street NW, 5th Floor
Warren, Ohio 44481

Letter of Notification
Evergreen – Niles 138 kV Transmission
Line Reconductor Project
Case No. 12- -EL-BLN


Dear Mr. Fuda,

In the above captioned project, American Transmission Systems, Incorporated (“ATSI”), a subsidiary of FirstEnergy Corp., is proposing to reconductor approximately 3.07 miles of the Evergreen – Niles 138 kV Transmission Line. The transmission line will be reconducted with 795 ACSR 26/7. As part of the Project, four wood pole structures will be replaced with four two – pole wood structures and an additional four two – pole wood intermediate structures will be installed within the transmission line. The Project area is located near the intersection of Burnett East Road and County Road 67 (Main Ave. SW), in Warren, Trumbull County, Ohio.

In accordance with the provisions of Ohio Administrative Code (“OAC”) Rule 4906-1-01, this project falls within the Ohio Power Siting Board’s requirements for a Letter of Notification (“LON”). Therefore, in compliance with OAC 4906-11-01 of the OPSB’s Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be glad to answer your questions concerning this matter. You may contact me at ((330) 384-4564.

Sincerely,



John T. Toth
Supervisor, Siting
Energy Delivery Transmission and
Substation Design
FirstEnergy Service Company

Attachment

November 8, 2012

The Honorable Paul E. Heltzel
Trumbull County Commissioner
160 High Street NW, 5th Floor
Warren, Ohio 44481

Letter of Notification
Evergreen – Niles 138 kV Transmission
Line Reconductor Project
Case No. 12- -EL-BLN


Dear Mr. Heltzel,

In the above captioned project, American Transmission Systems, Incorporated (“ATSI”), a subsidiary of FirstEnergy Corp., is proposing to reconductor approximately 3.07 miles of the Evergreen – Niles 138 kV Transmission Line. The transmission line will be reconducted with 795 ACSR 26/7. As part of the Project, four wood pole structures will be replaced with four two – pole wood structures and an additional four two – pole wood intermediate structures will be installed within the transmission line. The Project area is located near the intersection of Burnett East Road and County Road 67 (Main Ave. SW), in Warren, Trumbull County, Ohio.

In accordance with the provisions of Ohio Administrative Code (“OAC”) Rule 4906-1-01, this project falls within the Ohio Power Siting Board’s requirements for a Letter of Notification (“LON”). Therefore, in compliance with OAC 4906-11-01 of the OPSB’s Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be glad to answer your questions concerning this matter. You may contact me at ((330) 384-4564.

Sincerely,



John T. Toth
Supervisor, Siting
Energy Delivery Transmission and
Substation Design
FirstEnergy Service Company

Attachment

November 8, 2012

The Honorable Daniel E. Polivka
Trumbull County Commissioner
160 High Street NW, 5th Floor
Warren, Ohio 44481

Letter of Notification
Evergreen – Niles 138 kV Transmission
Line Reconductor Project
Case No. 12- -EL-BLN


Dear Mr. Polivka,

In the above captioned project, American Transmission Systems, Incorporated (“ATSI”), a subsidiary of FirstEnergy Corp., is proposing to reconductor approximately 3.07 miles of the Evergreen – Niles 138 kV Transmission Line. The transmission line will be reconducted with 795 ACSR 26/7. As part of the Project, four wood pole structures will be replaced with four two – pole wood structures and an additional four two – pole wood intermediate structures will be installed within the transmission line. The Project area is located near the intersection of Burnett East Road and County Road 67 (Main Ave. SW), in Warren, Trumbull County, Ohio.

In accordance with the provisions of Ohio Administrative Code (“OAC”) Rule 4906-1-01, this project falls within the Ohio Power Siting Board’s requirements for a Letter of Notification (“LON”). Therefore, in compliance with OAC 4906-11-01 of the OPSB’s Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be glad to answer your questions concerning this matter. You may contact me at ((330) 384-4564.

Sincerely,



John T. Toth
Supervisor, Siting
Energy Delivery Transmission and
Substation Design
FirstEnergy Service Company

Attachment

November 8, 2012

Ms. Paulette A. Godfrey
Clerk/Interim Administrator, Trumbull County Commissioners
160 High Street NW, 5th Floor
Warren, Ohio 44481

Letter of Notification
Evergreen – Niles 138 kV Transmission
Line Reconductor Project
Case No. 12- -EL-BLN


Dear Ms. Godfrey,

In the above captioned project, American Transmission Systems, Incorporated (“ATSI”), a subsidiary of FirstEnergy Corp., is proposing to reconductor approximately 3.07 miles of the Evergreen – Niles 138 kV Transmission Line. The transmission line will be reconducted with 795 ACSR 26/7. As part of the Project, four wood pole structures will be replaced with four two – pole wood structures and an additional four two – pole wood intermediate structures will be installed within the transmission line. The Project area is located near the intersection of Burnett East Road and County Road 67 (Main Ave. SW), in Warren, Trumbull County, Ohio.

In accordance with the provisions of Ohio Administrative Code (“OAC”) Rule 4906-1-01, this project falls within the Ohio Power Siting Board’s requirements for a Letter of Notification (“LON”). Therefore, in compliance with OAC 4906-11-01 of the OPSB’s Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be glad to answer your questions concerning this matter. You may contact me at ((330) 384-4564.

Sincerely,



John T. Toth
Supervisor, Siting
Energy Delivery Transmission and
Substation Design
FirstEnergy Service Company

Attachment

November 8, 2012

Mr. Lewis Kostoff
Chairman, Trumbull County Planning Commission
347 N. Park Avenue
Warren, OH 44481

Letter of Notification
Evergreen – Niles 138 kV Transmission
Line Reconductor Project
Case No. 12- -EL-BLN

Dear Mr. Kostoff,

In the above captioned project, American Transmission Systems, Incorporated (“ATSI”), a subsidiary of FirstEnergy Corp., is proposing to reconductor approximately 3.07 miles of the Evergreen – Niles 138 kV Transmission Line. The transmission line will be reconducted with 795 ACSR 26/7. As part of the Project, four wood pole structures will be replaced with four two – pole wood structures and an additional four two – pole wood intermediate structures will be installed within the transmission line. The Project area is located near the intersection of Burnett East Road and County Road 67 (Main Ave. SW), in Warren, Trumbull County, Ohio.

In accordance with the provisions of Ohio Administrative Code (“OAC”) Rule 4906-1-01, this project falls within the Ohio Power Siting Board’s requirements for a Letter of Notification (“LON”). Therefore, in compliance with OAC 4906-11-01 of the OPSB’s Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be glad to answer your questions concerning this matter. You may contact me at ((330) 384-4564.

Sincerely,



John T. Toth
Supervisor, Siting
Energy Delivery Transmission and
Substation Design
FirstEnergy Service Company

Attachment

November 8, 2012

Mr. William Miller
Director, Trumbull County Planning Commission
347 N. Park Avenue
Warren, OH 44481

Letter of Notification
Evergreen – Niles 138 kV Transmission
Line Reconductor Project
Case No. 12- -EL-BLN


Dear Mr. Miller,

In the above captioned project, American Transmission Systems, Incorporated (“ATSI”), a subsidiary of FirstEnergy Corp., is proposing to reconductor approximately 3.07 miles of the Evergreen – Niles 138 kV Transmission Line. The transmission line will be reconducted with 795 ACSR 26/7. As part of the Project, four wood pole structures will be replaced with four two – pole wood structures and an additional four two – pole wood intermediate structures will be installed within the transmission line. The Project area is located near the intersection of Burnett East Road and County Road 67 (Main Ave. SW), in Warren, Trumbull County, Ohio.

In accordance with the provisions of Ohio Administrative Code (“OAC”) Rule 4906-1-01, this project falls within the Ohio Power Siting Board’s requirements for a Letter of Notification (“LON”). Therefore, in compliance with OAC 4906-11-01 of the OPSB’s Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be glad to answer your questions concerning this matter. You may contact me at ((330) 384-4564.

Sincerely,



John T. Toth
Supervisor, Siting
Energy Delivery Transmission and
Substation Design
FirstEnergy Service Company

Attachment

November 8, 2012

Mr. Randy Smith, P.E., P.S.
Trumbull County Engineer
650 North River Road, N.W.
Warren, OH 44483

Letter of Notification
Evergreen – Niles 138 kV Transmission
Line Reconductor Project
Case No. 12- -EL-BLN


Dear Mr. Smith,

In the above captioned project, American Transmission Systems, Incorporated (“ATSI”), a subsidiary of FirstEnergy Corp., is proposing to reconductor approximately 3.07 miles of the Evergreen – Niles 138 kV Transmission Line. The transmission line will be reconducted with 795 ACSR 26/7. As part of the Project, four wood pole structures will be replaced with four two – pole wood structures and an additional four two – pole wood intermediate structures will be installed within the transmission line. The Project area is located near the intersection of Burnett East Road and County Road 67 (Main Ave. SW), in Warren, Trumbull County, Ohio.

In accordance with the provisions of Ohio Administrative Code (“OAC”) Rule 4906-1-01, this project falls within the Ohio Power Siting Board’s requirements for a Letter of Notification (“LON”). Therefore, in compliance with OAC 4906-11-01 of the OPSB’s Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be glad to answer your questions concerning this matter. You may contact me at ((330) 384-4564.

Sincerely,



John T. Toth
Supervisor, Siting
Energy Delivery Transmission and
Substation Design
FirstEnergy Service Company

Attachment

November 8, 2012

Mr. William Franklin
Mayor, City of Warren
391 Mahoning Avenue N.W.
Warren, OH 44483

Letter of Notification
Evergreen – Niles 138 kV Transmission
Line Reconductor Project
Case No. 12- -EL-BLN

Dear Mr. Franklin,

In the above captioned project, American Transmission Systems, Incorporated (“ATSI”), a subsidiary of FirstEnergy Corp., is proposing to reconductor approximately 3.07 miles of the Evergreen – Niles 138 kV Transmission Line. The transmission line will be reconducted with 795 ACSR 26/7. As part of the Project, four wood pole structures will be replaced with four two – pole wood structures and an additional four two – pole wood intermediate structures will be installed within the transmission line. The Project area is located near the intersection of Burnett East Road and County Road 67 (Main Ave. SW), in Warren, Trumbull County, Ohio.

In accordance with the provisions of Ohio Administrative Code (“OAC”) Rule 4906-1-01, this project falls within the Ohio Power Siting Board’s requirements for a Letter of Notification (“LON”). Therefore, in compliance with OAC 4906-11-01 of the OPSB’s Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be glad to answer your questions concerning this matter. You may contact me at ((330) 384-4564.

Sincerely,



John T. Toth
Supervisor, Siting
Energy Delivery Transmission and
Substation Design
FirstEnergy Service Company

Attachment

November 8, 2012

Mr. Robert Dean
President of Council, City of Warren
391 Mahoning Avenue N.W.
Warren, OH 44483

Letter of Notification
Evergreen – Niles 138 kV Transmission
Line Reconductor Project
Case No. 12- -EL-BLN


Dear Mr. Dean,

In the above captioned project, American Transmission Systems, Incorporated (“ATSI”), a subsidiary of FirstEnergy Corp., is proposing to reconductor approximately 3.07 miles of the Evergreen – Niles 138 kV Transmission Line. The transmission line will be reconducted with 795 ACSR 26/7. As part of the Project, four wood pole structures will be replaced with four two – pole wood structures and an additional four two – pole wood intermediate structures will be installed within the transmission line. The Project area is located near the intersection of Burnett East Road and County Road 67 (Main Ave. SW), in Warren, Trumbull County, Ohio.

In accordance with the provisions of Ohio Administrative Code (“OAC”) Rule 4906-1-01, this project falls within the Ohio Power Siting Board’s requirements for a Letter of Notification (“LON”). Therefore, in compliance with OAC 4906-11-01 of the OPSB’s Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be glad to answer your questions concerning this matter. You may contact me at ((330) 384-4564.

Sincerely,



John T. Toth
Supervisor, Siting
Energy Delivery Transmission and
Substation Design
FirstEnergy Service Company

Attachment

November 8, 2012

Mr. Arno Hill
Mayor, Village of Lordstown
1455 Salt Springs Road
Warren, OH 44481

Letter of Notification
Evergreen – Niles 138 kV Transmission
Line Reconductor Project
Case No. 12- -EL-BLN

Dear Mr. Hill,

In the above captioned project, American Transmission Systems, Incorporated (“ATSI”), a subsidiary of FirstEnergy Corp., is proposing to reconductor approximately 3.07 miles of the Evergreen – Niles 138 kV Transmission Line. The transmission line will be reconducted with 795 ACSR 26/7. As part of the Project, four wood pole structures will be replaced with four two – pole wood structures and an additional four two – pole wood intermediate structures will be installed within the transmission line. The Project area is located near the intersection of Burnett East Road and County Road 67 (Main Ave. SW), in Warren, Trumbull County, Ohio.

In accordance with the provisions of Ohio Administrative Code (“OAC”) Rule 4906-1-01, this project falls within the Ohio Power Siting Board’s requirements for a Letter of Notification (“LON”). Therefore, in compliance with OAC 4906-11-01 of the OPSB’s Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be glad to answer your questions concerning this matter. You may contact me at ((330) 384-4564.

Sincerely,



John T. Toth
Supervisor, Siting
Energy Delivery Transmission and
Substation Design
FirstEnergy Service Company

Attachment

November 8, 2012

Mr. Michael Sullivan
Council President, Village of Lordstown
1455 Salt Springs Road
Warren, OH 44481

Letter of Notification
Evergreen – Niles 138 kV Transmission
Line Reconductor Project
Case No. 12- -EL-BLN


Dear Mr. Sullivan,

In the above captioned project, American Transmission Systems, Incorporated (“ATSI”), a subsidiary of FirstEnergy Corp., is proposing to reconductor approximately 3.07 miles of the Evergreen – Niles 138 kV Transmission Line. The transmission line will be reconducted with 795 ACSR 26/7. As part of the Project, four wood pole structures will be replaced with four two – pole wood structures and an additional four two – pole wood intermediate structures will be installed within the transmission line. The Project area is located near the intersection of Burnett East Road and County Road 67 (Main Ave. SW), in Warren, Trumbull County, Ohio.

In accordance with the provisions of Ohio Administrative Code (“OAC”) Rule 4906-1-01, this project falls within the Ohio Power Siting Board’s requirements for a Letter of Notification (“LON”). Therefore, in compliance with OAC 4906-11-01 of the OPSB’s Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be glad to answer your questions concerning this matter. You may contact me at ((330) 384-4564.

Sincerely,



John T. Toth
Supervisor, Siting
Energy Delivery Transmission and
Substation Design
FirstEnergy Service Company

Attachment

November 8, 2012

Mr. William Blank
Clerk, Village of Lordstown
1455 Salt Springs Road
Warren, OH 44481

Letter of Notification
Evergreen – Niles 138 kV Transmission
Line Reconductor Project
Case No. 12- -EL-BLN


Dear Mr. Blank,

In the above captioned project, American Transmission Systems, Incorporated (“ATSI”), a subsidiary of FirstEnergy Corp., is proposing to reconductor approximately 3.07 miles of the Evergreen – Niles 138 kV Transmission Line. The transmission line will be reconducted with 795 ACSR 26/7. As part of the Project, four wood pole structures will be replaced with four two – pole wood structures and an additional four two – pole wood intermediate structures will be installed within the transmission line. The Project area is located near the intersection of Burnett East Road and County Road 67 (Main Ave. SW), in Warren, Trumbull County, Ohio.

In accordance with the provisions of Ohio Administrative Code (“OAC”) Rule 4906-1-01, this project falls within the Ohio Power Siting Board’s requirements for a Letter of Notification (“LON”). Therefore, in compliance with OAC 4906-11-01 of the OPSB’s Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be glad to answer your questions concerning this matter. You may contact me at ((330) 384-4564.

Sincerely,



John T. Toth
Supervisor, Siting
Energy Delivery Transmission and
Substation Design
FirstEnergy Service Company

Attachment

November 8, 2012

Ms. Terry Ambrose
Chairwoman, Warren Township Trustees
3765 W. Market Street
Leavittsburg, OH 44430

Letter of Notification
Evergreen – Niles 138 kV Transmission
Line Reconductor Project
Case No. 12- -EL-BLN


Dear Ms. Ambrose,

In the above captioned project, American Transmission Systems, Incorporated (“ATSI”), a subsidiary of FirstEnergy Corp., is proposing to reconductor approximately 3.07 miles of the Evergreen – Niles 138 kV Transmission Line. The transmission line will be reconducted with 795 ACSR 26/7. As part of the Project, four wood pole structures will be replaced with four two – pole wood structures and an additional four two – pole wood intermediate structures will be installed within the transmission line. The Project area is located near the intersection of Burnett East Road and County Road 67 (Main Ave. SW), in Warren, Trumbull County, Ohio.

In accordance with the provisions of Ohio Administrative Code (“OAC”) Rule 4906-1-01, this project falls within the Ohio Power Siting Board’s requirements for a Letter of Notification (“LON”). Therefore, in compliance with OAC 4906-11-01 of the OPSB’s Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be glad to answer your questions concerning this matter. You may contact me at ((330) 384-4564.

Sincerely,



John T. Toth
Supervisor, Siting
Energy Delivery Transmission and
Substation Design
FirstEnergy Service Company

Attachment

November 8, 2012

Ms. Kay Anderson
Vice Chairwoman, Warren Township Trustees
3765 W. Market Street
Leavittsburg, OH 44430

Letter of Notification
Evergreen – Niles 138 kV Transmission
Line Reconductor Project
Case No. 12- -EL-BLN


Dear Ms. Anderson,

In the above captioned project, American Transmission Systems, Incorporated (“ATSI”), a subsidiary of FirstEnergy Corp., is proposing to reconductor approximately 3.07 miles of the Evergreen – Niles 138 kV Transmission Line. The transmission line will be reconducted with 795 ACSR 26/7. As part of the Project, four wood pole structures will be replaced with four two – pole wood structures and an additional four two – pole wood intermediate structures will be installed within the transmission line. The Project area is located near the intersection of Burnett East Road and County Road 67 (Main Ave. SW), in Warren, Trumbull County, Ohio.

In accordance with the provisions of Ohio Administrative Code (“OAC”) Rule 4906-1-01, this project falls within the Ohio Power Siting Board’s requirements for a Letter of Notification (“LON”). Therefore, in compliance with OAC 4906-11-01 of the OPSB’s Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be glad to answer your questions concerning this matter. You may contact me at ((330) 384-4564.

Sincerely,



John T. Toth
Supervisor, Siting
Energy Delivery Transmission and
Substation Design
FirstEnergy Service Company

Attachment

November 8, 2012

Ms. Cheryl Ranttila Zaben
Warren Township Trustees
3765 W. Market Street
Leavittsburg, OH 44430

Letter of Notification
Evergreen – Niles 138 kV Transmission
Line Reconductor Project
Case No. 12- -EL-BLN

Dear Ms. Zaben,

In the above captioned project, American Transmission Systems, Incorporated (“ATSI”), a subsidiary of FirstEnergy Corp., is proposing to reconductor approximately 3.07 miles of the Evergreen – Niles 138 kV Transmission Line. The transmission line will be reconducted with 795 ACSR 26/7. As part of the Project, four wood pole structures will be replaced with four two – pole wood structures and an additional four two – pole wood intermediate structures will be installed within the transmission line. The Project area is located near the intersection of Burnett East Road and County Road 67 (Main Ave. SW), in Warren, Trumbull County, Ohio.

In accordance with the provisions of Ohio Administrative Code (“OAC”) Rule 4906-1-01, this project falls within the Ohio Power Siting Board’s requirements for a Letter of Notification (“LON”). Therefore, in compliance with OAC 4906-11-01 of the OPSB’s Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be glad to answer your questions concerning this matter. You may contact me at ((330) 384-4564.

Sincerely,



John T. Toth
Supervisor, Siting
Energy Delivery Transmission and
Substation Design
FirstEnergy Service Company

Attachment

November 8, 2012

Ms. Debra D'Orio
Fiscal Officer, Warren Township
3765 W. Market Street
Leavittsburg, OH 44430

Letter of Notification
Evergreen – Niles 138 kV Transmission
Line Reconductor Project
Case No. 12- -EL-BLN

Dear Ms. D'Orio,

In the above captioned project, American Transmission Systems, Incorporated ("ATSI"), a subsidiary of FirstEnergy Corp., is proposing to reconductor approximately 3.07 miles of the Evergreen – Niles 138 kV Transmission Line. The transmission line will be reconducted with 795 ACSR 26/7. As part of the Project, four wood pole structures will be replaced with four two – pole wood structures and an additional four two – pole wood intermediate structures will be installed within the transmission line. The Project area is located near the intersection of Burnett East Road and County Road 67 (Main Ave. SW), in Warren, Trumbull County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be glad to answer your questions concerning this matter. You may contact me at ((330) 384-4564.

Sincerely,

John T. Toth
Supervisor, Siting
Energy Delivery Transmission and
Substation Design
FirstEnergy Service Company

Attachment