

Case No. 13-0526-EL-REN
Kirkpatrick Residence
Staff Interrogatories – Initial Set

Question 1: Section B of the application is for facility owner information, the legal name of the facility owner representative appears to be for the aggregator/installer not the facility owner. The facility owner representative should be the facility owner unless the facility owner is a corporation or LLC. Does Kastle Solar own the facility? If not, please submit corrected information for section B.

Answer 1: The owner is Gary L Kirkpatrick, 721 W Springvalley-Paintersville Rd, Springvalley, OH 45370

Question 2: In Section G.2, you included the formula for the capacity factor instead of describing how the facility's output will be measured. Please include a detailed description of how the output of the facility is going to be measured and verified, including the configuration of the meter(s) and the meter type(s).

Answer 2: The system will be monitored by a revenue grade ITRON meter. They system will also be monitored by SMA web portal reporting system.

Question 3: In section I.1 the nameplate capacity is listed as 0.01428 MW. But in section G.1 you state the facility has forty eight 240W panels and twelve 225W panels . Since $(26 \times 230W) + (12 \times 225W) = 14,220W$ or 0.01422 MW. Is the nameplate capacity 0.01422 MW?

Answer 3: Nameplate capacity is 0.01422MW

This foregoing document was electronically filed with the Public Utilities

Commission of Ohio Docketing Information System on

3/13/2013 12:41:38 PM

in

Case No(s). 13-0526-EL-REN

Summary: Reply Interrogatories answer set one electronically filed by Mr. Mark C Wiley on behalf of Wiley, Mark C Mr.