

**Case No. 13-0387-EL-REN**  
**Holly James**  
**Staff Interrogatories – 2nd Set**

**Section A**

Question 1: In Section A of the application, according to Bing Maps, and Yahoo maps the facility street address and the facility latitude and longitude are 1.4 miles apart. Google Maps is unable to locate the facility address either. Please provide the correct facility street address and the facility latitude and longitude.

Answer 1:

I have used three different latitude/longitude tools and this address:

101 Summerfield Estates Dr  
Oakdale, PA

And have come up with the exact latitude and longitude listed on the application. I have found Google Maps to be missing too many addresses and use itouchmap.com for my address searches.

In this case, I also used worldatlast.com and stevemorse.org.

Question 2: In section I.1 the nameplate capacity is listed as 6.24 MW. But in section G.1 you state the facility has twenty four 260W panels. Since  $24 \times 260W = 6240W$  or 0.00624 MW. Is the nameplate capacity 0.00624 MW?

Answer 2: yes, the NPC is .00624

**This foregoing document was electronically filed with the Public Utilities**

**Commission of Ohio Docketing Information System on**

**3/18/2013 7:10:29 AM**

**in**

**Case No(s). 13-0387-EL-REN**

Summary: Reply in the matter of the application of Holly James for a renewable energy facility electronically filed by Mr. Gary Lakritz on behalf of Holly James