



5001 NASA Boulevard
Fairmont, WV 26554

August 5, 2013

**Ms. Barcy F. McNeal
Secretary
Docketing Division
The Public Utilities Commission of Ohio
180 East Broad Street
Columbus, OH 43215-3793**

RECEIVED-DOCKETING DIV
2013 AUG -6 PM 12:08
PUCO

Letter of Notification
Evergreen-Ivanhoe 138 kV Transmission Line
Tap to Ohio Star Forge Substation
Case No. 13-1746-EL-BLN

Dear Ms. McNeal:

In accordance with Rule 4906-11-01 of the Ohio Administrative Code, American Transmission Systems, Incorporated ("ATSI") and Ohio Edison Company ("Ohio Edison"), transmit one (1) original and eleven (11) copies of the enclosed Letter of Notification for the above captioned project. In this project, ATSI and Ohio Edison are proposing to install an approximately 219 foot long single circuit 138 kV transmission line tap to the new customer owned Ohio Star Forge Substation from the existing Evergreen-Ivanhoe 138 kV Transmission Line. As a part of installing the transmission line tap, one (1) new switch structure will be installed in the existing Evergreen-Ivanhoe 138 kV Transmission Line right-of-way to accommodate the new Ohio Star Forge 138 kV Transmission Line Tap. The transmission line tap and one (1) three pole dead end and one (1) three pole corner dead end structures will be placed in new right-of-way. The Project area is located west and south of the intersection of North River Road and Mohoning Avenue in the City of Warren, and Warren Township, Trumbull County, Ohio.

Please be advised of the following:

- | | |
|---------------------------------------|---|
| a) Name and address of the applicant: | <p>American Transmission Systems, Incorporated
 76 South Main Street
 Akron, Ohio 44308</p> <p>Ohio Edison, Incorporated
 76 South Main Street
 Akron, Ohio 44308</p> |
| b) Name of proposed facilities: | Evergreen-Ivanhoe 138 kV Transmission Line Tap to Ohio Star Forge Substation |


This is to certify that the images appearing are an accurate and complete reproduction of a case file document delivered in the regular course of business
Technician TM Date Processed AUG 06 2011

- c) Location of proposed facilities: The Project area is located west and south of the intersection of North River Road and Mahoning Avenue in the City of Warren, and Warren Township, Trumbull County, Ohio
- d) Description of proposed facilities: The Project involves installing an approximately 219 foot long single circuit 138 kV transmission line tap to the new customer owned Ohio Star Forge Substation from the existing Evergreen-Ivanhoe 138 kV Transmission Line. As a part of installing the transmission line tap, one (1) new switch structure will be installed in the existing Evergreen-Ivanhoe 138 kV Transmission Line right-of-way to accommodate the Ohio Star Forge 138 kV Transmission Line Tap. The transmission line tap and one (1) three pole dead end and one (1) three pole corner dead end structures will be placed in new right-of-way.
- e) Applicant's representative: Travis M. Turner, Engineer
Energy Delivery Transmission Engineering
FirstEnergy Service Company
5001 NASA Blvd.
Fairmont, WV 26554

After docketing this filing, please return one time-stamped copy of the Letter of Notification for our records to us in the enclosed envelope. We have provided a copy of the Letter of Notification by certified mail, with return receipt requested, to each official of the political subdivisions immediately affected by the proposed project as listed in the attached Exhibit 1. Copies of the transmittal letters addressed to the local government representatives of the City of Warren, Warren Township, and Trumbull County are enclosed for your file.

Should the Ohio Power Siting Board desire further information or discussion of this submittal, please contact me at (304) 534-7456.

Sincerely,



Travis M. Turner
Engineer
Energy Delivery Transmission and
Substation Design
FirstEnergy Service Company

Attachments

**EXHIBIT 1: OFFICIALS SERVED COPY OF LON
Evergreen-Ivanhoe 138 kV Transmission Line
Tap to Ohio Star Forge Substation
Case No. 13- -EL-BLN**

Trumbull County

The Honorable Frank S. Fuda
President, Trumbull County
Commissioner
160 High Street N.W.
Warren, OH 44481

Mr. Randy Smith, P.E., P.S.
Trumbull County Engineer
650 North River Road
N.W. Warren, OH 44483

The Honorable Daniel E. Polivka
Trumbull County Commissioner
160 High Street N.W.
Warren, OH 44481

Mr. Lewis Kostoff
Chairman, Trumbull County
Planning Commission
347 North Park Avenue
Warren, OH 44481

The Honorable Paul E. Heltzel
President, Trumbull County
Commissioner
160 High Street N.W.
Warren, OH 44481

Ms. Paulette A. Godfrey
County Clerk, Trumbull County
160 High Street N.W.
Warren, OH 44481

Warren Township

Ms. Ranttila Zaben
Chairwoman, Warren Township
Trustee
3765 W. Market Street
Leavittsburg, Ohio 44430

Ms. Kay Anderson
Warren Township Trustee
3765 W. Market Street
Leavittsburg, Ohio 44430

Ms. Terry Ambrose
Vice-Chairwoman, Warren Township
Trustee
3765 W. Market Street
Leavittsburg, Ohio 44430

Ms. Debra D'Orio
Fiscal Officer, Warren Township
3765 W. Market Street
Leavittsburg, Ohio 44430

City of Warren

The Honorable William Franklin
Mayor, City of Warren
391 Mahoning Avenue, N.W.
Warren, Ohio 44483

Mr. Robert L. Dean, Jr
President of Council, City of Warren
4110 Sunnybrook, S.E.
Warren, Ohio 44484

Ms. Brenda Smith
Clerk of Council, City of Warren
141 South Street, S.E.
Warren, Ohio 44483

Mr. Paul Makosky
Director of Engineering,
City of Warren
540 Laird Ave., S.E.
Warren, Ohio 44484

Mr. D.J. Sferra
Director, Planning and Zoning City of
Warren
540 Laird Avenue, S.E.
Warren, Ohio 44484

August 5, 2013

The Honorable Frank S. Fuda
President, Trumbull County Commissioner
160 High Street N.W.
Warren, OH 44481

Letter of Notification
Evergreen-Ivanhoe 138 kV Transmission Line
Tap to Ohio Star Forge Substation
Case No. 13-1749-EL-BLN


Dear Mr. Fuda,

In the above captioned project, American Transmission Systems, Incorporated ("ATSI") and Ohio Edison Company ("Ohio Edison"), FirstEnergy companies, are proposing to install an approximately 219 foot long single circuit 138 kV transmission line tap to the new customer owned Ohio Star Forge Substation. As a part of installing the transmission line tap, one (1) new switch structure will be installed in the existing Evergreen-Ivanhoe 138 kV Transmission Line right-of-way. The transmission line tap, one (1) three pole dead end, and one (1) three pole corner dead end structures will be placed in new right-of-way. The Project area is located west and south of the intersection of North River Road and Mohoning Avenue in the City of Warren and Warren Township, Trumbull County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be glad to answer your questions concerning this matter. You may contact me at (304) 534-7456.

Sincerely,



Travis M. Turner

Engineer

Energy Delivery Transmission and
Substation Design

FirstEnergy Service Company

Attachment

August 5, 2013

The Honorable Paul E. Heltzel
Trumbull County Commissioner
160 High Street N.W.
Warren, OH 44481

Letter of Notification
Evergreen-Ivanhoe 138 kV Transmission Line
Tap to Ohio Star Forge Substation
Case No. 13- -EL-BLN


Dear Mr. Heltzel,

In the above captioned project, American Transmission Systems, Incorporated ("ATSI") and Ohio Edison Company ("Ohio Edison"), FirstEnergy companies., are proposing to install an approximately 219 foot long single circuit 138 kV transmission line tap to the new customer owned Ohio Star Forge Substation. As a part of installing the transmission line tap, one (1) new switch structure will be installed in the existing Evergreen-Ivanhoe 138 kV Transmission Line right-of-way. The transmission line tap, one (1) three pole dead end, and one (1) three pole corner dead end structures will be placed in new right-of-way. The Project area is located west and south of the intersection of North River Road and Mohoning Avenue in the City of Warren and Warren Township, Trumbull County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be glad to answer your questions concerning this matter. You may contact me at (304) 534-7456.

Sincerely,



Travis M. Turner
Engineer
Energy Delivery Transmission and
Substation Design
FirstEnergy Service Company

Attachment

August 5, 2013

The Honorable Daniel E. Polivka
Trumbull County Commissioner
160 High Street N.W.
Warren, OH 44481

Letter of Notification
Evergreen-Ivanhoe 138 kV Transmission Line
Tap to Ohio Star Forge Substation
Case No. 13- -EL-BLN


Dear Mr. Polivka,

In the above captioned project, American Transmission Systems, Incorporated ("ATSI") and Ohio Edison Company ("Ohio Edison"), FirstEnergy companies., are proposing to install an approximately 219 foot long single circuit 138 kV transmission line tap to the new customer owned Ohio Star Forge Substation. As a part of installing the transmission line tap, one (1) new switch structure will be installed in the existing Evergreen-Ivanhoe 138 kV Transmission Line right-of-way. The transmission line tap, one (1) three pole dead end, and one (1) three pole corner dead end structures will be placed in new right-of-way. The Project area is located west and south of the intersection of North River Road and Mohoning Avenue in the City of Warren and Warren Township, Trumbull County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be glad to answer your questions concerning this matter. You may contact me at (304) 534-7456.

Sincerely,



Travis M. Turner
Engineer
Energy Delivery Transmission and
Substation Design
FirstEnergy Service Company

Attachment

August 5, 2013

Ms. Paulette A. Godfrey
County Clerk, Trumbull County
160 High Street N.W.
Warren, OH 44481

Letter of Notification
Evergreen-Ivanhoe 138 kV Transmission Line
Tap to Ohio Star Forge Substation
Case No. 13- -EL-BLN


Dear Ms. Godfrey,

In the above captioned project, American Transmission Systems, Incorporated ("ATSI") and Ohio Edison Company ("Ohio Edison"), FirstEnergy companies., are proposing to install an approximately 219 foot long single circuit 138 kV transmission line tap to the new customer owned Ohio Star Forge Substation. As a part of installing the transmission line tap, one (1) new switch structure will be installed in the existing Evergreen-Ivanhoe 138 kV Transmission Line right-of-way. The transmission line tap, one (1) three pole dead end, and one (1) three pole corner dead end structures will be placed in new right-of-way. The Project area is located west and south of the intersection of North River Road and Mohoning Avenue in the City of Warren and Warren Township, Trumbull County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be glad to answer your questions concerning this matter. You may contact me at (304) 534-7456.

Sincerely,



Travis M. Turner
Engineer
Energy Delivery Transmission and
Substation Design
FirstEnergy Service Company

Attachment

August 5, 2013

Mr. Lewis Kostoff
Chairman, Trumbull County
Planning Commission
347 North Park Avenue
Warren, OH 44481

Letter of Notification
Evergreen-Ivanhoe 138 kV Transmission Line
Tap to Ohio Star Forge Substation
Case No. 13- -EL-BLN

Dear Mr. Kostoff,

In the above captioned project, American Transmission Systems, Incorporated ("ATSI") and Ohio Edison Company ("Ohio Edison"), FirstEnergy companies., are proposing to install an approximately 219 foot long single circuit 138 kV transmission line tap to the new customer owned Ohio Star Forge Substation. As a part of installing the transmission line tap, one (1) new switch structure will be installed in the existing Evergreen-Ivanhoe 138 kV Transmission Line right-of-way. The transmission line tap, one (1) three pole dead end, and one (1) three pole corner dead end structures will be placed in new right-of-way. The Project area is located west and south of the intersection of North River Road and Mohoning Avenue in the City of Warren and Warren Township, Trumbull County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be glad to answer your questions concerning this matter. You may contact me at (304) 534-7456.

Sincerely,



Travis M. Turner
Engineer
Energy Delivery Transmission and
Substation Design
FirstEnergy Service Company

Attachment

August 5, 2013

Mr. Randy Smith, P.E., P.S.
Trumbull County Engineer
650 North River Road
N.W. Warren, OH 44483

Letter of Notification
Evergreen-Ivanhoe 138 kV Transmission Line
Tap to Ohio Star Forge Substation
Case No. 13- -EL-BLN


Dear Mr. Smith,

In the above captioned project, American Transmission Systems, Incorporated ("ATSI") and Ohio Edison Company ("Ohio Edison"), FirstEnergy companies, are proposing to install an approximately 219 foot long single circuit 138 kV transmission line tap to the new customer owned Ohio Star Forge Substation. As a part of installing the transmission line tap, one (1) new switch structure will be installed in the existing Evergreen-Ivanhoe 138 kV Transmission Line right-of-way. The transmission line tap, one (1) three pole dead end, and one (1) three pole corner dead end structures will be placed in new right-of-way. The Project area is located west and south of the intersection of North River Road and Mohoning Avenue in the City of Warren and Warren Township, Trumbull County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be glad to answer your questions concerning this matter. You may contact me at (304) 534-7456.

Sincerely,



Travis M. Turner
Engineer
Energy Delivery Transmission and
Substation Design
FirstEnergy Service Company

Attachment

August 5, 2013

Ms. Ranttila Zaben
Chairwoman, Warren Township Trustee
3765 W. Market Street
Leavittsburg, Ohio 44430

Letter of Notification
Evergreen-Ivanhoe 138 kV Transmission Line
Tap to Ohio Star Forge Substation
Case No. 13- -EL-BLN


Dear Ms. Zaben,

In the above captioned project, American Transmission Systems, Incorporated ("ATSI") and Ohio Edison Company ("Ohio Edison"), FirstEnergy companies, are proposing to install an approximately 219 foot long single circuit 138 kV transmission line tap to the new customer owned Ohio Star Forge Substation. As a part of installing the transmission line tap, one (1) new switch structure will be installed in the existing Evergreen-Ivanhoe 138 kV Transmission Line right-of-way. The transmission line tap, one (1) three pole dead end, and one (1) three pole corner dead end structures will be placed in new right-of-way. The Project area is located west and south of the intersection of North River Road and Mohoning Avenue in the City of Warren and Warren Township, Trumbull County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be glad to answer your questions concerning this matter. You may contact me at (304) 534-7456.

Sincerely,



Travis M. Turner
Engineer
Energy Delivery Transmission and
Substation Design
FirstEnergy Service Company

Attachment

August 5, 2013

Ms. Terry Ambrose
Vice-Chairwoman, Warren Township Trustee
3765 W. Market Street
Leavittsburg, Ohio 44430

Letter of Notification
Evergreen-Ivanhoe 138 kV Transmission Line
Tap to Ohio Star Forge Substation
Case No. 13- -EL-BLN


Dear Ms. Ambrose,

In the above captioned project, American Transmission Systems, Incorporated ("ATSI") and Ohio Edison Company ("Ohio Edison"), FirstEnergy companies, are proposing to install an approximately 219 foot long single circuit 138 kV transmission line tap to the new customer owned Ohio Star Forge Substation. As a part of installing the transmission line tap, one (1) new switch structure will be installed in the existing Evergreen-Ivanhoe 138 kV Transmission Line right-of-way. The transmission line tap, one (1) three pole dead end, and one (1) three pole corner dead end structures will be placed in new right-of-way. The Project area is located west and south of the intersection of North River Road and Mohoning Avenue in the City of Warren and Warren Township, Trumbull County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be glad to answer your questions concerning this matter. You may contact me at (304) 534-7456.

Sincerely,



Travis M. Turner
Engineer
Energy Delivery Transmission and
Substation Design
FirstEnergy Service Company

Attachment

August 5, 2013

Ms. Kay Anderson
Warren Township Trustee
3765 W. Market Street
Leavittsburg, Ohio 44430

Letter of Notification
Evergreen-Ivanhoe 138 kV Transmission Line
Tap to Ohio Star Forge Substation
Case No. 13- -EL-BLN


Dear Ms. Anderson,

In the above captioned project, American Transmission Systems, Incorporated ("ATSI") and Ohio Edison Company ("Ohio Edison"), FirstEnergy companies., are proposing to install an approximately 219 foot long single circuit 138 kV transmission line tap to the new customer owned Ohio Star Forge Substation. As a part of installing the transmission line tap, one (1) new switch structure will be installed in the existing Evergreen-Ivanhoe 138 kV Transmission Line right-of-way. The transmission line tap, one (1) three pole dead end, and one (1) three pole corner dead end structures will be placed in new right-of-way. The Project area is located west and south of the intersection of North River Road and Mohoning Avenue in the City of Warren and Warren Township, Trumbull County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be glad to answer your questions concerning this matter. You may contact me at (304) 534-7456.

Sincerely,



Travis M. Turner
Engineer
Energy Delivery Transmission and
Substation Design
FirstEnergy Service Company

Attachment

August 5, 2013

Ms. Debra D'Orio
Fiscal Officer, Warren Township
3765 W. Market Street
Leavittsburg, Ohio 44430

Letter of Notification
Evergreen-Ivanhoe 138 kV Transmission Line
Tap to Ohio Star Forge Substation
Case No. 13- -EL-BLN


Dear Ms. D'Orio,

In the above captioned project, American Transmission Systems, Incorporated ("ATSI") and Ohio Edison Company ("Ohio Edison"), FirstEnergy companies, are proposing to install an approximately 219 foot long single circuit 138 kV transmission line tap to the new customer owned Ohio Star Forge Substation. As a part of installing the transmission line tap, one (1) new switch structure will be installed in the existing Evergreen-Ivanhoe 138 kV Transmission Line right-of-way. The transmission line tap, one (1) three pole dead end, and one (1) three pole corner dead end structures will be placed in new right-of-way. The Project area is located west and south of the intersection of North River Road and Mohoning Avenue in the City of Warren and Warren Township, Trumbull County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be glad to answer your questions concerning this matter. You may contact me at (304) 534-7456.

Sincerely,



Travis M. Turner
Engineer
Energy Delivery Transmission and
Substation Design
FirstEnergy Service Company

Attachment

August 5, 2013

The Honorable William Franklin
Mayor, City of Warren
391 Mahoning Avenue, N.W.
Warren, Ohio 44483

Letter of Notification
Evergreen-Ivanhoe 138 kV Transmission Line
Tap to Ohio Star Forge Substation
Case No. 13- -EL-BLN


Dear Mayor Franklin,

In the above captioned project, American Transmission Systems, Incorporated ("ATSI") and Ohio Edison Company ("Ohio Edison"), FirstEnergy companies, are proposing to install an approximately 219 foot long single circuit 138 kV transmission line tap to the new customer owned Ohio Star Forge Substation. As a part of installing the transmission line tap, one (1) new switch structure will be installed in the existing Evergreen-Ivanhoe 138 kV Transmission Line right-of-way. The transmission line tap, one (1) three pole dead end, and one (1) three pole corner dead end structures will be placed in new right-of-way. The Project area is located west and south of the intersection of North River Road and Mahoning Avenue in the City of Warren and Warren Township, Trumbull County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be glad to answer your questions concerning this matter. You may contact me at (304) 534-7456.

Sincerely,



Travis M. Turner
Engineer
Energy Delivery Transmission and
Substation Design
FirstEnergy Service Company

Attachment

August 5, 2013

Mr. Robert L. Dean, Jr
President of Council, City of Warren
4110 Sunnybrook, S.E.
Warren, Ohio 44484

Letter of Notification
Evergreen-Ivanhoe 138 kV Transmission Line
Tap to Ohio Star Forge Substation
Case No. 13- -EL-BLN


Dear Mr. Dean,

In the above captioned project, American Transmission Systems, Incorporated ("ATSI") and Ohio Edison Company ("Ohio Edison"), FirstEnergy companies., are proposing to install an approximately 219 foot long single circuit 138 kV transmission line tap to the new customer owned Ohio Star Forge Substation. As a part of installing the transmission line tap, one (1) new switch structure will be installed in the existing Evergreen-Ivanhoe 138 kV Transmission Line right-of-way. The transmission line tap, one (1) three pole dead end, and one (1) three pole corner dead end structures will be placed in new right-of-way. The Project area is located west and south of the intersection of North River Road and Mohoning Avenue in the City of Warren and Warren Township, Trumbull County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be glad to answer your questions concerning this matter. You may contact me at (304) 534-7456.

Sincerely,



Travis M. Turner
Engineer
Energy Delivery Transmission and
Substation Design
FirstEnergy Service Company

Attachment

August 5, 2013

Mr. D.J. Sferra
Director, Planning and Zoning City of Warren
540 Laird Avenue, S.E.
Warren, Ohio 44484

Letter of Notification
Evergreen-Ivanhoe 138 kV Transmission Line
Tap to Ohio Star Forge Substation
Case No. 13- -EL-BLN


Dear Mr. Sferra,

In the above captioned project, American Transmission Systems, Incorporated ("ATSI") and Ohio Edison Company ("Ohio Edison"), FirstEnergy companies., are proposing to install an approximately 219 foot long single circuit 138 kV transmission line tap to the new customer owned Ohio Star Forge Substation. As a part of installing the transmission line tap, one (1) new switch structure will be installed in the existing Evergreen-Ivanhoe 138 kV Transmission Line right-of-way. The transmission line tap, one (1) three pole dead end, and one (1) three pole corner dead end structures will be placed in new right-of-way. The Project area is located west and south of the intersection of North River Road and Mohoning Avenue in the City of Warren and Warren Township, Trumbull County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be glad to answer your questions concerning this matter. You may contact me at (304) 534-7456.

Sincerely,



Travis M. Turner
Engineer
Energy Delivery Transmission and
Substation Design
FirstEnergy Service Company

Attachment

August 5, 2013

Ms. Brenda Smith
Clerk of Council, City of Warren
141 South Street, S.E.
Warren, Ohio 44483

Letter of Notification
Evergreen-Ivanhoe 138 kV Transmission Line
Tap to Ohio Star Forge Substation
Case No. 13- -EL-BLN


Dear Ms. Smith,

In the above captioned project, American Transmission Systems, Incorporated ("ATSI") and Ohio Edison Company ("Ohio Edison"), FirstEnergy companies., are proposing to install an approximately 219 foot long single circuit 138 kV transmission line tap to the new customer owned Ohio Star Forge Substation. As a part of installing the transmission line tap, one (1) new switch structure will be installed in the existing Evergreen-Ivanhoe 138 kV Transmission Line right-of-way. The transmission line tap, one (1) three pole dead end, and one (1) three pole corner dead end structures will be placed in new right-of-way. The Project area is located west and south of the intersection of North River Road and Mohoning Avenue in the City of Warren and Warren Township, Trumbull County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be glad to answer your questions concerning this matter. You may contact me at (304) 534-7456.

Sincerely,



Travis M. Turner
Engineer
Energy Delivery Transmission and
Substation Design
FirstEnergy Service Company

Attachment

August 5, 2013

Mr. Paul Makosky
Director of Engineering, City of Warren
540 Laird Ave., S.E.
Warren, Ohio 44484

Letter of Notification
Evergreen-Ivanhoe 138 kV Transmission Line
Tap to Ohio Star Forge Substation
Case No. 13- -EL-BLN


Dear Mr. Makosky,

In the above captioned project, American Transmission Systems, Incorporated ("ATSI") and Ohio Edison Company ("Ohio Edison"), FirstEnergy companies, are proposing to install an approximately 219 foot long single circuit 138 kV transmission line tap to the new customer owned Ohio Star Forge Substation. As a part of installing the transmission line tap, one (1) new switch structure will be installed in the existing Evergreen-Ivanhoe 138 kV Transmission Line right-of-way. The transmission line tap, one (1) three pole dead end, and one (1) three pole corner dead end structures will be placed in new right-of-way. The Project area is located west and south of the intersection of North River Road and Mohoning Avenue in the City of Warren and Warren Township, Trumbull County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be glad to answer your questions concerning this matter. You may contact me at (304) 534-7456.

Sincerely,



Travis M. Turner
Engineer
Energy Delivery Transmission and
Substation Design
FirstEnergy Service Company

Attachment