

Case No. 13-1412-EL-REN
Abbott, Dan Residence - D. Abbott
Staff Interrogatory – Initial Set

Question 1: Section N1 lists the meter as a Schlumberger J5S. According to our data, this meter does not meet ANSI 12.1 requirements. If the meter has been refurbished, please submit documentation that proves this meter meets ANSI 12.1 (i.e. demonstrates an accuracy level of $\pm 2\%$).

Answer 1: **This is a Schlumberger CL200 240V 3W type J5S utility grade meter. It says on the meter that it is $\pm 0.3\%$. Does this not suffice?**

Section N:

Manufacturer: Schlumberger

Serial Number: 74 512 793

Type: J5S

Date of last certification: 6/14/2012

Question 2: In section N.1.e, the meter reading does not match the reading from the photo that you submitted. Please submit a dated photo of the meter in which the meter reading is clearly visible or insert documentation from the remote monitoring and reporting system.



Please let me know if you have any other questions.

Best regards,

Alisa Hobdy

SRECTrade

Telephone: [\(757\) 598-1553](tel:7575981553)

Fax: [\(732\) 453-0065](tel:7324530065)

Email: alisa.hobdy@srectrade.com

This foregoing document was electronically filed with the Public Utilities

Commission of Ohio Docketing Information System on

8/28/2013 4:49:00 PM

in

Case No(s). 13-1412-EL-REN

Summary: Memorandum Additional information about meter; photo included electronically
filed by Mr. Brad Bowery on behalf of Mr. Dan Abbott