

**Case No. 14-0248-EL-REN**  
**AB Martin Garden Spot R**  
**Staff Interrogatories – Initial Set**

Question 1: In section I.1 the nameplate capacity is listed as 0.1075 MW. But in section G.1 you state the facility has 385 280W panels. Since  $385 \times 280W = 107,800W$  or 0.1078 MW. Is the nameplate capacity 0.1078 MW?

Answer 1: The nameplate capacity for this facility is 0.01078.

**This foregoing document was electronically filed with the Public Utilities**

**Commission of Ohio Docketing Information System on**

**4/3/2014 7:34:49 PM**

**in**

**Case No(s). 14-0248-EL-REN**

Summary: Reply in the matter of the NPC error for the AB Martin Garden Spot Rd renewable energy facility electronically filed by Mr. Gary Lakritz on behalf of AB Martin Garden Spot Rd