

Attachment B: Electric and Magnetic Field Study



MEMORANDUM

DATE: March 7, 2014

TO: Andrew S. Degon
Director, Engineering and Construction
Advanced Power
31 Milk Street, Suite 1001
Boston, MA 02109

c: Steve Walker (POWER-FRE), Jon Ferguson (POWER-FTW)
Tyler Kent (POWER-SYR), DMS SR-06/133424.001.001

FROM: Andrea Wood

SUBJECT: 140203 Advanced Power – Carroll County Energy 345 kV Preliminary
EMF Study, Rev. B

MESSAGE

Dear Mr. Degon,

This memorandum provides the predicted electric and magnetic field (EMF) effects for the Advanced Power Carroll County Energy proposed 345 kV double circuit transmission line. In addition, it also provides the predicted EMF effects of the existing AEP Tidd-Canton Central 345 kV single transmission line for comparison.

POWER's engineering service for this study was to analyze the electric and magnetic fields for the proposed structure using a two conductor bundle 954 Rail ACSR conductor and for the existing structure using a two conductor bundle of 954 Cardinal ACSR conductor. The field calculations were performed at mid-span with a minimum clearance of 28 feet. The study was performed using version 3.0 of the Bonneville Power Administration's Corona and Field Effects Program.


Proposed 345 kV Double Circuit Line

A study was performed on the proposed conductor to estimate electric and magnetic fields at one meter above ground level for standard 345 kV single pole double circuit steel tangent structures with loading of 3,000 amps per phase and an operating voltage of 105% of nominal (see structure drawing in Appendix A). In order to produce conservative results the phase configuration of both circuits were assumed to be A phase on the top, B phase in the middle, C phase on the bottom.

The field results are summarized in Table 1 compared against the maximum permissible exposure (MPE) limit of IEEE C95.6-2002. Plots of the results throughout the Right-of-Way can be found in Figure 1 and Figure 2.

Table 1: Maximum Calculated EMF Levels on the Edge of ROW and within the ROW of the proposed double circuit line

Effect:	IEEE MPE Limit for General Public Edge of ROW	Calculated Value Edge of ROW	IEEE MPE Limit for General Public within ROW	Maximum Calculated Value Within ROW
Electric Fields (kV/m)	5.0 kV/m	0.158 kV/m	10.0 kV/m	8.8 kV/m
Magnetic Fields (mG)	9,040 mG	218.9 mG	9,040 mG	586.2 mG

**Figure 1: Electric Field within the ROW (Proposed 345 kV line)**




Figure 2: Magnetic Field within the ROW (Proposed 345 kV line)

Existing AEP 345 kV Single Circuit Line

A comparison study was performed on the existing electric and magnetic fields at one meter above ground level for the standard 345 kV single pole single circuit steel horizontal structures with a maximum summer emergency loading of 2,675 amps and an operating voltage of 105% of nominal (see structure drawing in Appendix B).

The field effects results are summarized in Table 2 compared against the maximum permissible exposure (MPE) limit of IEEE C95.6-2002. Plots of the results throughout the Right-of-Way can be found in Figure 3 and Figure 4.

Table 2: Maximum Calculated EMF Levels on the Edge-of-ROW and within the ROW of the existing AEP single circuit line				
Effect:	IEEE MPE Limit for General Public Edge of ROW	Calculated Value Edge of ROW	IEEE MPE Limit for General Public within ROW	Maximum Calculated Value Edge of ROW
Electric Fields (kV/m)	5.0 kV/m	2.3 kV/m	10.0 kV/m	7.6 kV/m
Magnetic Fields (mG)	9,040 mG	202.4 mG	9,040 mG	670.1 mG




Figure 3: Electric Field within the ROW (Existing 345 kV line)





Figure 4: Magnetic Field within the ROW (Existing 345 kV line)

Conclusion


It was found for the two conductor bundle 954 Rail ACSR conductor the predicted electric and magnetic fields levels are below the IEEE Standard C95.6-2002 maximum permissible exposure limits for the general public within and at the edge-of-ROW. In addition, the maximum predicted values are also found to be similar to the existing 345 kV line conditions. To accomplish the cut-in of the existing line, the existing horizontal configuration transforms to a vertical configuration at the dead-end cut-in structures. Since, for the same ampacity and lowest conductor height above ground, a vertical line configuration along the ROW centerline will have a lower magnetic field when measured at one meter above ground at the edge of the ROW than a horizontal configuration, it is reasonable to state that the magnetic field one meter above ground at the edge of the ROW is lowered as the line transitions from horizontal to vertical than it is within the existing (current) horizontal spans. The results presented in this memorandum should be re-verified if the structure geometries, minimum line clearance or loading conditions are modified.

Thank you,

A handwritten signature in cursive script that reads "Andrea Wood". The signature is written in dark ink and is positioned above the printed name.





Andrea Wood

APPENDIX A – STRUCTURE DRAWING PROPOSED DOUBLE CIRCUIT 345 KV LINE



CROSS ARM INFORMATION				
ARM	LENGTH "AL" (FT)	RISE "AR" (FT)	WIRE ATTACHMENT	POLE STANDARD DETAIL
G1, G2	13'-0"	TBD	G.W. ATTACHMENT DETAIL	0105-1216-SHT.2
C1 THRU C6	17'-0"	TBD	CONDUCTOR ATTACHMENT DETAIL	0105-1216-SHT.1

"TBD" - to be determined by Vendor



CONDUCTOR CLEARANCE INFORMATION		
INSULATOR LENGTH "IL" =	13'-6 1/4"	LIMITING SIDESWING ANGLES
		FIXED α ACTIVE β
FLEXIBLE HANGER LENGTH "HL" =	1'-0"	18.0° 45.0°
CLEARANCE REQD. TO ARM & STRUCTURE =		
NOTE: REFER TO DRAWING 0105-1216-SHT.1		

- NOTES:
- 1) This structure is intended to be used in a line angle range of 0° to 2°. This range may or may not be valid and will depend on satisfying clearance checks where influencing factors include wind span, weight span, and line angle.
 - 2) The shake loading for this structure has been verified for an 1100' galloping check. The design engineer will need to recheck galloping if a span greater than 1100' is used.
 - 3) Refer to drawing 002-1208-SHT.1 for structure clearances.

HEAVY SUSPENSION STRUCTURE: R8VDC

NO.		DESCRIPTION	WIND (PSF)	ICE (IN.)	ULTIMATE LOAD (KIPS)												STRUCTURE WIND PRESSURE (PSF)	ALLOWABLE DEFLECTION (INCHES) (% OF POLE HEIGHT)
					G1	G2	C1	C2	C3	C4	C5	C6	C7	C8	C9	C10		
1	INTACT	NESC HEAVY 0° F Includes OLF	4.0	0.50	V 3.29 T 2.39 L 0.00	3.29 2.39 0.00	11.59 6.49 0.00	11.59 6.49 0.00	11.59 6.49 0.00	11.59 6.49 0.00	11.59 6.49 0.00	11.59 6.49 0.00	11.59 6.49 0.00	11.59 6.49 0.00	11.59 6.49 0.00	11.59 6.49 0.00	10	10
2	INTACT	NESC MEDIUM 15° F Includes OLF	4.0	0.25	V 2.20 T 1.68 L 0.00	2.20 1.68 0.00	8.54 5.02 0.00	8.54 5.02 0.00	8.54 5.02 0.00	8.54 5.02 0.00	8.54 5.02 0.00	8.54 5.02 0.00	8.54 5.02 0.00	8.54 5.02 0.00	8.54 5.02 0.00	8.54 5.02 0.00	10	10
3	INTACT	HIGH WIND 60° F	28.0	NONE	V 1.01 T 2.31 L 0.00	1.01 2.31 0.00	4.21 8.65 0.00	4.21 8.65 0.00	4.21 8.65 0.00	4.21 8.65 0.00	4.21 8.65 0.00	4.21 8.65 0.00	4.21 8.65 0.00	4.21 8.65 0.00	4.21 8.65 0.00	4.21 8.65 0.00	37	10
4	INTACT	WIND & ICE 0° F	6.25	1.0	V 4.45 T 2.35 L 0.00	4.45 2.35 0.00	13.38 5.80 0.00	13.38 5.80 0.00	13.38 5.80 0.00	13.38 5.80 0.00	13.38 5.80 0.00	13.38 5.80 0.00	13.38 5.80 0.00	13.38 5.80 0.00	13.38 5.80 0.00	13.38 5.80 0.00	10	10
5	INTACT	HEAVY ICE 60° F	NONE	1.25	V 5.96 T 0.48 L 0.00	5.96 0.48 0.00	16.98 1.27 0.00	16.98 1.27 0.00	16.98 1.27 0.00	16.98 1.27 0.00	16.98 1.27 0.00	16.98 1.27 0.00	16.98 1.27 0.00	16.98 1.27 0.00	16.98 1.27 0.00	16.98 1.27 0.00	0	10
6	BROKEN GW	0° F ANY ONE WIRE	12.25	NONE	V 1.01 T 0.85 L 4.33	1.01 0.85 0.00	4.21 4.00 0.00	4.21 4.00 0.00	4.21 4.00 0.00	4.21 4.00 0.00	4.21 4.00 0.00	4.21 4.00 0.00	4.21 4.00 0.00	4.21 4.00 0.00	4.21 4.00 0.00	4.21 4.00 0.00	17	10
7	BROKEN BUNDLED COND.	60° F	NONE	NONE	V 1.01 T 0.11 L 0.00	1.01 0.11 0.00	4.21 0.20 8.68	4.21 0.39 0.00	4.21 0.39 0.00	4.21 0.39 0.00	4.21 0.39 0.00	4.21 0.39 0.00	4.21 0.39 0.00	4.21 0.39 0.00	4.21 0.39 0.00	4.21 0.39 0.00	0	10
8	UNBALANCED ICE WITH WIND	ONE SPAN BARE OTHER ICE 0° F	6.25	0.5/NONE	V 1.61 T 1.04 L 1.00	1.61 1.04 1.00	5.98 3.11 4.88	5.98 3.11 4.88	5.98 3.11 4.88	5.98 3.11 4.88	5.98 3.11 4.88	5.98 3.11 4.88	5.98 3.11 4.88	5.98 3.11 4.88	5.98 3.11 4.88	5.98 3.11 4.88	10	10
9	DEFLECTION	60° F	1.0	NONE	V 1.01 T 0.19 L 0.00	1.01 0.19 0.00	4.21 0.67 0.00	4.21 0.67 0.00	4.21 0.67 0.00	4.21 0.67 0.00	4.21 0.67 0.00	4.21 0.67 0.00	4.21 0.67 0.00	4.21 0.67 0.00	4.21 0.67 0.00	4.21 0.67 0.00	2.0	1.5
10					V 0.00 T 0.00 L 0.00	0.00 0.00 0.00	0.00 0.00 0.00	0.00 0.00 0.00	0.00 0.00 0.00	0.00 0.00 0.00	0.00 0.00 0.00	0.00 0.00 0.00	0.00 0.00 0.00	0.00 0.00 0.00	0.00 0.00 0.00	0.00 0.00 0.00	0	0

WIRE			NESC HEAVY TENSION (LBS)	NESC MEDIUM TENSION (LBS)	RULING SPAN (FT)	VERTICAL SPAN (FT)	WIND SPAN (FT)	LINE ANGLE
G	OPGW - 0.646 Dia. Wt = 0.578	AHEAD	8070 PER WIRE	5950 PER WIRE	1100	1680	1400	0° 2°
C	2 - 954,000 ACSR, 54/7 Cardinal	AHEAD	11900 PER WIRE	9250 PER WIRE	1100	1680	1400	0° 2°

POLE ATTACHMENTS FURNISHED BY VENDOR				
ITEM	POLE STANDARD DETAIL	LOCATION	REFERENCE POINT	ORIENTATION
POLE CAP	0104-1158 DETAIL A	0.0'	TOP OF POLE	AS NOTED
HAND HOLD (TOP)	0100-1159	0.35'	TOP OF POLE	FLATS 6, 12
HAND HOLD (OTHER)	0103-1155	2.0'	ABOVE TOP OF CROSSARM BRACKET	FLATS 6, 12
BAIL STEPS	0100-1159	4.0'	BELOW HAND HOLD	FLATS 6, 12
MAINTENANCE VANGS	0100-1272	0.25'	BELOW CROSSARM BRACKET	FLATS 4, 10
LADDER CLIPS	0100-1159	AS NOTED	AS NOTED	AS NOTED
GROUND LUGS	0101-1163	AS NOTED	AS NOTED	AS NOTED
GROUND PAD	0104-1125	1.5'	ABOVE REVEAL BASE PLATE OR AS NOTED	FLATS 1, 7
NAME PLATE	0104-1133	3.5'	ABOVE GROUND LINE	FLAT 1
ANCHOR BOLT ASS'Y.	0101-1165	AS NOTED	BASE PLATE	
DIRECT EMBEDDED	0101-1160 OR 0103-1180	AS NOTED	BOTTOM OF POLE	
STEEL POLE NOTES	0105-1179			

POLE ATTACHMENTS FURNISHED BY AEP				
ITEM	POLE STANDARD DETAIL	LOCATION	REFERENCE POINT	ORIENTATION
AERIAL PATROL SIGN	70A0-1163	0.5'	TOP OF POLE	FLATS 1, 7
DANGER SIGN	70A0-1164	11.0'	ABOVE GROUND LINE	FLATS 1, 7
McGREGOR LADDER	0100-1159 0100-1165 0100-1161	AS NOTED	AS NOTED	FLATS 1, 7

APPENDIX B – STRUCTURE DRAWING EXISTING AEP 345 KV SINGLE CIRCUIT LINE

MEDIUM SUSPENSION GUYED V-TYPE VITA

THIS TOWER IS DESIGNED TO SUPPORT 2 GROUNDWIRES OF 7 #8 ALUMINUM WELD (3/8") WIRE AND 3 BUNDLES OF 2 EACH 954000 CM² 54 ACSR CONDUCTORS ON A MAXIMUM TANGENT SPAN OF 2010', OR AT AN ANGLE IN LINE OF 3' WITH A SPAN OF 955', OR ANY COMBINATION OF ANGLE AND SPAN NOT EXCEEDING THE LOADS SHOWN BELOW.

THE CABLES ARE ASSUMED TO BE SO STRUNG THAT THE MAXIMUM TENSION WILL NOT EXCEED 6400# FOR EACH GROUNDWIRE AND 7400# FOR EACH BUNDLE OF 2 CONDUCTORS.

TOWER LOADING IS BASED ON A CONDITION OF 12" WIND ON BARE CABLES AND THE ABOVE MAXIMUM TENSIONS FOR ANGLE LOADS. VERTICAL LOADS ARE ASSUMED FOR BARE CONDUCTORS ON 1.5 TIMES THE MAXIMUM TANGENT SPAN. HEAVY VERTICAL LOADS ARE CALCULATED ON A BASIS OF 3/4" RADIAL COATING OF ICE ON ALL CONDUCTORS ON 1.5 TIMES THE MAXIMUM TANGENT SPAN.

THE LONGITUDINAL LOADING IS BASED ON A CONDITION OF 1/2" RADIAL ICE, 0°F, NO WIND ON ONE SPAN AND NO ICE @ 0°F, NO WIND ON AN ADJACENT SPAN (DIFFERENTIAL ICE LOAD)

LOADS

1) VERTICAL

2 GROUNDWIRES @ 800# = 1600#
3 BUNDLES OF 2 CONDUCTORS @ 7450# = 22350# 23950#

2) TRANSVERSE

2 GROUNDWIRES @ 1040# = 2080#
3 BUNDLES OF 2 CONDUCTORS @ 4800# = 14400# 16480#

3) LONGITUDINAL (DIFFERENTIAL ICE LOAD)

2 GROUNDWIRES @ 2000# = 4000#
3 BUNDLES OF 2 CONDUCTORS @ 5780# = 17340# 21340#

4) TORSIONAL

1 BUNDLE OF 2 CONDUCTORS @ 6725#

5) WIND ON TOWER OF 13 3/4" x 1 1/2" FACES.

6) DEAD LOAD OF TOWER



7) HEAVY VERTICAL

2 GROUNDWIRES @ 4000# = 8000#
3 BUNDLES OF 2 CONDUCTORS @ 18400# = 55200# 63200#

COMBINE:


(1, 2, 54 G) x 1.9
(1, 3, 2, 3, 54 G) x 1.5
(1, 3, 2, 4, 54 G) x 1.5
(7) x 1.5
(1/2 of 5) x G.C. (N.E.S.C. WIND ON TOWER)

FOR ULTIMATE UNIT STRESSES, MAT'L, COATING, CONNECTIONS & SPECIFICATIONS, SEE A.B.D. DWG. NPT-10347
NOTE: EXTENSIONS TO POSTS TO BE BUTT SPICED.



SECTION B-B

THIS PRINT AND THE DESIGNS SHOWN HEREON ARE THE EXCLUSIVE PROPERTY OF AMERICAN BRIDGE DIVISION, UNITED STATES STEEL CORPORATION, AND ARE LOANED IN CONFIDENCE WITH THE UNDERSTANDING THAT THEY MUST NOT BE REPRODUCED OR THE INFORMATION CONTAINED HEREIN DIVULGED IN ANY MANNER. THESE DRAWINGS SHALL BE USED ONLY AS A MEANS OF REFERENCE TO WORK DESIGNED OR FURNISHED BY AMERICAN BRIDGE DIVISION.



AMERICAN ELECTRIC POWER SERVICE CORP.
345KV SINGLE CIRCUIT TRANSMISSION LINE
MEDIUM SUSPENSION GUYED V-TYPE VITA
AMERICAN BRIDGE
UNITED STATES STEEL CORP.

TOWER DEPARTMENT

DRAWING NO. T-10348

INQUIRY NO. T-9522

DATE: 4-10-61

CONTRACT NO.

This foregoing document was electronically filed with the Public Utilities

Commission of Ohio Docketing Information System on

4/17/2014 3:52:31 PM

in

Case No(s). 14-0591-EL-BLN

Summary: Exhibit (Attachment B) electronically filed by Mr. Michael J. Settineri on behalf of Carroll County Energy LLC