

April 29, 2014

**Case No. 14-0462-EL-REN  
Hunt 1192  
Staff Interrogatories – Initial Set**

**Question 1:** In Section G.4 of the application, you have submitted the following:

**G.4b Total number of Modules:** 14

However the photograph of the facility submitted under Section G.3 shows more than 14 modules. Please clarify the number of modules and submit additional photographs if necessary.

**Answer 1:** The total number of modules is 34.





**Question 2:** In Section G.4.1 of the application, you have submitted the following:

**G.4.1.a Manufacturer:** Solarworld

**G.4.1.b Model and Rating:** SW 230 and SW 255 & 230/255

Please clarify how many panels have a rating of 230W and how many of 255W, and confirm the nameplate capacity of the entire facility submitted (8.42kW) in Section I.a.

**Answer 2:** 14 modules at a power rating of 230 watts, and 20 modules at a power rating of 255 watts.

Please let me know if you have any further questions and thank you for your cooperation.

Best,

Anna Nocas  
Senior Associate  
Sol Systems, LLC

**This foregoing document was electronically filed with the Public Utilities**

**Commission of Ohio Docketing Information System on**

**4/30/2014 6:55:31 PM**

**in**

**Case No(s). 14-0462-EL-REN**

Summary: Reply reply to staff interrogatory electronically filed by Ms. Anna Noucas on behalf of Hunt, Stephen