

FILE



76 South Main Street
Akron, Ohio 44308

1-800-646-0400

May 9, 2014

Mr. Jim O'Dell
Facilities, Siting & Environmental Analysis Division
Ohio Power Siting Board
Public Utilities Commission of Ohio
180 East Broad Street
Columbus, OH 43215-3793

Cloverdale-Harmon #2 69 kV Transmission Line Construction Project
Engineering Change
Case No. 14-0108-EL-BNR

Dear Mr. O'Dell:

This letter will serve as notice of an engineering design change that is being submitted in Case No. 14-0108-EL-BNR, the Cloverdale-Harmon #2 69 kV Transmission Line Construction Project ("Project"). Based upon the final engineering design of the Project, the conductor that will be installed in the Project has been revised from the 477 kcmil ACSR conductor described in the Construction Notice to 795 kcmil ACSS/TW/HS285 conductor. This minor engineering change does not result in a change or other affects to the transmission line structures and other features of the Project.

Should the Ohio Power Siting Board desire further information or discussion of this submittal, please contact me at (330) 761-4268.

Sincerely,

Ted Krauss
Manager Siting, Survey and Right-of-way
Transmission and Substation Design
FirstEnergy Service Company

RECEIVED-SOCKETING DIV

2014 MAY 16 AM 10:14

PUCO

This is to certify that the images appearing are an accurate and complete reproduction of a case file document delivered in the regular course of business
Technician Ann Date Processed 5/16/14