



June 30, 2014

**Case No. 14-0927-EL-REN
Ursu-John-OH-PV-5.67kW Residence
Staff Interrogatories – Initial Set**

Question 1: The nameplate capacity provided in section I.a of the application is 5.67 kW, but the calculated capacity based on the values in section G.4 would be 22 modules * 250 watts per module = 5.5 kW. Please explain.

Answer 1: The nameplate capacity should be 5.5 kW. Please change.

Please let me know if you have any further questions and thank you for your cooperation.

Best,

Anna Nocas
Senior Associate
Sol Systems, LLC

This foregoing document was electronically filed with the Public Utilities

Commission of Ohio Docketing Information System on

6/30/2014 12:16:00 PM

in

Case No(s). 14-0927-EL-REN

Summary: Reply reply to staff interrogatory electronically filed by Ms. Anna Noucas on behalf of Ursu, John