



August 29, 2014

**Case No. 14-1388-EL-REN  
Woodworth-Larry-PA-PV-9.36kW Residence  
Staff Interrogatories – Initial Set**

This is with regard to PUCO Case No. 14-1388-EL-REN (Woodworth-Larry-PA-PV-9.36kW Residence).

**Section J:**

Section "J" says that the facility is located within the geographic area of Midwest ISO. According to PJM's website the facility is located within the geographic area of PJM Interconnection L.L.C. Can you confirm this information and file it in the docking system?

**Answer:** This facility is located within the geographic area of PJM Interconnection LLC. Please change.

**Section N:**

The the type of the meter (**I-70-S**) doesn't match with the meter in the picture. Can you please double check the given information and file it in the docking system?

**Answer:** Type of meter should be CL 200 240 V.

Please let me know if you have any further questions and thank you for your cooperation.

Best,

Anna Noucas  
Senior Associate  
Sol Systems, LLC

**This foregoing document was electronically filed with the Public Utilities**

**Commission of Ohio Docketing Information System on**

**8/29/2014 12:13:39 PM**

**in**

**Case No(s). 14-1388-EL-REN**

Summary: Reply reply to staff interrogatory electronically filed by Ms. Anna Noucas on behalf of Woodworth, Larry