

Case No. 14-1551-EL-REN
Glenn Shenton Solar Array
Staff Interrogatories – Initial Set

Question 1: In section I.1 the nameplate capacity is listed as 0.005 MW. But in section G.1 you state the facility has 18 265W panels. Since $18 \times 265\text{W} = 4770\text{W}$ or 0.00477 MW. Is the nameplate capacity 0.00477 MW?

Answer 1: The system consists of 18 - 265W modules and is rated at 0.00477 MW.

This foregoing document was electronically filed with the Public Utilities

Commission of Ohio Docketing Information System on

10/7/2014 8:42:46 AM

in

Case No(s). 14-1551-EL-REN

Summary: Reply Reply to Staff Interrogatories - Shenton Solar Array electronically filed by Mr. Matthew L Partymiller on behalf of Shenton, Glenn Mr.