



December 18, 2014

Mark Bellamy,

I am writing with regards to staff interrogatories for the following case:

Case No. 14-2002-EL-REN  
Lancaster Historical Society-PA-PV-38kW Facility  
Staff Interrogatories – Initial Set

Question 1: In section I.1 the nameplate capacity is listed as 0.038 MW. But in section G.1 you state the facility has two hundred sixty four 144 Watt panels. Since  $264 \times 144W = 38,016W$  or 0.038016 MW. Is the nameplate capacity 0.038016 MW?

Answer 1: Yes, the nameplate capacity is .038016 MW

Please let me know if there is any additional information which you will require for this application.

Best,  
Bridget Callahan

**This foregoing document was electronically filed with the Public Utilities**

**Commission of Ohio Docketing Information System on**

**12/18/2014 10:49:25 AM**

**in**

**Case No(s). 14-2002-EL-REN**

Summary: Reply to staff inquiries electronically filed by Ms. Bridget Callahan on behalf of Robin Sarratt