

FIL



RECEIVED-DOCKETING DIV

2015 JUL 16 PM 1:01

Utility Technologies International  
4700 Homer Ohio Lane  
Groveport, OH 43125  
P: 614-482-8080  
[www.uti-corp.com](http://www.uti-corp.com)

PUCO

July 15, 2015

*Via Electronic Filing*

Mr. Patrick Donlon  
Interim Executive Director  
Ohio Power Siting Board  
180 East Broad Street, 6<sup>th</sup> Floor  
Columbus, OH 43215

Ms. Barcy McNeal  
Administration/Docketing  
Public Utilities Commission of Ohio  
180 East Broad Street, 11<sup>th</sup> Floor  
Columbus, OH 43215

**Re: REQUEST FOR EXPEDITED PROCESSING**  
**Vectren Energy Delivery of Ohio, Inc., Glen Karn ANR Interconnect**  
**Liberty Township, Darke County, Ohio**  
**OPSB Case No. 15-1268-GA-BNR**

Dear Mr. Donlon and Ms. McNeal:

Vectren Energy Delivery of Ohio ("Vectren") is proposing to build a 1,975-foot, 12-inch diameter connector pipeline from an ANR station to their existing Z-51 transmission pipeline located off Mikesell Road in Liberty Township, Darke County, Ohio. This interconnect will enable Vectren to continue to meet their supply demands on the Z-51 transmission line when the current agreement with Panhandle Eastern Pipe Line expires. The proposed 12-inch high-pressure line will have a maximum allowable operating pressure of 1,480 psig. The steel pipe will be externally coated with 14-16 Mils of fusion bonded epoxy coating and cathodically protected.

Construction on the pipeline is anticipated to begin in October 2015. Vectren plans to have the line in-service by April 2016.

Vectren will submit payment of \$2,000 in accordance with Ohio Administrative Code Rule 4906-5-11(I) so that the Construction Notice will be considered on an expedited basis. Please contact me at the number listed above or at [mstahl@uti-corp.com](mailto:mstahl@uti-corp.com) if you have any questions.

Sincerely,

Melinda Stahl  
Environmental Coordinator

This is to certify that the images appearing are an  
accurate and complete reproduction of a case file  
document delivered in the regular course of business.  
Technician   M   Date Processed   JUL 16 2015