

August 16, 2017

Ms. Barcy F. McNeal  
Docketing Division  
The Public Utilities Commission of Ohio  
180 East Broad Street  
Columbus, OH 43215-3793

**Supplemental Information Letter**  
**Inland-Harding (S-8) 345 kV Transmission Line**  
**Structure Addition Project**  
**Case No. 17-1571-EL-BNR**

Dear Ms. McNeal,

This letter provides supplemental information to the Ohio Power Siting Board ("Board") concerning the Inland-Harding 345 kV Transmission Line Structure Addition Project ("Project"), Case No. 17-1571-EL-BNR. Per a discussion with Board Staff, American Transmission Systems, Incorporated ("ATSI") is providing the following clarification.

ATSI will install a new transmission structure, Structure 15517-1, on the Inland-Harding (S-8) 345 kV Transmission Line, approximately 30 feet northeast of existing structure 15517 to support the installation of additional wireless communications facilities at this location. Existing structure 15517 is a double circuit structure that supports both the Inland-Harding (S-8) 345 kV Transmission Line, and the Harding-Leroy Center (S-6) 345 kV Transmission Line. The Inland-Harding (S-8) 345 kV Transmission Line will be transferred from the existing Structure 15517 to the proposed new structure, 15517-1. The existing Structure 15517, which is currently a double circuit structure, will be modified to a single circuit structure to support only the existing Harding-Leroy Center (S-6) 345 kV Transmission Line. Both structures will therefore be single circuit transmission structures supporting existing transmission lines.

Should the Ohio Power Siting Board desire further information or discussion of this submittal, please contact me at (330) 384-2740.

Sincerely,



William R. Beutler, P.E.

Engineer III

Energy Delivery Transmission and Substation Design  
FirstEnergy Service Company

cc: J. O'Dell

**This foregoing document was electronically filed with the Public Utilities**

**Commission of Ohio Docketing Information System on**

**8/16/2017 4:39:30 PM**

**in**

**Case No(s). 17-1571-EL-BNR**

Summary: Notice of the Filing of Supplemental Information electronically filed by Mr. Robert J Schmidt on behalf of American Transmission Systems Inc.