

March 7, 2018

Ms. Barcy F. McNeal
Docketing Division
The Public Utilities Commission of Ohio
180 East Broad Street
Columbus, OH 43215-3793

Letter of Notification
Clark-Greene 138 kV and Clark-East Springfield 138 kV
Transmission Lines Rebuild Project
Case No. 18-0226-EL-BLN

Dear Ms. McNeal:

In accordance with Ohio Administrative Code ("OAC") Rule 4906-2-04(A)(3) and OAC Chapter 4906-6, American Transmission Systems, Incorporated ("ATSI"), a FirstEnergy company, transmits five (5) paper copies and ten (10) digital copies on compact disc of the enclosed Letter of Notification application which was electronically filed. The Letter of Notification application was completed in accordance with the requirements of OAC Chapter 4906-6.

In this Project, ATSI is proposing a partial transmission line rebuild for an approximately 7.8-mile-long section of the existing Clark-Greene 138 kV and Clark-East Springfield 138 kV Transmission Lines within existing maintained transmission corridor. This Project involves the replacement of approximately forty-six (46) existing wood pole structures. These structures will be replaced in approximately the same locations using either: single wood poles, laminate poles or single steel poles. The new transmission line structures will be owned and operated by ATSI. The Project will be in Springfield Township and the City of Springfield, Clark County, Ohio.

ATSI is requesting an expedited review of this Project.

Pursuant to OAC Rule 4906-2-04(A)(3), please be advised of the following:

a) Name and address of the applicants:

American Transmission Systems, Incorporated
76 South Main Street
Akron, Ohio 44308

b) Name and location of proposed facilities:

Clark-Greene 138 kV and Clark-East Springfield 138 kV Transmission Lines Rebuild Project.

The Project area is located in an existing transmission corridor in the City of Springfield and Springfield Township, Clark County, Ohio

c) Applicant's representative:

Nataliya Bryksenkova
Engineer
Energy Delivery Transmission and Substation Design
FirstEnergy Service Company
76 South Main Street
Akron, OH 44308-1890

d) The number of structures to be replaced provided in the pre-application letter required by OAC Rule 4906-6-03 has been changed in the attached Letter of Notification application from forty-five (45) to forty-six (46).

e) A notarized statement that the information contained in the Letter of Notification application is complete and accurate to the best of my information and belief is enclosed as Attachment 1 to this letter.

We have provided a copy of this Letter of Notification application by certified mail, with return receipt requested, to officials of the political subdivisions immediately affected by the proposed Project as listed in the attached Exhibit 1 of this letter. Copies of the transmittal letters addressed to the local government representatives of the City of Springfield, Springfield Township and Clark County are enclosed for your file. In addition to the local officials, this Letter of Notification application is being provided to the libraries listed in Exhibit 1. These materials are being provided as proof of compliance with OAC Rule 4906-6-07. A list of the property owners affected by the proposed Project and who will receive a letter describing this Project is attached as Exhibit 2. This is being provided as proof of compliance with OAC Rule 4906-6-08(B).

After docketing this filing, please return one time-stamped copy of the Letter of Notification application for our records in the enclosed envelope. Should staff of the Ohio Power Siting Board desire further information or discussion of this submittal, please contact me at (330) 761-4473.

Sincerely,



Nataliya Bryksenkova
Engineer
Energy Delivery
Transmission and Substation Design
FirstEnergy Service Company

Attachments

**Clark-Greene 138 kV and Clark-East Springfield 138 kV
Transmission Lines Rebuild Project
Case No. 18-0226-EL-BLN**

Date: March 7, 2018

**Attachment 1
Affidavit of Nataliya Bryksenkova**

BEFORE THE
OHIO POWER SITING BOARD

In the Matter Of:)

The Application of American Transmission)

Systems, Incorporated for a Certificate of)

Environmental Compatibility and Public)

Need for the Construction of the Clark-)

Greene 138 kV and Clark-East Springfield)

138 kV Transmission Lines Rebuild)

Project)

Case No. 18-0226-EL-BLN

AFFIDAVIT OF NATALIYA BRYKSENKOVA

I, Nataliya Bryksenkova, state the following:

Pursuant to Ohio Administrative Code Rule 4906-2-04(A)(3)(e), I am the authorized representative of the Applicant in this case and I affirm that the Letter of Notification application filed in this matter is true and accurate to the best of my information and belief.

N. Bryksenkova

Nataliya Bryksenkova
FirstEnergy Service Company

State of Ohio)

)

ss:

County of Summit)

Sworn and subscribed before me this 17th day of March 2018.

T. M. Miller

Notary Public



Tereasa M. Miller
Resident Summit County
Notary Public, State of Ohio
My Commission Expires: 04/07/2020

EXHIBIT 1
Clark-Greene 138 kV and Clark-East Springfield 138 kV
Transmission Lines Rebuild Project
Case No. 18-0226-EL-BLN

Clark County

Ms. Melanie Flax Wilt
Clark County Commissioner
Clark County Administration
50 East Columbia Street
Springfield, OH 45501

Mr. Lowell R. McGlothlin
Clark County Commissioner
Clark County Administration
50 East Columbia Street
Springfield, OH 45501

Mr. Richard Lohnes
Clark County Commissioner
Clark County Administration
50 East Columbia Street
Springfield, OH 45501

Ms. Jennifer Hutchinson,
Clark County Administrator
Board of Clark County
Commissioners
50 East Columbia Street
Springfield, OH 45501

Ms. Jo Anderson, Chairperson
Clark County Planning
Commission
50 East Columbia Street
Springfield, OH 45501

Mr. Johnathan A. Burr, P.E., P.S.
Clark County Engineer
4075 Laybourne Road
Springfield, OH 45505

City of Springfield

Mr. Warren R. Copeland
Mayor, City of Springfield
76 East High Street, City Hall
Springfield, OH 45502

Ms. Jill Pierce
City Clerk, City of Springfield
76 East High Street, City Hall
Springfield, OH 45502

Mr. Leo Shanayda, P.E.
City Engineer, City of Springfield
76 East High Street,
2nd Floor, City Hall
Springfield, OH 45502

Ms. Jim Bodenmiller
City Manager, City of Springfield
76 East High Street,
3rd Floor, City Hall
Springfield, OH 45502

Springfield Township

Mr. Tim Foley
Trustee, Springfield Township
2777 Springfield-Xenia Road
Springfield, OH 45506

Mr. Jim Scoby
Trustee, Springfield Township
2777 Springfield-Xenia Road
Springfield, OH 45506

Mr. John Roeder
Trustee, Springfield Township
2777 Springfield-Xenia Road
Springfield, OH 45506

Mr. Mike Hively
Fiscal Officer,
Springfield Township
2777 Springfield-Xenia Road
Springfield, OH 45506

Libraries

Ms. Sally Rizer, Director
Clark County Public Library
201 South Fountain Avenue
Springfield, OH 45506

March 7, 2018

Ms. Melanie Flax Wilt
Clark County Commissioner
Clark County Administration
50 East Columbia Street
Springfield, OH 45501

Letter of Notification
Clark-Greene 138 kV and Clark-East Springfield 138 kV
Transmission Lines Rebuild Project
Case No. 18-0226-EL-BLN

Dear Ms. Flax Wilt,

American Transmission Systems, Incorporated ("ATSI"), a FirstEnergy company, has recently filed an application with the Ohio Power Siting Board ("OPSB") for a Project that involves a partial transmission line rebuild for an approximately 7.8-mile-long section of the existing Clark-Greene 138 kV and Clark-East Springfield 138 kV Transmission Lines. The Project will be within existing maintained transmission corridor and involves the replacement of approximately forty-six (46) existing wood pole structures. These structures will be replaced in approximately the same locations using either: single wood poles, laminate poles or single steel poles. The new transmission line structures will be owned and operated by ATSI. The Project will be located in the City of Springfield and Springfield Township, Clark County, Ohio.

In accordance with Ohio Administrative Code ("OAC") Rule 4906-1-01, this Project falls within the OPSB's requirements for a Letter of Notification application. Therefore, in compliance with OAC Rule 4906-6, we have prepared and filed the attached application, on enclosed compact disc, with the OPSB for their review and approval. The Letter of Notification application contains a more detailed description of the Project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 761-4473.

Sincerely,



Nataliya Bryksenkova
Engineer
Energy Delivery
Transmission & Substation Design
FirstEnergy Service Company

Attachment

March 7, 2018

Mr. Lowell R. McGlothlin
Clark County Commissioner
Clark County Administration
50 East Columbia Street
Springfield, OH 45501

Letter of Notification
Clark-Greene 138 kV and Clark-East Springfield 138 kV
Transmission Lines Rebuild Project
Case No. 18-0226-EL-BLN

Dear Mr. McGlothlin,

American Transmission Systems, Incorporated ("ATSI"), a FirstEnergy company, has recently filed an application with the Ohio Power Siting Board ("OPSB") for a Project that involves a partial transmission line rebuild for an approximately 7.8-mile-long section of the existing Clark-Greene 138 kV and Clark-East Springfield 138 kV Transmission Lines. The Project will be within existing maintained transmission corridor and involves the replacement of approximately forty-six (46) existing wood pole structures. These structures will be replaced in approximately the same locations using either: single wood poles, laminate poles or single steel poles. The new transmission line structures will be owned and operated by ATSI. The Project will be located in the City of Springfield and Springfield Township, Clark County, Ohio.

In accordance with Ohio Administrative Code ("OAC") Rule 4906-1-01, this Project falls within the OPSB's requirements for a Letter of Notification application. Therefore, in compliance with OAC Rule 4906-6, we have prepared and filed the attached application, on enclosed compact disc, with the OPSB for their review and approval. The Letter of Notification application contains a more detailed description of the Project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 761-4473.

Sincerely,



Nataliya Bryksenkova
Engineer
Energy Delivery
Transmission & Substation Design
FirstEnergy Service Company

Attachment

March 7, 2018

Mr. Richard Lohnes
Clark County Commissioner
Clark County Administration
50 East Columbia Street
Springfield, OH 45501

Letter of Notification
Clark-Greene 138 kV and Clark-East Springfield 138 kV
Transmission Lines Rebuild Project
Case No. 18-0226-EL-BLN

Dear Mr. Lohnes,

American Transmission Systems, Incorporated ("ATSI"), a FirstEnergy company, has recently filed an application with the Ohio Power Siting Board ("OPSB") for a Project that involves a partial transmission line rebuild for an approximately 7.8-mile-long section of the existing Clark-Greene 138 kV and Clark-East Springfield 138 kV Transmission Lines. The Project will be within existing maintained transmission corridor and involves the replacement of approximately forty-six (46) existing wood pole structures. These structures will be replaced in approximately the same locations using either: single wood poles, laminate poles or single steel poles. The new transmission line structures will be owned and operated by ATSI. The Project will be located in the City of Springfield and Springfield Township, Clark County, Ohio.

In accordance with Ohio Administrative Code ("OAC") Rule 4906-1-01, this Project falls within the OPSB's requirements for a Letter of Notification application. Therefore, in compliance with OAC Rule 4906-6, we have prepared and filed the attached application, on enclosed compact disc, with the OPSB for their review and approval. The Letter of Notification application contains a more detailed description of the Project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 761-4473.

Sincerely,



Nataliya Bryksenkova
Engineer
Energy Delivery
Transmission & Substation Design
FirstEnergy Service Company

Attachment

March 7, 2018

Ms. Jennifer Hutchinson,
Clark County Administrator
Board of Clark County Commissioners
50 East Columbia Street
Springfield, OH 45501

Letter of Notification
Clark-Greene 138 kV and Clark-East Springfield 138 kV
Transmission Lines Rebuild Project
Case No. 18-0226-EL-BLN

Dear Ms. Hutchinson,

American Transmission Systems, Incorporated (“ATSI”), a FirstEnergy company, has recently filed an application with the Ohio Power Siting Board (“OPSB”) for a Project that involves a partial transmission line rebuild for an approximately 7.8-mile-long section of the existing Clark-Greene 138 kV and Clark-East Springfield 138 kV Transmission Lines. The Project will be within existing maintained transmission corridor and involves the replacement of approximately forty-six (46) existing wood pole structures. These structures will be replaced in approximately the same locations using either: single wood poles, laminate poles or single steel poles. The new transmission line structures will be owned and operated by ATSI. The Project will be located in the City of Springfield and Springfield Township, Clark County, Ohio.

In accordance with Ohio Administrative Code (“OAC”) Rule 4906-1-01, this Project falls within the OPSB’s requirements for a Letter of Notification application. Therefore, in compliance with OAC Rule 4906-6, we have prepared and filed the attached application, on enclosed compact disc, with the OPSB for their review and approval. The Letter of Notification application contains a more detailed description of the Project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 761-4473.

Sincerely,



Nataliya Bryksenkova
Engineer
Energy Delivery
Transmission & Substation Design
FirstEnergy Service Company

Attachment

March 7, 2018

Ms. Jo Anderson, Chairperson
Clark County Planning Commission
50 East Columbia Street
Springfield, OH 45501

Letter of Notification
Clark-Greene 138 kV and Clark-East Springfield 138 kV
Transmission Lines Rebuild Project
Case No. 18-0226-EL-BLN

Dear Ms. Anderson,

American Transmission Systems, Incorporated ("ATSI"), a FirstEnergy company, has recently filed an application with the Ohio Power Siting Board ("OPSB") for a Project that involves a partial transmission line rebuild for an approximately 7.8-mile-long section of the existing Clark-Greene 138 kV and Clark-East Springfield 138 kV Transmission Lines. The Project will be within existing maintained transmission corridor and involves the replacement of approximately forty-six (46) existing wood pole structures. These structures will be replaced in approximately the same locations using either: single wood poles, laminate poles or single steel poles. The new transmission line structures will be owned and operated by ATSI. The Project will be located in the City of Springfield and Springfield Township, Clark County, Ohio.

In accordance with Ohio Administrative Code ("OAC") Rule 4906-1-01, this Project falls within the OPSB's requirements for a Letter of Notification application. Therefore, in compliance with OAC Rule 4906-6, we have prepared and filed the attached application, on enclosed compact disc, with the OPSB for their review and approval. The Letter of Notification application contains a more detailed description of the Project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 761-4473.

Sincerely,



Nataliya Bryksenkova
Engineer
Energy Delivery
Transmission & Substation Design
FirstEnergy Service Company

Attachment

March 7, 2018

Mr. Johnathan A. Burr, P.E., P.S.
Clark County Engineer
4075 Laybourne Road
Springfield, OH 45505

Letter of Notification
Clark-Greene 138 kV and Clark-East Springfield 138 kV
Transmission Lines Rebuild Project
Case No. 18-0226-EL-BLN

Dear Mr. Burr,

American Transmission Systems, Incorporated ("ATSI"), a FirstEnergy company, has recently filed an application with the Ohio Power Siting Board ("OPSB") for a Project that involves a partial transmission line rebuild for an approximately 7.8-mile-long section of the existing Clark-Greene 138 kV and Clark-East Springfield 138 kV Transmission Lines. The Project will be within existing maintained transmission corridor and involves the replacement of approximately forty-six (46) existing wood pole structures. These structures will be replaced in approximately the same locations using either: single wood poles, laminate poles or single steel poles. The new transmission line structures will be owned and operated by ATSI. The Project will be located in the City of Springfield and Springfield Township, Clark County, Ohio.

In accordance with Ohio Administrative Code ("OAC") Rule 4906-1-01, this Project falls within the OPSB's requirements for a Letter of Notification application. Therefore, in compliance with OAC Rule 4906-6, we have prepared and filed the attached application, on enclosed compact disc, with the OPSB for their review and approval. The Letter of Notification application contains a more detailed description of the Project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 761-4473.

Sincerely,



Nataliya Bryksenkova
Engineer
Energy Delivery
Transmission & Substation Design
FirstEnergy Service Company

Attachment

March 7, 2018

Mr. Warren R. Copeland
Mayor, City of Springfield
76 East High Street, City Hall
Springfield, OH 45502

Letter of Notification
Clark-Green 138 kV and Clark-East Springfield 138 kV
Transmission Lines Rebuild Project
Case No. 18-0226-EL-BLN

Dear Mr. Copeland,

American Transmission Systems, Incorporated ("ATSI"), a FirstEnergy company, has recently filed an application with the Ohio Power Siting Board ("OPSB") for a Project that involves a partial transmission line rebuild for an approximately 7.8-mile-long section of the existing Clark-Green 138 kV and Clark-East Springfield 138 kV Transmission Lines. The Project will be within existing maintained transmission corridor and involves the replacement of approximately forty-six (46) existing wood pole structures. These structures will be replaced in approximately the same locations using either: single wood poles, laminate poles or single steel poles. The new transmission line structures will be owned and operated by ATSI. The Project will be located in the City of Springfield and Springfield Township, Clark County, Ohio.

In accordance with Ohio Administrative Code ("OAC") Rule 4906-1-01, this Project falls within the OPSB's requirements for a Letter of Notification application. Therefore, in compliance with OAC Rule 4906-6, we have prepared and filed the attached application, on enclosed compact disc, with the OPSB for their review and approval. The Letter of Notification application contains a more detailed description of the Project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 761-4473.

Sincerely,



Nataliya Bryksenkova
Engineer
Energy Delivery
Transmission & Substation Design
FirstEnergy Service Company

Attachment

March 7, 2018

Ms. Jill Pierce
City Clerk, City of Springfield
76 East High Street, City Hall
Springfield, OH 45502

Letter of Notification
Clark-Greene 138 kV and Clark-East Springfield 138 kV
Transmission Lines Rebuild Project
Case No. 18-0226-EL-BLN

Dear Mr. Pierce,

American Transmission Systems, Incorporated ("ATSI"), a FirstEnergy company, has recently filed an application with the Ohio Power Siting Board ("OPSB") for a Project that involves a partial transmission line rebuild for an approximately 7.8-mile-long section of the existing Clark-Greene 138 kV and Clark-East Springfield 138 kV Transmission Lines. The Project will be within existing maintained transmission corridor and involves the replacement of approximately forty-six (46) existing wood pole structures. These structures will be replaced in approximately the same locations using either: single wood poles, laminate poles or single steel poles. The new transmission line structures will be owned and operated by ATSI. The Project will be located in the City of Springfield and Springfield Township, Clark County, Ohio.

In accordance with Ohio Administrative Code ("OAC") Rule 4906-1-01, this Project falls within the OPSB's requirements for a Letter of Notification application. Therefore, in compliance with OAC Rule 4906-6, we have prepared and filed the attached application, on enclosed compact disc, with the OPSB for their review and approval. The Letter of Notification application contains a more detailed description of the Project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 761-4473.

Sincerely,



Nataliya Bryksenkova
Engineer
Energy Delivery
Transmission & Substation Design
FirstEnergy Service Company

Attachment

March 7, 2018

Mr. Leo Shanayda, P.E.
City Engineer, City of Springfield
76 East High Street,
2nd Floor, City Hall
Springfield, OH 45502

Letter of Notification
Clark-Greene 138 kV and Clark-East Springfield 138 kV
Transmission Lines Rebuild Project
Case No. 18-0226-EL-BLN

Dear Mr. Shanayda,

American Transmission Systems, Incorporated ("ATSI"), a FirstEnergy company, has recently filed an application with the Ohio Power Siting Board ("OPSB") for a Project that involves a partial transmission line rebuild for an approximately 7.8-mile-long section of the existing Clark-Greene 138 kV and Clark-East Springfield 138 kV Transmission Lines. The Project will be within existing maintained transmission corridor and involves the replacement of approximately forty-six (46) existing wood pole structures. These structures will be replaced in approximately the same locations using either: single wood poles, laminate poles or single steel poles. The new transmission line structures will be owned and operated by ATSI. The Project will be located in the City of Springfield and Springfield Township, Clark County, Ohio.

In accordance with Ohio Administrative Code ("OAC") Rule 4906-1-01, this Project falls within the OPSB's requirements for a Letter of Notification application. Therefore, in compliance with OAC Rule 4906-6, we have prepared and filed the attached application, on enclosed compact disc, with the OPSB for their review and approval. The Letter of Notification application contains a more detailed description of the Project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 761-4473.

Sincerely,



Nataliya Bryksenkova
Engineer
Energy Delivery
Transmission & Substation Design
FirstEnergy Service Company

Attachment

March 7, 2018

Ms. Jim Bodenmiller
City Manager, City of Springfield
76 East High Street,
3rd Floor, City Hall
Springfield, OH, 45502

Letter of Notification
Clark-Greene 138 kV and Clark-East Springfield 138 kV
Transmission Lines Rebuild Project
Case No. 18-0226-EL-BLN

Dear Mr. Bodenmiller,

American Transmission Systems, Incorporated ("ATSI"), a FirstEnergy company, has recently filed an application with the Ohio Power Siting Board ("OPSB") for a Project that involves a partial transmission line rebuild for an approximately 7.8-mile-long section of the existing Clark-Greene 138 kV and Clark-East Springfield 138 kV Transmission Lines. The Project will be within existing maintained transmission corridor and involves the replacement of approximately forty-six (46) existing wood pole structures. These structures will be replaced in approximately the same locations using either: single wood poles, laminate poles or single steel poles. The new transmission line structures will be owned and operated by ATSI. The Project will be located in the City of Springfield and Springfield Township, Clark County, Ohio.

In accordance with Ohio Administrative Code ("OAC") Rule 4906-1-01, this Project falls within the OPSB's requirements for a Letter of Notification application. Therefore, in compliance with OAC Rule 4906-6, we have prepared and filed the attached application, on enclosed compact disc, with the OPSB for their review and approval. The Letter of Notification application contains a more detailed description of the Project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 761-4473.

Sincerely,



Nataliya Bryksenkova
Engineer
Energy Delivery
Transmission & Substation Design
FirstEnergy Service Company

Attachment

March 7, 2018

Mr. Tim Foley
Trustee, Springfield Township
2777 Springfield-Xenia Road
Springfield, OH 45506

Letter of Notification
Clark-Greene 138 kV and Clark-East Springfield 138 kV
Transmission Lines Rebuild Project
Case No. 18-0226-EL-BLN

Dear Mr. Foley,

American Transmission Systems, Incorporated ("ATSI"), a FirstEnergy company, has recently filed an application with the Ohio Power Siting Board ("OPSB") for a Project that involves a partial transmission line rebuild for an approximately 7.8-mile-long section of the existing Clark-Greene 138 kV and Clark-East Springfield 138 kV Transmission Lines. The Project will be within existing maintained transmission corridor and involves the replacement of approximately forty-six (46) existing wood pole structures. These structures will be replaced in approximately the same locations using either: single wood poles, laminate poles or single steel poles. The new transmission line structures will be owned and operated by ATSI. The Project will be located in the City of Springfield and Springfield Township, Clark County, Ohio.

In accordance with Ohio Administrative Code ("OAC") Rule 4906-1-01, this Project falls within the OPSB's requirements for a Letter of Notification application. Therefore, in compliance with OAC Rule 4906-6, we have prepared and filed the attached application, on enclosed compact disc, with the OPSB for their review and approval. The Letter of Notification application contains a more detailed description of the Project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 761-4473.

Sincerely,



Nataliya Bryksenkova
Engineer
Energy Delivery
Transmission & Substation Design
FirstEnergy Service Company

Attachment

March 7, 2018

Mr. John Roeder
Trustee, Springfield Township
2777 Springfield-Xenia Road
Springfield, OH 45506

Letter of Notification
Clark-Greene 138 kV and Clark-East Springfield 138 kV
Transmission Lines Rebuild Project
Case No. 18-0226-EL-BLN

Dear Mr. Roeder,

American Transmission Systems, Incorporated ("ATSI"), a FirstEnergy company, has recently filed an application with the Ohio Power Siting Board ("OPSB") for a Project that involves a partial transmission line rebuild for an approximately 7.8-mile-long section of the existing Clark-Greene 138 kV and Clark-East Springfield 138 kV Transmission Lines. The Project will be within existing maintained transmission corridor and involves the replacement of approximately forty-six (46) existing wood pole structures. These structures will be replaced in approximately the same locations using either: single wood poles, laminate poles or single steel poles. The new transmission line structures will be owned and operated by ATSI. The Project will be located in the City of Springfield and Springfield Township, Clark County, Ohio.

In accordance with Ohio Administrative Code ("OAC") Rule 4906-1-01, this Project falls within the OPSB's requirements for a Letter of Notification application. Therefore, in compliance with OAC Rule 4906-6, we have prepared and filed the attached application, on enclosed compact disc, with the OPSB for their review and approval. The Letter of Notification application contains a more detailed description of the Project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 761-4473.

Sincerely,



Nataliya Bryksenkova
Engineer
Energy Delivery
Transmission & Substation Design
FirstEnergy Service Company

Attachment

March 7, 2018

Mr. Jim Scoby
Trustee, Springfield Township
2777 Springfield-Xenia Road
Springfield, OH 45506

Letter of Notification
Clark-Greene 138 kV and Clark-East Springfield 138 kV
Transmission Lines Rebuild Project
Case No. 18-0226-EL-BLN

Dear Mr. Scoby,

American Transmission Systems, Incorporated ("ATSI"), a FirstEnergy company, has recently filed an application with the Ohio Power Siting Board ("OPSB") for a Project that involves a partial transmission line rebuild for an approximately 7.8-mile-long section of the existing Clark-Greene 138 kV and Clark-East Springfield 138 kV Transmission Lines. The Project will be within existing maintained transmission corridor and involves the replacement of approximately forty-six (46) existing wood pole structures. These structures will be replaced in approximately the same locations using either: single wood poles, laminate poles or single steel poles. The new transmission line structures will be owned and operated by ATSI. The Project will be located in the City of Springfield and Springfield Township, Clark County, Ohio.

In accordance with Ohio Administrative Code ("OAC") Rule 4906-1-01, this Project falls within the OPSB's requirements for a Letter of Notification application. Therefore, in compliance with OAC Rule 4906-6, we have prepared and filed the attached application, on enclosed compact disc, with the OPSB for their review and approval. The Letter of Notification application contains a more detailed description of the Project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 761-4473.

Sincerely,



Nataliya Bryksenkova
Engineer
Energy Delivery
Transmission & Substation Design
FirstEnergy Service Company

Attachment

March 7, 2018

Mr. Mike Hively
Fiscal Officer,
Springfield Township
2777 Springfield-Xenia Road
Springfield, OH 45506

Letter of Notification
Clark-Greene 138 kV and Clark-East Springfield 138 kV
Transmission Lines Rebuild Project
Case No. 18-0226-EL-BLN

Dear Mr. Hively,

American Transmission Systems, Incorporated ("ATSI"), a FirstEnergy company, has recently filed an application with the Ohio Power Siting Board ("OPSB") for a Project that involves a partial transmission line rebuild for an approximately 7.8-mile-long section of the existing Clark-Greene 138 kV and Clark-East Springfield 138 kV Transmission Lines. The Project will be within existing maintained transmission corridor and involves the replacement of approximately forty-six (46) existing wood pole structures. These structures will be replaced in approximately the same locations using either: single wood poles, laminate poles or single steel poles. The new transmission line structures will be owned and operated by ATSI. The Project will be located in the City of Springfield and Springfield Township, Clark County, Ohio.

In accordance with Ohio Administrative Code ("OAC") Rule 4906-1-01, this Project falls within the OPSB's requirements for a Letter of Notification application. Therefore, in compliance with OAC Rule 4906-6, we have prepared and filed the attached application, on enclosed compact disc, with the OPSB for their review and approval. The Letter of Notification application contains a more detailed description of the Project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 761-4473.

Sincerely,



Nataliya Bryksenkova
Engineer
Energy Delivery
Transmission & Substation Design
FirstEnergy Service Company

Attachment

March 7, 2018

Ms. Sally Rizer, Director
Clark County Public Library
201 South Fountain Avenue
Springfield, OH 45506

Letter of Notification
Clark-Greene 138 kV and Clark-East Springfield 138 kV
Transmission Lines Rebuild Project
Case No. 18-0226-EL-BLN

Dear Ms. Rizer,

Enclosed please find one copy of the Letter of Notification application of American Transmission Systems, Incorporated ("ATSI"), a FirstEnergy company, that has been filed with the Ohio Power Siting Board ("OPSB") for the Project named above. Please make the application available for public reference in the Clark County Public Library. We are providing a copy of the Letter of Notification application pursuant to Ohio Administrative Code ("OAC") Rule 4906-5-06, which requires us to place a copy of the Application in the main public libraries of the political subdivisions in which any portion of the Project is to be located.

As described in the application, the Project proposes a partial transmission line rebuild for an approximately 7.8-mile-long section of the existing Clark-Greene 138 kV and Clark-East Springfield 138 kV Transmission Lines within existing maintained transmission corridor. This Project involves the replacement of approximately forty-six (46) existing wood pole structures. These structures will be replaced in approximately the same locations using either: single wood poles, laminate poles or single steel poles. The new transmission line structures will be owned and operated by ATSI. The Project will be located in the City of Springfield and Springfield Township, Clark County, Ohio.

In accordance with Ohio Administrative Code ("OAC") Rule 4906-1-01, this Project falls within the OPSB's requirements for a Letter of Notification application. Therefore, in compliance with OAC Rule 4906-6, we have prepared and filed the attached application with the OPSB for their review and approval. The Letter of Notification application contains a description of the Project, and is provided for public information and review.

Please feel free to call me with any question you have on making the Letter of Notification application available to your patrons. My phone number is (330) 761-4473.

Sincerely,



Nataliya Bryksenkova
Engineer
Energy Delivery
Transmission and Substation Design
FirstEnergy Service Company

Enclosure

EXHIBIT 2
Property Owners Served Notice of the Letter of Notification
Clark-Greene 138 kV and Clark-East Springfield 138 kV
Transmission Lines Rebuild Project
Case No. 18-0226-EL-BLN

Property Owner(s) & Address	Parcel Number(s)
8888 Park LTD 750 Shrine Road Springfield OH 45504	3400600009200018; 3000600010000036; 3400600009200001
A&B Asphalt Corporation 11641 Mosteller Road Cincinnati OH 45241	3000600009200015
Agle William James 993 South Urbana Lisbon Road South Vienna OH 45369	3000700014000039
Archbishop of Cincinnati Trustee 3155 East Possum Road Springfield OH 45502	30007000202001010
Bell Nursery USA, LLC P.O. Box 1108 Springfield OH 45501	3000700026100056; 3000700026100077
Boyd Anthony G. & Susan G. 1946 Rebert Pike Springfield OH 45506	3000600009203016
Bradley Norma M. & Laura Miller 2010 Rebert Pike Springfield OH 45506	3000600009203013
Cappelli Louis Anthony 2249 Selma Road Springfield OH 45505	3000700020100013
Capper Danny L. & Marilyn S. 3226 East Possum Road Springfield OH 45502	3000700014000140
Castle Mark H. 2245 Scioto Street Springfield OH 45506	3000600003300018
Cedar Lane Investments Inc. P.O. Box 443 Degraff OH 43318	3000700020200007
Church of God Third of Springfield Ohio 1408 Clifton Avenue Springfield OH 45505	3000700020200013
City of Springfield (Old City Dump) 76 East High Street Springfield OH 45502	33006000100001031; 33006000100001030; 33006000100001004

Property Owner(s) & Address	Parcel Number(s)
Columbia Gas Transmission Corporation P.O. Box 2168 Houston TX 77252	3000700026600002
Combs Paige D. & Cody 2356 South Burnett Road Springfield OH 45506	3000700020201001; 3000700020201007
Conrail Railroad 1717 Arch Street, 13 th Floor Philadelphia, PA 19103	3300600016500009
CRD Commercial Limited Liability Company 2112 Amarillo Avenue Springfield OH 45506	3050700032100048
Daulton Ryan J. & Lindsay B. 3396 East Possum Road Springfield OH 45502	3000700014000143
Davis Julia K. 2992 Moorefield Road. Springfield OH 45502	3000600002100028
Edwards Harold C. & Patricia L. 2475 Old Clifton Road Springfield OH 45502	3000700026100083
Felty Patricia 19 The Fairway Woodstock GA 30188	3000700020100011
Fine Jonathan H. & Sharon L. Trustees 35 Emerald Circle Vallejo CA 94589	3000600002100013
Freese David A. & Marcia E. 2187 Scioto Drive Springfield OH 45506	3000600003300012
Fry Larry G. & Barbara S. 2498 South York Street Springfield OH 45505	3000700026100017; 3000700026100018
Gamble Bryan K. & Valarie K. 44 Prospect Avenue Dayton, OH 45415	3000600002100031
Garberich Michael J. 2449 Springfield-Xenia Road Springfield OH 45506	3000600002100031
Gottlieb Jolene P. 1813 Rhonemous Street Springfield OH 45506	3000600009200014
Gram Donald L. & Dawn A. 5777 North River Road Springfield OH 45502	3000700026201046

Property Owner(s) & Address	Parcel Number(s)
Grand & Reserve, LLC 6000 Old Clifton Road Springfield OH 45502	3000700026201065
Indiana & Ohio Railway 2856 Cypress Way Cincinnati OH 45212	3000700020500001; 3000700014500001
Johnson Collin R. & Kathryn I. 2075 Rebert Pike Springfield OH 45506	3000600009200011
Lobdell Dallas J. & Diana L. 2375 Selma Pike Springfield OH 45505	3000700026200008
Lower David V. & Mary J. 2545 South Limestone Street Springfield OH 45505	3000700032100016
Lower Frederic R. & David V. 2531 South Limestone Street Springfield OH 45505	3050700032100038
Lynn Mary Ann 1334 Willow Chase Circle Springfield OH 45503	3000700020100012
Lyon Henry H. & Rose A. Trustees 1996 Rebert Pike Springfield OH 45506	3000600009203014
Miesse Irene M. Trustee 2525 Springfield-Xenia Road Springfield OH 45506	3000600002100030; 3000600003314011
Miller Kevin A. & Tina M. 1463 Driscoll Avenue Springfield OH 45506	3000600003127013
Morgan Michael F. 4949 South Pitchin Road Springfield OH 45502	3000600002101014; 3000600002102015
Mounts Andre J. Sr. 5331 Beard Road Springfield OH 45502	3000600003300013
National Trail Parks & Recreation 1301 Mitchell Boulevard Springfield OH 45503	3000700032200016
Nave Max E. & Helen L. 2211 Scioto Street Springfield OH 45506	3000600003300015
Ohio Edison Company 800 Cabin Hill Drive Greensburg PA 15601	3400600009600003; 3000600010600013; 3000600002600002; 3000600010600014; 3300600016210005

Property Owner(s) & Address	Parcel Number(s)
Peel Darren C. & Robin 3135 Scioto Street Springfield OH 45506	3000600003300006
Pence Stephen M. 2436 Old Salma Pike Springfield OH 45506	3000700026202020
Perkins Barry C. & Pamela 2072 Rebert Pike Springfield OH 45506	3000600009203012
Pillion Gerald R. & Carlene L. 4823 Ashley Dr. Springfield OH 45503	3000600003300020
R Way Travel Plaza, Inc. 629 Aberfelda Drive Springfield OH 45504	3000700032100055; 3050700032100041; 3050700032100040
Rose Brad L. & Teena 1900 Rebert Pike Springfield OH 45506	3000600009203017
Rousculp Robert E. & Melissa A. 3276 East Possum Road Springfield OH 45502	3000700014000134
Ruf Ryan D. & Cathleen C. 2201 Scioto Street Springfield OH 45506	3000600003300014
Russel Christopher M. 2247 Scioto Street Springfield OH 45506	3000600003300019
Rutan Robert E. 1986 Rebert Pike Springfield OH 45506	3000600009203015
Seminole Villa, Inc. P.O. Box 25965 Attention: Tax Administrator Shawnee Mission KS 66225	3000600003314018
Severs Donald E. Jr. 2157 Scioto Street Springfield OH 45506	3000600003300009; 3000600003300010
Shipley Sandra Lea Trustee 2147 Scioto Street Springfield OH 45506	3000600003300008
Siegfried Donald L. 1811 High Tower Drive Columbus OH 432365	3000600008000028
Smith Douglas Myles 2990 State Route 235 Xena OH 45385	3000700020100002

Property Owner(s) & Address	Parcel Number(s)
Speaks Brenda 4000 Bosart Road. Springfield OH 45503	3000600003300011
Springfield Township Board of Trustees 2777 Springfield-Xenia Road Springfield OH 45506	3000600002102020; 30007000261001037
Springfield Youth Baseball Association P.O. Box 867 Springfield OH 45501	3000600010000021; 3400600010402075
Stacey Jordan D. 300 Enon Road Enon OH 45323	3000600009200010; 3400600009200006
Stevenson Harold O. Trustees 400 West Possum Road Springfield OH 45506	3000600002200019; 3000700032100042; 3000600002200009
Taylor Verne V. 650 West Possum Road Springfield OH 45506	3000600002102016
Thompson R. Alan & Teresa L. 5785 Springfield Jamestown Road Springfield OH 45502	3000700014000013
Thompson Ramona Y. Trustees 1432 West Possum Road Springfield OH 45502	3050700026100092
Turner Timothy L. & Tammy M. 3223 East Possum Road Springfield OH 45502	3000700014000132
Veterans of Foreign Wars Post No. 8673 2825 East Leffel Lane Springfield OH 45502	3000700020200015
Winkler Steven D. & Deda M. Trustees 434 Dune Ridge South Saint Joseph MI 49085	3000600009000109
Zeus Investments, Inc. 750 Shrine Road Springfield OH 45502	3000600009000099; 3000700020204012

This foregoing document was electronically filed with the Public Utilities

Commission of Ohio Docketing Information System on

3/7/2018 1:44:05 PM

in

Case No(s). 18-0226-EL-BLN

Summary: Letter of Notification Application for a Certificate of Environmental Compatibility and Public Need (Part 1 of 10) electronically filed by Mr. Robert J Schmidt on behalf of American Transmission Systems Inc.