17-1721-EL-CSS2

RECEIVED-DOCKETING DIV

2018 MAR -9 PM 2:39

PUCO

March 3, 2018

Picture # 1

Inverter plugged in. Green light on, Sending 110-120 volts to plug.

Picture # 2

Pluq pulled and fingers across pluq.
No voltage, No power. Grid tie inverter.
No power. Nothing out. Simpletest will
duplicate test. All inverters grid tie.

All inverters grid tie.

Pete Rohloff

This is to certify that the images appearing are an accurate and complete reproduction of a case file document delivered in the regular course of business. Technician MM Date Processed 03 09 118



