Hardin Solar Energy II LLC Case No. 18-1360-EL-BGN

Application Part 3 of 6

Part 3 includes:

- Exhibit A Battery System Data Sheet
- Exhibit B Module Specifications
- Exhibit C Tracking Specifications
- Exhibit D Inverter Specifications
- Exhibit E Substation Transformer Specifications
- Exhibit F TRC Site Characterization Report October 2018
- Exhibit G TRC Hardin Raptor Nest Survey October 2018

Christine M.T. Pirik (0029759) (Counsel of Record) William V. Vorys (0093479) Dickinson Wright PLLC 150 East Gay Street, Suite 2400 Columbus, Ohio 43215 Phone: (614) 591-5461 Email: <u>cpirik@dickinsonwright.com</u> <u>wvorys@dickinsonwright.com</u>

Attorneys for Hardin Solar Energy II LLC

Date Filed: October 12, 2018

Hardin Solar Energy II LLC Case No. 18-1360-EL-BGN

Exhibit A Battery System Data Sheet

Christine M.T. Pirik (0029759) (Counsel of Record) William V. Vorys (0093479) Dickinson Wright PLLC 150 East Gay Street, Suite 2400 Columbus, Ohio 43215 Phone: (614) 591-5461 Email: <u>cpirik@dickinsonwright.com</u> wvorys@dickinsonwright.com

Attorneys for Hardin Solar Energy II LLC

LG Chem Gen 3 Cell/Module/Rack Data Sheet Package

2016.02.26

<u>Rev</u>	<u>Date</u>	Writer	<u>Updates</u>
AA	2015.08.06	Yongjun Hong	First Draft
AB	2015.09.10	Yongjun Hong	Rack Size Modification
AC	2015.09.14	Yongjun Hong	Typo Correction
AD	2015.10.20	Yongjun Hong	Picture Correction
AE	2015.11.03	Yongjun Hong	Dimension Correction
AF	2015.11.27	Yongjun Hong	JP3 Module Spec Correction
AG	2015.12.03	Yongjun Hong	Rack Width Correction
AH	2015.12.24	Injung Kim	JP3 Cell and Module Capacity
			Modification
AI	2016.01.25	Luke Kim	BPU info. Added
AJ	2016.02.26	Luke Kim	Module/Rack Dimension
			revised

1. Battery System Overview

Main Compor	Main Components				
Component	Appearance	Cell Model	Description	Energy	
		JH3	Energy-centric cell (63Ah)	233 Wh	
Cell		JP3	Power-centric cell (63.9Ah)	234.5 Wh	
			14S1P configuration	3.26 kWh	
		JH3	14S2P configuration	6.52 kWh	
Module			14S3P configuration	9.79 kWh	
		102	14S1P configuration	3.28 kWh	
		JP3	14S2P configuration	6.56kWh	
		JH3 – R800	800VDC Rack with JH3 14S2P Module	91.2 kWh	
			800VDC Rack with JH3 14S3P Module	137.0 kWh	
		JH3 – R1000	1000VDC Rack with JH3 14S2P Module	55.4 kWh	
			1000VDC Rack with JH3 14S2P Module	110.8 kWh	
Rack			1000VDC Rack with JH3 14S3P Module	166.4 kWh	
		102 0000	800VDC Rack with JP3 14S1P Module	45.9 kWh	
		JP3 – R800	800VDC Rack with JP3 14S2P Module	91.9 kWh	
	a c	JP3 – R1000	1000VDC Rack with JP3 14S1P Module	55.8 kWh	
			1000VDC Rack with JP3 14S2P Module	111.6 kWh	
BPU		P160DF1	UL Complaint DC Protection Fuse/Contactor	-	

1.1. Battery Cell



Cell Features

JH3	JP3
-Long Cycle Life	- Long Cycle Life and High Power
-Safety Reinforced Separator	- Safety Reinforced Separator
-High Energy density	- High power performance
-Low Self-discharge rate	- Low Self-discharge rate
-Wide Temperature Range	- Wide Temperature Range

Nominal Specifications: Typical values at 25°C

	JH3	JP3
Nominal Capacity (Ah)	63.0Ah (0.3C)	63.9Ah (1C)
Nominal Voltage (3.0 ~ 4.2 V, Discharge)	3.70 V (0.3C)	3.67 V (1C)
Energy Density	198 Wh/kg	202 Wh/kg
Power Density (at 50% SOC, 10 sec.)	TBD	TBD
Voltage Range	3.0 ~ 4.2 V	3.0-4.25V
Temperature Range	-30 ~ 60 °C	-30 ~ 60 °C
Weight	approx. 1175 g	approx. 1160 g
Volume	approx. 565 mL	approx. 569 mL
Ready for Shipment	'16.1Q	'16.3Q

2. Battery Module

LG Chem's Battery modules are offered in two options, namely product for Energy oriented application (JH3) and Power oriented application (JP3).

Battery Module – JH3_14S3P & 14S2P & 14S1P					
Appearance	Appearance				
Module Type	JH3_14S3P (M48189P3B)	JH3_14S2P (M48126P3B)	JH3_14S1P (M4863P3B)		
Image					
Module Features	5				
Built in BMS for s Flexible power ar Easy to integrate Efficient dimensio	Built in BMS for self-diagnostic and balancing Flexible power and energy ratio Easy to integrate(19" standard rack compatible) Efficient dimension to maximize Energy density				
Nominal Charact	eristics				
Voltage Range	42~ 58.8 V	42~ 58.8 V	42~ 58.8 V		
Capacity (0.3C)	189 Ah	126 Ah	63 Ah		
Energy (0.3C)	9.79 KWh	6.52 KWh	3.26 KWh		
Maximum Power Rate	0.5CP	1.0CP	1.0CP		
Physical Charact	eristics				
Width	W/O MTG: 445 mm W MTG: 483mm	W/O MTG: 445 mm W MTG: 483mm	W/O MTG: 445 mm W MTG: 483mm		
Depth	846.4 mm	586.6mm	338.8mm		
Height	110 mm (2.5U)	110 mm (2.5U)	110 mm (2.5U)		
Weight	68.0 kg	46.5 kg	25.0 kg		
Cell Configuration	14S3P	14S2P	14S1P		
Control and Prot	ection				
Module BMS	Integrated	Integrated	Integrated		
Cooling	Air-Cooled Air-Cooled Air-Cooled				
Ready for Shipm	ent				
Ready for Shipment	'16.1Q				

2.1. Battery Module with JH3 Cell for Energy Application

2.2. Battery Module with JP3 Cell for Power Application

Battery Module – JP3_2P & JP3_1P				
Appearance	Appearance			
Module Type	JP3_2P	JP3_1P		
inoune i jpe	(M48128P6B)	(M4864P6B)		
Image				
Module Features				
Built in BMS for self-diagnostic and balancing Flexible power and energy ratio Easy to integrate(19" standard rack compatible) Efficient dimension to maximize performance for power application				
Nominal Characteri	stics			
Voltage Range	42~ 59.5 V	42~ 59.5 V		
Capacity (1C)	127.8 Ah	63.9 Ah		
Energy (1C)	6.56 kWh	3.28 kWh		
Maximum Power Rate	2.0CP 2.0CP			
	Physical Characterist	tics		
Width	W/O MTG: 445 mm W MTG: 483mm	W/O MTG: 445 mm W MTG: 483mm		
Depth	586.6mm	338.8 mm		
Height	110 mm (2.5U)	110 mm (2.5U)		
Weight	46.1 kg	24.8 kg		
Cell Configuration	14S2P	14S1P		
Control and Protect	tion			
Module BMS	Integrated	Integrated		
Cooling	Air-Cooled	Air-Cooled		
Ready for Shipment	t			
Ready for Shipment	'16.3Q			

3. Battery Rack

LG Chem's Battery Rack systems are offered in two options, namely product for Energy oriented application (JH3) and Power oriented application (JP3).

Rack Type		R1000 – JH3		R800	– JH3
Type of Module	14S3P	14S2P	14S1P	14S3P	14S2P
Number of					
Modules per rack		17		14	
[EA]					
DC Voltage		714 000 6 588 833 3			873.7
Range[VDC]		714-555.0		566-	023.2
Size	520 x 930	520 x 670	520 x 425	520 x 945	520 x 670
[W x D x H, mm]	x 2200	x 2200	x 2200	x 2000	x 2000
Weight [kg]	1300	920	540	TBD	TBD
Total Rack Energy	166.4	110.8	55 /	137.0	01.2
[kWh]	100.4	110.8	55.4	137.0	51.2
Rack	220520	220520	220010	106520	106520
Configuration	23035P	230328	23031P	190226	19032P
Cooling			Air Cooling		

3.1. Battery Rack with JH3 Modules for Energy Application

BPU can be positioned at the bottom or at the top of the rack depending on the interface with the main DC bus.



Rack Type	R1000 – JP3		R800 – JP3	
Type of Module	14S2P	14S1P	14S2P	14S1P
Number of				
Modules per rack	17		14	
[EA]				
DC Voltage	714-0	9996	588-873 2	
Range[VDC]	/ 14-5		500-025.2	
Size	520 x 670	520 x 425	520 x 670	520 x 425
[W x D x H, mm]	x 2200	x 2200	x 2000	x 2000
Weight [kg]	920	540	TBD	TBD
Total Rack Energy [kWh]	111.7	55.8	91.9	45.9
Rack Configuration	238S2P	238S1P	196S2P	196S1P
Cooling	Air Cooling			

3.2. Battery Rack with JP3 Modules for Power Application

Battery Protection Unit (BPU) can be positioned at the bottom or at the top of the rack depending on the interface with the main DC bus.



4. Battery Protection Unit (BPU)

Battery Protection Unit is designed to protect Battery System during operation

Battery Protection Unit (BPU)

- Product Name : ESS BPU

- Model Name : P160DF1

4.1. ELECTRICAL SPECIPICATION

MODEL		P160DF1
Main DC	Voltage	1,000V DC
	Current (Rated)	160A
	Voltage Range	24VDC
Aux power	Input Current	113W
Ins	ulation resistance	100 M2 (1,000Vdc)

4.2. MECHANICAL SPECIPICATION

Housing	Material	SGCC(2.0T)	
Dimension	(W x D x H)	438 x 282 x 126 (mm)	
Unit W	/eight	10.2kg	
Indicator	Status	Green On (Normal), Yellow On (Warning), Red On (Fault)	
Cooling	System	FAN	
Main DC1	Ferminal	M10 SEMS BOLT / 10.2 (N.m)	
Control	Power	M3 SCREW / 1.0 (N.m)	3
E-STOP Inpu	t Terminal	MSTB 2.5/2-STF-5.08 Connector (PHOENIX)	
Main DC Wire		1/0 AWG	

4.3. PROTECTION^(*)

Over/Under Voltage	If the sensing value exceed or falls below a specified CB Shunt Trip by BMS
OverCurrent	If the sensing value exceed or falls below a specified CB Shunt Trip by BMS
over current	in the sensing value exceed of rails below a specifical ob shart http by birds
Over Temperature	If the sensing value exceed or falls below a specified CB Shunt Trip by BMS
Over/Under SOC	If the sensing value exceed or falls below a specified CB Shunt Trip by BMS
Short Circuit	If a short circuit occurs CB Trip by itself
Inrush Current	Pre-charge resistor

(*): Above condition should be defined by request from customers. Please see specification of BMS for more details.

4.4. OPERATING ENVIRONMENT

Storage temperature	-25~70 °C
Operating Temperature Range	-10~40 °C
Recommended Operating Temperature	23±5℃
Operating Humidity	< 95%
Operating Altitude	3,000 METERS
Pollution Degree	2
Warranty	4 Years

4.5. FRONT LAYOUT



DC Power Connection

BATT POS	BATT NEG
TOP = Top Module (+) Connect	BTM = Bottom Module (-) Connect
PCS = Power Conversion System (+) Connect	PCS = Power Conversion System (-) Connect

Auxiliary Power Connection

Input Terminal	FAN Power / BMS Power
+	DC 24V
÷1	

• E-Stop signal Connection

E-Stop Terminal	DC 24V				
2PIN Housing (Phoenix : MSTB 2.5/2-STF-5.08)					

4.6. INTERNAL LAYOUT



4.7. COMPONENTS LIST AND FUNCTION

Component	Part Number	Function
Relay	HE1aN-Q-24V	Fan ON/OFF
Pre-charge Relay	EVR100-24S	Prevents Inrush Current when the contactor to the inverter is closed.
Contactor ⁽¹⁾	EVR400A-24S/G	Switch RackCircuit
Fuse	170M1811	Protect to Over Current by Battery or Grid Power System Protection from battery module failure
Current Sensor	DHAB S 118	Measuring current of Battery Charge/Discharge
Pre-charge Resistor	ULH200 200HM 3500V	Limits Inrush Current when Pre-charge Relay On State
Terminal Block	SL33TA-1P	PCS Connection
	0168-1002	Control power
	2219247-1	
Header	(Positive : RD, "+")	Battery Connection
	1-2219247-2	
	(Negative : BK, "-")	
FAN	9GA0424G6001P	BPU Cooling
Housing	2PIN Housing	Emergency Stop
_	(Phoenix : MSTB 2.5/2-STF-5.08)	

(1): Contactor is located on BPU in the backward direction of battery charging

4.8. SCHEMATIC DIAGRAM



Hardin Solar Energy II LLC Case No. 18-1360-EL-BGN

Exhibit B Module Specifications

- 1) Jinko
- 2) Longi
- 3) FirstSolar
- 4) Trina
- 5) Hanwha Qcells
- 6) JA Solar

Christine M.T. Pirik (0029759) (Counsel of Record) William V. Vorys (0093479) Dickinson Wright PLLC 150 East Gay Street, Suite 2400 Columbus, Ohio 43215 Phone: (614) 591-5461 Email: <u>cpirik@dickinsonwright.com</u> <u>wvorys@dickinsonwright.com</u>

Attorneys for Hardin Solar Energy II LLC



Eagle HC 72M-V 355-375 Watt

MONO CRYSTALLINE MODULE

Positive power tolerance of 0~+3%



KEY FEATURES



Innovative Solar Cells Five busbar mono half cell technology



High Efficiency

Higher module conversion efficiency (up to 19.02%) due to lower resistance characteristics



High Voltage UL and IEC 1500V certified; lowers BOS costs and yields better LCOE



PID-Free



World's 1st PID-Free module



Low-Light Performance Advanced glass technology improves light absorption and retention



Strength and Durability

Certified for high snow (5400 Pa) and wind (2400 Pa) loads

LINEAR PERFORMANCE WARRANTY

10 Year Product Warranty • 25 Year Linear Power Warranty





ISO9001:2008 Quality Standards

- ISO14001:2004 Environmental Standards
- OHSAS18001 Occupational Health & Safety Standards
- IEC61215, IEC61730 certified products

Nomenclature: JKM375M-72H-V







Packaging Configuration

(Two pallets =One stack)

26pcs/pallet , 52pcs/stack, 572 pcs/40'HQ Container

Electrical Performance & Temperature Dependence



Mechanical Characteristics Mono-crystalline 156×156mm (6 inch) Cell Type No.of Half-cells 144 (12×12) Dimensions 1987×992×40mm (78.23×39.05×1.57 inch) Weight 26.5 kg (58.4 lbs) Front Glass 4.0mm, High Transmission, Low Iron, Tempered Glass Anodized Aluminium Alloy Frame Junction Box IP67 Rated **Output Cables** anode 290mm, cathode 145mm

SPECIFICATIONS											
Module Type	JKM355	M-72H-V	JKM360	M-72H-V	JKM365	M-72H-V	JKM370	M-72H-V	JKM375	M-72H-V	
	STC	NOCT	STC	NOCT	STC	NOCT	STC	NOCT	STC	NOCT	
Maximum Power (Pmax)	355Wp	266Wp	360Wp	270Wp	365Wp	274Wp	370Wp	278Wp	375Wp	282Wp	
Maximum Power Voltage (Vmp)	39.5V	37.7V	39.7V	37.9V	39.9V	38.1V	40.1V	38.3V	40.3V	38.5V	
Maximum Power Current (Imp)	8.99A	7.06A	9.07A	7.12A	9.15A	7.19A	9.23A	7.26A	9.31A	7.32A	
Open-circuit Voltage (Voc)	48.1V	46.5V	48.3V	46.8V	48.5V	47.1V	48.7V	47.4V	48.9V	47.7V	
Short-circuit Current (Isc)	9.23A	7.25A	9.33A	7.31A	9.43A	7.37A	9.53A	7.43A	9.63A	7.49A	
Module Efficiency STC (%)	18.0)1%	18.2	26%	18.	52%	18.	77%	19.0	02%	
Operating Temperature(°C)					-40°C~	+85°C					
Maximum system voltage				15	500VDC(UL)	/1500VDC	(IEC)				
Maximum series fuse rating					20	A					
Power tolerance					0~-	⊦3%					
Temperature coefficients of Pmax					-0.37	″%/°C					
Temperature coefficients of Voc					-0.29	9%/°C					
Temperature coefficients of Isc					0.04	8%/°C					
Nominal operating cell temperature	(NOCT)				45:	±2℃					







NOCT: 🔆 Irradiance 800W/m² 🕼 Ambient Temperature 20°C <

Wind Speed 1m/s

* Power measurement tolerance: ± 3%

LR6-72BP 350~370M





Hi-MO2 High Efficiency Low LID Bifacial PERC Technology Best Solution for Lower LCOE



Complete System and Product Certifications

IEC 61215, IEC61730, UL1703

ISO 9001:2008: ISO Quality Management System

ISO 14001: 2004: ISO Environment Management System

TS62941: Guideline for module design qualification and type approval

OHSAS 18001: 2007 Occupational Health and Safety



* Specifications subject to technical changes and tests. LONGi Solar reserves the right of interpretation.

Front side performance equivalent to conventional low LID mono PERC:

- High module conversion efficiency (up to 19%)

- Better energy yield with excellent low irradiance performance and temperature coefficient

- First year power degradation <2%

Bifacial technology enables additional energy harvesting from rear side (up to 25%)

Glass/glass lamination ensures 30 year product lifetime, with annual power degradation < 0.45%, 1500V compatible to reduce BOS cost

40mm frame design enables easy installation and robust mechanical strength

Solid PID resistance ensured by solar cell process optimization and careful module BOM selection



Room 201, Building 8, Sandhill Plaza, Lane 2290, Zuchnongzhi Road, Pudong District, Shanghai, 201203 Tel: + 86-21-61047332 Fax: +86-21-61047377 E-mail: module@longi-silicon.com Facebook: www.facebook.com/LONGi Solar

Note: Due to continuous technical innovation, R&D and improvement, technical data above mentioned may be of modification accordingly. LONGi Solar have the sole right to make such modification at anytime without further notice; Demanding party shall request for the latest datasheet for such as contract need, and make it a consisting and binding part of lawful documentation duly signed by both parties.

LR6-72BP 350~370M

Design (mm)



Mechanical Parameters

Junction Box: IP67, three diodes

Output Cable: 4mm², 300mm in length,

Connector: MC4 or MC4 compatible

Dimension: 1978×997×40mm

Packaging: 26pcs per pallet

Weight: 26.5kg

length can be customized

Cell Orientation: 72 (6×12)

Operating Parameters

Operational Temperature: -40°C ~ +85°C Power Output Tolerance: 0 ~ +5 W Voc and Isc Tolerance: ±3% Maximum System Voltage: DC1500V (IEC, UL) Maximum Series Fuse Rating: 15A Nominal Operating Cell Temperature: 45±2°C Application Class: Class II Bifaciality: ≥75%

Electrical Characteristics

Model Number	LR6-72BP-350M		LR6-72BP-355M		LR6-72BP-360M		LR6-72BP-365M		LR6-72BP-370M	
Testing Condition	Front	Back								
Maximum Power (Pmax/W)	350	263	355	267	360	271	365	274	370	278
Open Circuit Voltage (Voc/V)	47.2	46.8	47.4	47.0	47.6	47.2	47.8	47.4	47.9	47.5
Short Circuit Current (Isc/A)	9.39	7.19	9.48	7.26	9.58	7.34	9.66	7.40	9.77	7.49
Voltage at Maximum Power (Vmp/V)	39.2	40.2	39.4	40.4	39.5	40.5	39.7	40.7	39.8	40.8
Current at Maximum Power (Imp/A)	8.93	6.54	9.02	6.62	9.11	6.69	9.19	6.73	9.30	6.82
Module Efficiency(%)	17.8	13.3	18.0	13.5	18.3	13.7	18.5	13.9	18.8	14.1
STC (Standard Testing Conditions): Irradiance 1000W/m ² , Cell Temperature 25 [°] C , Spectra at AM1.5										

Electrical characteristics with different rear side power gain (reference to 360W front)

Pmax /W	Voc/V	Isc /A	Vmp/V	Imp /A	Pmax gain
378	47.6	9.98	39.5	9.57	5%
396	47.6	10.45	39.5	10.03	10%
432	47.7	11.39	39.4	10.97	20%
450	47.7	11.87	39.4	11.43	25%

Temperature Ratings (STC)		Mechanical Loading	
Temperature Coefficient of Isc	+0.060%/ °C	Front Side Maximum Static Loading	5400Pa
Temperature Coefficient of Voc	-0.300%/°C	Rear Side Maximum Static Loading	2400Pa
Temperature Coefficient of Pmax	-0.380%/°C	Hailstone Test	25mm Hailstone at the speed of 23m/s

I-V Curve



Power-Voltage Curve (LR6-72BP-360M)



Current-Voltage Curve (LR6-72BP-360M)



LONGI Solar

Room 201, Building 8, Sandhill Plaza, Lane 2290, Zuchnongzhi Road, Pudong District, Shanghai, 201203 Tel: + 86-21-61047332 Fax: +86-21-61047377 E-mail: module@longi-silicon.com Facebook: www.facebook.com/LONGi Solar

Note: Due to continuous technical innovation, R&D and improvement, technical data above mentioned may be of modification accordingly. LONGi Solar have the sole right to make such modification at anytime without further notice; Demanding party shall request for the latest datasheet for such as contract need, and make it a consisting and binding part of lawful documentation duly signed by both parties.



First Solar Series 6[™] ADVANCED THIN FILM SOLAR TECHNOLOGY



INDUSTRY BENCHMARK SOLAR MODULES

As a global leader in PV energy, First Solar's advanced thin film solar modules have set the industry benchmark with over 17 gigawatts (GW) installed worldwide and a proven performance advantage over conventional crystalline silicon solar modules. Generating more energy than competing modules with the same power rating, First Solar's Series 6[™] and Series 6A[™] PV Modules deliver superior performance and reliability to our customers. First Solar's Series 6™ and Series 6A™ PV Modules provide faster installation times and lower installed costs with a form factor similar to crystalline silicon modules.



PROVEN ENERGY YIELD ADVANTAGE

- More energy than conventional c-Si with the same power in hot, humid climates
- Anti-reflective coated glass (Series 6A™) • enhances energy production
- Visit <u>PlantPredict.com</u> The only Energy Prediction Software designed for Utility Scale PV

Superior Temperature Coefficient



Superior Spectral Response



REDUCED INSTALLATION COSTS

- Easily adapts to 3rd party structures
- Single frame type for Fixed Tilt and Tracker
- More watts per connection than 72-cell multicrystalline modules



V

ADVANCED PERFORMANCE & RELIABILITY

- Independently certified for reliable performance in high temperature, high humidity, extreme desert and coastal environments based on accelerated life and stress tests
- Recycling services available through First Solar's industry-leading recycling program or customer-selected third party

MODULE WARRANTY¹



- 25-Year Linear Performance Warranty²
- **10-Year Limited Product Warranty**

First Solar, Inc. | firstsolar.com | info@firstsolar.com

FIRST SOLAR SERIES 6[™]

MECHANICAL DESC	RIPTION	MODEL TYPES AND RATINGS AT S	TANDARD TEST	NDARD TEST CONDITIONS (1000W/m², AM 1.5, 25°C)3						
Length	2009 mm	NOMINAL VALUES		FS-6420	FS-6425	FS-6430	FS-6435	FS-6440	FS-6445	
Width	1232 mm			FS-6420A	FS-6425A	FS-6430A	FS-6435A	FS-6440A	FS-6445A	
Laminate	5.4 mm	Nominal Power ⁴ (-0/+5%)	P _{MPP} (W)	420.0	425.0	430.0	435.0	440.0	445.0	
Thickness	5.4 mm	Efficiency (%)	%	17.0	17.2	17.4	17.6	17.8	18.0	
Area	2.47 m ²	Voltage at P _{MAX}	V _{MPP} (V)	178.5	179.4	180.3	181.2	182.0	182.8	
Module Weight	35 kg	Current at P _{MAX}	I _{MPP} (A)	2.35	2.37	2.38	2.40	2.42	2.43	
Leadwire ⁵	2.5 mm ² , 51.5 cm (+) &	Open Circuit Voltage	V _{OC} (V)	214.6	215.0	215.3	215.7	216.1	216.5	
	Bulkhead (-)	Short Circuit Current	I _{SC} (A)	2.62	2.63	2.63	2.64	2.65	2.65	
Connectors	TBD	Maximum System Voltage	V _{SYS} (V)			150	00 ⁶			
Bypass Diode	None	Limiting Reverse Current I _R (A) 6.0								
Cell Type	Thin-film CdTe semiconductor.	Maximum Series Fuse	I _{CF} (A)		6.0					
	up to 260 cells	RATINGS AT NOMINAL OPERATING	CELL TEMPER	ATURE OF 45°C (A	DF 45°C (800W/m², 20°C air temperature, AM 1.5, 1m/s wind speed) ³					
Frame Material	Anodized Aluminum	Nominal Power	P _{MPP} (W)	317.1	320.9	324.7	328.4	332.3	336.1	
Front Glass	2.8 mm heat	Voltage at P _{MAX}	V _{MPP} (V)	166.9	168.0	169.1	169.3	170.4	171.5	
	strengthened	Current at P _{MAX}	I _{MPP} (A)	1.90	1.91	1.92	1.94	1.95	1.96	
	Series 6A™ includes	Open Circuit Voltage	V _{oc} (V)	202.6	203.0	203.3	203.7	204.0	204.4	
	anti-reflective coating	Short Circuit Current	I _{SC} (A)	2.12	2.12	2.12	2.13	2.13	2.14	
Back Glass	strengthened	TEMPERATURE CHARACTERISTICS								
Encapsulation	Laminate	Module Operating Temperat	ure Range	(°C)			-40 to +85			
	material with edge seal	Temperature Coefficient of I	P	T _K (P _{MPP})	-0.2	8%/K [Temper	ature Range: 29	8.15 K to 348.1	L5 K]	
Frame to Glass Adhesive	Silicone	Temperature Coefficient of	V _{oc}	T _κ (V _{oc})	-0.28%/K					
Wind Load ⁷	2400 Pa	Temperature Coefficient of I	sc	$T_{\kappa}(I_{sc})$			+0.04%/K			
Snow Load ⁷	5400 Pa									

MECHANICAL DRAWING



PACKAGING INFORMATION	
Modules Per Pallet	26
Pallet Weight	1025 kg
Pallet Dimensions (L x W x H)	2200 x 1300 x 1150 mm (86 x 51 x 45 in)
Pallets per 40' Container	18

CERTIFICATIONS AND TESTS ⁸					
	61215 & 61730 1500V, CE 61701 Salt Mist Corrosion 60068-2-68 Dust and Sand Resistance				
UL c UL LISTED	UL 1703 1500V Listed ⁶ UL Construction and Fire Performance PV Module Type [TBD]				
Regional Certifications	CSI Eligible FSEC MCS CEC Australia	JET SII InMetro			
Extended Durability Tests	PID Resistant Long-Term Thresher Test ATLAS 25				
Quality	ISO 9001:2008 & 14001:2004				

Install in portrait only

- 1
 Limited power output and product warranties subject to warrant terms and conditions.

 2
 Ensures 98% rated power in first year, -0.5%/year through year 25.
- 3 All ratings ±10%, unless specified otherwise. Specifications are subject to change.
- 4 Measurement uncertainty applies.
- Minimum leadwire length from junction box exit to connector mating surface. 6 IEC 61730-1: 2016 Class II | ULC 1703 1000V listed
- 7 See User Guide
- 8 Testing Certifications/Listings pending.

Disclaimer The information included in this Module Datasheet is subject to change without notice and is provided for informational purposes only. No contractual rights are established or should be inferred because of user's reliance on the information contained in this Module Datasheet. Please refer to the appropriate Module User Guide and Module Product Specification document for more detailed technical information regarding module performance, installation and use.

The First Solar logo, First SolarTM, and all products denoted with * are registered trademarks, and those denoted with a TM are trademarks of First Solar, Inc.

THE

FRAMED 72-CELL MODULE (1500V)

72 CELL MONOCRYSTALLINE MODULE

335-365W POWER OUTPUT RANGE

18.8% MAXIMUM EFFICIENCY

0~+5W POSITIVE POWER TOLERANCE

Founded in 1997, Trina Solar is the world's leading comprehensive solutions provider for solar energy. we believe close cooperation with our partners is critical to success. Trina Solar now distributes its PV products to over 60 countries all over the world. Trina is able to provide exceptional service to each customer in each market and supplement our innovative, reliable products with the backing of Trina as a strong, bankable partner. We are committed to building strategic, mutually beneficial collaboration with installers, developers, distributors and other partners.

Comprehensive Products And System Certificates

IEC61215/IEC61730/UL1703/IEC61701/IEC62716 ISO 9001: Quality Management System ISO 14001: Environmental Management System ISO14064: Greenhouse gases Emissions Verification OHSAS 18001: Occupation Health and Safety

Management System







Ideal for large scale installations

• Reduce BOS cost by connecting more modules in a string

• 1500V UL/1500V IEC certified



Maximize limited space with top-end efficiency

- Up to 188 W/m² power density
- Low thermal coefficients for greater energy production at high operating temperatures



Highly reliable due to stringent quality control

- Over 30 in-house tests (UV, TC, HF, and many more)
- In-house testing goes well beyond certification requirements
- 100% EL double inspection
- PID Resistant



Certified to withstand the most challenging environmental conditions

- 2400 Pa wind load
- 5400 Pa snow load
- 35 mm hail stones at 97 km/h









I-V CURVES OF PV MODULE(365W)



P-V CURVES OF PV MODULE(365W)





ELECTRICAL DATA (STC)

Peak Power Watts-P _{MAX} (Wp)*	335	340	345	350	355	360	365		
Power Output Tolerance-P _{MAX} (W)	0~+5								
Maximum Power Voltage-V _{MPP} (V)	37.9	38.2	38.4	38.5	38.7	38.9	39.1		
Maximum Power Current-IMPP (A)	8.84	8.90	9.00	9.09	9.17	9.26	9.35		
Open Circuit Voltage-Voc (V)	46.3	46.5	46.7	46.9	47.0	47.2	47.3		
Short Circuit Current-Isc (A)	9.36	9.45	9.50	9.60	9.69	9.79	9.88		
Module Efficiency ኩ (%)	17.3	17.5	17.8	18.0	18.3	18.5	18.8		

STC: Irradiance 1000W/m², Cell Temperature 25°C, Air Mass AM1.5. *Measuring tolerance: ±3%.

ELECTRICAL DATA (NOCT)

Maximum Power-PMAX (Wp)	250	253	257	261	264	268	272
Maximum Power Voltage-V _{MPP} (V)	35.1	35.2	35.5	35.6	35.8	35.9	36.1
Maximum Power Current-I _{MPP} (A)	7.12	7.19	7.25	7.33	7.40	7.47	7.54
Open Circuit Voltage-Voc (V)	43.1	43.2	43.4	43.5	43.7	43.8	43.9
Short Circuit Current-Isc (A)	7.56	7.63	7.67	7.75	7.82	7.88	7.95

NOCT: Irradiance at 800W/m², Ambient Temperature 20°C, Wind Speed 1m/s.

MECHANICAL DATA

Solar Cells	Monocrystalline 156.75 × 156.75 mm (6 inches)
Cell Orientation	72 cells (6 × 12)
Module Dimensions	1956 × 992 × 40 mm (77.0 × 39.1 × 1.57 inches)
Weight	26.0 kg (57.3 lb) with 4.0 mm glass
Glass	4.0 mm (0.16 inches) High Transmission, AR Coated Tempered Glass
Backsheet	White
Frame	Silver Anodized Aluminium Alloy
J-Box	IP 67 or IP 68 rated
Cables	Photovoltaic Technology Cable 4.0mm ² (0.006 inches ²),
	1200 mm (47.2 inches)
Connector	MC4 or Amphenol H4/UTX (1500V)
Fire Type	Type 1 or Type 2

TEMPERATURE RATINGS	
NOCT (Nominal Operating Cell Temperature)	44°C (±2°C)
Temperature Coefficient of PMAX	- 0.39%/°C
Temperature Coefficient of Voc	- 0.29%/°C
Temperature Coefficient of Isc	0.05%/°C

WARRANTY

- 10 year Product Workmanship Warranty
- 25 year Linear Power Warranty

(Please refer to product warranty for details)

MAXIMUM RATINGS

Operational Temperature	-40∼+85°C
Maximum System Voltage	1500V DC (IEC)
	1500V DC (UL)
Max Series Fuse Rating	15A
(DO NOT connect Fuse in Combiner Box v parallel connection)	vith two or more strings in

PACKAGING CONFIGURATION

- Modules per box: 27 pieces
- Modules per 40' container: 648 pieces

CAUTION: READ SAFETY AND INSTALLATION INSTRUCTIONS BEFORE USING THE PRODUCT. © 2017 Trina Solar Limited. All rights reserved. Specifications included in this datasheet are subject to change without notice.

Version number: TSM_EN_2017_A www.trinasolar.com

FRAMED 72-CELL MODULE (1500V)



Q.PEAK DUO L\G5.2 380-395

Q.ANTUM SOLAR MODULE

The new high-performance module Q.PEAK DUO L-G5.2 Is the ideal solution for commercial and utility applications thanks to a combination of its Innovative cell technology Q.ANTUM and cutting edge cell interconnection. This 1500V IEC/UL solar module with its 6 busbar cell design ensures superior yields with up to 395 Wp while having a very low LCOE.



Higher yield per surface area, lower BOS costs, higher power classes, and an efficiency rate of up to 19.9%.

2

INNOVATIVE ALL-WEATHER TECHNOLOGY

Optimal yields, whatever the weather with excellent low-light and temperature behavior.



ENDURING HIGH PERFORMANCE

Long-term yield security with Anti LID Technology, Anti PID Technology¹, Hot-Spot Protect and Traceable Quality Tra.Q[™].



EXTREME WEATHER RATING

High-tech aluminum alloy frame, certified for high snow (5400 Pa) and wind loads (2400 Pa).



A RELIABLE INVESTMENT

Inclusive 12-year product warranty and 25-year linear performance warranty².







Coccus Coccus Intel polycrystatiline solar module 2014 sono-so 205

- ¹ APT test conditions according to IEC/TS 62804-1:2015,
- method B (-1500V, 168h)
- ² See data sheet on rear for further
 - information.



THE IDEAL SOLUTION FOR:





Engineered in Germany

MECHANICAL SPECIFICATION

Format	2015 mm × 1000 mm × 35 mm (including frame)	_		100100	14
Weight	23.5 kg			130fam	
Front Cover	3.2 mm thermally pre-stressed glass with anti-reflection technology	11	A - December Solar (1.5 res)	1.3000101.00	
Back Cover	Composite film		4 - Ranting side getan Sacker (STSUL 8)	0	
Frame	Anodised aluminium				
Cell	6 x 24 monocrystalline Q.ANTUM solar half cells			0	1000-
Junction	70-85 mm × 50-70 mm × 13-21 mm Protection class IP67, with bypass diodes			a the	
Cable	4mm ² Solar cable; (+) ≥ 1350mm, (-) ≥ 1350mm		4 - Burling side (SPIML B)	No. and the lot of	
Connector	Multi-Contact MC4-EV02, JMTHY PV-JM601A, IP68 or Renhe 05-6, IP67	-		- ²⁰¹	┉╅┶╴╵

ELECTRICAL CHARACTERISTICS

PO	WER CLASS			390	385	390	395
MI	NIMUM PERFORMANCE AT STANDARD	TEST CONDITIONS, ST	C ¹ (POWER TOLEI	RANCE +5W/-OW)			
	Power at MPP	PMP	[W]	380	385	390	395
	Shore Circuit Current ¹	l _{sc}	[A]	10.05	10.10	10.14	10.19
	Open Circuit Voltage ¹	Vac	[V]	47.95	48.21	48.48	48.74
i.	Current at MPP	Inter	[A]	9.57	9.61	9.66	9.70
-	Voltage at MPP	Vare	[V]	39.71	40.05	40.38	40.71
	Efficiency ¹	ŋ	[%]	≥18.9	≥19.1	≥19.4	>19.6
MI	NIMUM PERFORMANCE AT NORMAL OF	ERATING CONDITIONS,	NMOT ²				
	Power at MPP	Pare	[W]	283.9	287.6	291.3	295.1
E	Short Circuit Current	Isc	IAI	8.10	8.14	8.17	8.21
i.	Open Circuit Voltage	Vac	[V]	45.12	45.37	45.62	45.87
ž	Current at MPP	INTE	[A]	7.53	7.57	7.60	7.64
	Voltage at MPP	Varr	[V]	37.69	38.01	38.33	38.64

Weasurement tolerances Pare 4 3%; In: Viz: 45% at STC: 1000W/m², 25+2*C, AM 1.5C according to IEC 60904-3 - 7800 W/m², NMOT, spectrum AM 1.5G

Q CELLS PERFORMANCE WARRANTY



At least 98% of nominal power during first year. Thereafter max. 0.54% degradation per year. At least 93.1 % of nominal power up to 10 years. At least 85% of nominal power up to 25 years.

All data within measurement tolerances. Full warranties in accordance with the warranty terms of the Q CELLS sales organization of your respective country.



PERFORMANCE AT LOW IRRADIANCE

Typical module performance under low irradiance conditions in comparison to STC conditions (25 °C, 1000W/m²).

TEMPERATURE COEFFICIENTS							
Temperature Coefficient of Ist	α	[%/K]	+0.04	Temperature Coefficient of Vac	β	[%/K]	-0.2
Temperature Coefficient of Pare	Y	[%/K]	-0.37	Normal Module Operating Temperature	NMOT	["C]	43±
PROPERTIES FOR SYSTEM	DESIGN						
Maximum System Voltage	Vsrs	[V]	1500 (IEC) / 1500 (UL)	Safety Class			
Maximum Reverse Current	la la	[A]	20	Fire Rating			C / TYPE
Max. Design Load, Push / Pull		[Pa]	3600/1600	Permitted Module Temperature		-40°C u	p to +85 %
Max. Test Load, Push / Pull		[Pa]	5400/2400	on Continuous Duty			
QUALIFICATIONS AND CERT	TIFICATE	s	P	ARTNER			
IEC 61215:2016, IEC 61730:2016, A This data sheet complies with DIN EN	oplication of 50380.	lass A					
02201	-						
A CC	GD						
(D'E) (E	· · · · ·	.8					
	084041)						

CE 🔮 DE

NOTE: Installation instructions must be followed. See the installation and operating manual or contact our technical service department for further information on approved installation and use of this product.

Hanwha & CELLS GmbH

Sonnenellee 17-21, 06766 Bitterfeld-Wolfen, Germany I TEL +49 (0)3494 66 99-23444 I FAX +49 (0)3494 66 99-23000 I EMAIL sales@q-cells.com I WEE www.q-cells.com



1

ų -9 5

Ster H





375 Mono PERC Half-Cell



Harvest the Sunshine Premium Cells, Premium Modules

JASOLAR

MECHANICAL DIAGRAMS





SPECIFICATIONS Mono 156.75x78.38mm Cell 23kg±3% Weight 2000×991×40mm Dimensions 4mm² Cable Cross Section Size 144 (12×12) No. of cells Junction Box IP67, 3 diodes MC4 Compatible (1000V) Connector PV-ZH202B (1500V) 27 Per Pallet Packaging Configuration

OPERATING CONDITIONS

Maximum System Voltage	1000V/1500V DC (IEC)
Operating Temperature	-40°C~+85
Maximum Series Fuse	20A
Maximum Static Load, Front Maximum Static Load, Back	5400Pa 2400Pa
NOCT	45±2℃
Application Class	Class A

ELECTRICAL PARAMETERS AT STC

TYPE	JAM72S03 -355/PR	JAM72S03 -360/PR	JAM72S03 -365/PR	JAM72S03 -370/PR	JAM72S03 -375/PR
Rated Maximum Power (Pmax) [W]	355	360	365	370	375
Open Circuit Voltage (Voc) [V]	46.75	46.98	47.30	47.56	47.78
Maximum Power Voltage (Vmp) [V]	38.35	38.73	39.05	39.36	39.58
Short Circuit Current (Isc) [A]	9.82	9.87	9.92	9.97	10.03
Maximum Power Current (Imp) [A]	9.26	9.30	9.35	9.41	9.48
Module Efficiency [%]	17.91	18.16	18.42	18.67	18.92
Power Tolerance			-0~+5W		
Temperature Coefficient of Isc (a_lsc)			+0.051%/ [°] C		
Temperature Coefficient of Voc (β _Voc))		-0.289%/°C		
Temperature Coefficient of Pmax (y_Pn	np)		-0.370%/°C		
STC	Irradia	ance 1000W/m ²	, cell temperat	ure 25°C, AM	1.5G

ELECTRICAL PARAMETERS AT NOCT

TYPE	JAM72S03 -355/PR	JAM72S03 -360/PR	JAM72S03 -365/PR	JAM72S03 -370/PR	JAM72S03 -375/PR
Max Power (Pmax) [W]	263	266	270	274	278
Open Circuit Voltage (Voc) [V]	43.25	43.48	43.80	44.06	44.28
Maximum Power Voltage (Vmp) [V]	35.46	35.81	36.11	36.37	36.59
Short Circuit Current (Isc) [A]	7.86	7.90	7.94	7.98	8.02
Maximum Power Current (Imp) [A]	7.41	7.44	7.48	7.53	7.58
NOCT	Irradia	ince 800W/m wind spe	², ambient ter ed 1m/s, AM ²	nperature 20 1.5G	°C,







Electrical data in this catalog do not refer to a single module and they are not part of the offer. They only serve for comparison among different module types.

Exhibit C Tracking Specifications

- 1) Soltec
- 2) ATI
- 3) NEXTracker SPT

Christine M.T. Pirik (0029759) (Counsel of Record) William V. Vorys (0093479) Dickinson Wright PLLC 150 East Gay Street, Suite 2400 Columbus, Ohio 43215 Phone: (614) 591-5461 Email: <u>cpirik@dickinsonwright.com</u> <u>wvorys@dickinsonwright.com</u>

Attorneys for Hardin Solar Energy II LLC

SF UTILITY SOLAR TRACKER

COST EFFECTIVENESS

A cost-effective installation is assured beginning with the lowest piles-per-MW spec on the market combined with the widest range of installation and assembly tolerances that reduce all aspects of civil works, installation labor, and machine costs.

> HIGHER YIELD

Higher yield is enabled by less array-gap on the tracker and less site-gaps on the ground, along with the widest tracking range of 120°+ and TeamTrack asymmetric backtracking control.

> GREATER LAND-USE OPTIONS

SF Utility provides greater land-use options that enable greater site-fill even on irregular land, and reduced civil works that minimize costs and environmental impact issues including earth grading and emissions of carbon dioxide. Moreover, SF Utility standard steep-slope tolerance of 17% NS and short-track configuration makes for simple installation where others simply cannot install without special cost.

> FACTORY SERVICED

SF Utility is Factory Serviced with dedicated customer project support in plant design and factory response, and onsite services including tutelage, supervision, logistics, training, commissioning, and regionally available installation and O&M contracting.

Soltec

SFUTILITY SOLAR TRACKER

Technical Datasheet

MAIN	FEATURES	
Trackir	ng System	Horizontal Single-Axis with independent rows
Trackir	ng Range	120° +
Drive S	System	Enclosed Slewing Drive, DC Motor
Power	Supply	AC/DC Universal Input
		Self-Powered with Battery Backup
Trackir	ng Algorithm	Astronomical with Adaptive Backtracking
Comm	unication	
	Wire	RS485 Cable between Trackers and Gateway
	Wireless	Wireless Mesh Network
Wind F	Resistance	Per Local Codes
Land U	lse Features	
	Independent Rows	YES
	Slope North-South	17%
	Slope East-West	Unlimited
	Ground Coverage Rat	io Configurable. Typical range: 28-50%
Found	ation	Driven Pile Ground Screw Concrete
Tempe	erature Range	
	Standard	- 4°F to +131°F -20°C to +55°C
	Extended	-40°F to +131°F -40°C to +55°C
Availat	oility	>99%
Tracke	r Installation Service	YES
Module	es T	Standard: 72 cells Optional: 60 Cells; Crystalline, nin Film (Solar Frontier, First Solar and others): Bifacial

TYPICAL MODULE CONFIGURATIONS

1000V			
	Length	Height	Width
2x38	127' 7" (38.9 m)	12' 10''	12' 10"
2x40	123' 4' (37.6 m)	(3.9 m)	(3.9 m)

1500V					
		Length	Height	Width	
	2x42	141' (43 m)			
	2x43.5	146' 2" (44.8 m)	12' 10" (3.9 m)	12' 10" (3.9 m)	
	2x45	150' 7" (45.9 m)			

MAINTENANCE		
Self-lubricating Bearings	YES	
Face to Face Cleaning Mode	YES	
Maintenance Service	YES	

WARRANTY	
Structure	10 years (extendable)
Motor	5 years (extendable)
Electronics	5 years (extendable)





UNITED STATES 5800 Las Positas Rd. Livermore, CA 94551 usa@soltec.com +1 510 440 9200

> **SPAIN** info@soltec.com +34 968 603 153

BRAZIL brasil@soltec.com +55 71 3026 1444

CHILE chile@soltec.com +56 (02) 25738559

CHINA china@soltec.com +86 15021713965

MEXICO mexico@soltec.com +52 1 55 5557 3144

> PERU peru@soltec.com +51 53 50 7315

> INDIA india@soltec.com +91 124 4568202

SCANDINAVIA scandinavia@soltec.com +45 70 43 01 50

DNV GL Technology Review available Bankability report WIND TUNNEL TESTED





DuraTrack®HZ v3



A (r)evolutionary design that builds on the DuraTrack heritage while adding innovative features engineered to deliver the best LCOE in the industry.

THE (R)EVOLUTION IN TRACKER DESIGN IS HERE.

DuraTrack HZ v3 is not just an evolution of our innovative single-axis horizontal solar tracker, it incorporates revolutionary features found nowhere else in the industry.

Array Technologies Inc.

- 3901 Midway Place NE Albuquerque, NM 87109 USA
- +1 505.881.7567 +1 855.TRACKPV (872.2578)
- **()** +1 505.881.7572
- sales@arraytechinc.com
- arraytechinc.com

HIGHEST POWER DENSITY

In fact, 6% more than our closest competitor. Increase capacity on a reduced footprint, or add to production by cutting down on backtracking.

GREATEST RELIABILITY

Reducing the number of sensitive components has resulted in the highest operational uptime in the industry. An improved driveline design allows for fewer motors—less than two per megawatt. No stow required—a failure-free wind relief management feature takes care of that.

ULTRA-EFFICIENT INSTALLATION

One single-fastener clamp per module streamlines the most labor-intensive step. Per megawatt, this equals 15,000 fewer fasteners than competitive systems, adding up to big savings.

ZERO MAINTENANCE

Gearboxes are sealed and lubricated for life resulting in zero scheduled maintenance. All tracker rows self-calibrate twice daily ensuring that each row is always at the optimal tracking angle.

DuraTrack HZ v3



THE V3 DELIVERS LOWEST LCOE

Add it up. Working together, all the features of the DuraTrack HZ v3 are designed to result in the best LCOE. When you calculate what you'll save on installation due to the streamlined design, what you won't be spending on O&M due to zero scheduled maintenance, and what you'll add in production due to 99.996% uptime, 6% more density and optimized 52° ROM, you'll discover the value added by going with the industry leader in solar tracking.

With more gigawatts installed, and nearly 30 years dedicated to tracker design and manufacturing, Array's reliability and reputation make it the low-risk choice that you and your financial institution can rely on.

THE ARRAY ADVANTAGE

Array Technologies is the worldwide leader in tracking solutions for utility and commercial solar electric generation systems, with multiple gigawatts across the globe. After more than 28 years in the industry, Array's innovations in solar tracking continue to provide the best levelized cost of electricity through reliable, easy to install and maintain systems. Array Technologies' solutions are engineered in the USA and shipped worldwide.

STRUCTURAL & MECHANICAL FEATURES/SPECIFICATIONS

Tracking Type	Horizontal single axis
Tilt Angle	0°
kW per Drive Motor	~ 650-800 kW DC
String Voltage	Up to 1,500V DC
Maximum Linked Rows	28
Maximum Row Size	80 modules (crystalline, 1,000V DC) & 90 modules (crystalline, 1,500V DC)
Drive Type	Rotating gear drive
Motor Type	2 HP, 3 PH, 480V AC
Motors per 1 MW AC	Less than 2
East-West / North-South Dimensions	Site / module specific
Array Height	54" standard, adjustable (46" min height above grade)
Ground Coverage Ratio (GCR)	Flexible, 28–45% typical
Modules Supported	Most commercially available, including frameless crystalline and thin film
Tracking Range of Motion	± 52°
Operating Temperature Range	-30°F to 140°F (-34°C to 60°C)
Module Configuration	Single-in-portrait standard. Dual-in-landscape (crystalline), four-in-landscape (thin film) also available.
Module Attachment	Single fastener, high-speed mounting clamps with integrated grounding. Traditional rails for crystalline in landscape, custom racking for thin film and frameless crystalline per manufacturer specs.
Materials	HDG steel and aluminum structural members
Allowable Wind Load (IBC 2012)	135 mph, 3-second gust exposure C
Wind Protection	Passive mechanical system relieves wind and
ELECTRONIC CONTROLLER FEATURES/SPE	
Solar Tracking Method	Algorithm with GPS input
Control Electronics	
	MCU plus Central Controller
Data Feed	MCU plus Central Controller MODBUS over Ethernet to SCADA system
Data Feed Night-time Stow	MCU plus Central Controller MODBUS over Ethernet to SCADA system Yes
Data Feed Night-time Stow Tracking Accuracy	MCU plus Central Controller MODBUS over Ethernet to SCADA system Yes ± 2° standard, field adjustable
Data Feed Night-time Stow Tracking Accuracy Backtracking	MCU plus Central Controller MODBUS over Ethernet to SCADA system Yes ± 2° standard, field adjustable Yes
Data Feed Night-time Stow Tracking Accuracy Backtracking INSTALLATION, OPERATION & MAINTENANC	MCU plus Central Controller MODBUS over Ethernet to SCADA system Yes ± 2° standard, field adjustable Yes E
Data Feed Night-time Stow Tracking Accuracy Backtracking INSTALLATION, OPERATION & MAINTENANC PE Stamped Structural Calculations & Drawings	MCU plus Central Controller MODBUS over Ethernet to SCADA system Yes ± 2° standard, field adjustable Yes E Yes
Data Feed Night-time Stow Tracking Accuracy Backtracking INSTALLATION, OPERATION & MAINTENANC PE Stamped Structural Calculations & Drawings On-site Training & System Commissioning	MCU plus Central Controller MODBUS over Ethernet to SCADA system Yes ± 2° standard, field adjustable Yes E Yes Yes
Data Feed Night-time Stow Tracking Accuracy Backtracking INSTALLATION, OPERATION & MAINTENANC PE Stamped Structural Calculations & Drawings On-site Training & System Commissioning Connection Type	MCU plus Central Controller MODBUS over Ethernet to SCADA system Yes ± 2° standard, field adjustable Yes E Yes Yes Fully bolted connections, no welding
Data Feed Night-time Stow Tracking Accuracy Backtracking INSTALLATION, OPERATION & MAINTENANC PE Stamped Structural Calculations & Drawings On-site Training & System Commissioning Connection Type In-field Fabrication Required	MCU plus Central Controller MODBUS over Ethernet to SCADA system Yes ± 2° standard, field adjustable Yes E Yes Yes Fully bolted connections, no welding No
Data Feed Night-time Stow Tracking Accuracy Backtracking INSTALLATION, OPERATION & MAINTENANC PE Stamped Structural Calculations & Drawings On-site Training & System Commissioning Connection Type In-field Fabrication Required Dry Slide Bearings & Articulating Driveline Connections	MCU plus Central Controller MODBUS over Ethernet to SCADA system Yes ± 2° standard, field adjustable Yes Fully bolted connections, no welding No No lubrication required
Data Feed Night-time Stow Tracking Accuracy Backtracking INSTALLATION, OPERATION & MAINTENANCE PE Stamped Structural Calculations & Drawings On-site Training & System Commissioning Connection Type In-field Fabrication Required Dry Slide Bearings & Articulating Driveline Connections Scheduled Maintenance	MCU plus Central Controller MODBUS over Ethernet to SCADA system Yes ± 2° standard, field adjustable Yes E Yes Yes Fully bolted connections, no welding No No lubrication required None required
Data Feed Night-time Stow Tracking Accuracy Backtracking INSTALLATION, OPERATION & MAINTENANCE PE Stamped Structural Calculations & Drawings On-site Training & System Commissioning Connection Type In-field Fabrication Required Dry Slide Bearings & Articulating Driveline Connections Scheduled Maintenance GENERAL	MCU plus Central Controller MODBUS over Ethernet to SCADA system Yes ± 2° standard, field adjustable Yes E Yes Yes Fully bolted connections, no welding No No lubrication required None required
Data Feed Night-time Stow Tracking Accuracy Backtracking INSTALLATION, OPERATION & MAINTENANCE PE Stamped Structural Calculations & Drawings On-site Training & System Commissioning Connection Type In-field Fabrication Required Dry Slide Bearings & Articulating Driveline Connections Scheduled Maintenance GENERAL Annual Power Consumption (kWh per 1 MW)	MCU plus Central Controller MODBUS over Ethernet to SCADA system Yes ± 2° standard, field adjustable Yes E Yes Yes Yes Fully bolted connections, no welding No No No lubrication required None required 400 kWh per MW per year, estimated
Data Feed Night-time Stow Tracking Accuracy Backtracking INSTALLATION, OPERATION & MAINTENANCE PE Stamped Structural Calculations & Drawings On-site Training & System Commissioning Connection Type In-field Fabrication Required Dry Slide Bearings & Articulating Driveline Connections Scheduled Maintenance GENERAL Annual Power Consumption (kWh per 1 MW) Land Area Required per 1 MW	MCU plus Central Controller MODBUS over Ethernet to SCADA system Yes ± 2° standard, field adjustable Yes E Yes Yes Fully bolted connections, no welding No No No lubrication required None required 400 kWh per MW per year, estimated Approx. 5 to 5.75 acres per MW @ 33% GCR (site and design specific)
Data Feed Night-time Stow Tracking Accuracy Backtracking INSTALLATION, OPERATION & MAINTENANCE PE Stamped Structural Calculations & Drawings On-site Training & System Commissioning Connection Type In-field Fabrication Required Dry Slide Bearings & Articulating Driveline Connections Scheduled Maintenance GENERAL Annual Power Consumption (kWh per 1 MW) Land Area Required per 1 MW Energy Gain vs. Fixed-Tilt	MCU plus Central Controller MODBUS over Ethernet to SCADA system Yes ± 2° standard, field adjustable Yes E Yes Fully bolted connections, no welding No No No lubrication required None required 400 kWh per MW per year, estimated Approx. 5 to 5.75 acres per MW @ 33% GCR (site and design specific) Up to 25%, site specific
Data Feed Night-time Stow Tracking Accuracy Backtracking INSTALLATION, OPERATION & MAINTENANCE PE Stamped Structural Calculations & Drawings On-site Training & System Commissioning Connection Type In-field Fabrication Required Dry Slide Bearings & Articulating Driveline Connections Scheduled Maintenance GENERAL Annual Power Consumption (kWh per 1 MW) Land Area Required per 1 MW Energy Gain vs. Fixed-Tilt Warranty	MCU plus Central Controller MODBUS over Ethernet to SCADA system Yes ± 2° standard, field adjustable Yes E Yes Yes Yes Yes Fully bolted connections, no welding No No No No lubrication required None required 400 kWh per MW per year, estimated Approx. 5 to 5.75 acres per MW @ 33% GCR (site and design specific) Up to 25%, site specific 10 year structural, 5 year drive & control components
Data Feed Night-time Stow Tracking Accuracy Backtracking INSTALLATION, OPERATION & MAINTENANCE PE Stamped Structural Calculations & Drawings On-site Training & System Commissioning Connection Type In-field Fabrication Required Dry Slide Bearings & Articulating Driveline Connections Scheduled Maintenance GENERAL Annual Power Consumption (kWh per 1 MW) Land Area Required per 1 MW Energy Gain vs. Fixed-Tilt Warranty Patent Numbers	MCU plus Central Controller MODBUS over Ethernet to SCADA system Yes ± 2° standard, field adjustable Yes E Yes Fully bolted connections, no welding No No No lubrication required None required 400 kWh per MW per year, estimated Approx. 5 to 5.75 acres per MW @ 33% GCR (site and design specific) Up to 25%, site specific 10 year structural, 5 year drive & control components US patent 9,281,778 US patent 9,281,778 US patent 9,581 678 82 and patents populiar.

NEXTracker



INTRODUCING A WHOLE NEW WAY TO TRACK THE SUN

The NEXTracker[™] Self-Powered Tracker (SPT) brings self-contained motor power to each row, saving time and money. No more external power wiring. No more UPS backup systems. Safer, more reliable with higher performance.

Independent, Mechanically-Balanced Rows

The NEXTrackerSPT leverages NEXTracker's mechanically-balanced row design, which aligns the PV panels with the tracker's axis of rotation. This alignment greatly reduces torsional load, requiring less energy from the motor to track throughout the day and freeing each row to track independently.

Plug and Play with No Power Wiring

NEXTrackerSPT's independent rows eliminate external AC power source systems, wiring, and associated trenching. Self-contained units on each row include a dedicated 30W PV panel to provide power to the Self-Powered Controller (SPC), which powers the motor and hosts intelligent control electronics to position each tracker. NEXTrackerSPT's wireless power and communication from the SPC enable each row to be truly plug and play.

Higher Performance & Safety

Independently powered rows eliminate parasitic utility draw for a higher net energy yield. Those intelligent, autonomous rows optimize operation and maintenance activities. The tracking system rapidly moves into safe stow positions; an entire site can be stowed in one to two minutes, versus up to 45 minutes for other horizontal trackers. That same quick positioning makes it five times faster to clean.

More Site Flexibility, Less Site Preparation

NEXTrackerSPT's autonomous rows enable maximum flexibility in system design, freeing layouts from the rectilinear constraints of typical linked-row trackers. No East/West grading, reduced access roads, and better utilization of corner areas increase power capacity 10-20% per site while reducing construction timelines. The self-powered rows allow the system to be commissioned without grid power.

Quicker to track, quicker to commission, quicker to profits.

NEXTrackerSPT Specifications

	Horizontal single-axis balanced-mass tracker with independently-driven rows	
Tracking RangeUp to 120° (± 60°)		
Control System 1 Self-Powered Controller (SPC) per tracker; 1 Network Control Unit per 100 SPCs		
Communications Wireless ZigBee® mesh network/SCADA; no communication wiring required		
Drive System One slew gear, 24VDC motor and self-powered controller w/ dedicated solar panel pe	One slew gear, 24VDC motor and self-powered controller w/ dedicated solar panel per row	
DC Capacity 23-35kWp per tracker row, depending on module type	23-35kWp per tracker row, depending on module type	
System Voltage Flexible, based on system design	Flexible, based on system design	
Power Consumption No grid power required		
Ground Coverage Ratio Any - fully configurable by customer; typical range 33%-50%	Any - fully configurable by customer; typical range 33%-50%	
Installation Method Rapid field assembly, no welding required		
Foundation Types Compatible with all major foundation types (driven pier, concrete foundation, ground set	crew)	
Standard Wind Design 100mph/161kph, 3 second gust per ASCE7-10; configurable for higher wind speeds		
Safety Stowing Automated wind and snow stowing with self-contained backup power - no external po	ver required	
Torsional Limiter Included at each foundation/bearing for additional wind & snow load protection		
Principal Materials Galvanized and stainless steel		
Grounding Method Self grounding structure. Separate materials and labor not required		
Compliance Grounding/bonding: UL2703; Structural Design: ASCE7-10		
Other Available Options Snow and flood sensors		
Warranty10 years on structural components, 5 years on drive and control systems		
Typical DimensionsHeight 2.1m/6.8ft (@ 60 degrees), Width 2.0m/6.4ft, Length 85m/283ft		

Typical 72-cell c-Si configuration: 85m row with 80 modules mounted in portrait:







6200 Paseo Padre Parkway Fremont, CA 94555 USA +1 510 270 2500 nextracker.com

Exhibit D Inverter Specifications

- 1) Power Electronics
- 2) TMEIC
- 3) SMA
- 4) ABB
- 5) INGE TEAM

Christine M.T. Pirik (0029759) (Counsel of Record) William V. Vorys (0093479) Dickinson Wright PLLC 150 East Gay Street, Suite 2400 Columbus, Ohio 43215 Phone: (614) 591-5461 Email: <u>cpirik@dickinsonwright.com</u> <u>wvorys@dickinsonwright.com</u>

Attorneys for Hardin Solar Energy II LLC



		645V
REFERENCE		FS3225M
	AC Output Power(kVA/kW) @50°C ^[1]	3225
	AC Output Power(kVA/kW) @25°C ^[1]	3545
	Operating Grid Voltage(VAC) ^[2]	34.5kV
OUTPUT	Operating Grid Frequency(Hz)	50Hz/60Hz
	Current Harmonic Distortion (THDi)	< 3% per IEEE519
	Power Factor (cosine phi)[3]	0.5 leading 0.5 lagging adjustable / Reactive Power injection at night
	MPPt @full power (VDC)	913V-1310V
INDUT	Maximum DC voltage	1500V
INPUT	Number of inputs	4 per MPPt
	Number of MPPts	Up to 6
EFFICIENCY &	Max. Efficiency PAC, nom (ŋ)	98% (preliminary)
AUXILIARY SUPPLY	Max. Power Consumption (KVA)	20
CADINET	Dimensions [WxDxH] (ft)	20x6.5x7 (preliminary)
CABINET	Type of ventilation	Forced air cooling
	Degree of protection [4]	IP54 / NEMA3R
	Permissible Ambient Temperature	-35°C ^[5] to +60°C / >50°C Active Power derating
ENVIRONMENT	Relative Humidity	4% to 100% non condensing
	Max. Altitude (above sea level)	1000m
	Noise level [6]	< 79 dBA
	Interface	Graphic Display
CONTROL	Communication protocol	Modbus TCP
INTERFACE	Plant Controller Communication	Optional
	Keyed ON/OFF switch	Standard
	Ground Fault Protection	GFDI and Isolation monitoring device
PROTECTIONS	General AC Protection	MV Switchgear (configurable)
PROTECTIONS	General DC Protection	Fuses
	Overvoltage Protection	AC, DC Inverter and auxiliary supply type 2
	Safety	UL1741, CSA 22.2 No.107.1-01, UL62109-1, IEC62109-1, IEC62109-2
CERTIFICATIONS	Compliance	NEC 2014 / NEC 2017 (optional)
	Utility interconnect	UL 1741SA-Sept. 2016 / IEEE 1547.1-2005

 Values at 1.00+Vac nom and cos Φ=1. Consult Power Electronics for derating curves.
 Consult Power Electronics for other configurations.
 Consult P-Q charts available: (Q(kVAr)=((S(kVA)²-P(kW)²).
 P65 available: Consult Power Electronics.
 Heating resistors kit option below -20°C.
 Readings taken 1 meter from the back of the unit. NOTES


		630V				
REFERENCE		FS3150M				
	AC Output Power(kVA/kW) @50°C ^[1]	3150				
	AC Output Power(kVA/kW) @25°C ^[1]	3465				
	Operating Grid Voltage(VAC) ^[2]	34.5kV				
OUTPUT	Operating Grid Frequency(Hz)	50Hz/60Hz				
	Current Harmonic Distortion (THDi)	< 3% per IEEE519				
	Power Factor (cosine phi)[3]	0.5 leading 0.5 lagging adjustable / Reactive Power injection at night				
	MPPt @full power (VDC)	891V-1310V				
INDUT	Maximum DC voltage	1500V				
INPUT	Number of inputs	4 per MPPt				
	Number of MPPts	Up to 6				
EFFICIENCY &	Max. Efficiency PAC, nom (ŋ)	98% (preliminary)				
AUXILIARY SUPPLY	Max. Power Consumption (KVA)	20				
CADINET	Dimensions [WxDxH] (ft)	20x6.5x7 (preliminary)				
CABINET	Type of ventilation	Forced air cooling				
	Degree of protection [4]	IP54 / NEMA3R				
	Permissible Ambient Temperature	-35°C ^[5] to +60°C / >50°C Active Power derating				
ENVIRONMENT	Relative Humidity	4% to 100% non condensing				
	Max. Altitude (above sea level)	1000m				
	Noise level [6]	< 79 dBA				
	Interface	Graphic Display				
CONTROL	Communication protocol	Modbus TCP				
INTERFACE	Plant Controller Communication	Optional				
	Keyed ON/OFF switch	Standard				
	Ground Fault Protection	GFDI and Isolation monitoring device				
PROTECTIONS	General AC Protection	MV Switchgear (configurable)				
PROTECTIONS	General DC Protection	Fuses				
	Overvoltage Protection	AC, DC Inverter and auxiliary supply type 2				
	Safety	UL1741, CSA 22.2 No.107.1-01, UL62109-1, IEC62109-1, IEC62109-2				
CERTIFICATIONS	Compliance	NEC 2014 / NEC 2017 (optional)				
	Utility interconnect	UL 1741SA-Sept. 2016 / IEEE 1547.1-2005				

 Values at 1.00+Vac nom and cos Φ=1. Consult Power Electronics for derating curves.
 Consult Power Electronics for other configurations.
 Consult P-Q charts available: (Ω(k/VA)r)=((S(k/VA)²-P(k/V)²).
 P65 available: Consult Power Electronics.
 Heating resistors kit option below -20°C.
 Readings taken 1 meter from the back of the unit. NOTES



		600V				
REFERENCE		FS3000M				
	AC Output Power(kVA/kW) @50°C ^[1]	3000				
	AC Output Power(kVA/kW) @25°C ^[1]	3300				
	Operating Grid Voltage(VAC) ^[2]	34.5kV				
OUTPUT	Operating Grid Frequency(Hz)	50Hz/60Hz				
	Current Harmonic Distortion (THDi)	< 3% per IEEE519				
	Power Factor (cosine phi)[3]	0.5 leading 0.5 lagging adjustable / Reactive Power injection at night				
	MPPt @full power (VDC)	849V-1310V				
INDUT	Maximum DC voltage	1500V				
INPUT	Number of inputs	4 per MPPt				
	Number of MPPts	Up to 6				
EFFICIENCY &	Max. Efficiency PAC, nom (η)	98% (preliminary)				
AUXILIARY SUPPLY	Max. Power Consumption (KVA)	20				
CADINET	Dimensions [WxDxH] (ft)	20x6.5x7 (preliminary)				
CABINET	Type of ventilation	Forced air cooling				
	Degree of protection [4]	IP54 / NEMA3R				
	Permissible Ambient Temperature	-35°C ^[5] to +60°C / >50°C Active Power derating				
ENVIRONMENT	Relative Humidity	4% to 100% non condensing				
	Max. Altitude (above sea level)	1000m				
	Noise level [6]	< 79 dBA				
	Interface	Graphic Display				
CONTROL	Communication protocol	Modbus TCP				
INTERFACE	Plant Controller Communication	Optional				
	Keyed ON/OFF switch	Standard				
	Ground Fault Protection	GFDI and Isolation monitoring device				
PROTECTIONS	General AC Protection	MV Switchgear (configurable)				
PROTECTIONS	General DC Protection	Fuses				
	Overvoltage Protection	AC, DC Inverter and auxiliary supply type 2				
	Safety	UL1741, CSA 22.2 No.107.1-01, UL62109-1, IEC62109-1, IEC62109-2				
CERTIFICATIONS	Compliance	NEC 2014 / NEC 2017 (optional)				
	Utility interconnect	UL 1741SA-Sept. 2016 / IEEE 1547.1-2005				

 Values at 1.00+Vac nom and cos Φ=1. Consult Power Electronics for derating curves.
 Consult Power Electronics for other configurations.
 Consult P-Q charts available: (Ω(k/VA)r)=((S(k/VA)²-P(k/V)²).
 P65 available: Consult Power Electronics.
 Heating resistors kit option below -20°C.
 Readings taken 1 meter from the back of the unit. NOTES



Electrical Equipment Technical Specification

3360kW/3360kVA SOLAR WARE® SAMURAI (PVH-L3360GR)

March 27, 2018, Rev 0



CHAPTER 1: General

1.1 Application

The equipment described in the specification below is intended to be used as a Grid-Connected Photovoltaic Inverter System for a photovoltaic generation power plant.

1.2 Scope

This specification will cover the design, fabrication, commissioning, and supply of the following equipment:

No.	Equipment	Description
1	PV Skid	Outdoor type
1.1	3360kW/3360kVA Inverter Unit	Outdoor type
1.2	DC Recombiner Box	Outdoor type
1.3	Aux Equipment (optional)	Outdoor type
		3360kVA - 34.5kV MV, 630V LV
2	MV/LV 3-phase Transformer	Liquid-Filled MTR Pad mounted
	(MV IR)	Transformer

1.3 Applicable Standards

The following standards are applied for the equipment unless otherwise stated in the specification.

NEC 2017	(National Electrical Code, >5MW)
111 4744 2045	(Inverter, Converter, Controllers and Interconnection System
011741 2015	Equipment for Power Systems)
	(IEEE Standard for Interconnecting Distributed Resources with
IEEE 1547:2003	Electric Power Systems)
	(IEEE Standard Conformance Test Procedures for Equipment
IEEE 1547.1:2005	Interconnecting Distributed Resources with Electric Power Systems)

All bolts, nuts, and screws for the inverter will conform to the Metric Thread of ISO (International Organization for Standardization). All manufacturing and design of the equipment will conform to the metric system standards.



1.4 Documentation

All submittals will be in electronic form and will include:

- Final Specification
- Test Reports
- Instruction Manual
- Installation Manual
- Schematic Diagrams
- Outline Drawing

1.5 Packing, Transportation and Storage

The equipment may be divided into several sections for protection during transportation when necessary. The equipment will be properly packaged for the respective mode of transportation. Customer is responsible for disposal of packaging materials. Special notations such as "Fragile", "This side Up", "Center of Gravity, "Weight", etc.. when necessary, will be clearly labeled on each package. Manufacturer's recommendations for storage should be followed upon receipt.

1.6 Product Testing

Testing will be carried out at the manufacturer's facility for each piece of equipment. Test reports of major equipment will be submitted.

1.7 Maintenance Contract

Performing scheduled inspections and maintenance will improve the reliability of the equipment and prolong its service life. It is recommended that periodical inspections and maintenance be performed by specialists of the service representative. Such maintenance is not included in this scope and can be quoted separately. The warranty is dependent upon performing periodical inspections and maintenance as per the manufacturer's manual.

1.8 Testing and Commissioning

The equipment presented in this proposal will require authorized startup & commissioning services by TMEIC.

The commissioning scope includes but is not limited to the following:

- De-energized checks including proper installation of equipment, torque mark verification, and proper electrical connections between major equipment.

- Energized checks including software updates, verification of set-points and IP addresses, and proper operation of communications and equipment.

- Commissioning tests will be performed per TMEIC Commissioning Checklist

Note: Testing of grid protection relay is not included. Post-shipping tests of the MV Transformer, such as NETA tests, are not included and can be quoted separately.



The commissioning scope and price are based on the following conditions:

- The pre-commissioning checklist must be filled out and returned to the TMEIC project manager at least two weeks before resources will be scheduled to mobilize to site.

- DC voltage and polarity from array inputs inside the DC recombiner box have been verified and documented by others.

- Back feed is available upon arrival of TMEIC technicians.

- De-energized and energized checks will be completed during the same trip.

- Inverters will be available for commissioning continuously.

- Conditions outside of the TMEIC technician's control which result in delay may be subject to extra charge. Conditions could include, but not limited to: Waiting time for grid connection, bad weather to clear out, other related equipment required for PV inverter commissioning to be installed.

- Technicians will not travel with commissioning spares; critical spares will be available either via client stock on hand, or via TMEIC customer support process.

- Brief operations and maintenance overview can be provided immediately following the conclusion of commissioning to available onsite personnel. This is not a formal O&M training class. TMEIC offers regularly scheduled formal classroom and hands-on training. Schedule, curriculum, and pricing can be found at <u>tmeic.com/customer-support</u>.

Any deviation from these conditions will result in extra charges in accordance with TMEIC's published rate sheet during the time that the work is completed. See TMEIC Solar Ware Terms and Conditions for additional information.

Added Services Technical advisory services for supervision of equipment installation and post commissioning services can be quoted but are not within the scope of TMEIC commissioning services.

1.9 Dispatch of TMEIC Engineers

Except for the purpose of implementing the repair under the warranty set forth in 1.7, the dispatch of TMEIC engineers for any service whatsoever will be made under a separate agreement offering the buyer to pay additional fees for services.



CHAPTER 2: General Conditions

2.1 Grounding System

The inverter should be grounded providing a grounding resistance of less than 5 ohms.

2.2 Installation and Operation Environment

When installing or operating the inverter and related devices, ensure that the installation and operation environment complies with Table 1. Failing to observe these standards may result in deterioration of the insulation, causing short life and malfunctions. Before installation, measure and evaluate the environment of the installation location. The inverter must be protected from marine environments and must be sealed from corrosive gas and salty air in accordance with Table1. The warranty is dependent upon meeting the environmental conditions.

No.	ltem	Environment standard					
1	Installation location	Outdoors					
	Full power ambient temperature range	-20°C to +40°C					
2	Operational Ambient temperature	-20°C to +50°C					
3	Relative humidity	The relative humidity must be held between s due to temperature change.	5 and 95%. There must	be no condensation			
4	Altitude	Up to 2000 meters above sea level.					
5	Air pressure	The air pressure must be maintained in the ra	nge 860 to 1060 hPa.	(pending)			
6	Vibration and mechanical shock (pending)	Vibrations in the installation environment must have frequencies lower than 10 Hz, or higher than 20 Hz. For vibrations less than 10 Hz, the resulting acceleration must not exceed 0.5G. For vibrations between 20 Hz and 50Hz, the resulting acceleration must not exceed 0.5G. For vibrations between 50Hz and 100Hz, the total amplitude must not exceed 0.1 mm					
7	Dust	Dust in the air where the inverter is installed must not exceed normal atmospheric dust levels. In particular, that dust must not include electrically conductive particles, oils or fats, or organic materials such as silicone.					
8	Flammability	There should be no flammable or explosive gas present.					
			Average	Max Allowable			
		Hydrogen sulfide(H2S)	<0.003 PPM	< 0.01 PPM			
		Sulfurous acid gas (SO2)	<0.01 PPM	<0.03 PPM			
		Chlorine gas (Cl2) (Relative humidity > 50%)	<0.0005 PPM	<0.001 PPM			
9	9 Corrosive factors	Chlorine gas(Cl2) (Relative humidity < 50%)	<0.002 PPM	<0.01 PPM			
		Hydrogen fluoride(HF)	<0.001 PPM	<0.005 PPM			
		Ammonia gas (NH3)	<1 PPM	<5 PPM			
		Nitrogen oxide (NOx)	<0.05 PPM	<0.1 PPM			
		Ozone (O3)	<0.002 PPM	<0.005 PPM			

Table 1. Solar Ware Inverter System installation and operation environment guidelines

CHAPTER 3: Equipment Specifications



The inverter employs IGBT switches and continuously convers DC power to AC power. The inverter output voltage will automatically be synchronized with the grid AC source as long as the source is within a tolerable frequency and voltage range. Regarding the details of the unit configuration, refer to the inverter single line diagram (figure 1) and the outline of the inverter (figure 2).

3.1 3360 kW Inverter Unit

3.1.1 Main Circuit Type

Conversion method	Voltage source inverter with instantaneous current control
Switching method	Pulse Width Modulation (PWM) control
Inverter configuration	Three-phase bridge
Isolation method	Galvanic isolation provided for isolated type. External transformer is required for Transformerless type.
Cooling method	Forced Air cooling (Natural Convection Cooling when operating at less than 50% output power). Hybrid liquid – air cooling system.

3.1.2 Control Method

DC side control functions	Maximum Power Point Tracking $(MPPT)$ control
Grid side control functions	Active power control, reactive power control, Voltage Control Mode*
Operation	Auto start/stop(soft-start at startup)
Other functions	Output power limiter. (If the capacity of solar power exceed the generation capacity of the Inverter, the Inverter limits the output power)

*Voltage Control Mode is available via TMEIC Main Site Controller integration.



3.1.3 Electrical Ratings (Preliminary)

ITEM		SPECIFICATIONS				
System type		Grid-connected system				
	Rated Power*, ***	3360kW/3360kVA (derated to 3050kW at 50C)				
	Rated Voltage	630V (+10%,-12%) / 3Φ3W				
	Rated Frequency	60Hz (+0.5Hz, -0.7Hz)				
Output side (AC)	Rated power factor	Over 0.99				
()	PF Operating Range***	+/9PF				
	Rated Current	3079 Arms				
	Maximum Current	3079 Arms				
	Maximum Power	3265 kW @ 98% Efficiency				
Input side	Maximum Voltage	1500 Vdc				
(00)	MPPT Operation Range	915Vdc ~ 1300Vdc**				
Maximum Efficiency		98.9% @ PF=1				
CEC Efficiency		98.5 % @ PF= 1				
Weight		13,228 lbs (6000kg)				
Inverter Dimen	sions (H x W x D)	90 x 200 x 76 inch (2283 x 5071 x 1920 mm)				
Floor space W >	(D	15,200 sq. in. (9.74m²)				
Enclosure Prote	ection Ratings	NEMA 3R				
Installation		Outdoor				
Full Power Temperature Range		-20°C ~ 40°C (-4°F ~ 104°F)				
Communication type		Modbus				
Standards Com	pliance	UL1741				
Standard Control Power Supply		Control Power Supply form Inverter output and Capacitor backup circuit (3sec. compensation)				

* Maximum output power rating is de-rated by input DC voltage, output AC voltage and temperature condition. Details are described in 3.1.5(4).

** Transition from constant DC voltage mode to MPPT mode occurs between 905V and 915V.

*** Rated output power and power factor variation range is only for rated voltage condition.



3.1.4 Protective Functions

Input (DC) side	Ground Fault, DC Reverse Current, Over Voltage, Over Current
Grid (AC) side	Anti-islanding, Over/Under Voltage, Over/Under Frequency, Over current

3.1.5 Grid Connection Features

$(1) \ {\bf Anti-islanding} \ {\bf protection}$

The objective of this system feature is to detect the islanding condition and drive the system to a stable operating condition.



Patented (Japanese patent number 2796035)

(2) Reactive Power Control

Reactive power can be injected to the grid according to the grid voltage through the TMEIC Main Site Controller. The TMEIC Main Site Controller will communicate with each inverter via a communication port, in a Modbus protocol.

(3) Active Power Limit

Site wide active power can be controlled via TMEIC's Main Site Controller.



(4) Temperature Derate Curve (Preliminary)

The curve depicted below displays the inverter de-rate characteristics at different ambient and grid voltage conditions.





(5) Power Factor Control (Preliminary)

The D-Curve depicted below shows the Solar Ware Samurai PF characteristics.



* Operation area will be curtailed by input DC voltage, output AC voltage and temperature condition.

PQ curve for PVH-L3360GR



(6) LVRT and FRT Functionality

Fault Ride Through Capabilities for PVH-L3360GR will be better than below. TBD Low Voltage Ride-Through



Deservation	Trip L	evel Adjust	ability	Trip	Trip Time Adjustability		IEEE1547a		PRC-024-1		HECO		PREPA (Equivalent)	
Parameter	Min	Default	Max	Min	Default	Max	Trip Level	Trip Time	Trip Level	Trip Time	Trip Level	Trip Time	Trip Level	Trip Time
OVR4	105%	125%	140%	1	nstantaneo	JS	125%	10	120%		120%		140%	1072
OVR3	105%	120%	140%	100ms	160ms	65s	120%	160ms	117.50%	200ms	117.50%	200ms	130%	150ms
OVR2	105%	120%	140%	100ms	160ms	65s	120%	160ms	115%	500ms	115%	500ms	125%	1s
OVR1	105%	110%	140%	100ms	15	65s	110%	1s	110%	15	110%	1s	115%	35
UVR4	0%	50%	95%	100ms	160ms	65s	45%	160ms	45%	150ms	0%	600ms	10%	600ms
UVR3	10%	50%	95%	100ms	160ms	65s	45%	160ms	65%	300ms	50%	600ms	35%	1.4s
UVR2	10%	50%	95%	100ms	160ms	65s	60%	1s	75%	25	75%	5s	60%	2.2s
UVR1	10%	88%	95%	100ms	25	65s	88%	25	90%	3s	88%	20s	85%	35

Default value set according to IEEE1547

Remarks:

- For voltage settings over 125%, an optional circuit is required for the control power supply.
 Some embedded anti-islanding features may need to be disabled in some cases. In those cases transfer trip is allowed.
- 3) PRC-024-1 has been tested using down-scaled model with anti-islanding features enabled 4) The IGBTs may stop switching for voltages close to 0%.
- The inverter is not set to supply reactive power during the fault above the settings prior to the fault.
- 6) During the fault, active power and reactive power will proportionally decrease depending on the voltage level
- 3) For overvoltage events, there may be an impact on power quality when the DC voltage is close to the mini 8) Current may be not perfectly sinusoidal for some asymmetrical faults.

9) Settable characteristics are limited to what the above parameter settings allow. No ramp-style characteristic.

Frequency Ride-Through



UFR1 Remarks:

1) Maximum over-frequency adjustability is 63Hz

59.3Hz

Default value set according to IEEE1547

59.9Hz

2) Settable characteristics are limited to what the above parameter settings allow. No ramp-style characteristic.

10m

- i. Back-up power supply such as UPS or CVT may be required for some of the LVRT capabilities. They are currently not included in the proposal.
- ii. LVRT capabilities described in this section is available and tested but currently disabled. Inverter will have standard IEEE 1547 settings. Changing this setting will violate UL listing on inverter.

59.4Hz



3.1.6 Panel Display Outline and Description

(1) Main

The display contents for the MAIN tab are explained in the picture below.



① Measurement Display for Status Supervision

In order to see the equipment status at a glance, the following information is displayed under the MAIN tab.

PV (DC)	DC Voltage (V), DC Current (A)
GRID (AC)	AC Voltage (V), AC Current (A), Frequency (Hz)
POWER	Instantaneous Active Power (kW)
DAILY	Power harvested during the day (kWh)
TOTAL	Total Power harvested (kWh)

② Circuit Status Diagram

PV (DC)	Photovoltaic Array
DS	DC input load-break Disconnect Switch
INV	Inverter (DC/AC Converter)
СВ	Grid Connection Switch (Air Circuit Breaker)
GRID	Utility Grid



③ Start/Stop Operation

When operating in local mode and in normal conditions, the START and STOP buttons can be used to stop the operation of the inverter.

< PV) ดบ	jî.	Øn		<u> Йы</u> 7	ወッነ
DC.	2 U U 10 U		۳N		UKW (0%)
PU:	0 V					
CN:	۷V	12				
<gr d<="" i="" td=""><td>></td><td></td><td></td><td></td><td></td><td></td></gr>	>					
UV:	Ø٧	U:	ØA	Ρ:	0kW (0%)
VW:	Ø٧	V:	ØA	Q :	Økvar(0%)
WU:	ЙV	W:	ЙA	pf:	N. NN	-~,
R	. ØHz	10.5%	2	10100		
<amb i<="" td=""><td>ENT T</td><td>EMP.></td><td></td><td>0</td><td>.Ødeg</td><td></td></amb>	ENT T	EMP.>		0	.Ødeg	

(2) Measurement

The screen below appears when the MEASUREMENT tab is selected.

DC:	Í ØV		ЙΑ				ЙkW	(N%)
PC:	٥v		0				Old In	3	0,07
CN:	Ø۷								
<gr id:<="" td=""><td>></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></gr>	>								
UV:	Ø٧	U:	ØA	Ρ			ØkW	(0%)
VW:	Ø٧	V:	ØA	Q	2		Økvar	(0%)
WU:	Ø٧	W:	ØA	pf	:	Ø.	. 00		10-24577
Ø.	0Hz								
<amb i="" i<="" td=""><td>ENT TI</td><td>EMP.></td><td></td><td></td><td>Ø.</td><td>0</td><td>deg</td><td></td><td></td></amb>	ENT TI	EMP.>			Ø.	0	deg		



1 Measurement items

DC	DC Voltage, DC current, DC power
UV	AC Voltage (U-V Line to Line)
VW	AC Voltage (V-W T Line to Line)
WU	AC Voltage (W-U Line to Line)
U	AC Current (U Phase)
V	AC Current (V Phase)
W	AC Current (W Phase)
Ρ	Active Power (kW)
Q	Reactive Power (kVAR)
Pf	Power Factor
Blank Space (No Indicator)	Frequency (Hz)

(3) LED Indicator

The Inverter is equipped with 2 LED Lamps. The following table shows its available statuses.

Item	Status
	Turns On; Operating
Run Status Lamp (Green)	Turns Off; Stopping or Stand-by condition or
	Grid-connected stand-by condition
	Turns On; Fault status happens
Status Lamp (Red)	Turns Off; Normal condition





3.1.7 Relay Signal for Remote Use

(1) Output signal for remote use will entail the following minimum items.

OUT1	Running	Normally open (1a)
OUT2	Restricted Running	Normally open (1a)
0012	nest neced naming	Normany open (14)
OUT3	Ston	Normally open (1a)
0015	5100	Normany open (14)
OUT4	Minor Failure	Normally open (1a)
0014	Number 1 and C	Normany open (14)
OUT5	Stand-By	Normally open (1a)
0015	Stand-Dy	Normany Open (1a)
Maior Fault	Maior Failure	Normally open (1a)
OUT3 OUT4 OUT5 Major Fault	Stop Minor Failure Stand-By Major Failure	Normally open (1a) Normally open (1a) Normally open (1a) Normally open (1a)

(2) Relay input signal for remote use will entail the following minimum items.

The Relay signal will be dry contact with a rating of DC24V1A or AC100V .2A.

IN1	Ready	Normally open (1a)
IN2	N/A	N/A
IN3	N/A	N/A
IN4	N/A	N/A

3.1.8 Communication Interface

Communication system: Modbus TCP or Ethernet socket

3.1.9 Utility Interactive Protection Items

Dere de adirere Idaare	Detection Dhene Manuber	Operating Conditions		
Protection Item	Detection Phase Number	GB (*1)	CB Trip (*2)	
Over Voltage Relay (OVR)	3	Υ	Y	
Under Voltage Relay (UVR)	3	Y	Y	
Over Frequency Relay (OFR)	1	Υ	Y	
Under Frequency Relay (UFR)	1	Y	Y	
Passive anti-islanding Detection	1	Y	Ν	
Active anti-islanding detection*3	1	Y	Y	

*1 "Y" indicates the inverter gate signal is blocking and stops its operation. "N" indicates grid side circuit breaker (CB) is still closed.

*2 "Y" indicates a trip and opening of the grid side circuit breaker (CB). "N" indicates grid side circuit breaker (CB) is still closed.

*3 Refer to paragraph 3.1.5(1)



3.1.10 Structural Specifications

(1) General Construction of Equipment		Metal-enclosed, free standing cubicle outdoor- use NEMA3R.	
(2) Inverter Cabinet Dimensions (Height×Width×Depth)		: 90" x 200" x 76" (2,283mm x 5,071mm x 1,920 mm)	
(3) Weight		: approx. 13,228lbs (6,000kg) 🖊 1 set	
(4) Paint	Outside general surface Inside surface Base Roof	: Sand White : Sand White : Sand White : Munsel N4.5	
(5) Input/output interface	DC input AC output Control Wire Grounding Wire	: Lower left DC side : Upper left AC side : Internal in the AC cabinet : Bottom part of the AC and first inverter cabinets	



BILL OF MATERIAL

Per Skid



1000 3.36 MW SOLAR WARE[®] SKID

Generic System configuration is shown in Figure 1. The equipment described below: 1000-NA, 1000-NB and 1000-NC will be installed on the Solar Ware[®] Skid.

Engineering

Package integration engineering for 3.2MW Solar Ware® Skid.

Control Circuit and Communication Wiring

Control circuit and communication wiring for TMEIC supplied equipment are included.

Auxiliary Power (Optional)

10kVA Auxiliary Transformer 630V-208/120V 30A Fused Safety Disconnect Switch 120V Panelboard

All Auxiliary equipment is NEMA 3R rated.

Canopy Shade Structure

Not included

Customer Furnished Equipment (CFE)

SCADA, DAS and site data controller should be provided by others. Wiring and Installation of customer supplied equipment is not included in the base price. Optional pricing can be provided with additional information on CFE equipment. FO cables and tracker motor wiring are also not included.

Stairs and Safety Railings

If the skid(s) are to be mounted on piers requiring stairs and safety railings, the stairs and safety railings are not part of this quote and will be supplied by others.

Stamped Drawings

PE stamped drawings are included.

Back-up Power Requirement

This quote does not include any backup power provision (UPS or Generator). If this is required, it will be quoted separately. This can also affect the length of the skid and overall skid pricing.

Note: The skid dimensions are approximately 33'L x 6'6"W. Customer is to provide other means for additional maintenance space if required to meet any code or county specific requirements.



1000-NA SOLAR WARE® SAMURAI

1 x 3.36 MW Solar Ware® inverter per Skid. Refer to Chapter-3 for inverter specifications.

1000-NB DC RE-COMBINER BOX*

1 x DC master combiner Box per Solar Ware® Inverter

20-Circuit 1500 VDC Dead break switch Box with the following (customer specify other than 20-inputs available):

- 1) 5 x 400-amp, 4 Pole, 1500 VDC dead-break disconnect switches
- 2) Fuses sized for: 20 x 400 amp
- 3) 20 x Positive inputs with $\frac{1}{2}$ " 13 hardware for compression lugs
- 4) 20 x Negative inputs with $\frac{1}{2}$ " 13 hardware for compression lugs
- 5) 2 x DC bus bars for connections with inverter
- 6) Door switch and LED
- 7) Temperature sensor

Zone Monitoring Accessories:

- 1) 0 400A solid core CTs, 24VAC/DC
- 2) 7-8 x EZ I/O modules
- 3) EZ I/O PLC Monitoring 8 Slots
- 4) EZIOP-4DC14DCOP module
- 5) 30 watt, 24 VDC power supply

Note: The DC recombiner can accept up to 40 positive and negative inputs. Alternate configurations to the description shown above may impact cost.

Note: TMEIC interprets compliance with NEC 2017 to mean that Article 691 should govern for sites larger than 5MWac. As such, this recombiner box does not include the capability breaking the negative legs of inputs from the field.



<u>1000-NC</u>	MV 3-Phase Transformer (Typical; specific designs can be requested)
kVA	3360 kVA 3 Phase Pad Mounted Transformer
Special Application	Two-Winding
Temperature Rise	65 degree rise at 30C average, 40C maximum ambient temperature
	NLL less than .1% of rated power
Efficiency	LL less than .9% of rated power
	>99% Efficient @ 100% load
Cooling Class	ONAN
Frequency	60 Hz
Duty Cycle	Designed for step-up operation
Insulating fluid	Mineral Oil
Elevation	Typically designed for operation at 1000 m (3300 ft.) above sea level
Sound Level	NEMA TR1 Standard
High Voltage	34500 Grounded Wye Volts, 150kV BIL
Electrostatic Shield	Electrostatic Shield between Primary & Secondary Windings
	Ground Shield Bushing
kV Class	35 kV
High Voltage Configu	ration Dead Front, Loop Feed
High Voltage Bushing	5 600 amp Cooper dead break one-piece bushings (Oty: 6)
Neutral Bushings	250 amp 2 hole spade bushing
Load-break Switching	2 38 kV. 300A 2 Position
Switch Cover	Padlock cover over Switch (Outside of Cabinet)
Overcurrent Protecti	on Internal Cartridge in Series with Parallel oil-immersed partial range current limiting fuse x 6
Expulsion Fuses	Internal Expulsion x 3
Low Voltage	630 Volts Delta, 45kV BIL
kV Class	1.2 kV
Low Voltage Bushing	s Integral aluminum 6-hole spade bushings (Qty: 3)
Bushing Supports	Standard LV Bushing Support Assembly
Cabinet hardware	Penta-head cabinet door bolts
Coatings	Touch-up paint (Qty: 2)
Taps	2 - 2.5% taps above and 2 - 2.5% taps below nominal
Certifications	UL Listed (UL logo on nameplate)
Notifications	Shock and Arc Flash Warning Decal
	Liquid level gauge with Alarm Contact
	Thermometer, dial-type with Alarm Contact
0.000	Pressure/vacuum gauge with Alarm Contact
Gauges & Fittings	Schrader valve
	Pressure relief device, 50 SCFM
	Drain valve with sampler (1") located outside of cabinet, with cover
	Oil Fill Plug
	IEEE standard two-hole ground pads (Qty: 3)
Tank accessories	Nitrogen Blanket
	Load break switch located outside cabinet on HV side padlocked door
Special Feature	Padlock cover over drain valve

Note: Secondary oil containment is not included with transformer. If required, a provision should be made onsite by others.



Factory Tests:

The following standard factory tests will be performed on the MV Transformer:

- Ratio, Polarity and Phase Rotation Test
- Resistance Test
- Routine Impulse Test
- Applied Potential Test
- Induced Potential Test
- Loss Test
- Leak Test
- ANSI Routine Testing
- Nameplate verifications, alarm, trip setting verifications
- Physical and Mechanical inspections
- Demag Test
- No-Load Loss and Excitation Current

Transformer is pressurized at manufacture's facility and may vary depending on site location and conditions; customer is responsible for maintaining transformer pressure per manufacturer's recommendations.



<u>1000-ND</u> <u>Oty 1 (1/site)</u> <u>MAIN SITE CONTROLLER</u> (Option)

Hardware

1 - RTAC SEL-3355-4 Real Time Automation Controller

	Communications
Ethernet Ports	2 rear; 10 or 100/Mbps, RJ-45
USB Ports	2 front, 4 rear
Encrypted Communications	RDP
Protocols	DNP3, Modbus TCP/IP
User Interface	2 rear; 10 or 100/Mbps, RJ-45

	Physical
Dimensions	19" (W) x 5.22" (H) x 11.49" (D)
Dimensions	482.6mm (W) x 132.6mm (H) x 291.8mm (D)
Weight	20 lb (9.072kg)
Mounting	Treated for chemically harsh / humid environments
Enclosure	125/250 VDC or 120/240 VAC, 160W HV power supply
Power Supply	-40C to +75C
Operating Temperature	2000m
Maximum Altitude	19" (W) x 5.22" (H) x 11.49" (D)

Main Site Controller (MSC) Function

One Main Site Controller communicates over an Ethernet network to control multiple power converters for a single site.

- 1) Sequential Start-up/Shut-down
 - Based on a command from the SCADA system, the MSC issues a single command to start and stop all inverters.
- 2) Power Factor Control
 - Using power generation feedback from the inverter network, the MSC will calculate a reactive current reference for each power converter such that the total power factor does not change with load.
- 3) Output Limitation Control
 - Using power generation feedback from the inverter network, the MSC will calculate a power limit for each inverter such that the power output of the entire site does not exceed a preset value.
- 4) Power slew rate control
 - Based on an adjustable power slew rate the MSC controls the rate at which power output from the system changes.
- 5) Live Trending
 - Capable of monitoring inverter signals such as input current, total power output, power factor etc.
- 6) Data Historian
 - Record of all site signals that are processed by the MSCex. Stored for a week before they are replaced with new data.
- 7) Dynamic Power Factor Control:
 - Using feedback from a Power Factor meter at the POCC (customer supplied), the MSC will adjust the behavior of the Solar Ware[®] inverters to meet a required PF at the measured point.



8) Q Priority Control

• Prioritize maintaining reactive power contribution by limiting site real power output.

9) Frequency Droop Control

Adds or Subtracts to the site power limit reference in proportion to grid frequency when frequency exceeds th e frequency deadband.

Note: The customer will provide one (1) Grid Meter for use in our integration and test procedures to be performed in Roanoke, VA.



G0-A5ES-20160118-001-A

SMA UTILITY POWER SYSTEM MEDIUM VOLTAGE BLOCK 2200 / 2500





Flexible

- Global solution for international markets
- For all medium-voltage grids from 6.6 kV to 35 kV
- System with modular design
- Various options

Reliable

- All components are type-tested
- 5-year statutory warranty
- Life expectancy of at least 25 years

Easy to Use

- Optimized for new Sunny Central inverters
- Outdoor transformer with effective, thermal design
- Short power connection between inverter and transformer

Cost-Optimized

- Concrete housing not required
- Low operating costs thanks to highest efficiencies of over 99%
- Inexpensive transport by standard truck or in sea freight container
- SMA UTILITY POWER SYSTEM MEDIUM-VOLTAGE BLOCK ACCORDING TO IEC STANDARDS

Compact Medium-Voltage Block for the perfect interplay with Sunny Central

The transformer is highly efficient and has been optimized for installation outdoors in accordance with the Ecodesign regulation, making it the perfect partner for the new Sunny Central inverters. The busbar connection between the inverter and transformer is contained as standard. The medium-voltage transformer can be expanded modularly with medium-voltage switchgear, an oil tray and a low-voltage transformer.

SMA UTILITY POWER SYSTEM MEDIUM-VOLTAGE BLOCK 2200 / 2500

Technical Data	MV Block IEC for
	Sunny Central 2200 (1,000 V DC)
Input MV Transformer	
Rated power (at 25°C)	2200 kVA
Rated power (at 40°C)	2080 kVA
Rated power (at 50°C)	2000 kVA
Nominal voltage	385 V
Power frequency	50 Hz, 60 Hz
Max. input current at nominal voltage	3300 A
Output MV Transformer	
Nominal voltage	20 kV
Optional nominal voltages	6.6 kV to 35 kV
Transformer tap changer	-5.0% / -2.5% / 0% / +2.5% / +5.0%
Max. output current at nominal voltage	64 A
Standby power losses ¹⁾	1.595 kW
Short-circuit losses ¹⁾	19.8 kW
Efficiency MV Transformer	
Max. efficiency / European weighted efficiency / CEC weighted efficiency	99.4% / 99.2% / 99.2%
Degree of protection	
Degree of protection according to IEC 60529	IP23D
Degree of protection according to IEC 60721-3-4 (4C1, 4S2 / 4C2, 4S2)	• / 0
General Data	
Dimensions $(W / H / D)^{2}$	5724 mm / 2601 mm / 2150 mm
Weight ³	9150 kg
Ambient temperature (-25°C to 50°C)	•
Max permissible value for relative humidity (condensing)	0% to 95%
Maximum operating altitude above MSI	1000 m at 50°C 2000 m at 45°C 3000 m at 40°C
Fauinment	
Transformer with mineral oil / organic oil	
Transformer vector group Dv11 / YNd11	
Without / with oil trav	
Without / with medium voltage switchgogr	
2 nanole (2 apple nanole with load break switch 1 transformer nanol with sizewit breaker)	•/ 0
modium voltage switch geges with gege guilt algorities then IAC AEL 20 kA 1 a	
autologi anglesura with are fault classification IAC A 20 kA 1 s	
	• / 0
	•/0
Application in unprotected outdoor environment / in chemically active environment	
	KAL 9010
Certificates and Approvals	IEC 600/6, IEC 622/1-200, IEC 622/1-202,
	IEC 01930-1
Standard features Optional	
Type designation	MVB-2200-SC

Technical Data	MV Block IEC for		
	Sunny Central 2500-EV (1,500 V DC)		
Input MV Transformer			
Rated power (at 25°C)	2500 kVA		
Rated power (at 40°C)	2350 kVA		
Rated power (at 50°C)	2250 kVA		
Nominal voltage	550 V		
Power frequency	50 Hz, 60 Hz		
Max. input current at nominal voltage	2624 A		
Output MV Transformer			
Nominal voltage	20 kV		
Optional nominal voltages	6.6 kV to 35 kV		
Transformer tap changer	-5.0% / -2.5% / 0% / +2.5% / +5.0%		
Max. output current at nominal voltage	72 A		
Standby power losses ¹⁾	1.76 kW		
Short-circuit losses ¹⁾	22 kW		
Efficiency MV Transformer			
Max. efficiency / European weighted efficiency / CEC weighted efficiency	99.4% / 99.2% / 99.2%		
Degree of protection			
Degree of protection according to IEC 60529	IP23D		
Degree of protection according to IEC 60721-3-4 (4C1, 4S2 / 4C2, 4S2)	•/0		
General Data			
Dimensions (W / H / D) ^{2]}	5724 mm / 2601 mm / 2150 mm		
Weight ³⁾	9150 kg		
Ambient temperature (-25°C to 50°C)	•		
Max. permissible value for relative humidity (condensing)	0% to 95%		
Maximum operating altitude above MSL	1000 m at 50°C, 2000 m at 45°C, 3000 m at 40°C		
Equipment			
Transformer with mineral oil / organic oil	• / 0		
Transformer vector group Dy11 / YNd11	•/0		
Without / with oil tray	•/0		
Without / with medium-voltage switchgear,	•/0		
3 panels (2 cable panels with load-break switch, 1 transformer panel with circuit breaker),			
medium-voltage switchgear with arc fault classification IAC AFL 20 kA 1 s			
outdoor enclosure with arc fault classification IAC A 20 kA 1 s			
Without / with low-voltage transformer (10 kVA, 20 kVA, 30 kVA)	• / 0		
Application in unprotected outdoor environment / in chemically active environment	• / 0		
Enclosure color	RAL 9016		
Certificates and Approvals	IEC 60076, IEC 62271-200, IEC 62271-202,		
	IEC 61936-1		
Standard features Optional			
· · · · · · · · · · · · · · · · · · ·			
	MVB-2500-SC-EV		
The designation	INTY D-ZUUU-UU-LY		

Loss class Bk +10%, Ao +10% according to eco design standard
 Maximum dimensions of the entire medium-voltage block without platform for power block
 Maximum weight of the entire medium-voltage block without platform for power block



ABB central inverters PVS980 1818 to 2000 kVA



ABB central inverters raise reliability, efficiency and ease of installation to new levels. The inverters are aimed at system integrators and end users who require high-performance solar inverters for large photovoltaic (PV) power plants. PVS980 central inverters are available from 1818 kVA up to 2000 kVA, and are optimized for cost-effective, multi-megawatt power plants.

World's leading inverter platform

Like other ABB central inverters, the PVS980 has been developed on the basis of decades of experience in the industry and proven technology platform. Unrivalled expertise from the world's market and technology leader in frequency converters is the hallmark of this solar inverter series. The PVS980 inverter is one of the most efficient and cost-effective ways of converting the direct current (DC) generated by solar modules into high-quality and CO_2 -free alternating current (AC) that can be fed into the power distribution network.

PVS980 central inverters from ABB

ABB PVS980 central inverters are ideal for large PV power plants. The high DC input voltage, high efficiency, proven components, compact and modular design and a host of life cycle services ensure ABB PVS980 central inverters provide a rapid return on investment.

Highlights

- High total performance
- Outstanding endurance for outdoor use
- Compact, modular product design
- High DC input voltage up to 1500 V_{DC}
- Extensive DC and AC side protection
- Self-contained cooling system with high efficiency
- Versatile design for large-scale PV plants to minimize system costs
- Complete range of industrial data communication options, including remote monitoring
- Life cycle service and support through ABB's extensive global service network

Maximum energy revenues

Maximum energy revenues

ABB central inverters have a high total efficiency. Precise, optimized system control and maximum power point tracking (MPPT) combine with the unit's highly efficient power converter design to deliver the maximum energy from the PV modules to the power distribution network. For end users, this generates the highest possible revenues from the energy sales.

Self-contained, low-maintenance cooling system

PVS980 inverters feature a proven closed loop cooling system used in other ABB industrial applications. This innovative, truly low-maintenance cooling solution is designed for demanding applications and harsh environments, cutting maintenance costs and ensuring outstanding endurance.

Compact and modular design

PVS980 inverters are designed for fast and easy installation. The industrial design and modular platform provide a wide range of options, such as remote monitoring, fieldbus connection and modular and flexible DC input connections. The integrated DC saves space and costs as the solar array junction boxes can be connected directly to the fused busbars in the DC cabinet. PVS980 inverters are customized for the needs of end users and will be available with short delivery times.

Versatile design for large-scale PV plants to minimize system costs

ABB's PVS980 central inverter enables system integrators to design PV power plants that use the optimum combination of inverters with different power ratings. Equipped with extensive electrical and mechanical protection, the inverters are engineered to provide a long and reliable service life of at least 25 years.

Advanced grid support features

The PVS980 software includes all the latest grid support and monitoring features, including active power limitation, fault ride through (FRT) with current feed-in and reactive power control. Active and reactive power output can be controlled by an external control system or automatically by the inverter.

All grid support functions are parameterized, allowing easy adjusting for local utility requirements. ABB central inverters are also able to support grid stability at night by providing reactive power with the DC input disconnected.

ABB central inverters PVS980 1818 to 2000 kVA



High total performance

- High efficiency
- Low auxiliary power consumption
- Innovative controlled cooling
- Efficient maximum power point tracking
- Long and reliable service life of at least 25 years

Outstanding endurance for outdoor use

- Water- and dustproof outdoor enclosure
- Designed to withstand the toughest environments
- Long and reliable service life following the ABB life cycle model

Modular industrial design

- Compact and easy-to-maintain product design
- Fast and easy installation
- Integrated and flexible DC input section

ABB self-contained cooling system

- Closed loop cooling system based on phase transition and thermosiphon technology
- Liquid-cooled inverter power ratings with the simplicity of air cooling
- No fillable liquids, pumps, valves, inhibitors or leaks
- Low maintenance

Versatile design for largescale PV plants

- Integrated DC connection with variable number of inputs
- Wide standard option palette for tailoring
- Versatile AC connection methods

Minimizes system costs

- 1500 V_{DC} system voltage
- Wide ranged and highly efficient MPPT algorithm
- Integrated protection to minimize external components
- Fast and easy installation and commissioning

Life cycle service and support

- ABB's extensive global service network
- Extended warranties
- Service contracts
- Technical support throughout the service life

Wide communication options

- Complete range of industrial data communication options for SCADA connections
- Ethernet/Internet Protocol
- Remote monitoring

ABB central inverters PVS980 1818 to 2000 kVA





Technical data and types					
Type designation	-1818kVA-I	-1909kVA-J	-2000kVA-K		
PVS980-58	1818 kVA	1909 kVA	2000 kVA		
Input (DC)					
Maximum input power (P _{PV,max}) ¹⁾	2910 kWp	3055 kWp	3200 kWp		
DC voltage range, mpp (U _{DC, mpp}) at 50 °C	850 to 1100 V	893 to 1100 V	935 to 1100 V		
DC voltage range, mpp (U _{DC, mpp}) at 35 °C	850 to 1500 V	893 to 1500 V	935 to 1500 V		
Maximum DC voltage ($U_{\max(DC)}$)	1500 V	1500 V	1500 V		
Number of MPPT trackers	1	1	1		
Number of protected DC inputs	8 ²⁾ to 24 (+/-)	8 ²⁾ to 24 (+/-)	8 ²⁾ to 24 (+/-)		
Output (AC)					
Nominal power $(S_{N(AC)})^{3)}$	1818 kVA	1909 kVA	2000 kVA		
Maximum output power (S _{max (AC)}) ⁴⁾	2000 kVA	2100 kVA	2200 kVA		
Nominal AC current (I _{N(AC)})	1750 A	1750 A	1750 A		
Nominal output voltage $(U_{N(AC)})^{5}$	600 V	630 V	660 V		
Output frequency	50/60 Hz	50/60 Hz	50/60 Hz		
Harmonic distortion, current 6)	< 3%	< 3%	< 3%		
Distribution network type 7)	TN and IT	TN and IT	TN and IT		
Efficiency					
Maximum ⁸⁾	98.8%	98.8 %	98.8%		
Euro-eta 8)	98.6%	98.6 %	98.6%		
Power consumption					
Own consumption in operation	2500 W	2500 W	2500 W		
Standby operation consumption	225 W	225 W	225 W		
Auxiliary voltage type	internal	internal	internal		
Dimensions and weight					
Width/Height/Depth, mm (W/H/D)	3180/2366/1522	3180/2366/1522	3180/2366/1522		
Weight appr.	3850 kg	3850 kg	3850 kg		

¹⁾ DC/AC ratio over 1.6 might decrease time

between maintenance intervals

2) As standard

³⁾ At 50 °C

4) At 35 °C

 $^{5)}$ $\pm 10\%$

6) At nominal power

7) Inverter side must be IT type

 $^{\rm (8)}$ Without auxiliary power consumption at min $U_{\rm DC}$

ABB PVS980 central inverter design and power network connection



Technical data and types

Type designation	-1818kVA-I	-1909kVA-J	-2000kVA-K			
PVS980-58	1818 kVA	1909 kVA	2000 kVA			
Environmental limits						
Degree of protection	IP65 ⁹⁾ /Type 4X					
Ambient temp. range (nom. ratings) 10)	-20 °C to +50 °C					
Maximum ambient temperature ¹¹⁾	+60°C					
Relative humidity	5% to 100%					
Maximum altitude (above sea level)	4000 m ¹²⁾					
Maximum noise level	85 dBA ¹³⁾					
Protection						
Ground fault monitoring 14)	Yes					
Grid monitoring	Yes					
Anti-islanding	Yes					
DC reverse polarity	Yes					
AC and DC short circuit and overcurrent	Yes					
AC and DC overvoltage and temperature	Yes					
User interface and communications						
Local user interface	ABB local control panel					
Analog inputs/outputs	Extendable as option					
Digital inputs/relay outputs	Extendable as option					
Fieldbus connectivity	Modbus, Profinet, Ethernet 14)					
Product compliance						
Safety and EMC ¹⁵⁾	CE conformity according to LV and EMC directives					
Certifications and approvals ¹⁵⁾	IEC, UL, CEI, RD, EDF, P.O. 12.3, BDEW, GOST, AS					
Grid support and grid functions	Reactive power compensation ¹⁶⁾ , Power reduction, LVRT, Anti-islanding					

⁹⁾ Excluding underpressure testing

¹⁰⁾ -40 °C as option

¹¹⁾ Power derating after 50 °C

¹²⁾ Derating above 1000 m

 $^{\scriptscriptstyle 13)}$ At partial power typically < 75 dBA

¹⁴⁾ More communication options as engineered option

 $^{\scriptscriptstyle 15)}$ Approvals pending, contact ABB for more information

¹⁶⁾ Also at night



Options

- Integrated and flexible DC input extension
- AC breaker
- AC busbar interface
- DC grounding (negative and positive)
- Fieldbus and Ethernet connections
- Current measurement to each DC input
- High altitude version
- Warranty extensions
- Solar inverter care contracts

Related products

- Medium voltage station (transformer and switchgear) as outdoor or containerised solution
- String monitoring junction boxes
- Remote monitoring solutions

Support and service

ABB supports its customers with a dedicated service network in more than 60 countries and provides a complete range of life cycle services from installation and commissioning to preventative maintenance, spare parts, repairs and recycling.

For more information please contact your local ABB representative or visit:

www.abb.com/solarinverters www.abb.com

© Copyright 2015 ABB. All rights reserved. Specifications subject to change without notice.



3AXD50000027473 REV D EN 11.4.2016


INGECON SUN

TRANSFORMERLESS CENTRAL INVERTERS WITH A SINGLE POWER BLOCK

B Series inverter up to 1.8 MVA at 1500 V

Maximum power density

These PV central inverters feature more power per cubic foot. Thanks to the use of highquality components, this inverter series performs at the highest possible level.

Latest generation electronics

The B Series inverters integrate an innovative control unit that runs faster and performs a more efficient and sophisticated inverter control, as it uses a last-generation digital signal processor. Furthermore, the hardware of the control unit allows some more accurate measurements and very reliable protections.

These inverters feature a low voltage ridethrough capability and also a lower power consumption thanks to a more efficient power supply electronic board.

Improved AC connection

The output connection has been designed in order to facilitate a direct close-coupled connection with the MV transformer.

Maximum protection

These PV inverters are supplied with the combiner box already integrated. Thus, they can guarantee the maximum protection thanks to their DC load break switches and the motorized DC switch to decouple the PV generator from the inverter.

Moreover, they are also supplied with a motorized AC circuit breaker. Optionally, they can be supplied with DC fuses, smart grounding kit and input current monitoring.

Maximum efficiency values

Through the use of innovative electronic conversion topologies, efficiency values of up to 98.9% can be achieved.

Enhanced functionality

(ETI).

This new INGECON[®] SUN PowerMax range features a revamped, improved enclosure which, together with its innovative air cooling system, makes it possible to increase the ambient operating temperature.



www.ingeteam.com solar.us@ingeteam.com

Long-lasting design

These inverters have been designed to guarantee a long life expectancy. Standard 5 year warranty, extendable for up to 25 years.

Grid support

The INGECON® SUN PowerMax B Series has been designed to comply with the grid connection requirements UL1741SA, IEEE1547 and RULE21, contributing to the quality and stability of the electric system. These inverters therefore feature a low voltage ride-through capability, and can deliver reactive power and control the active power delivered to the grid. Moreover, they can operate in weak power grids with a low SCR.

PROTECTIONS

- Integrated combiner box with DC isolators.
- DC Reverse polarity.
- Short-circuits and overloads at the output.
- Anti-islanding with automatic disconnection.
- Insulation failure DC.
- Up to 12 pairs of fuse holders (up to 15 if the combiner box is not integrated).
- Lightning induced DC and AC surge arrestors, type II.
- Motorized DC switch to automatically disconnect the inverter from the PV array.
- Low voltage ride-through capability.
- Motorized AC circuit breaker.
- Hardware protection via firmware.
- Additional protection for the power stack, as it is air cooled by a closed loop.

Ease of maintenance

All the elements can be removed or replaced directly from the inverter's front side, thanks to its new design.

Easy to operate

The INGECON[®] SUN PowerMax inverters feature an LCD screen for the simple and convenient monitoring of the inverter status and a range of internal variables. The display also includes a number of LEDs to show the inverter operating status with warning lights to indicate any incidents. All this helps to simplify and facilitate maintenance tasks.

OPTIONAL ACCESSORIES

- Insulation failure AC.
- Grounding kit.
- Sand trap kit.
- Heating kit, for operating at an ambient temperature of down to -22 °F.
- DC fuses.
- Monitoring of the group currents at the DC input.
- Extendable up to 15 fuse holders per inverter.
- PID prevention kit (PID: Potential Induced Degradation).
- Night time reactive power injection.

Monitoring and communication

Ethernet communications supplied as standard. The following applications are included at no extra cost: INGECON® SUN Manager, INGECON® SUN Monitor and its Smartphone version Web Monitor, available on the App Store. These applications are used for monitoring and recording the inverter's internal operating variables through the Internet (alarms, real time production, etc.), in addition to the historical production data.

Two communication ports available (one for monitoring and one for plant controlling), allowing fast and simultaneous plant control.

ADVANTAGES OF THE B SERIES

- Higher power density.
- Latest generation electronics.
- More efficient electronic protection.
- Night time supply to communicate with the inverter at night.
- Enhanced performance.
- Easier maintenance thanks to its new design and enclosure.
- Lightweight spares.
- It allows to ground the PV array.
- Components easily replaceable.



INGECON SUN

PowerMax B Series 1,500 Vdc

	1170TL U B450	1245TL U B480	1400TL U B540	1500TL U B578	1560TL U B600	1600TL U B615
Input (DC)						
Recommended PV array power range ⁽¹⁾	1,157 - 1,520 kWp	1,234 - 1,622 kWp	1,389 - 1,824 kWp	1,486 - 1,952 kWp	1,543 - 2,027 kWp	1,581 - 2,077 kWp
Voltage Range MPP ⁽²⁾	655 - 1.300 V	697 - 1 300 V	783 - 1.300 V	837 - 1 300 V	868 - 1.300 V	889 - 1 300 V
Maximum voltage ⁽³⁾	000 1,000 1	007 1,000 1	1 5	00 V	000 1,000 1	303 1,000 1
			1,8	50 A		
N° inputs with fuse-holders		6	up to 12 (up to 15 if the co	mbiner box is not integrate	ed)	
Fuse dimensions			63 A / 1.500 V to 500 A	/ 1.500 V fuses (optional)		
Type of connection			Connection t	o copper bars		
Power blocks				1		
MPPT				1		
Innut protections						
			Type II sur	ze arresters		
DC switch			Motorized DC load	break disconnect		
	Integrated DC combiner h	nox / Lin to 12 nairs of DC fus	ses (ontional) / Reverse polari	ty / Insulation failure monitor	ing / Anti-islanding protectio	n / Emergency pushbutton
					ing / the islanding protectio	The Energency pushbatton
Output (AC)						
Power NEMA 3 @86 °F / @122 °F	1,169 kVA / 1,052 kVA	1,247 kVA / 1,122 kVA	1,403 kVA / 1,263 kVA	1,502 kVA / 1,352 kVA	1,559 kVA / 1,403 kVA	1,598 kVA / 1,438 kVA
Current NEMA 3 @86 °F / @122 °F			1,500 A	/ 1,350 A		
Power NEMA 4 @80.5 °F / @122 °F ⁽⁴⁾	1,169 kVA / 1,035 kVA	1,247 kVA / 1,104 kVA	1,403 kVA / 1,242 kVA	1,502 kVA / 1,330 kVA	1,559 kVA / 1,380 kVA	1,598 kVA / 1,415 kVA
Current NEMA 4 @80.5 °F / @122 °F ⁽⁴⁾			1,500 A	/ 1,328 A		
Rated voltage	450 V IT System	480 V IT System	540 V IT System	578 V IT System	600 V IT System	615 V IT System
Frequency			50/	60 Hz		
Power Factor ⁽⁵⁾				1		
Power Factor adjustable			Yes, 0-1 (lead	ding / lagging)		
THD (Total Harmonic Distortion) ⁽⁶⁾			<	3%		
Output protections						
Overvoltage protections			Type II sur	ge arresters		
AC breaker			Motorized AC	circuit breaker		
Anti-islanding protection			Yes, with automa	tic disconnection		
Other protections			AC short-circuit	s and overloads		
Factures						
reatures						
			98.	9%		
			90	.5 /o		
Stand by or night concumption ⁽⁷⁾			4,23			
			2.00	00 W		
Average power consumption per day			2,00	JO W		
General Information						
Ambient temperature			-4 °F to	+140 °F		
Relative humidity (non-condensing)			0-10	00%		
Protection class			NEMA 3 (NEMA 4 w	ith the sand trap kit)		
Maximum altitude		14,770 ft (for installa	ations beyond 3,300 ft, ple	ase contact Ingeteam's sol	ar sales department)	
Cooling system		Air forced	d with temperature control (230 V phase+ neutral pow	ver supply)	
Air flow range			0 - 84 ft³/s (0	- 7,800 m³/h)		
Average air flow			45 ft³/s (4	,200 m³/h)		
Acoustic emission (100% / 50% load)			<66 dB(A) at 33 ft /	<54.5 dB(A) at 33 ft		
Marking			CE,	ETL		
EMC and security standards		UL1741	I, FCC Part 15, IEEE C37.90	.1, IÉEE C37.90.2, CSA22.2	2 No107	
Grid connection standards		IEC 62116, UL1741S	A, IEEE1547, IEEE1547.1,	NEC CODE, Rule 21, Rule	14H, CSA22.2 No107	

Notes: ⁽¹⁾ Depending on the type of installation and geographical location. Data for STC conditions ⁽²⁾ Vmpp.min is for rated conditions (Vac=1 p.u. and Power Factor=1) ⁽³⁾ Consider the voltage increase of the 'Voc' at low temperatures ⁽⁴⁾ With the sand trap kit ⁽⁵⁾ For Pout>25% of the rated power ⁽⁶⁾ For Pout>25% of the rated power and voltage in accordance with IEC 61000-3-4 ⁽⁷⁾ Consumption from PV field when there is PV power available.

INGECON SUN

PowerMax B Series 1,500 Vdc

	1640TL U B630	1665TL U B640	1690TL U B650	1715TL U B660	1740TL U B670	1800TL U B690
Input (DC)						
Recommended PV array power range ⁽¹⁾	1,620 - 2,128 kWp	1,646 - 2,162 kWp	1,672 - 2,195 kWp	1,698 - 2,229 kWp	1,723 - 2,263 kWp	1,775 - 2,330 kWp
Voltage Range MPP ⁽²⁾	911 - 1,300 V	925 - 1,300 V	939 - 1,300 V	953 - 1,300 V	968 - 1,300 V	996 - 1,300 V
Maximum voltage ⁽³⁾			1,5	00 V		
Maximum current			1,8	50 A		
N° inputs with fuse-holders		6	up to 12 (up to 15 if the co	mbiner box is not integrate	ed)	
Fuse dimensions			63 A / 1,500 V to 500 A	/ 1,500 V fuses (optional)		
Type of connection			Connection t	o copper bars		
Power blocks				1		
MPPT				1		
Innut protections						
Overvoltage protections			Type II sur	ge arresters		
DC switch			Motorized DC load	break disconnect		
	Integrated DC combiner h	nox / Lin to 12 nairs of DC fus	es (ontional) / Reverse polari	ty / Insulation failure monitor	ing / Anti-islanding protectio	n / Emergency pushbutton
		0x7 0p to 12 pails of Do 103		ty / moulation failure monitor	ing / Anti-Islanding protectio	Tr Energency pushbutton
Output (AC)						
Power NEMA 3 @86 °F / @122 °F	1,637 kVA / 1,473 kVA	1,663 kVA / 1,497 kVA	1,689 kVA / 1,520 kVA	1,715 kVA / 1,543 kVA	1,741 kVA / 1,567 kVA	1,793 kVA / 1,613 kVA
Current NEMA 3 @86 °F / @122 °F			1,500 A	/ 1,350 A		
Power NEMA 4 @80.5 °F / @122 °F ⁽⁴⁾	1,637 kVA / 1,449 kVA	1,663 kVA / 1,472 kVA	1,689 kVA / 1,495 kVA	1,715 kVA / 1,518 kVA	1,741 kVA / 1,541 kVA	1,793 kVA / 1,587 kVA
Current NEMA 4 @80.5 °F / @122 °F(4)			1,500 A	/ 1,328 A		
Rated voltage	630 V IT System	640 V IT System	650 V IT System	660 V IT System	670 V IT System	690 V IT System
Frequency			50/	60 Hz		
Power Factor ⁽⁵⁾				1		
Power Factor adjustable			Yes, 0-1 (lead	ding / lagging)		
THD (Total Harmonic Distortion)(6)			<	3%		
Output protections						
Overvoltage protections			Type II sur	ge arresters		
AC breaker			Motorized AC	circuit breaker		
Anti-islanding protection			Yes, with automa	tic disconnection		
Other protections			AC short-circuit	ts and overloads		
Features						
Maximum efficiency			98	.9%		
CEC			98	.5%		
Max. consumption aux. services			4,25	50 W		
Stand-by or night consumption ⁽⁷⁾			90	W		
Average power consumption per day			2,00	W 00		
General Information						
Ambient temperature			-4 °F to	+140 °F		
Relative humidity (non-condensing)			0-10	00%		
Protection class			NEMA 3 (NEMA 4 w	vith the sand trap kit)		
Maximum altitude		14,770 ft (for installa	ations beyond 3.300 ft. ple	ase contact Ingeteam's sol	ar sales department)	
Cooling system		Air forcer	with temperature control (230 V phase+ neutral pow	ver supply)	
Air flow range			0 - 84 ft³/s (0	- 7.800 m ³ /h)	ioi ouppi);	
Average air flow			45 ft ³ /s (4	.200 m³/h)		
Acoustic emission (100% / 50% load)			<66 dB(A) at 33 ft /	<54.5 dB(A) at 33 ft		
Marking			CF	FTI		
EMC and security standards		17/1	ECC Part 15 JEEE C37.90	1 IFFE 03790 2 08422	2 No107	
Grid connection standards		IEC 62116 UI 17419	A IEEE1547 IEEE15471	NEC CODE Rule 21 Rule	1/H_CSA22.2 No107	
and connection standards		100 02110, 011/413	N, ILLLI347.1,	REGOODE, Rule 21, Rule	I III, OOR22.2 NOIO/	

Notes: ⁽¹⁾ Depending on the type of installation and geographical location. Data for STC conditions ⁽²⁾ Vmpp.min is for rated conditions (Vac=1 p.u. and Power Factor=1) ⁽³⁾ Consider the voltage increase of the 'Voc' at low temperatures ⁽⁴⁾ With the sand trap kit ⁽⁵⁾ For Pout>25% of the rated power ⁽⁶⁾ For Pout>25% of the rated power and voltage in accordance with IEC 61000-3-4 ⁽⁷⁾ Consumption from PV field when there is PV power available.

Exhibit E Substation Transformer Specifications

1) GE Prolec

Christine M.T. Pirik (0029759) (Counsel of Record) William V. Vorys (0093479) Dickinson Wright PLLC 150 East Gay Street, Suite 2400 Columbus, Ohio 43215 Phone: (614) 591-5461 Email: <u>cpirik@dickinsonwright.com</u> <u>wvorys@dickinsonwright.com</u>

Attorneys for Hardin Solar Energy II LLC





Exhibit F

TRC Site Characterization Report October 2018

Christine M.T. Pirik (0029759) (Counsel of Record) William V. Vorys (0093479) Dickinson Wright PLLC 150 East Gay Street, Suite 2400 Columbus, Ohio 43215 Phone: (614) 591-5461 Email: <u>cpirik@dickinsonwright.com</u> <u>wvorys@dickinsonwright.com</u>

Attorneys for Hardin Solar Energy II LLC

SITE CHARACTERIZATION STUDY REPORT

Hardin Solar II Energy Center Hardin County, Ohio

October 2018

TRC Project No. 302899.0002.0000



Prepared For:

Hardin Solar Energy II LLC One South Wacker Drive, Suite 1800 Chicago, IL 60606 Phone: 312.224.1400 Prepared By:

TRC Environmental Corporation 921 Eastwind Drive, Suite 122 Westerville, OH 43081 Phone: 614.423.6353

Tracy Engle Office Practice Leader Justin Pitts Ecological Project Manager



CONFIDENTIAL BUSINESS INFORMATION

Table of Contents

ACRO	NYMS			iii
1.0	INTRO	ODUCT	'ION	1
2.0	METH	IODS		4
	2.1	EXIST	ING INFORMATION FROM AVAILABLE PUBLIC SOURCES	4
	2.2	FIELD	RECONNAISSANCE	5
3.0	RESU	LTS		7
	3.1	LAND	COVER	7
	3.2	WETL	ANDS AND OTHER WATERS	7
	3.3	HABIT	ΓΑΤ DESCRIPTION	8
	3.4	WILDI	LIFE SPECIES	15
		3.4.1	FEDERALLY THREATENED AND ENDANGERED SPECIES	19
		3.4.2	STATE-LISTED SPECIES	22
		3.4.3	FEDERAL AND STATE SPECIES OF CONCERN	22
		3.4.4	WILDLIFE OBSERVATIONS	22
		3.4.5	MIGRATORY BIRDS OF CONSERVATION CONCERN	
		3.4.6	USGS BREEDING BIRD SURVEY	
		3.4.7	CHRISTMAS BIRD COUNTS	27
		3.4.8	IMPORTANT BIRD AREAS	
		3.4.9	SPECIES OF HABITAT FRAGMENTATION CONCERN	
4.0	SPECI	AL STA	ATUS LANDS	31
	4.1	CONS	ERVATION LANDS	
	4.2	HABIT	TATS OF BIODIVERSITY SIGNIFICANCE	
5.0	PLAN	т сом	MUNITIES OF CONCERN	
6.0	REFE	RENCE	CS CITED	



List of Tables

Table 3.1	Field-Verified National Land Cover Database Land Cover Types within the Hardin Solar II Energy Center Study Area, Hardin County, Ohio, 2018
Table 3.2.1	National Wetlands Inventory Wetland Types within the Hardin Solar II Energy Center 0.25-Mile (0.40-Kilometer) Buffer Area, Hardin County, Ohio, 2018
Table 3.2.2	Wetland and Waterbody Features Delineated within the Hardin Solar II Energy Center Study Area, Hardin County, Ohio, 2018
Table 3.2.3	Other Waters of the United States Delineated within the Hardin Solar II Energy Center Study Area, Hardin County, Ohio, 2018
Table 3.3	Wildlife Species Of Concern, Status, Preferred Habitat, And Potential Seasons Of Occurrence For Species That Are Known Or Likely To Occur In The Hardin Solar II Energy Center Study Area
Table 3.4	Species Observations at the Hardin Solar Energy Center Study Area, Hardin County, Ohio, 2018
Table 3.5	Ten Most common Species Observed on the NO Kenton Breeding Bird Survey Route, Hardin County, Ohio, 2018
Table 3.6	Bird Species Commonly Observed on National Audubon Society's Indian Lake Christmas Bird Counts

List of Figures

Figure 1.1	Hardin Solar II Energy Center, USGS Topographic Map, Project Location Map, Hardin County, Ohio, 2018
Figure 3.1	Hardin Solar II Energy Center, National Land Cover Database Land Cover Types, Ground- Truthed Landcover Types, within the Study Area, Hardin County, Ohio, 2018
Figure 3.2	Hardin Solar II Energy Center, National Wetland Inventory and Delineated Features, Study Area, Hardin County, Ohio, 2018
Figure 3.3	Hardin Solar II Energy Center, Breeding Bird Survey Routes, Christmas Bird Count Circles, and Important Bird Areas Locations Nearest to the Study Area, Hardin County, Ohio, 2018



Acronyms

DOW	Division of Wildlife
Ft	Feet
GIS	Geographic Information System
GPS	Global Positioning System
HSE	Hardin Solar Energy II LLC
IPaC	Information for Planning and Conservation
MW	Megawatt
m	Meter
NLCD	National Land Cover Database
NRCS	Natural Resources Conservation Service
NWI	National Wetland Inventory
OAC	Ohio Administration Code
ODNR	Ohio Department of Natural Resources
OEPA	Ohio Environmental Protection Agency
OPSB	Ohio Power Siting Board
ORAM	Ohio Rapid Assessment Method
TRC	TRC Environmental Corporation
U.S.	United States
USACE	United States Army Corps of Engineers
USDA	United States Department of Agriculture
USFWS	United States Fish and Wildlife Service
USGS	United States Geological Survey



1.0 INTRODUCTION

On behalf of Hardin Solar Energy II LLC (HSE), TRC Environmental Corporation (TRC) has prepared this Site Characterization Report as part of the environmental studies conducted for the Hardin Solar II Energy Center Project (Project). The proposed solar facility will generate up to 170 megawatts (MW) of power. The October 2018 Project Area is the area which HSE will propose to include within their Ohio Power Siting Board (OPSB) application for a certificate of environmental compatibility and public need, issued by the OPSB. In total, the Project Area is approximately 3,388 acres (1,371 hectares), including 396 acres (160 hectares) of underground collection corridors. The privately owned land is located approximately 2.5 miles (3.9 kilometers) southeast of Alger, in Hardin County, Ohio. The Project Area is bisected by Township Road 120 (east/west) and is bounded by Township Road 100 on the north, County Road 65 on the east, and neighboring landowners to the south and west in Marion, McDonald, and Roundhead Township, Hardin County, Ohio (Figure 1.1).

The Study Area consists of the potential construction Project Area and a 100-foot (30-meter) buffer in accordance with Ohio Administrative Code (OAC) 4906-4-08(B)(1)(b). This Study Area is approximately 3,696 acres (1,496 hectares) of primarily cultivated, rotational cropland.

A literature review was completed using publicly available data sources, including a 0.25-mile (0.40-kilometer) buffer beyond the Project Area boundary in accordance with OAC 4906-4-08(B)(1)(c). The approximate area studied for the literature review is 7,525 acres (3,045 hectares).

The study objectives were to provide information needed to address questions posed under the Tier 1 Preliminary Site Evaluation and Tier 2 Site Characterization Study tiers of the United States Fish and Wildlife Service's (USFWS) Land-Based Wind Energy Guidelines (WEG; USFWS 2012), and to provide data to comply with the Ohio Power Siting Board (OPSB) requirements at OAC 4906-4-08(B)(1). The wind guidelines were used because a similar tiered approach for solar development projects has not been established by the USFWS.

The Project lies within the Eastern Corn Belt Plains Ecoregion. The Eastern Corn Belt Plains is generally characterized by loamy and well-drained soils associated with rolling plains and local end moraines (Wilkin, E, F J Nava, and G Griffith. 2011). The vegetation of the ecoregion was originally dominated by American beech (*Fagus grandifolia*), sugar maple (*Acer saccharum*) and American basswood (*Tilia americana*) forests (Wilkin, E, F J Nava, and G Griffith. 2011). Field observations, aerial photography and National Land Cover Database (NLCD) mapping show this landscape has been significantly altered by farming practices. Project Area elevation ranges from approximately 950 feet (290 meters) to 1,022 feet



(312 meters) above mean sea level. Soils consist of Blount silt loam, end moraine, 0 to 2 percent slopes (Ble1A1); Blount silt loam, end moraine, 2 to 4 percent slopes (Ble1B1); Blount silt loam, ground moraine, 0 to 2 percent slopes (Blg1A1); Blount silt loam, ground moraine, 2 to 4 percent slopes (Blg1B1); Carlisle muck, Central Ohio clayey till plain, drained, 0 to 2 percent slopes (Ca); Colwood loam (Co); Glynwood clay loam, 6 to 12 percent slopes, eroded (Gwd5C2); Glynwood silt loam, end moraine, 2 to 6 percent slopes (Gwe1B1); Glynwood silt loam, ground moraine, 2 to 6 percent slopes (Gwe1B1); Glynwood clay loam, ground moraine, 2 to 6 percent slopes (Gwg1B1); Glynwood clay loam, ground moraine, 2 to 6 percent slopes, eroded (Gwg5B2); Glynwood clay loam, ground moraine, 6 to 12 percent slopes, eroded (Gwg5C2); Linwood muck (Ln); McGuffey muck (Mc); Milford silty clay loam, 0 to 2 percent slopes (Mf); Morley clay loam, 12 to 18 percent slopes, eroded (MrD2); Olentangy silt loam (Ot); Pewamo silty clay loam, 0 to 1 percent slopes (PkA); Pewamo variant muck (Po); Roundhead muck (Ro); and Sloan silt loam, frequently flooded (So) (NRCS 2018).



Confidential Business Information



Page | 3

C TRO

Coordinate System: NAD 1915 CORSES Searchane Onio South FIFS3482 R. US (Foot US) Map Robation: Map Robation:

2.0 METHODS

The preliminary site assessment and site characterization were completed using a combination of a) existing information obtained from available public sources including reports, published literature, on-line databases, and geographic information system (GIS) data, b) field reconnaissance, and c) agency consultation.

2.1 EXISTING INFORMATION FROM AVAILABLE PUBLIC SOURCES

The following publicly available data sources were used to complete a literature review required by OAC 4906-4-08(B)(1)(c), which specifies review of a 0.25-mile (0.40-kilometer) buffer beyond the Project Area boundary – (Figure 1.1 - Quarter Mile Buffer). The following data sources were used to complete this review:

- Google Earth[™] ("Google Earth Google Earth." Google Earth. Google, no date (n.d.) Web. 1 June 2018. <u>https://earth.google.com/</u>).
- National Audubon's Important Bird Areas ("Important Bird Areas." Audubon. No publisher (N.p., n.d.) Web. 1 June 2018. <u>http://www.audubon.org/important-bird-areas</u>).
- National Audubon's Christmas Bird Count ("Christmas Bird Count." Audubon. N.p., n.d. Web. 1 June 2018. <u>http://www.audubon.org/conservation/science/christmas-bird-count</u>).
- National Land Cover Database (NLCD) (Survey, U.S. Geological. "National Land Cover Database (NLCD)." LCS Program: NLCD. N.p., n.d. Web. 1 June 2018. <u>https://www2.usgs.gov/climate_landuse/lcs/projects/nlcd.asp</u>).
- Ohio Department of Natural Resources (ODNR), Division of Wildlife and USFWS, Ohio Ecological Services Field Office. "Ohio Mussel Survey Protocol." April 2018. <u>https://wildlife.ohiodnr.gov/portals/wildlife/pdfs/licenses%20&%20permits/OH%20Mussel%20S</u> <u>urvey%20Protocol.pdf</u>
- ODNR National Heritage Database (Ohio DNR Division of Wildlife. "Ohio.gov / search." ODNR Division of Wildlife (DOW). N.p., n.d. Web. 7 June 2018. http://wildlife.ohiodnr.gov/species-and-habitats/ohio-natural-heritage-database).
- U.S. Department of Agriculture (USDA), National Resource Conservation Service (NRCS), Web-Soil Survey (Web Soil Survey. N.p., n.d. Web. 1 June 2018. <u>https://websoilsurvey.sc.egov.usda.gov/App/WebSoilSurvey.aspx</u>).
- USFWS Information for Planning and Conservation (IPaC) IPaC: Home. N.p., n.d. Web. 8 June 2018. <u>https://ecos.fws.gov/ipac/</u>).
- USFWS National Wetlands Inventory (NWI) (U.S. Fish and Wildlife Service (USFWS (2018a); National Wetlands Inventory; National Standards and Support Team. "Wetlands Mapper." Official Web page of the USFWS. N.p., n.d. Web. 21 May 2018. https://www.fws.gov/wetlands/data/Mapper.html).



From these sources, TRC generated a NLCD Land Cover Types map (Figure 3.1), a NWI wetland features map (Figure 3.2), a Breeding Bird Survey Routes, Christmas Bird Count Circles, and Important Bird Areas Locations map (Figure 3.3). TRC also generated a summary of designated sensitive lands and of sensitive species possibly occurring in the Study Area, along with their typical habitat requirements (Section 3.4 Wildlife Species). Sensitive species include: state and federally-listed species (endangered, threatened or candidate), potentially threatened species, USFWS birds of conservation concern, and special interest or species of concern species.

Correspondence with the USFWS (2018b) was received in a Technical Assistance Letter on June 25, 2018. The USFWS conducted a literature review within a 1-mile radius of the Project, including records review of federally-listed threatened and endangered species and their habitats, and known locations of bald eagle nests. For additional information, a review of the USFWS County Distribution List (2018d) was conducted to determine the species distribution of federally-listed endangered, threatened and proposed species in Hardin County, Ohio. Based on this literature review and subsequent field reconnaissance (Section 2.2) of the Study Area, the likelihood of species occurrence (e.g. High Potential, Moderate Potential, Low Potential, No Potential and Confirmed Sighting) within the Study Area was determined by TRC.

Correspondence with the ODNR (2018a) through an inter-disciplinary review within the Department was received July 2, 2018. For this Project, the ODNR conducted a Natural Heritage Database review within a 1-mile radius including known eagle's nests, an Indiana bat (*Myotis sodalis*) and northern long-eared bat (*Myotis septentrionalis*) records review within a 5-mile radius, and hibernacula records review within a 10-mile radius of the Project.

2.2 FIELD RECONNAISSANCE

A field reconnaissance of the Study Area was conducted on May 16th, 18th, 22nd, 23rd, 29th, June 12th – 14th, and September 14th and 17th, 2018 to complete the following:

- Ground-truth NLCD land cover types and locations;
- Document where land cover types provide habitat for species of concern;
- Ground-truth NWI mapped potential wetland locations;
- Document readily observable features that may serve to attract wildlife, if any; and
- Record incidental wildlife and plant observations while in the Study Area.

Vegetation and surface waters were surveyed in the Study Area. Based on field observations within the Study Area, the NLCD classification map units were either confirmed or reclassified. Readily identifiable



land cover changes (i.e., areas that had been converted to cultivated crops) were recorded and mapped. Land cover changes were mapped based on vegetative structure and dominant species composition. The boundaries were mapped in the field using a global positioning system (GPS) (where land parcel was accessible) and completed using current Google EarthTM imagery.

Data developed from existing information were utilized during the field reconnaissance to document areas where land cover types may provide suitable habitat for federal and state species of concern. Land cover types were field-verified, and locations were documented if they provided potentially suitable habitat for species of concern. For species with specific or narrowly defined habitat requirements, potentially suitable habitats were viewed (where land parcel was accessible), and the presence or absence of the specific habitat requirements were recorded.

NWI mapped wetland locations within the Study Area were assessed during field reconnaissance to ascertain the presence or absence of wetland vegetation and wetland hydrology (noting the predominant vegetative strata, dominant plant species, and type: stream, pond, lake, etc.). Wetland resources within the Study Area were identified and their boundaries determined in accordance with the United States Army Corps of Engineers (USACE) *Wetlands Delineation Manual (1987 Manual)* (USACE 1987), utilizing the *Regional Supplement to the United States (U.S.) Army Corps of Engineers Wetland Delineation Manual: Midwest (Version 2.0) (Regional Supplement)* (USACE 2012). Consistent with the *1987 Manual*, wetland determinations were based on dominant plant species, soil characteristics, and hydrologic characteristics. In addition, wetlands and other waters of the U.S. were evaluated in accordance with the State of Ohio's Water Quality Standards (OAC Chapter 3745-1) as managed by the Ohio Environmental Protection Agency (OEPA). Areas that exhibit hydric soils, wetland hydrology, and a dominance of hydrophytic vegetation were considered potentially jurisdictional wetlands. See the Wetlands and Other Waters of the U.S. Delineation Report (TRC 2018) for additional information.

NWI wetlands other waters of the U.S. are summarized in the Results (Section 3.2 Wetlands and Other Waters) section of this Report. Based on results of the field investigations, fourteen (14) wetlands, ten (10) streams, one (1) ditch, and six (6) open water resources (ponds) were field-identified and delineated within the Study Area.

Readily observable features that could serve as suitable habitat for wildlife such as summer bat roosting habitat, caves, freshwater mussel beds, and wetlands were mapped and briefly described. Additionally, animal and plant observations made during field reconnaissance were recorded for inclusion in this Report (Table 3.4).



3.0 RESULTS

3.1 LAND COVER

Land cover types within the Study Area consist primarily of cultivated crops (Figure 3.1). As shown in Table 3.1, approximately 94.53 percent of the Study Area is comprised of cultivated crops.

Cover Type	Acres	Hectares	Percent (%)
Cultivated Crops	3,494.24	1,414.07	94.53
Deciduous Forest	52.18	21.12	1.41
Developed, Open Space	118.72	48.04	3.21
Developed, Medium Intensity	2.21	0.89	0.06
Developed, Low Intensity	23.76	9.62	0.64
Developed, High Intensity	0.03	0.01	< 0.01
Grassland/Herbaceous	5.22	2.11	0.14
Woody Wetlands	0.17	0.07	< 0.01
Total	3,696.53	1,495.93	100.00

Table 3.1	Field-Verified National Land Cover Database Land Cover Types within the Hardin Solar II
	Energy Center Study Area, Hardin County, Ohio, 2018.

3.2 WETLANDS AND OTHER WATERS

Prior to conducting the field reconnaissance, in accordance with OAC 4906-4-08(B)(1)(c), a literature review of NWI maps (USFWS 2018a) identified freshwater forested/shrub wetlands, freshwater emergent wetlands, and freshwater ponds as being located within the 0.25-mile (0.40-kilometer) buffer around the Project Area boundary (Figure 3.2). Table 3.2.1 summarizes the wetland types noted on the NWI maps (Figure 3.2). In total, ten (10) NWI features are located within the 0.25-mile (0.40-kilometer) buffer.

Table 3.2.1National Wetlands Inventory Wetland Types within the Hardin Solar II Energy Center 0.25-Mile
(0.40-Kilometer) Buffer Area, Hardin County, Ohio, 2018.

Wetland Type	Number of Features	Acres	Hectares
Freshwater Forested/Shrub Wetland	3	27.28	11.04
Freshwater Emergent Wetland	5	12.48	4.89
Freshwater Pond	2	5.19	2.10
Total	10	44.95	18.03



TRC field-determined and delineated the boundaries of a combined total of one (1) freshwater forested/shrub wetland, one (1) freshwater forested/emergent wetland, nine (9) freshwater emergent wetlands, and three (3) freshwater forested wetlands, comprising 16.51 acres (6.68 hectares), within the Study Area. In addition, six (6) freshwater ponds, totaling 3.58 acres (1.45 hectares) were also identified within the Study Area (TRC 2018).

Wetland Type	Number of Features	Acres	Hectares
Freshwater Forested/Shrub Wetland	1	1.91	0.77
Freshwater Forested/Emergent Wetland	1	0.14	0.07
Freshwater Emergent Wetland	9	9.21	3.73
Freshwater Forested Wetland	3	5.25	2.12
Freshwater Pond	6	3.58	1.45
Total	20	20.09	8.14

Table 3.2.2Wetland and Waterbody Features Delineated within the Hardin Solar II Energy Center Study
Area, Hardin County, Ohio, 2018.

Ten (10) streams and one (1) ditch were identified within the Study Area, including Elder Creek, Scioto River, Cottonwood Ditch, Twin Branches, and their unnamed tributaries (TRC 2018). In general, the streams have perennial, intermittent and ephemeral flow with substrates comprised primarily of silt, gravel and muck. Instream cover (i.e. shallows, overhanging vegetation, large woody debris, and boulders) was minimal throughout the Study Area. The dominant vegetation within the Study Area along the channelized streams and ditches consists of smooth brome (*Bromus inermis*) and reed canary grass (*Phalaris arundinacea*).

Table 3.2.3Other Waters of the United States Delineated within the Hardin Solar II Energy Center Study
Area, Hardin County, Ohio, 2018.

Stream Type	Number of Feature	Length (ft.; m) ¹
Intermittent	2	42.30 (12.89)
Perennial	8	28,554.18 (8,703.31)
Ditch	1	1,307.61 (398.56)
Total	11	29,904.09 (9,114.77)

1 Represents delineated length, in feet, and meters within Study Area

3.3 HABITAT DESCRIPTION

Habitat diversity within the Study Area is low; the area is comprised primarily of agricultural fields with a corn (*Zea mays*) and soybean (*Glycine max*) monoculture that provides minimal habitat for foraging and



nesting. The Study Area lacks large areas of remnant forests, however, there are areas of early successional to mature deciduous woodlots and tree lines, emergent, scrub/shrub and forested wetlands, streams, and grasslands that offer some habitat variability for terrestrial and aquatic wildlife (Figure 3.1).

Areas of early successional to mature deciduous forests contain typical Ohio hardwoods, including but not limited to, the American elm (*Ulmus americana*), American basswood, eastern cottonwood (*Populus deltoids*), silver maple (*Acer saccharinum*), sugar maple, green ash (*Fraxinus pennsylvanica*), white ash (*Fraxinus americana*), shagbark hickory (*Carya ovata*), red oak (*Quercus rubra*) and white oak (*Quercus alba*). The understory of forested wetland areas identified during field reconnaissance were comprised primarily of spicebush (*Lindera benzoin*), while the understory of the upland forested areas was dominated by stinging nettle (*Urtica dioica*). A complete list of vegetation, including herbaceous, scrub/shrub and trees, is documented in Table 3.4.

Overall, wetland habitat within the Study Area occurred within the agricultural fields, tree lines, grass swales and forested depressions. Vegetation and shallow water levels in these wetland habitats benefit plant and animal species by providing them with a source of food and water, shelter, social interactions, breeding, and nesting.

Field tiles, which drain hydrology from the agricultural fields for the purpose of creating manageable farmland, traverse the Study Area creating a network of channelized streams. Stream substrates were comprised of silt, gravel and muck, and instream cover (i.e. shallows, overhanging vegetation, large woody debris, and boulders) was minimal throughout the Study Area. Vegetation along the streams and ditches was dominated by smooth brome and reed canary grass. These modified streams exhibit an ordinary high water mark and possess a defined channel within the Study Area; however, drainage from the drain tiles have influenced the channel morphology, increased embeddedness, reduced sinuosity, and affected the overall water quality of the streams.

Desktop assessment completed within the Study Area confirmed USFWS (2018b) and ODNR (2018a) results; no federal wilderness areas, wildlife refuges, and dedicated, unique, sensitive or critical habitats are present within the Study Area. In addition, field survey results are consistent with the land use data, indicating that minimal habitat diversity exists within the Study Area.





Confidential Business Information



Page | 8

Confidential Business Information



LISC - CRI

Plot Date: Path:

Confidential Business Information



19 - 381

Coordinate System: NAD 1953 2011 StatePlane Onio South FIPS 2402 FLUS (Fost US) (1/4/7 millip Rotation: 0 Page | 10

Plot Date: Path:

(T1:<t

Confidential Business Information



) - *381*

Page | 11

Plot Date: Path:



Confidential Business Information



SID - ORL

Page | 12

Confidential Business Information



118C - CN

Coordinate System: NAD 1953 2011 StatePlane Ohio South FIPS 3-402 FLUS (Foot US) (fillighe Rolation: 0 Page | 13

Piot Oate: Path:

10,22015,07,44-17,6M64,04,6M640,07147 - LAYOUT,ANSI B(11,117) 10,22015,07,44-17,6M64,0463535-1446014_W400_SOLAR_INHSI 2628,5Fg5-2, UM2_0EU M Results you can rely on

Confidential Business Information



1BC - C

Page | 14

Piot Date: Path:

(71× H) BISINA TUOVAL - YHTROWAYDK AMA 51 AA 50,81053501 2. IISHNI, AAJOS, QIVIM, JNIGRAH-665504Y50AENEVINK2TOELOFI-14.2

3.4 WILDLIFE SPECIES

According to ODNR (2018a) and USFWS (2018b), there are no records of sensitive species within the Study Area; however, there were sensitive species with records in the vicinity of the Study Area or with ranges that overlap the Study Area. Consultation correspondence with the ODNR (2018a) indicated the Project is within the range of the Indiana bat, a state endangered and federally endangered species, clubshell (*Pleurobema clava*), a state endangered and federally endangered mussel, the rayed bean (*Villosa fabalis*), a state endangered mussel, purple lilliput (*Toxolasma lividus*), a state endangered mussel, the pondhorn (*Uniomerus tetralasmus*), a state threatened mussel, eastern massasauga (*Sistrurus catenatus*), a state endangered and federal candidate snake species, upland sandpiper (*Bartramia longicauda*), a state endangered bird, and northern harrier (*Circus cyaneus*), a state endangered bird. Consultation with the USFWS (2018b) indicated the Project is within the range of the federally endangered Indiana bat and the federally threatened northern long-eared bat.

The USFWS IPaC resource (USFWS 2018c) identified the clubshell and rayed bean mussels, the copperbelly water snake (*Nerodia erythrogaster neglecta*), the bobolink (*Dolichoyx oryzivorus*), and the Indiana and northern long-eared bats species as having ranges that overlap the Study Area.

The USFWS County Distribution of Federally-Listed Endangered, Threatened, and Proposed Species (2018d) identified the federally endangered Indiana bat, clubshell mussel, and rayed bean mussel, and the federally threatened northern long-eared bat, eastern massasauga rattlesnake, and copperbelly water snake as having the potential to occur within Hardin County, Ohio.

The following sections and Table 3.3 outline the seasonal habitat requirements and potential for sensitive species to occur in the Project Area.



Table 3.3 Wildli Occur	fe Species Of Concern, Status, In The Hardin Solar II Energ	, Preferred I y Center Stu	Habitat, And Potential Seasons Of Occurrence Foudy Area.	for Species 1	Fhat Are Kn	own Or]	Likely To
				Seasons Likelihoo	of Potential (od of Occurre Area ²	Occurred ance in th	nce and ne Study
Wildlife Type / Common Name	Scientific Name	Status ¹	- Habitat by Season	Spring	Summer	Fall	Winter
MUSSELS							
Rayed Bcan	Villosa fabilis	FE	Small, headwater creeks, but has potential to occur in large rivers and wave-washed areas of glacial lakes	Z	Z	Z	Z
Clubshell	Pleurobema clava	FE	Clean, loose sand and gravel in medium to small rivers and streams	Z	Z	Z	Z
Purple Lilliput	Toxolasma lividus	SE	Headwaters of rivers, lakes, and reservoirs. From slow to swift currents, in mud, sand, and gravel substrates or shallow rocky gravel points and sandbars	Μ	W	M	Μ
Pondhorn	Uniomerus tetralasmus	ST	Ponds, small creeks, and the headwaters of larger streams in mud or sand.	Μ	Μ	Μ	Μ
REPTILES							
Copperbelly Water Snake	Nerodia erythrogaster neglecta	FT	Mosaic of shallow wetlands or floodplain wetlands surrounded by forested uplands; seasonally flooded wetlands without fish favored for foraging	Μ	W	W	Μ
Eastern Massasauga rattlesnake	Sistrurus catenatus	FΤ	Wet areas, including wet prairies, marshes and low-lying areas along rivers and lakes; adjacent uplands	Z	Z	Z	Z

Page | 16



Confidential Business Information

Hardin Solar II Energy Center Project Site Characterization Study Report October 2018

Table 3.3 Wildlife Occur I	Species Of Concern, Status, n The Hardin Solar II Energ	Preferred H y Center Sti	labitat, And Potential Seasons Of Occurrence Fo idy Area.	or Species 1	Chat Are Kno	wn Or I	ikely To
Wildlife Tyme /				Seasons Likelihoo	of Potential (d of Occurre Area ²	Occurren ence in th	ice and ie Study
Common Name	Scientific Name	Status ¹	Habitat by Season	Spring	Summer	Fall	Winter
BIRDS							
Raptors							
Bald cagle	Haliaeetus leucocephalus	FSC	Bald eagle nesting season occurs in January through the end of August, and roosting season begins in mid-October and ends mid-March. Outside the breeding season, eagles of all ages typically perch and forage near open water where food and tall trees for perching are available.	Г	Ц	Ц	Ц
Northern Harrier	Circus cyaneus	SE	Northern harriers breed from April to late July in wide-open habitats ranging from Arctic tundra to prairie grasslands to fields and wetlands (marshes). During migration and winter, harriers typically move south away from areas that receive heavy snow cover.	Г	Ц	Ц	Ц
Golden eagle	Aquila chrysaetos	FSC	Inhabits the mountainous and hilly areas of western North America and winters as far as the southern Great Plains. During migration or over winter months, eagles are known to inhabit the Great Lakes region.	Z	Z	Z	Z
Non-raptors							
Bobolink	Dolichonyx oryzivorus	SSC	Resides in grassy hayfields and pastures, clover/alfalfa hayfields, wet prairies, and the grassy margins of marshes. Fallow fields comprised of grasses and weeds also provide suitable nesting habitat.	X	W	Μ	Μ

Confidential Business Information

Hardin Solar II Energy Center Project Site Characterization Study Report October 2018

Page | 17



Hardin Solar II Energy Site Characterization S October 2018	Center Project tudy Report			Con	fidential Busin	ness Info	rmation
Table 3.3 Wildlif Occur	è Species Of Concern, Status, F In The Hardin Solar II Energy	Preferred H Center Stu	labitat, And Potential Seasons Of Occurrence Fo ıdy Area.	or Species 1	'hat Are Kno	wn Or I	ikely To
				Seasons Likelihoo	of Potential (d of Occurre)ccurren nce in th	ice and ie Study
Wildlife Type / Common Name	Scientific Name	Status ¹	- Habitat by Season	Spring	Area- Summer	Fall	Winter
Upland Sandpiper	Bartramia longicauda	SE	Dry grasslands including native, seeded, grazed and ungrazed pasture, hayfields, and grasslands established through the Conservation Reserve Program.	Г	Г		Г
MAMMALS							
Indiana bat	Myotis sodalis	FE	Summer roosting in trees with loose bark over 9.0 inches (22.9 centimeters) in diameter; winters in caves.	Γ	Γ	Γ	Z
Northern long-eared bat	Myotis septentrionalis	FT	Summer roosting in trees with loose bark over 3.0 inches (7.6 centimeters) in diameter; winters in caves.	Γ	Γ	Γ	Z
Sources: Cornell Lab of Ornith McCormac, Jim, and McCormac, Jim, and USFWS website <u>https</u> USFWS website <u>https</u> USFWS website <u>https</u> F FE = Federal-enda of Concern ² Likelihood of occu.	ology, Birds of North America w Gregory Kennedy. Birds of Ohio <u>wildlife.ohiodnr.gov/species-and</u> :://www.fws.gov/midwest/endang ngered, FT = Federal-threatened, <i>rrence Key:</i> H = High potential;	ebsite <u>https</u> . Edmonton . Edmonton habitats/sti <u>ered/index</u> SE = State <i>M</i> = Mode	:://birdsna.org/Species-Account/bna/species, accesso :: Lone Pine Pub., 2004. Print. ate-listed-species, accessed June 8, 2018 <u>html</u> , accessed June 8, 2018. -endangered, ST=State-threatened, FSC = Federal 9 <i>rate potential; L = Low potential and N = No poten</i> <i>rate potential; L = Low potential and N = No poten</i>	sed June 8, 2 Species of C <i>ntial; C = C</i>	018 Concern, SSC onfirmed sigh	= State S	pecies



3.4.1 FEDERALLY THREATENED AND ENDANGERED SPECIES

According to USFWS (2018b, 2018c and 2018d), there are six (6) species with ranges that overlap the Study Area, including the rayed bean mussel, clubshell mussel, copperbelly water snake, eastern massasauga rattlesnake, Indiana bat and northern long-eared bat. No federally-listed species were observed during field reconnaissance for the Project (Table 3.4).

Rayed Bean Mussel (Villosa fabilis)

The federally endangered rayed bean mussel is generally found in small, headwater creeks, but has the potential to occur in large rivers and wave-washed areas of glacial lakes (USFWS 2018d). A total of ten (10) streams including Elder Creek, Scioto River, Cottonwood Ditch, Twin Branches, and their unnamed tributaries are present within the Study Area. Based on stream size and the potential presence for federally listed mussel species to occur, the Ohio Mussel Survey Protocol (ODNR and USFWS 2018) provides a list of the streams where mussels may occur. The Scioto River and Cottonwood Ditch within the Study Area are listed as Group 1 Streams (small to mid-size stream, federally listed species not expected). According to USFWS (2018b) and ODNR (2018a), no rayed bean mussels have been recorded in the Study Area. Based on the information obtained from the USFWS and ODNR, the rayed bean mussel has no potential to occur in the Study Area (Table 3.3).

Clubshell Mussel (Pleurobema clava)

The federally endangered clubshell mussel occurs in areas of clean, loose sand and gravel in medium to small rivers and streams. This mussel will bury itself in the bottom of substrate to depths up to 4.0 inches (10.1 centimeters) (USFWS 2018d). According to USFWS (2018b) and ODNR (2018a), no clubshell mussel occurrences have been recorded in the Study Area. Based on the information obtained from the USFWS and ODNR, the clubshell mussel has no potential to occur in the Study Area (Table 3.3).

Copperbelly Water Snake (Nerodia erythrogaster neglecta)

The federally threatened copperbelly water snake requires a mosaic of shallow wetlands or floodplain wetlands surrounded by forested uplands. Copperbelly water snakes frequently move between these shallow wetland areas through use of the upland forested areas. Seasonally flooded wetlands without fish, which are a predator to the copperbelly water snake, are favored for foraging. During winter, copperbelly water snakes hibernate, often in crayfish burrows, in forested wetlands and immediately adjacent to forested uplands. They remain underground from late October until late April (USFWS 2018d). According to USFWS (2018b) and ODNR (2018a), no recorded occurrences of the copperbelly water snake exist in the Study Area.



A portion of the Study Area contains a mosaic of forested shallow wetlands, which is suitable habitat for the copperbelly water snake. However, with the predominance of actively farmed cropland and channelized tributaries, the copperbelly water snake has a moderate potential of occurring in the Study Area (Table 3.3).

Eastern Massasauga Rattlesnake (Sistrurus catenatus)

The federally threatened eastern massasauga rattlesnake primarily occurs in wet areas, including wet prairies, marshes and low-lying areas along rivers and lakes, as well as in adjacent uplands during their life history (USFWS 2018d). Eastern massasauga rattlesnakes may hibernate in crayfish burrows, under logs and tree roots, or in small mammal burrows during hibernation from late October to late April (USFWS 2018d). According to USFWS (2018b) and ODNR (2018a), no recorded occurrences of the eastern massasauga rattlesnake exist in the Study Area.

Based on the predominance of actively farmed cropland and lack of wet prairies, marshes and low-lying areas along rivers and lakes, the Study Area does not contain suitable habitat for the eastern massasauga rattlesnake. Therefore, the eastern massasauga rattlesnake has no potential to occur in the Study Area (Table 3.3).

Indiana bat (*Myotis sodalis*)

The federally endangered, Indiana bat occurs over a range that extends from the east coast to Midwestern United States, including Ohio (USFWS 2018d). Indiana bats hibernate during winter in caves and mines, subsequently migrating to their summer habitat in wooded areas where they usually roost under loose tree bark on dead or dying trees. Spring through fall, Indiana bats utilize a variety habitats to forage on flying insects found along rivers, lakes, open fields and uplands (USFWS 2018d).

Although Indiana bats have the potential to inhabit all counties in Ohio, correspondence with the ODNR (2018a) indicated no Indiana bat capture locations within a 5.0-mile (8.0-kilometer) radius, or hibernacula within a 10-mile (16-kilometer) radius of the Study Area. Suitable wooded habitat for roosting and foraging was found to be present in the Study Area. However, based on data reviewed, agency consultation and field reconnaissance, the potential of occurrence for the Indiana bat within the Study Area is low during spring, summer and fall months, and there is no potential to occur within the Study Area during winter months (Table 3.3).

Northern long-eared bat (Myotis septentrionalis)

The federally threatened northern long-eared bat range extends throughout most southern Canada, the eastern and midwestern United States (excluding parts of the southeast United States), and is primarily associated with North American forests (USFWS 2018d). Historically, the northern long-eared bat is found



statewide in Ohio (USFWS 2018b). Currently, ODNR (2018a) data related to the northern long-eared bat species remains incomplete.

During the spring through fall active seasons, the northern long-eared bat forages over open fields near caves and forests (USFWS 2018d). The northern long-eared bat is similar to the Indiana bat in its use of caves and mines for hibernation. The northern long-eared bat requires very high humidity in selected hibernacula. After hibernation, the bats are found in wooded or semi-wooded habitats for the duration of the summer months. The northern long-eared bat utilizes crevices and loose bark on trees (\geq 3.0 inches [7.6 centimeters]) in diameter at breast height) for roosting, although it is considered to be opportunistic and less selective than the Indiana bat (USFWS 2018d). The northern long-eared bat primarily flies through the understory of forested areas foraging on a variety of insects.

Suitable wooded habitat for roosting and foraging was found to be present in the Study Area. However, based on data reviewed, agency consultation and field reconnaissance, the likelihood of occurrence of the northern long-eared bat within the Study Area is low during spring, summer and fall months, and there is no potential to occur within the Study Area during winter months (Table 3.3).

Bald and Golden Eagle Protection Act

Bald eagle (*Haliaeetus leucocephalus*) habitat typically includes estuaries, large lakes, reservoirs, rivers and some seacoasts and marshes where they forage for fish. Bald eagles will also feed on waterfowl, turtles, rabbits, snakes, other small animals and carrion located in a variety of habitats (USFWS 2018c). Bald eagles require a combination of readily available prey, perching areas, and nesting sites. In winter, bald eagles congregate near open water in tall trees for spotting prey and night roosts for shelter (USFWS 2018c).

Golden eagles (*Aquila chrysaetos*) build nests on cliffs or in the largest trees of forested stands that often provide an unobstructed view of the surrounding habitat (USFWS 2018c). Golden eagles are rare in the eastern United States; however, may be observed during migration or winter months in the Great Lakes region. Based on data reviewed, agency consultation and field reconnaissance, bald and golden eagles have a low potential of occurrence in the Study Area.

According to USFWS (2018b) and ODNR (2018a), eagles are not known to occur within the Study Area. While eagles could pass through the Study Area, features (i.e. nests in tall trees near large lakes, reservoirs and rivers) that would attract an eagle to roost or forage were not observed.



3.4.2 STATE-LISTED SPECIES

According to ODNR (2018a), the Natural Heritage Database indicates no records of state-listed species in the Study Area or the surrounding area within a 1.0-mile (1.6-kilometer) radius. Although summer roosting occurrences for the state-listed Indiana bat have been recorded in Hardin County, ODNR (2018a) data indicates no occurrences for capture locations or roosts have been recorded within a 5.0-mile (8.0-kilometer) radius, or hibernacula within a 10-mile (16-kilometer) radius of the Study Area. However, ODNR (2018a) identified state-listed species with ranges that overlap the Study Area, including: the clubshell, rayed bean, purple lilliput and pondhorn mussels; the Indiana bat; eastern massasauga rattlesnake; upland sandpiper; and northern harrier. No state-listed species were observed during field reconnaissance for the Project (Table 3.4).

3.4.3 FEDERAL AND STATE SPECIES OF CONCERN¹

The Study Area is primarily active rotational cropland, resulting in limited habitat diversity. The ODNR Natural Heritage Database did not identify any of any species of concern at or within a 1.0-mile (1.6-kilometer) radius of the Project (ODNR 2018a). However, the Study Area is within the range of three (3) species of concern, including the bobolink, bald eagle, and golden eagle (Table 3.3). Additionally, no federal or state species of concern were observed during field reconnaissance for the Project (Table 3.4).

3.4.4 WILDLIFE OBSERVATIONS

During field reconnaissance, the following plant and animal species were observed within the Study Area for the Project.

Common Name	Scientific Name	Listed Status
American basswood	Tilia americana	
American bur-weed	Sparganium americanum	
American hophornbeam	Ostrya virginiana	
American hornbeam	Carpinus caroliniana	
American sycamore	Platanus occidentalis	
American crow	Corvus brachyrhynchos	
American elm	Ulmus americana	
American goldfinch	Cardulis tristis	
American kestrel	Falco sparverius	

Table 3.4Species Observations at the Hardin Solar Energy Center Study Area, Hardin County, Ohio,
2018.

¹ Federal Species of Concern is an informal term. It is not defined in the federal Endangered Species Act. The term commonly refers to species that are declining or appear to be in need of conservation to avoid listing.


Common Name	Scientific Name	Listed Status
American robin	Turdus migratorius	
Baltimore Oriole	Icterus galbula	
Barn swallow	Hirundo rustica	
Black cherry	Prunus serotina	
Blackgum	Nyssa sylvatica	
Bluejoint	Calamagrostis candensis	
Boxelder	Acer negundo	
Calico aster	Symphyotrichum laterflorum	
Canada goose	Branta canadensis	
Canada thistle	Cirsium arvense	
Canadian wildginger	Asarum canadense	
Cattail	Typha x glauca	
Clearweed	Pilea pumila	
Common barnyard grass	Echinochloa crus-galli	
Common chicory	Cichorium intybus	
Common dandelion	Taraxacum officinale	
Common duckweed	Lemna minor	
Common grackle	Quiscalus quiscula	
Common hackberry	Celtis occidentalis	
Common ragweed	Ambrosia artemisiifolia	
Common rush	Juncus effusus	
Common velvetgrass	Holcus lanatus	
Corn	Zea mays	
Curly duck	Rumex crispus	
Cursed buttercup	Ranunculus sceleratus	
Duckweed	Lemna minor	
Dutchman's breeches	Dicentra cucullaria	
Eastern black walnut	Juglans nigra	
Eastern chipmunk	Tamias striatus	
Eastern cottonwood	Populus deltoids	
Eastern gray squirrel	Sciurus carolinensis	
Eastern poison ivy	Toxicodendron radicans	
Eastern towhee	Pipilo erythrophthalmus	

Table 3.4Species Observations at the Hardin Solar Energy Center Study Area, Hardin County, Ohio,
2018.



Common Name	Scientific Name	Listed Status
Eastern woodland sedge	Carex blanda	
European privet	Ligustrum vulgare	
European starling	Sturnus vulgaris	
Fall panicgrass	Panicum dichotomiflorum	
Field sparrow	Spizella pusilla	USFWS Bird of Conservation Concern
Fringed sedge	Carex crinita	
Fowl bluegrass	Poa palustris	
Fowl mannagrass	Glyceria striata	
Fuller's teasel	Dipsacus fullonum	
Garden yellowrocket	Barbarea vulgaris	
Garlic mustard	Alliaria petiolate	
Giant ragweed	Ambrosia trifida	
Gray's sedge	Carex grayi	
Greater bladder sedge	Carex intumescens	
Green arrow arum	Peltandra virginica	
Groundhog	Marmota monax	
Green ash	Fraxinus pennsylvanica	
Hawthorne	Crataegus spp.	
Honey locust	Gleditsia triacanthos	
House sparrow	Passer domesticus	
Indianhemp	Apocynum cannabinum	
Indigo bunting	Passerina cyanea	
Jack in the pulpit	Arisaema triphyllum	
Killdeer	Charadrius vociferus	
Knotweed	Polygonum spp.	
Longhair sedge	Carex comosa	
Mallard	Anas platyrhynchos	
Mayapple	Podophyllum peltatum	
Mourning dove	Zenaida macroura	
Multiflora rose	Rosa multiflora	
Northern cardinal	Cardinalis	
Northern Spicebush	Lindera benzoin	
Ohio buckeye	Aesculus glabra	

Table 3.4Species Observations at the Hardin Solar Energy Center Study Area, Hardin County, Ohio,
2018.



Common Name	Scientific Name	Listed Status
Orchard grass	Dactylis glomerata	
Path rush	Juncus tenuis	
Pin oak	Quercus palustris	
Purple deadnettle	Lamium purpureum	
Raccoon	Procyon lotor	
Reed canary grass	Phalaris arundinacea	
Red clover	Trifolium pretense	
Red fescue	Festuca rubra	
Red maple	Acer rubrum	
Red oak	Quercus rubra	
Red-tailed hawk	Buteo jamaicensis	
Red-winged blackbird	Agelaius phoeniceus	
Rice cutgrass	Leersia oryzoides	
Rock pigeon	Columba livia	
Rough barnyardgrass	Echinochloa muricata	
Sandbar willow	Salix interior	
Sensitive fern	Onoclea sensibilis	
Shagbark hickory	Carya ovata	
Shellbark hickory	Carya laciniosa	
Shepherd's purse	Capsella bursa-pastoris	
Silky dogwood	Cornus amomum	
Silver maple	Acer saccharinum	
Slippery elm	Ulmus rubra	
Smooth brome	Bromus inermis	
Smooth Solomon's-seal	Polygonatum biflorum	
Soft-stemmed bulrush	Schoenoplectus tabernaemontani	
Soybean	Glycine max	
Spearmint	Mentha spicata	
Spotted geranium	Geranium maculatum	
Spotted ladysthumb	Persicaria maculosa	
Spotted touch-me-not	Impatiens capensis	
Stickwilly	Galium aparine	
Stinging nettle	Urtica dioica	

Table 3.4Species Observations at the Hardin Solar Energy Center Study Area, Hardin County, Ohio,
2018.



Common Name	Scientific Name	Listed Status
Sugar maple	Acer saccharum	
Swamp white oak	Quercus bicolor	
Timothy grass	Phleum pretense	
Turkey vulture	Cathartes aura	
Twinleaf	Jeffersonia diphylla	
Virginia creeper	Parthenocissus quinquefolia	
Virginia waterleaf	Hydrophyllum virginianum	
Woodland agrimony	Agrimonia rostellata	
White ash	Fraxinus americana	
White oak	Quercus alba	
White-tailed deer	Odocoileus	
Yellow nutsedge	Cyperus esculentus	
Yellowseed	Lindernia dubia	
Yellow troutlily	Erythronium rostratum	

Table 3.4Species Observations at the Hardin Solar Energy Center Study Area, Hardin County, Ohio,
2018.

3.4.5 MIGRATORY BIRDS OF CONSERVATION CONCERN

TRC reviewed the USFWS IPaC Resources Report for Migratory Birds of Conservation Concern that could potentially occur in the Study Area, which included one (1) species, the bobolink. As described in Table 3.3 above, the bobolink resides in grassy hayfields and pastures, clover/alfalfa hayfields, wet prairies, and the grassy margins of marshes. Fallow fields comprised of grasses and weeds also provide suitable nesting habitat. Based on field reconnaissance, the Study Area is primarily comprised of cultivated crop fields and developed, open space. Such areas primarily contain monotypic vegetation and poor habitat diversity, resulting in poor potential for a diversity of migratory bird species compared to grasslands and other diverse habitats (NABCI 2016). Therefore, the bobolink is not expected to occur because of the lack of preferred habitat within the Study Area.

3.4.6 USGS BREEDING BIRD SURVEY

The nearest USGS Breeding Bird Survey Route (USGS 2018), the NO Kenton Route, Ohio (BBS Route 66032), is located approximately 6.0 miles (9.7 kilometers) east of the Study Area (Figure 3.3). Of the forty-three (43) total species recorded, the ten (10) most common birds recorded on the breeding bird survey route (Table 3.5) are characteristic of open habitats with an agricultural landscape. Land cover along the NO Kenton Route is similar to the landscape found in the Project Area. Additionally, there are four (4) birds of conservation concern recorded along the NO Kenton Route, Ohio, including the red-headed



woodpecker (*Melanerpes erythrocephalus*), northern flicker (*Colaptes auratus*), wood thrush (*Hylocichla mustelina*), and field sparrow (*Spizella pusilla*). None of the species listed in Table 3.5 are birds of conservation concern.

Common Name	Scientific Name
Red-winged blackbird	Agelaius phoeniceus
House sparrow	Passer domesticus
European starling	Sturnus vulgaris
American robin	Turdus migratorius
Turkey vulture	Cathartes aura
Song sparrow	Melospiza melodia
Mourning dove	Zenaida macroura
American crow	Corvus brachyrhynchos
Chipping sparrow	Spizella passerina
Killdeer	Charadrius vociferus

Table 3.5Ten Most common Species Observed on the NO Kenton Breeding Bird Survey Route, Hardin
County, Ohio, 2018.

3.4.7 CHRISTMAS BIRD COUNTS

Indian Lake, located approximately 10.0 miles (16.1 kilometers) south of the Study Area, is the nearest Christmas Bird Count Circle (Figure 3.3). Of the fifty-four (54) total species recorded, the eight (8) most common species observed (Table 3.6) are birds that primarily utilize open spaces and water bodies (National Audubon Society 2018a). Additionally, there are four (4) birds of conservation concern recorded at the Christmas Bird Count area, including the peregrine falcon (*Falco peregrinus*), short-eared owl (*Asio flammeus*), red-headed woodpecker and northern flicker. None of these species listed in Table 3.6 are birds of conservation concern.

Table 3.6Bird Species Commonly Observed on National Audubon Society's Indian Lake Christmas Bird
Counts.

Common Name	Scientific Name
Canada goose	Branta canadensis
Mallard (all forms)	Anas platyrhynchos
Rock pigeon	Columba livia
Mourning dove	Zenaida macroura
Dark-eyed junco	Junco hyemalis
European starling	Sturnus vulgaris
Horned lark	Eremophila alpestris



	Common Name	Scientific Name
House sparrow		Passer domesticus

3.4.8 IMPORTANT BIRD AREAS

The nearest Important Bird Area (National Audubon Society 2018b) in the vicinity of the Study Area is in the Lawrence Woods State Nature Preserve located approximately 10.0 miles (16.1 kilometers) southeast of the Study Area (Figure 3.3). The Lawrence Woods State Nature Preserve is owned by the ODNR, Division of Natural Areas and Preserves and contains over 500 acres (202 hectares) of remnant wet forest habitat, mature woodland, and about 500 acres (202 hectares) of grassland and meadows. It has the largest known mature forest with large areas of button bush wetlands in west-central Ohio.

As determined by the National Audubon Society, important breeding species within the Lawrence Woods State Nature Preserve are the yellow-billed cuckoo (*Coccyzus americanus*), cerulean warbler (*Setophaga cerulea*), Kentucky warbler (*Geothlypis formosa*), ovenbird (*Seiurus aurocapilla*), American redstart (*Setophaga ruticilla*), hooded warbler (*Wilsonia citrina*), yellow-throated vireo (*Vireo flavifrons*), Acadian flycatcher (*Empidonax virescens*), eastern meadowlark (*Sturnella magna*), sedge wren (*Sturnella magna*), bobolink (*Dolichonyx oryzivorus*), Henslow's sparrow (*Ammodramus henslowii*), veery (*Catharus fuscescens*), pileated woodpecker (*Dryocopus pileatus*), and a breeding colony of great blue herons (*Ardea herodias*) (Audubon 2018). As noted in Section 3.4 of this Report, the bobolink is a state-listed species of concern in Ohio. Additionally, there are four (4) birds of conservation concern recorded at this Important Bird Area, including the cerulean warbler, Kentucky warbler, Acadian flycatcher, and Henslow's sparrow.

The Important Bird Area within the Lawrence Woods State Nature Preserve is located approximately 10.0 miles (16.1 kilometers) from the proposed Project. Based on data reviewed, agency consultation and field reconnaissance confirming the lack of large grasslands, marshlands and forests within the Study Area, as well as the distance of the Lawrence Woods State Nature Preserve, avian species identified at this Preserve have low potential to occur in the Study Area.

3.4.9 SPECIES OF HABITAT FRAGMENTATION CONCERN

The Study Area consists mainly of an agricultural monoculture of cropped fields, traversed by channelized tributaries, with small pockets of herbaceous and scrub/shrub wetland. The Study Area contains lesser amounts of wetland and upland deciduous forest. The region was once dominated by hardwood deciduous forests however, land conversion from forest to agricultural fields has altered the environment and biodiversity in the Study Area. Based on agency consultation, data reviewed and field reconnaissance, the Study Area and surrounding lands contain minimal habitat suitable for roosting and foraging, including the



agricultural lands, wetlands, streams, and forest complexes. Finally, due the mobile nature of most of the wildlife within the Study Area and due to the minimal impact to aquatic and forested area, the Project will likely have a minimal impact to wildlife and its habitat.



Hardin Solar II Energy Center Project Site Characterization Study Report October 2018

Confidential Business Information



Page | 30



4.0 SPECIAL STATUS LANDS

4.1 CONSERVATION LANDS

Agency correspondence and queries were based on a 1.0-mile (1.6-kilometer) radius surrounding the Study Area.

The USFWS (2018b) Technical Assistant Letter reported "no federal wilderness areas, wildlife refuges or designated critical habitat is present within the vicinity" of the Study Area. Correspondence from ODNR (2018a) reported that the agency is unaware of any unique ecological sites, geologic features, animal assemblages, scenic rivers, state wildlife areas, nature preserves, parks or forests, national wildlife refuges, parks or forests or other protected natural areas within a 1.0-mile (1.6-kilometer) radius of the Study Area.

Publicly available databases showed public lands located within 10.0 miles (16.1 kilometers) of the Study Area include Indian Lake State Park and Lawrence Woods State Nature Preserve (Figure 3.3). Both are located more than 8.0 miles (13.0 kilometers) from the Study Area. Indian Lake State Park (5,800 acres; 2,347 hectares) is utilized by the public for water-related recreational opportunities. Lawrence Woods State Nature Preserve, located approximately 10.0 miles (16.1 kilometers) from the Study Area, is both a State Nature Preserve and an Important Bird Area (National Audubon Society 2018b).

No designated conservation lands were identified within the Study Area or within the surrounding 1.0-mile (1.6-kilometer) radius.

4.2 HABITATS OF BIODIVERSITY SIGNIFICANCE

Ohio has a Natural Areas and Preserves program and it designates State Nature Preserves based on unique features that could be indicative of the presence of habitats with biodiversity significance. These include areas with pre-settlement habitat remnants, protected habitat for rare and endangered species, and/or distinctive geologic formations (ODNR 2018b). Lawrence Woods State Nature Preserve, located approximately 10.0 miles (16.1 kilometers) from the Study Area, is both a State Nature Preserve and an Important Bird Area (National Audubon Society 2018b). Unlike the Study Area, it has a diverse mosaic of buttonbush swamps, upland forests and lowland forests.

Additionally, correspondence received from the USFWS (2018b) and ODNR (2018a) indicated that no federal wilderness areas, wildlife refuges or designated critical habitat, unique ecological sites, geologic features, animal assemblages, scenic rivers, state wildlife, state nature preserves, state or nation parks, state or national forests, national wildlife refuges, or other protected naturals areas within the Study Area. Field



reconnaissance results are consistent with the information received from the USFWS and ODNR, indicating that no designated areas of biodiversity significance occurs within the Study Area.

5.0 PLANT COMMUNITIES OF CONCERN

Lawrence Woods State Nature Preserve, 10.0 miles (16.1 kilometers) from the Study Area, is both a State Nature Preserve and an Important Bird Area (National Audubon Society 2018b). Unlike the Study Area, it has a diverse mosaic of buttonbush swamps, upland forests and lowland forests that would support high quality plant communities.

Based on data reviewed, agency consultation (USFWS 2018b and ODNR 2018a) and field reconnaissance, no plant communities of concern were identified within the Study Area or within the surrounding 1.0-mile (1.6-kilometer) radius.



6.0 **REFERENCES CITED**

- Cornell University. 2018. *Birds of North America*. The Cornell Lab of Ornithology, New York. Web. 25 June 2018. <u>http://birdsna.org/Species-Account/bna/species/</u>.
- Google EarthTM. 2018. Google-Earth Google Earth. Retrieved from Google Earth: <u>http://earth.google.com/</u>.
- McCormac, Jim and Gregory Kennedy. Birds of Ohio. Edmonton: Lone Pine Pub., 2004. Print.
- National Audubon Society. 2018a. Christmas Bird County. Retrieved from Audubon: <u>http://www.audubon.org/conservation/science/christmas-bird-count/</u>.
- National Audubon Society. 2018b. Important Bird Areas. Retrieved from Audubon: <u>http://www.audubon.org/important-bird-areas</u>.
- ODNR and USFWS. 2018. Ohio Mussel Protocol. <u>https://wildlife.ohiodnr.gov/portals/wildlife/pdfs/licenses%20&%20permits/OH%20Mussel%20S</u> <u>urvey%20Protocol.pdf</u>. Accessed May 5, 2018.
- ODNR. 2018a. Natural Heritage Database Environmental Review response from John Kessler dated July 2, 2018. Ohio Department of Natural Resources (ODNR) National Heritage Database (Wildlife, Ohio DNR Division of. "Ohio.gov / search." Ohio DNR Division of Wildlife. N.p., n.d. Web. 7 June 2018. http://wildlife.ohiodnr.gov/species-and-habitats/ohio-natural-heritage-database).
- ODNR. 2018b. Natural Areas and Preserves website review: June 30, 2018. http://naturepreserves.ohiodnr.gov/.
- TRC. 2018. Wetlands and Other Waters of the U.S. Delineation Report. Westerville, Ohio.
- USACE. 1987. Corps of Engineers Wetlands Delineation Manual. Vicksburg, MS: Environmental Laboratory U.S. Armey Corps of Engineers, Waterways Experiment Station, Wetlands Research Project Technical Report Y-87-1.
- USACE. 2012. Regional Supplement to the Corps of Engineers Wetlands Delineation Manual: Midwest (Version 2.0). U.S. Army Corps of Engineers, Vicksburg: U.S. Army Engineer Research and Development Center Environmental Laboratory, 176.
- USDA. 2018. Web Soil Survey 3.0. U.S. Department of Agriculture, Natural Resources Conservation Service: <u>http://websoilsurvey.sc.egov.usda.gov/App?WebSoilSurvey.aspx</u>.
- USFWS. 2012. Land-Based Wind Energy Guidelines. <u>https://www.fws.gov/ecological-services/es-library/pdfs/WEG_final.pdf</u>. Accessed May 1, 2018.
- USFWS. 2018a. *National Wetlands Inventory Online Mapper v 2.0.* <u>https://www.fws.gov/wetlands/data/mapper.html</u>.
- USFWS. 2018b. Technical Assistance Letter from Scott Pruit. Dated June 25, 2018. TAILS #03E15000-2018-TA-1543.
- USFWS. 2018c. Information for Planning and Conservation (IPaC) IPaC: Home. N.p., n.d. Web. 8 June 2018. <u>https://ecos.fws.gov/ipac/</u>
- USFWS. 2018d. Endangered, Threatened, Proposed, and Candidates in the Upper Midwest. Available online: <u>https://www.fws.gov/midwest/endangered/lists/ohio-cty.html</u>.



USGS. 1994. Topographical Quadrangle Maps (7.5-minute series). U.S. Geological Survey.

- USGS. 2016. Land Change Science Program: National Land Cover Database. Washington D.C.: U.S. Department of the Interior, U.S. Geological Survey. Web. 25 June 2018. https://www2.usgs.gov/climate_landuse/lcs/projects/nlcd.asp.
- USGS. 2018. Patuxent Wildlife Research Center, North American Breeding Bird Survey. https://www.pwrc.usgs.gov/bbs/index.cfm.
- U.S. North American Bird Conservation Initiative. 2016. State of North America's Birds 2016. http://www.stateofthebirds.org/2016/. Accessed June 14, 2018.
- Wilkin, E, F J Navan, and G Griffith. 2011. North American Terrestrial Ecoregions Level III. Commission for Environmental Cooperation, Canada. <u>http://www.cec.org/tools-and-resources/map-files/terrestrial-ecoregions-level-iii</u>



Hardin Solar Energy II LLC Case No. 18-1360-EL-BGN

Exhibit G

TRC Hardin Raptor Nest Survey October 2018

Christine M.T. Pirik (0029759) (Counsel of Record) William V. Vorys (0093479) Dickinson Wright PLLC 150 East Gay Street, Suite 2400 Columbus, Ohio 43215 Phone: (614) 591-5461 Email: <u>cpirik@dickinsonwright.com</u> <u>wvorys@dickinsonwright.com</u>

Attorneys for Hardin Solar Energy II LLC

RAPTOR NEST SURVEY REPORT

Hardin Solar II Energy Center

Hardin County, Ohio

October 2018

TRC PROJECT NO. 302899.0003.0000



Prepared For:

Hardin Solar Energy II LLC One South Wacker Drive, Suite 1800 Chicago, IL 60606 Phone: 312.224.1400 Prepared By:

TRC Environmental Corporation 921 Eastwind Drive, Suite 122 Westerville, OH 43081 Phone: 614.423.6353

Tracy Engle Office Practice Leader Justin Pitts Ecological Project Manager



CONFIDENTIAL BUSINESS INFORMATION

TABLE OF CONTENTS

ACRO	ONYM	[S	II
1.0	INTE	RODUCTION	1
2.0	МЕТ	THODS	4
3.0	RES	ULTS	5
	3.1	AGENCY CONSULTATION DATA	5
	3.2	TETRA TECH 2016 RAPTOR NEST SURVEY	5
	3.3	SUMMARY	6
4.0	REF	ERENCES CITED	7

List of Tables

Table 1.1	National Land Cover Database Land Cover Types, Field-Verified, within the Hardin Solar
	Energy Center Raptor Nest Survey Area, Hardin County, Ohio, 2018

List of Figures

Figure 1.1	Hardin Solar II Energy Center, Raptor Nest Survey and Results, Project Location Map,
	Hardin County, Ohio, 2018



Confidential Business Information

ACRONYMS

GPS	Global Positioning System
HSE	Hardin Solar Energy, LLC
HW	Hardin Wind
IPaC	Information for Planning and Conservation
MW	Megawatt
NLCD	National Land Cover Database
ODNR	Ohio Department of Natural Resources
Project	Hardin Solar II Energy Center Project
Project Area	Potential Construction Impact Area
Report	Hardin Solar II Energy Center Raptor Nest Survey Report
Survey Area	Project Area and an Additional Buffer of 1.0 Mile
TRC	TRC Environmental Corporation
USFWS	United States Fish and Wildlife Service
USGS	United States Geological Survey



1.0 INTRODUCTION

On behalf of Hardin Solar Energy II LLC (HSE), TRC Environmental Corporation (TRC) has prepared this Hardin Solar II Energy Center Raptor Nest Survey Report (Report) as part of environmental studies conducted for the Hardin Solar II Energy Center (Project) located in Hardin County, Ohio. The proposed solar facility will generate up to 170 megawatts (MW) of power. The land is privately owned and is located approximately 2.5 miles (3.9 kilometers) southeast of Alger, in Hardin County, Ohio. The Project Area totals approximately 3,388 acres (1,371 hectares), including 396 acres (160 hectares) of underground collection corridors. The Project Area is a subset of the Survey Area, and is bisected by Township Road 120 (east/west) and is bounded by Township Road 100 on the north, County Road 65 on the east, and private landholdings to the south and west. The Project is located in Marion, McDonald, and Roundhead Townships, Hardin County, Ohio (Figure 1.1).

The objective of this desktop survey was to map previously known raptor nests within the Project Area and an additional surrounding buffer of 1.0 mile (1.6 kilometers), representing an area of 17,616 acres (5,369 hectares) (1 Mile Raptor Nest Survey Area [Survey Area]).

Within the Survey Area, elevations range from approximately 958 feet (292 meters) to 1,050 feet (320 meters) above mean sea level. Review of National Land Cover Database (NLCD) mapping (USGS 2016) indicates the Survey Area consists primarily of agricultural lands (95 percent cultivated crops). Generally, these conditions are not conducive to providing habitat for raptors (Cornell Lab of Ornithology 2018). Developed, open space accounted for three (3) percent; deciduous forest accounted for one (1) percent; and developed, low-, medium-, and high intensity; grassland/herbaceous and woody wetlands accounted for less than one (1) percent land cover (Table 1.1). Several large lakes that likely provide more suitable habitat for raptor nesting and foraging occur within 10 miles (16,093_meters) of the Survey Area.



Cover Type	Acres	Hectares	Percent (%)
Cultivated Crops	3,494.24	1,414.07	94.53
Deciduous Forest	52.18	21.12	1.41
Developed, Open Space	118.72	48.04	3.21
Developed, Medium Intensity	2.21	0.89	0.06
Developed, Low Intensity	23.76	9.62	0.64
Developed, High Intensity	0.03	0.01	< 0.01
Grassland/Herbaceous	5.22	2.11	0.14
Woody Wetlands	0.17	0.07	< 0.01
Total	3,696.53	1,495.93	100.00

Table 1.1Field-Verified National Land Cover Database Land Cover Types within the Hardin Solar II
Energy Center Study Area, Hardin County, Ohio, 2018.



Hardin Solar II Energy Center Raptor Nest Survey Report October 2018

Confidential Business Information



-38L

Page | 3



Coordinate System: NAD 1962 2011 StatePlane Oho South FIPS 2402 R US (Fort US) Map P Sotation: 0

2.0 METHODS

TRC conducted a desktop review of the *Hardin Wind Raptor Nest Survey Report* (Tetra Tech 2016) provided by HSE, as the Survey Area is completely within the area surveyed by Tetra Tech (2016) for the Hardin Wind Project. The results of the Tetra Tech (2016) Report are valid for five (5) years. In addition, information available from the United States Fish and Wildlife Service (USFWS) (USFWS 2018a) and Ohio Department of Natural Resources (ODNR 2018) on known eagle nests within the Survey Area and in the vicinity of the Survey Area was reviewed. A literature review and agency inquiry was performed to determine if records of historic nest sites were reported (ODNR-DOW, July 2, 2018; USFWS, June 25, 2018). In addition, TRC accessed the USFWS Information for Planning and Conservation (IPaC) tool (IPaC report, June 8, 2018).

The data regarding raptor nests was reviewed and raptor nests were searched for during on-the-ground subsequent field visits on May 16th, 18th, 22nd, 23rd, 29th, June 12th – 14th, and September 14th and 17th, 2018.

3.0 RESULTS

3.1 Agency Consultation Data

On June 8, 2018, TRC accessed the USFWS IPaC tool. Although the IPaC report identified the Study Area to be within known range of the bald eagle, no specific records were identified (USFWS 2018b). In addition, correspondence from the USFWS (USFWS 2018a) Technical Assistance Letter, dated June 25, 2018; and the ODNR Natural Heritage Database Review, dated July 2, 2018 did not identify known records of raptor nests within the Project's Survey Area or within a one-mile radius of the Survey Area.

3.2 Tetra Tech 2016 Raptor Nest Survey

Prior to conducting field surveys, Tetra Tech (2016) performed a desktop analysis of publicly available data and existing Project reports, including a review of Wildlife Baseline Protocol for the Proposed Hardin Wind Farm, Hardin County, Ohio (Carder and Good 2009) and the Hardin Wind Wildlife Baseline Report (Good et al 2009) (Tetra Tech 2016).

Tetra Tech (2016) then conducted raptor nest surveys between August 1, 2016 and August 4, 2016, along public roadways and within suitable raptor nest habitats, to locate new and known raptor nests and historical bald eagle (*Haliaeetus leucocephalus*) nests previously documented by the USFWS within suitable habitat. Suitable habitats included woodlots, forested riparian areas, shelterbelts, and utility poles. Nests were searched for and observed with binoculars and a spotting scope. The species and locations of nest sites were marked on United States Geological Survey (USGS) 1:24,000 topographic maps or aerial photograph field maps. Data recorded for each nest site included nest status (active or inactive), the number of adult and young present, species occupying the nest site, behavior of adults at the nest, nest condition (poor, fair, or good), nest location (geographic position system coordinates), and nest substrate. Definitions for active and inactive nests were not provided in the Tetra Tech (2016) report. For all active raptor nests that were identified, biologists exercised caution when in proximity to the nest to avoid disturbance to nesting raptors. Any raptor activity observed during the surveys was noted as an incidental observation and recorded using the global positioning system (GPS) (Tetra Tech 2016).

Review of the Tetra Tech (2016) report identified there were no raptor nests recorded within this Project's Survey Area. In addition, several raptor nests had been identified outside of but near the Survey Area in 2009, however in 2016, they were determined to be no longer present (Tetra Tech 2016). A historically documented USFWS bald eagle nest was located at France Lake and confirmed as unoccupied during the 2016 field survey (Tetra Tech 2016) (Figure 1.1). This nest is approximately 7.3 mi (11.7 km) from the

Project Area. The unoccupied status would be expected during the August window in which the survey was performed because most eaglets would have already fledged (USFWS Midwest Region 2018).

3.3 Summary

The desktop review of available sources determined there are no known raptor nests within the Survey Area. The subsequent field visits did not yield any additional raptor nest locations.

4.0 REFERENCES CITED

- Cornell University. 2018. *Birds of North America*. The Cornell Lab of Ornithology, New York. Web. 25 June 2018. birdsna.org/Species-Account/bna/species.
- Carder, M.L., and R.E. Good. 2009. *Wildlife Baseline Protocol for the Hardin Wind Farm, Hardin County, Ohi*o. Prepared for Invenergy, LLC by WEST, Inc. Revised Report June 25, 2009. 31 pp.
- Good, R.E., M. Rizert, and K. Bay. 2009. Wildlife Baseline Studies for the Hardin Wind Farm, Hardin County, Ohio. Prepared for Invenergy, LLC by WEST, Inc. Final Report September 3, 2008 – September 14, 2009. 100 pp.
- ODNR. 2018. Natural Heritage Database Environmental Review response from John Kessler dated July 2, 2018. Ohio Department of Natural Resources (ODNR) National Heritage Database (Wildlife, Ohio DNR Division of. "Ohio.gov / search." Ohio DNR Division of Wildlife. N.p., n.d. Web. 7 June 2018. http://wildlife.ohiodnr.gov/species-and-habitats/ohio-natural-heritage-database).
- USGS. 2016. Land Change Science Program: National Land Cover Database (NLCD). Washington D.C.: U.S. Department of the Interior, U.S. Geological Survey. Web. 25 June 2018. https://www2.usgs.gov/climate_landuse/lcs/projects/nlcd.asp.
- Tetra Tech. 2016. *Hardin Wind Energy Project Raptor Nest Survey Report Final.* Prepared for Hardin Wind, LLC. by Tetra Tech. Final Report October 27, 2016. 6 pp.
- USFWS. 2018a. Technical Assistance Letter from Scott Pruit dated June 25, 2018. TAILS: 03E15000-2018-TA-1543.
- USFWS. 2018b. Information for Planning and Conservation (IPaC). IPaC: Home. N.p., n.d. Web. 8 June. 2018. <u>https://ecos.fws.gov/ipac/.</u>
- USFWS Midwest Region. 2018. *Bald Eagle Conservation: Bald Eagle Natural History and Sensitivity to Human Activity Information*. Web. 30 September 2018. https://www.fws.gov/midwest/eagle/conservation/baea_nhstry_snstvty.html.

This foregoing document was electronically filed with the Public Utilities

Commission of Ohio Docketing Information System on

10/12/2018 10:47:12 AM

in

Case No(s). 18-1360-EL-BGN

Summary: Application Part 3 of 6, Exhibits A through G electronically filed by Christine M.T. Pirik on behalf of Hardin Solar Energy II LLC