

April 15, 2019

Ms. Barcy F. McNeal
Docketing Division
The Public Utilities Commission of Ohio
180 East Broad Street
Columbus, OH 43215-3793

Letter of Notification
Kirby-Roberts 138 kV Transmission Line
Loop to Crissinger Substation Project
Case No. 19-0803-EL-BLN

Dear Ms. McNeal:

In accordance with Ohio Administrative Code ("OAC") Rule 4906-2-04(A)(3) and OAC Chapter 4906-6, American Transmission Systems, Incorporated ("ATSI"), transmits five (5) paper copies and ten (10) copies on disc of the enclosed Letter of Notification application. The Letter of Notification application, which is attached, was completed in accordance with the requirements of OAC Chapter 4906-6.

In this Project, ATSI is proposing to construct approximately 6,900 feet (1.31 miles) of new transmission line to loop the existing Kirby-Roberts 138 kV Transmission Line into Crissinger Substation. In addition, the Project will expand Crissinger Substation from a four (4) breaker ringbus configuration to a six (6) breaker ringbus configuration requiring an approximately 11.8% expansion of the substation. The Project will be located in Pleasant Township, Green Camp Township, and Marion Township, Marion County, Ohio.

ATSI is requesting an expedited review of this Project.

Pursuant to OAC Rule 4906-2-04(A)(3), please be advised of the following:

a) Name and address of the applicants:

American Transmission Systems, Incorporated
76 South Main Street
Akron, Ohio 44308

b) Name and location of proposed facilities:

Crissinger-Kirby 138 kV Transmission Line
Crissinger-Roberts # 2 138 kV Transmission Line
Crissinger Substation

April 15, 2019

The Project area is located in Pleasant Township, Green Camp Township, and Marion Township, Marion County, Ohio.

c) Applicant's representative:

William R. Beutler, P.E.
Engineer III
Energy Delivery Transmission and Substation Design
FirstEnergy Service Company
76 South Main Street
Akron, OH 44308-1890

d) No information that was provided in the pre-application letter required by OAC Rule 4906-6-03 has been amended or changed in the attached Letter of Notification application.

e) A notarized statement that the information contained in the application is complete and accurate is attached as Attachment 1.

We have provided a copy of the Letter of Notification application by certified mail, with return receipt requested, to each official of the political subdivisions immediately affected by the proposed Project listed in Exhibit 1. Copies of the transmittal letters addressed to the local government representatives of Pleasant Township, Green Camp Township, and Marion Township, Marion County, Ohio are enclosed for your file. Copies of the transmittal letters to the local libraries are also enclosed. These materials are being provided as proof of compliance with OAC Rule 4906-6-07. A list of the property owners affected by the proposed Project and who will receive a letter describing this Project is attached as Exhibit 2. This is being provided as proof of compliance with OAC Rule 4906-6-08(B).

After docketing this filing, please return one time-stamped copy of the Letter of Notification for our records in the enclosed envelope. Should staff of the Ohio Power Siting Board desire further information or discussion of this submittal, please contact me at (330) 384-2740.

Sincerely,



William R. Beutler, P.E.
Engineer III
Energy Delivery Transmission and Substation Design
FirstEnergy Service Company

Attachments

**Kirby-Roberts 138 kV Transmission Lines Loop to Crissinger Project
Case Number 19-0803-EL-BLN**

Date: April 15, 2019

**Attachment 1
Affidavit of William R. Beutler**

In The Matter Of:)
The Application of American Transmission)
Systems, Incorporated for a Certificate of)
Environmental Compatibility and Public)
Need for the Construction for the Kirby-)
Roberts 138 kV Transmission Line Loop to)
Crissinger Substation Project)

AFFIDAVIT OF WILLIAM R. BEUTLER

William R. Beutler

State of Ohio)
) ss:
County of Summit)

A circular notarial seal for the State of Ohio. The outer ring contains the text "NOTARIAL SEAL" at the top and "STATE OF OHIO" at the bottom, separated by two stars. The center of the seal features a landscape with a sun rising over hills and a body of water.

Aslee E. White

2

Exhibit 1
Officials Served Copy of Letter of the Notification
Kirby-Roberts 138 kV Transmission Line
Loop to Crissinger Substation Project
Case No. 19-0803-EL-BLN

Marion County

Commissioner Kerr Murray
Marion County Commissioners
222 West Center Street
Marion, OH 43302

Mr. Bradley K. Irons, P.E., P.S.
Marion County Engineer
222 West Center Street
Marion, OH 43302

Commissioner Andy Appelfeller
Marion County Commissioners
222 West Center Street
Marion, OH 43302

Ms. Evelyn Warr-Cummings, Director
Marion County Planning Commission
222 West Center Street, 2nd Floor
Marion, OH 43302

Commissioner Ken Stiverson
Marion County Commissioners
222 West Center Street
Marion, OH 43302

Pleasant Township

Mr. David Schrote
Pleasant Township Trustee
1252 E Marion-Cardington Rd.
Marion, OH 43302

Mr. Wayne Creasap
Pleasant Township Trustee
2876 Smeltzer Rd.
Marion, OH 43302

Mr. Steve Lust
Pleasant Township Trustee
2650 W Newsman Cardington Rd.
Prospect, OH 43342

Mr. Lavon Verity
Pleasant Township Fiscal Officer
1035 Owens Road West
Marion, OH 43302

Green Camp Township

Mr. Steve Ruth
Green Camp Township Trustee
4245 Berry Rd
Marion, OH 43302

Mr. Thomas McBeth
Green Camp Township Trustee
P.O. Box 219
Green Camp, OH 43322

Ms. Virginia Ralph
Green Camp Township Trustee
P.O. Box 114
Green Camp, OH 43322

Ms. Mary McBeth
Green Camp Township Fiscal Officer
P. O. Box 219
Green Camp, OH 43322

Exhibit 1
Officials Served Copy of Letter of the Notification
Kirby-Roberts 138 kV Transmission Line
Loop to Crissinger Substation Project
Case No. 19-0803-EL-BLN

Marion Township

Mr. Larry Ballinger
Marion Township Trustee
1228 E. Fairground St
Marion, OH 43302

Mr. Lynn Thomas
Marion Township Trustee
1228 E. Fairground St
Marion, OH 43302

Ms. Karen McCleary
Marion Township Trustee
1228 E. Fairground St
Marion, OH 43302

Ms. Sheila Perin
Marion Township Fiscal Officer
1228 E. Fairground St
Marion, OH 43302

Library

Mr. Gary Branson
Marion Public Library
445 E Church St
Marion, OH 43302

April 15, 2019

Commissioner Kerr Murray
Marion County Commissioners
222 West Center Street
Marion, OH 43302

Letter of Notification
Kirby-Roberts 138 kV Transmission Line
Loop to Crissinger Substation Project
Case No. 19-0803-EL-BLN

Dear Commissioner Murray,

American Transmission Systems, Incorporated ("ATSI"), FirstEnergy company, has recently filed an application for a Certificate of Environmental Compatibility and Public Need from the Ohio Power Siting Board for the Kirby-Roberts 138 kV Transmission Line Loop to the Crissinger Substation Project. In this Project, ATSI is proposing to construct approximately 6,900 feet (1.31 miles) of new transmission line to loop the existing Kirby-Roberts 138 kV Transmission Line into the Crissinger Substation. In addition, the Project will expand Crissinger Substation from a four (4) breaker ringbus configuration to a six (6) breaker ringbus configuration requiring an approximately 11.8% expansion of the substation. The Project will be located in Pleasant Township, Green Camp Township, and Marion Township, Marion County, Ohio.

In accordance with Ohio Administrative Code ("OAC") Rule 4906-1-01, this Project falls within the Ohio Power Siting Board's requirements for a Letter of Notification application. Therefore, in compliance with OAC Chapter 4906-6, we have prepared and filed the attached application with the OPSB for their review and approval. The application contains a description of the Project and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2740.

Sincerely,



William R. Beutler, P.E.
Engineer III
Energy Delivery Transmission & Substation Design
FirstEnergy Service Company

Attachment

April 15, 2019

Commissioner Andy Appelfeller
Marion County Commissioners
222 West Center Street
Marion, OH 43302

Letter of Notification
Kirby-Roberts 138 kV Transmission Line
Loop to Crissinger Substation Project
Case No. 19-0803-EL-BLN

Dear Commissioner Appelfeller,

American Transmission Systems, Incorporated ("ATSI"), FirstEnergy company, has recently filed an application for a Certificate of Environmental Compatibility and Public Need from the Ohio Power Siting Board for the Kirby-Roberts 138 kV Transmission Line Loop to the Crissinger Substation Project. In this Project, ATSI is proposing to construct approximately 6,900 feet (1.31 miles) of new transmission line to loop the existing Kirby-Roberts 138 kV Transmission Line into the Crissinger Substation. In addition, the Project will expand Crissinger Substation from a four (4) breaker ringbus configuration to a six (6) breaker ringbus configuration requiring an approximately 11.8% expansion of the substation. The Project will be located in Pleasant Township, Green Camp Township, and Marion Township, Marion County, Ohio.

In accordance with Ohio Administrative Code ("OAC") Rule 4906-1-01, this Project falls within the Ohio Power Siting Board's requirements for a Letter of Notification application. Therefore, in compliance with OAC Chapter 4906-6, we have prepared and filed the attached application with the OPSB for their review and approval. The application contains a description of the Project and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2740.

Sincerely,

William R. Beutler

William R. Beutler, P.E.

Engineer III

Energy Delivery Transmission & Substation Design

FirstEnergy Service Company

Attachment

April 15, 2019

Commissioner Ken Stiverson
Marion County Commissioners
222 West Center Street
Marion, OH 43302

Letter of Notification
Kirby-Roberts 138 kV Transmission Line
Loop to Crissinger Substation Project
Case No. 19-0803-EL-BLN

Dear Commissioner Stiverson,

American Transmission Systems, Incorporated ("ATSI"), FirstEnergy company, has recently filed an application for a Certificate of Environmental Compatibility and Public Need from the Ohio Power Siting Board for the Kirby-Roberts 138 kV Transmission Line Loop to the Crissinger Substation Project. In this Project, ATSI is proposing to construct approximately 6,900 feet (1.31 miles) of new transmission line to loop the existing Kirby-Roberts 138 kV Transmission Line into the Crissinger Substation. In addition, the Project will expand Crissinger Substation from a four (4) breaker ringbus configuration to a six (6) breaker ringbus configuration requiring an approximately 11.8% expansion of the substation. The Project will be located in Pleasant Township, Green Camp Township, and Marion Township, Marion County, Ohio.

In accordance with Ohio Administrative Code ("OAC") Rule 4906-1-01, this Project falls within the Ohio Power Siting Board's requirements for a Letter of Notification application. Therefore, in compliance with OAC Chapter 4906-6, we have prepared and filed the attached application with the OPSB for their review and approval. The application contains a description of the Project and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2740.

Sincerely,

William R. Beutler

William R. Beutler, P.E.

Engineer III

Energy Delivery Transmission & Substation Design

FirstEnergy Service Company

Attachment

April 15, 2019

Mr. Bradley K. Irons, P.E., P.S.
Marion County Engineer
222 West Center Street
Marion, OH 43302

Letter of Notification
Kirby-Roberts 138 kV Transmission Line
Loop to Crissinger Substation Project
Case No. 19-0803-EL-BLN

Dear Mr. Irons,

American Transmission Systems, Incorporated ("ATSI"), FirstEnergy company, has recently filed an application for a Certificate of Environmental Compatibility and Public Need from the Ohio Power Siting Board for the Kirby-Roberts 138 kV Transmission Line Loop to the Crissinger Substation Project. In this Project, ATSI is proposing to construct approximately 6,900 feet (1.31 miles) of new transmission line to loop the existing Kirby-Roberts 138 kV Transmission Line into the Crissinger Substation. In addition, the Project will expand Crissinger Substation from a four (4) breaker ringbus configuration to a six (6) breaker ringbus configuration requiring an approximately 11.8% expansion of the substation. The Project will be located in Pleasant Township, Green Camp Township, and Marion Township, Marion County, Ohio.

In accordance with Ohio Administrative Code ("OAC") Rule 4906-1-01, this Project falls within the Ohio Power Siting Board's requirements for a Letter of Notification application. Therefore, in compliance with OAC Chapter 4906-6, we have prepared and filed the attached application with the OPSB for their review and approval. The application contains a description of the Project and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2740.

Sincerely,

William R. Beutler

William R. Beutler, P.E.
Engineer III
Energy Delivery Transmission & Substation Design
FirstEnergy Service Company

Attachment

April 15, 2019

Ms. Evelyn Warr-Cummings, Director
Marion County Planning Commission
222 West Center Street, 2nd Floor
Marion, OH 43302

Letter of Notification
Kirby-Roberts 138 kV Transmission Line
Loop to Crissinger Substation Project
Case No. 19-0803-EL-BLN

Dear Ms. Warr-Cummings,

American Transmission Systems, Incorporated ("ATSI"), FirstEnergy company, has recently filed an application for a Certificate of Environmental Compatibility and Public Need from the Ohio Power Siting Board for the Kirby-Roberts 138 kV Transmission Line Loop to the Crissinger Substation Project. In this Project, ATSI is proposing to construct approximately 6,900 feet (1.31 miles) of new transmission line to loop the existing Kirby-Roberts 138 kV Transmission Line into the Crissinger Substation. In addition, the Project will expand Crissinger Substation from a four (4) breaker ringbus configuration to a six (6) breaker ringbus configuration requiring an approximately 11.8% expansion of the substation. The Project will be located in Pleasant Township, Green Camp Township, and Marion Township, Marion County, Ohio.

In accordance with Ohio Administrative Code ("OAC") Rule 4906-1-01, this Project falls within the Ohio Power Siting Board's requirements for a Letter of Notification application. Therefore, in compliance with OAC Chapter 4906-6, we have prepared and filed the attached application with the OPSB for their review and approval. The application contains a description of the Project and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2740.

Sincerely,

William R. Beutler

William R. Beutler, P.E.

Engineer III

Energy Delivery Transmission & Substation Design

FirstEnergy Service Company

Attachment

April 15, 2019

Mr. David Schrote
Pleasant Township Trustee
1252 E Marion-Cardington Rd.
Marion, OH 43302

Letter of Notification
Kirby-Roberts 138 kV Transmission Line
Loop to Crissinger Substation Project
Case No. 19-0803-EL-BLN

Dear Mr. Schrote,

American Transmission Systems, Incorporated ("ATSI"), FirstEnergy company, has recently filed an application for a Certificate of Environmental Compatibility and Public Need from the Ohio Power Siting Board for the Kirby-Roberts 138 kV Transmission Line Loop to the Crissinger Substation Project. In this Project, ATSI is proposing to construct approximately 6,900 feet (1.31 miles) of new transmission line to loop the existing Kirby-Roberts 138 kV Transmission Line into the Crissinger Substation. In addition, the Project will expand Crissinger Substation from a four (4) breaker ringbus configuration to a six (6) breaker ringbus configuration requiring an approximately 11.8% expansion of the substation. The Project will be located in Pleasant Township, Green Camp Township, and Marion Township, Marion County, Ohio.

In accordance with Ohio Administrative Code ("OAC") Rule 4906-1-01, this Project falls within the Ohio Power Siting Board's requirements for a Letter of Notification application. Therefore, in compliance with OAC Chapter 4906-6, we have prepared and filed the attached application with the OPSB for their review and approval. The application contains a description of the Project and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2740.

Sincerely,

William R. Beutler

William R. Beutler, P.E.
Engineer III
Energy Delivery Transmission & Substation Design
FirstEnergy Service Company

Attachment

April 15, 2019

Mr. Steve Lust
Pleasant Township Trustee
2650 W Newsman Cardington Rd.
Prospect, OH 43342

Letter of Notification
Kirby-Roberts 138 kV Transmission Line
Loop to Crissinger Substation Project
Case No. 19-0803-EL-BLN

Dear Mr. Lust,

American Transmission Systems, Incorporated ("ATSI"), FirstEnergy company, has recently filed an application for a Certificate of Environmental Compatibility and Public Need from the Ohio Power Siting Board for the Kirby-Roberts 138 kV Transmission Line Loop to the Crissinger Substation Project. In this Project, ATSI is proposing to construct approximately 6,900 feet (1.31 miles) of new transmission line to loop the existing Kirby-Roberts 138 kV Transmission Line into the Crissinger Substation. In addition, the Project will expand Crissinger Substation from a four (4) breaker ringbus configuration to a six (6) breaker ringbus configuration requiring an approximately 11.8% expansion of the substation. The Project will be located in Pleasant Township, Green Camp Township, and Marion Township, Marion County, Ohio.

In accordance with Ohio Administrative Code ("OAC") Rule 4906-1-01, this Project falls within the Ohio Power Siting Board's requirements for a Letter of Notification application. Therefore, in compliance with OAC Chapter 4906-6, we have prepared and filed the attached application with the OPSB for their review and approval. The application contains a description of the Project and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2740.

Sincerely,



William R. Beutler, P.E.
Engineer III
Energy Delivery Transmission & Substation Design
FirstEnergy Service Company

Attachment

April 15, 2019

Mr. Wayne Creasap
Pleasant Township Trustee
2876 Smeltzer Rd.
Marion, OH 43302

Letter of Notification
Kirby-Roberts 138 kV Transmission Line
Loop to Crissinger Substation Project
Case No. 19-0803-EL-BLN

Dear Mr. Creasap,

American Transmission Systems, Incorporated ("ATSI"), FirstEnergy company, has recently filed an application for a Certificate of Environmental Compatibility and Public Need from the Ohio Power Siting Board for the Kirby-Roberts 138 kV Transmission Line Loop to the Crissinger Substation Project. In this Project, ATSI is proposing to construct approximately 6,900 feet (1.31 miles) of new transmission line to loop the existing Kirby-Roberts 138 kV Transmission Line into the Crissinger Substation. In addition, the Project will expand Crissinger Substation from a four (4) breaker ringbus configuration to a six (6) breaker ringbus configuration requiring an approximately 11.8% expansion of the substation. The Project will be located in Pleasant Township, Green Camp Township, and Marion Township, Marion County, Ohio.

In accordance with Ohio Administrative Code ("OAC") Rule 4906-1-01, this Project falls within the Ohio Power Siting Board's requirements for a Letter of Notification application. Therefore, in compliance with OAC Chapter 4906-6, we have prepared and filed the attached application with the OPSB for their review and approval. The application contains a description of the Project and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2740.

Sincerely,



William R. Beutler, P.E.

Engineer III

Energy Delivery Transmission & Substation Design
FirstEnergy Service Company

Attachment

April 15, 2019

Mr. Lavon Verity
Pleasant Township Fiscal Officer
1035 Owens Road West
Marion, OH 43302

Letter of Notification
Kirby-Roberts 138 kV Transmission Line
Loop to Crissinger Substation Project
Case No. 19-0803-EL-BLN


Dear Mr. Verity,

American Transmission Systems, Incorporated ("ATSI"), FirstEnergy company, has recently filed an application for a Certificate of Environmental Compatibility and Public Need from the Ohio Power Siting Board for the Kirby-Roberts 138 kV Transmission Line Loop to the Crissinger Substation Project. In this Project, ATSI is proposing to construct approximately 6,900 feet (1.31 miles) of new transmission line to loop the existing Kirby-Roberts 138 kV Transmission Line into the Crissinger Substation. In addition, the Project will expand Crissinger Substation from a four (4) breaker ringbus configuration to a six (6) breaker ringbus configuration requiring an approximately 11.8% expansion of the substation. The Project will be located in Pleasant Township, Green Camp Township, and Marion Township, Marion County, Ohio.

In accordance with Ohio Administrative Code ("OAC") Rule 4906-1-01, this Project falls within the Ohio Power Siting Board's requirements for a Letter of Notification application. Therefore, in compliance with OAC Chapter 4906-6, we have prepared and filed the attached application with the OPSB for their review and approval. The application contains a description of the Project and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2740.

Sincerely,



William R. Beutler, P.E.

Engineer III

Energy Delivery Transmission & Substation Design
FirstEnergy Service Company

Attachment

April 15, 2019

Mr. Steve Ruth
Green Camp Township Trustee
4245 Berry Rd
Marion, OH 43302

Letter of Notification
Kirby-Roberts 138 kV Transmission Line
Loop to Crissinger Substation Project
Case No. 19-0803-EL-BLN

Dear Mr. Ruth,

American Transmission Systems, Incorporated ("ATSI"), FirstEnergy company, has recently filed an application for a Certificate of Environmental Compatibility and Public Need from the Ohio Power Siting Board for the Kirby-Roberts 138 kV Transmission Line Loop to the Crissinger Substation Project. In this Project, ATSI is proposing to construct approximately 6,900 feet (1.31 miles) of new transmission line to loop the existing Kirby-Roberts 138 kV Transmission Line into the Crissinger Substation. In addition, the Project will expand Crissinger Substation from a four (4) breaker ringbus configuration to a six (6) breaker ringbus configuration requiring an approximately 11.8% expansion of the substation. The Project will be located in Pleasant Township, Green Camp Township, and Marion Township, Marion County, Ohio.

In accordance with Ohio Administrative Code ("OAC") Rule 4906-1-01, this Project falls within the Ohio Power Siting Board's requirements for a Letter of Notification application. Therefore, in compliance with OAC Chapter 4906-6, we have prepared and filed the attached application with the OPSB for their review and approval. The application contains a description of the Project and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2740.

Sincerely,



William R. Beutler, P.E.

Engineer III

Energy Delivery Transmission & Substation Design
FirstEnergy Service Company

Attachment

April 15, 2019

Ms. Virginia Ralph
Green Camp Township Trustee
P.O. Box 114
Green Camp, OH 43322

Letter of Notification
Kirby-Roberts 138 kV Transmission Line
Loop to Crissinger Substation Project
Case No. 19-0803-EL-BLN


Dear Ms. Ralph,

American Transmission Systems, Incorporated ("ATSI"), FirstEnergy company, has recently filed an application for a Certificate of Environmental Compatibility and Public Need from the Ohio Power Siting Board for the Kirby-Roberts 138 kV Transmission Line Loop to the Crissinger Substation Project. In this Project, ATSI is proposing to construct approximately 6,900 feet (1.31 miles) of new transmission line to loop the existing Kirby-Roberts 138 kV Transmission Line into the Crissinger Substation. In addition, the Project will expand Crissinger Substation from a four (4) breaker ringbus configuration to a six (6) breaker ringbus configuration requiring an approximately 11.8% expansion of the substation. The Project will be located in Pleasant Township, Green Camp Township, and Marion Township, Marion County, Ohio.

In accordance with Ohio Administrative Code ("OAC") Rule 4906-1-01, this Project falls within the Ohio Power Siting Board's requirements for a Letter of Notification application. Therefore, in compliance with OAC Chapter 4906-6, we have prepared and filed the attached application with the OPSB for their review and approval. The application contains a description of the Project and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2740.

Sincerely,



William R. Beutler, P.E.

Engineer III

Energy Delivery Transmission & Substation Design
FirstEnergy Service Company

Attachment

April 15, 2019

Mr. Thomas McBeth
Green Camp Township Trustee
P.O. Box 219
Green Camp, OH 43322

Letter of Notification
Kirby-Roberts 138 kV Transmission Line
Loop to Crissinger Substation Project
Case No. 19-0803-EL-BLN

Dear Mr. McBeth ,

American Transmission Systems, Incorporated ("ATSI"), FirstEnergy company, has recently filed an application for a Certificate of Environmental Compatibility and Public Need from the Ohio Power Siting Board for the Kirby-Roberts 138 kV Transmission Line Loop to the Crissinger Substation Project. In this Project, ATSI is proposing to construct approximately 6,900 feet (1.31 miles) of new transmission line to loop the existing Kirby-Roberts 138 kV Transmission Line into the Crissinger Substation. In addition, the Project will expand Crissinger Substation from a four (4) breaker ringbus configuration to a six (6) breaker ringbus configuration requiring an approximately 11.8% expansion of the substation. The Project will be located in Pleasant Township, Green Camp Township, and Marion Township, Marion County, Ohio.

In accordance with Ohio Administrative Code ("OAC") Rule 4906-1-01, this Project falls within the Ohio Power Siting Board's requirements for a Letter of Notification application. Therefore, in compliance with OAC Chapter 4906-6, we have prepared and filed the attached application with the OPSB for their review and approval. The application contains a description of the Project and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2740.

Sincerely,



William R. Beutler, P.E.

Engineer III

Energy Delivery Transmission & Substation Design
FirstEnergy Service Company

Attachment

April 15, 2019

Ms. Mary McBeth, Fiscal Officer
Green Camp Township
P. O. Box 219
Green Camp, OH 43322

Letter of Notification
Kirby-Roberts 138 kV Transmission Line
Loop to Crissinger Substation Project
Case No. 19-0803-EL-BLN

Dear Ms. McBeth,

American Transmission Systems, Incorporated ("ATSI"), FirstEnergy company, has recently filed an application for a Certificate of Environmental Compatibility and Public Need from the Ohio Power Siting Board for the Kirby-Roberts 138 kV Transmission Line Loop to the Crissinger Substation Project. In this Project, ATSI is proposing to construct approximately 6,900 feet (1.31 miles) of new transmission line to loop the existing Kirby-Roberts 138 kV Transmission Line into the Crissinger Substation. In addition, the Project will expand Crissinger Substation from a four (4) breaker ringbus configuration to a six (6) breaker ringbus configuration requiring an approximately 11.8% expansion of the substation. The Project will be located in Pleasant Township, Green Camp Township, and Marion Township, Marion County, Ohio.

In accordance with Ohio Administrative Code ("OAC") Rule 4906-1-01, this Project falls within the Ohio Power Siting Board's requirements for a Letter of Notification application. Therefore, in compliance with OAC Chapter 4906-6, we have prepared and filed the attached application with the OPSB for their review and approval. The application contains a description of the Project and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2740.

Sincerely,



William R. Beutler, P.E.

Engineer III

Energy Delivery Transmission & Substation Design
FirstEnergy Service Company

Attachment

April 15, 2019

Mr. Larry Ballinger
Marion Township Trustee
1228 E. Fairground St
Marion, OH 43302

Letter of Notification
Kirby-Roberts 138 kV Transmission Line
Loop to Crissinger Substation Project
Case No. 19-0803-EL-BLN

Dear Mr. Ballinger,

American Transmission Systems, Incorporated ("ATSI"), FirstEnergy company, has recently filed an application for a Certificate of Environmental Compatibility and Public Need from the Ohio Power Siting Board for the Kirby-Roberts 138 kV Transmission Line Loop to the Crissinger Substation Project. In this Project, ATSI is proposing to construct approximately 6,900 feet (1.31 miles) of new transmission line to loop the existing Kirby-Roberts 138 kV Transmission Line into the Crissinger Substation. In addition, the Project will expand Crissinger Substation from a four (4) breaker ringbus configuration to a six (6) breaker ringbus configuration requiring an approximately 11.8% expansion of the substation. The Project will be located in Pleasant Township, Green Camp Township, and Marion Township, Marion County, Ohio.

In accordance with Ohio Administrative Code ("OAC") Rule 4906-1-01, this Project falls within the Ohio Power Siting Board's requirements for a Letter of Notification application. Therefore, in compliance with OAC Chapter 4906-6, we have prepared and filed the attached application with the OPSB for their review and approval. The application contains a description of the Project and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2740.

Sincerely,



William R. Beutler, P.E.

Engineer III

Energy Delivery Transmission & Substation Design
FirstEnergy Service Company

Attachment

April 15, 2019

Ms. Karen McCleary
Marion Township Trustee
1228 E. Fairground St
Marion, OH 43302

Letter of Notification
Kirby-Roberts 138 kV Transmission Line
Loop to Crissinger Substation Project
Case No. 19-0803-EL-BLN

Dear Ms. McCleary,

American Transmission Systems, Incorporated ("ATSI"), FirstEnergy company, has recently filed an application for a Certificate of Environmental Compatibility and Public Need from the Ohio Power Siting Board for the Kirby-Roberts 138 kV Transmission Line Loop to the Crissinger Substation Project. In this Project, ATSI is proposing to construct approximately 6,900 feet (1.31 miles) of new transmission line to loop the existing Kirby-Roberts 138 kV Transmission Line into the Crissinger Substation. In addition, the Project will expand Crissinger Substation from a four (4) breaker ringbus configuration to a six (6) breaker ringbus configuration requiring an approximately 11.8% expansion of the substation. The Project will be located in Pleasant Township, Green Camp Township, and Marion Township, Marion County, Ohio.

In accordance with Ohio Administrative Code ("OAC") Rule 4906-1-01, this Project falls within the Ohio Power Siting Board's requirements for a Letter of Notification application. Therefore, in compliance with OAC Chapter 4906-6, we have prepared and filed the attached application with the OPSB for their review and approval. The application contains a description of the Project and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2740.

Sincerely,



William R. Beutler, P.E.
Engineer III
Energy Delivery Transmission & Substation Design
FirstEnergy Service Company

Attachment

April 15, 2019

Mr. Lynn Thomas
Marion Township Trustee
1228 E. Fairground St
Marion, OH 43302

Letter of Notification
Kirby-Roberts 138 kV Transmission Line
Loop to Crissinger Substation Project
Case No. 19-0803-EL-BLN

Dear Mr. Thomas,

American Transmission Systems, Incorporated ("ATSI"), FirstEnergy company, has recently filed an application for a Certificate of Environmental Compatibility and Public Need from the Ohio Power Siting Board for the Kirby-Roberts 138 kV Transmission Line Loop to the Crissinger Substation Project. In this Project, ATSI is proposing to construct approximately 6,900 feet (1.31 miles) of new transmission line to loop the existing Kirby-Roberts 138 kV Transmission Line into the Crissinger Substation. In addition, the Project will expand Crissinger Substation from a four (4) breaker ringbus configuration to a six (6) breaker ringbus configuration requiring an approximately 11.8% expansion of the substation. The Project will be located in Pleasant Township, Green Camp Township, and Marion Township, Marion County, Ohio.

In accordance with Ohio Administrative Code ("OAC") Rule 4906-1-01, this Project falls within the Ohio Power Siting Board's requirements for a Letter of Notification application. Therefore, in compliance with OAC Chapter 4906-6, we have prepared and filed the attached application with the OPSB for their review and approval. The application contains a description of the Project and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2740.

Sincerely,



William R. Beutler, P.E.
Engineer III
Energy Delivery Transmission & Substation Design
FirstEnergy Service Company

Attachment

April 15, 2019

Ms. Sheila Perin
Marion Township Fiscal Officer
1228 E. Fairground St
Marion, OH 43302

Letter of Notification
Kirby-Roberts 138 kV Transmission Line
Loop to Crissinger Substation Project
Case No. 19-0803-EL-BLN

Dear Ms. Perin,

American Transmission Systems, Incorporated ("ATSI"), FirstEnergy company, has recently filed an application for a Certificate of Environmental Compatibility and Public Need from the Ohio Power Siting Board for the Kirby-Roberts 138 kV Transmission Line Loop to the Crissinger Substation Project. In this Project, ATSI is proposing to construct approximately 6,900 feet (1.31 miles) of new transmission line to loop the existing Kirby-Roberts 138 kV Transmission Line into the Crissinger Substation. In addition, the Project will expand Crissinger Substation from a four (4) breaker ringbus configuration to a six (6) breaker ringbus configuration requiring an approximately 11.8% expansion of the substation. The Project will be located in Pleasant Township, Green Camp Township, and Marion Township, Marion County, Ohio.

In accordance with Ohio Administrative Code ("OAC") Rule 4906-1-01, this Project falls within the Ohio Power Siting Board's requirements for a Letter of Notification application. Therefore, in compliance with OAC Chapter 4906-6, we have prepared and filed the attached application with the OPSB for their review and approval. The application contains a description of the Project and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2740.

Sincerely,



William R. Beutler, P.E.
Engineer III
Energy Delivery Transmission & Substation Design
FirstEnergy Service Company

Attachment



76 South Main Street
Akron, Ohio 44308

HP LaserJet P1505

1-800-646-0400

Self Test / Configuration

Product Information

Product Name: = HP LaserJet P1505
Formatter Number: = CA9530P
Product Serial Number: = VNB3J03483
Service ID: = 18190
Firmware Version: = 20100617
Max Print Resolution: = FastRes 1200

Memory

Total Memory: = 2 MBytes
Available Memory: = 0 MBytes

Counters

Total Pages printed = 38250
Input Jams = 3
Output Jams = 0
Narrow Media Page Count = 2
Cartridge Jams = 0
Average Job Size = 2.43
Total Jobs Printed = 15701
Average Coverage = 5

Status Log

Code	Page
10.3000	37660
10.3000	37615
10.3000	37468
10.3000	37467
10.3000	37443

April 15, 2019

Mr. Gary Branson
Marion Public Library
445 E Church St
Marion, OH 43302

Letter of Notification
Kirby-Roberts 138 kV Transmission Line
Loop to Crissinger Substation Project
Case No. 19-0803-EL-BLN

Dear Mr. Gary Branson,

Enclosed please find one copy of the Letter of Notification application of American Transmission Systems, Incorporated ("ATSI"), a FirstEnergy company, for the Kirby-Roberts 138 kV Transmission Line Loop to Crissinger Substation Project ("Project") that has been filed with the Ohio Power Siting Board ("OPSB"). Please make the Letter of Notification application available for public reference in the Marion Public Library. We are providing a copy of the Letter of Notification application for placement in your library in response to the requirements of the Ohio Administrative Code ("OAC") Rule 4906-6-07(A)(2), which requires us to place a copy of the Letter of Notification application in the main public libraries of the political subdivisions in which any portion of the Project is located.

As described in the application, the Project proposes to construct approximately 6,900 feet (1.31 miles) of new transmission line to loop the existing Kirby-Roberts 138 kV Transmission Line into the Crissinger Substation. In addition, the Project will expand Crissinger Substation from a four (4) breaker ringbus configuration to a six (6) breaker ringbus configuration requiring an approximately 11.8% expansion of the substation. The Project will be located in Pleasant Township, Green Camp Township, and Marion Township, Marion County, Ohio.

Please feel free to call me with any question you have on making the Letter of Notification application available to your patrons. My phone number is (330) 384-2740.

Sincerely,

William R. Beutler

William R. Beutler, P.E.
Engineer III
Energy Delivery Transmission and
Substation Design
FirstEnergy Service Company

Enclosure

Exhibit 2
Property Owners Served Notice Letters on the Notification
Kirby-Roberts 138 kV Transmission Line
Loop to Crissinger Substation Project
Case No. 19-0803-EL-BLN

Property Owners

Parcel: 100040000400, & 250110000400

Ohio Department of Natural Resources
2045 Morse Rd, Bldg C4,
Columbus, OH 43229

Parcel: 250110000100, & 170080004600

Pheasants Forever Inc.
1783 Buerkle Circle,
St Paul, MN 55110

Parcel: 250830600300, & 250830600200

Ohio Edison
800 Cabin Hill Dr,
Greensburg, PA 15601

Parcel: 170080004700

David D Beaver, Etal
359 W Newmans Cardington Rd,
Prospect, OH 43342

Parcel: 170080004700

David D Beaver, Etal
2105 Marion green Camp Rd,
Marion, OH 43302

Parcel: 170080004500

Lynn M Clabaugh, Etal
572 Campbell Rd,
Marion, OH 43302

This foregoing document was electronically filed with the Public Utilities

Commission of Ohio Docketing Information System on

4/15/2019 1:24:25 PM

in

Case No(s). 19-0803-EL-BLN

Summary: Application for Certificate of Environmental Compatibility and Public Need (Part 1 of 4) electronically filed by Mr. Robert J Schmidt on behalf of American Transmission Systems Inc.