



Legal Department

American Electric Power
1 Riverside Plaza
Columbus, OH 43215-2373
AEP.com

May 7, 2019

Chairman Sam Randazzo
Ohio Power Siting Board
180 East Broad Street
Columbus, Ohio 43215-3793

Christen M. Blend
Senior Counsel –
Regulatory Services
(614) 716-1915 (P)
cmblend@aep.com

**RE: Case No. 16-1557-EL-BTX
West Bellaire-Glencoe 138 kV Transmission Line Project
Notice of Adjustments**

Dear Chairman Randazzo:

After consulting with OPSB Staff, AEP Ohio Transmission Company, Inc. (“AEP Ohio Transco”) provides the following notice of adjustments to structures associated with the above referenced Project.

AEP Ohio Transco proposes to adjust 4 structures along the West Bellaire-Glencoe 138kV Transmission Line. Structure 55A will shift 20 feet north and Structure 65 will shift 25 feet west to obtain more clearance from a stream. Structures 38 and 39 will shift 10 feet north to avoid an abandoned mine discovered under their original locations. The proposed adjustments do not affect any new property owners, require any additional tree clearing, require any new right-of-way, or impact additional wetlands or streams.

Please let me know if you have any questions or need additional information.

Respectfully submitted,







/s/ Christen M. Blend

Christen M. Blend (0086881), Counsel of Record







Counsel for AEP Ohio Transmission Company, Inc.

cc: John Jones, Counsel OPSB Staff
Jon Pawley, OPSB Staff



 Engineered Structure  OPSB Approved Centerline	OSIP Imagery		Figure 1 Structure 38 & 39
	Ohio State Plane, South NAD 83, Feet 		 Glencoe - West Bellaire 138kV Line
	April 18, 2019		



 Engineered Structure  OPSB Approved Centerline	OSIP Imagery		Figure 2 Structure 55A
	Ohio State Plane, South NAD 83, Feet 		 Glencoe - West Bellaire 138kV Line
	April 18, 2019		



<ul style="list-style-type: none">Engineered StructureOPSB Approved Centerline	OSIP Imagery		Figure 3 Structure 65	
	Ohio State Plane, South NAD 83, Feet			 Glencoe - West Bellaire 138kV Line
	April 18, 2019			 0 30 60 120 Feet

This foregoing document was electronically filed with the Public Utilities

Commission of Ohio Docketing Information System on

5/7/2019 3:00:19 PM

in

Case No(s). 16-1557-EL-BTX

Summary: Notice - Notice of Adjustment for West Bellaire-Glencoe 138 kV Transmission Line Project electronically filed by Ms. Christen M. Blend on behalf of AEP Ohio Transmission Company, Inc.