

June 3, 2019

Ms. Barcy F. McNeal  
Docketing Division  
The Public Utilities Commission of Ohio  
180 East Broad Street  
Columbus, OH 43215-3793

**PRE-APPLICATION NOTIFICATION LETTER**  
**Lordstown-Sammis 345 kV Loop to Wellsville Substation Project**  
**Case No. 19-0802-EL-BNR**

PUCO

2019 JUN -5 PM 12:16

RECEIVED-DOCKETING DIV

Dear Ms. McNeal:

In accordance with Ohio Administrative Code ("OAC") Rule 4906-6-03(A) and OAC Chapter 4906-6 generally, this letter will serve as the pre-application notice letter of applicant American Transmission Systems, Incorporated ("ATSI"), a FirstEnergy company, for the above referenced Project. ATSI expects to file a Construction Notice application with the Ohio Power Siting Board shortly.

ATSI proposes to extend a loop from the existing Lordstown-Sammis 345 kV Transmission Line approximately 725 feet (0.14 mile) in length to the new interconnection switchyard for the South Field Energy-Wellsville facility, which will be known as the Wellsville Substation, creating Lordstown-Wellsville 345 kV and Sammis-Wellsville 345 kV Transmission Lines. The transmission line loop will require the installation of two (2) new 3-pole steel deadend structures on concrete foundation and two (2) new 2-pole H-Frame steel tangent structures on concrete foundation. The Project will be located in the Village of Wellsville, Columbiana County, Ohio.

Construction on this Project is expected to begin as early as September 30, 2019 and completed by May 31, 2020.

Sincerely,



Nataliya Bryksenkova  
Engineer  
Energy Delivery  
Transmission and Substation Design  
FirstEnergy Service Company

This is to certify that the images appearing are an accurate and complete reproduction of a case file document delivered in the regular course of business.  
Technician MA Date Processed JUN 05 2019