



76 South Main Street
Akron, Ohio 44308

1-800-646-0400

September 9, 2019

Ms. Barcy F. McNeal
Docketing Division
The Public Utilities Commission of Ohio
180 East Broad Street
Columbus, OH 43215-3793

PUCO

2019 SEP 10 AM 11:23

RECEIVED-DOCKETING DIV

Letter of Notification
Fostoria West End (AEP)-Lemoyne-West Fremont 138kV Transmission Line
and Woodville No. 2 Substation Upgrade Project
Case No. 19-1337-EL-BLN

Dear Ms. McNeal:

In accordance with Ohio Administrative Code ("OAC") Rule 4906-2-04(A)(3) and OAC Chapter 4906-6, American Transmission Systems, Incorporated ("ATSI"), a FirstEnergy company, transmits five (5) paper copies and ten (10) digital copies on compact disc of the enclosed Letter of Notification application which was electronically filed. The Letter of Notification application was completed in accordance with the requirements of the OAC Chapter 4906-06.

In this Project, ATSI proposes the expansion of the existing Woodville No. 2 138kV Substation to convert the substation to a five (5) breaker ring bus and to eliminate the existing Fostoria West End (AEP)-Lemoyne-West Fremont four-terminal line configuration. The existing Woodville No. 2 138kV Substation is proposed to expand by 223% to facilitate the installation of new equipment. This Project will also involve replacing structures and rebuilding a 3.1-mile section of the Fostoria West End (AEP)-Lemoyne-West Fremont 138kV line from single circuit to double circuit. The Project will be located in Woodville Township, Sandusky County, Ohio and Troy Township, Wood County, Ohio.

Pursuant to OAC Rule 4906-2-04(A)(3), please be advised of the following:

a) Name and address of the applicant:

American Transmission Systems, Incorporated
76 South Main Street
Akron, Ohio 44308

b) Name and location of proposed facilities:

Fostoria West End (AEP)-Lemoyne-West Fremont 138kV Transmission Line and
Woodville No. 2 Substation Upgrade Project.

This is to certify that the images appearing are an
accurate and complete reproduction of the file
document submitted in the public utility case.
Technician A Date Processed 9/10/19

c) Applicant's representative:

Robert J. Maggiore, Transmission Specialist II
Energy Delivery
Transmission and Substation Design
FirstEnergy Service Company
76 South Main Street
Akron, OH 44308-1890

d) No information that was provided in the pre-application letter required by OAC Rule 4906-6-03 has been amended or changed in the attached Letter of Notification application. The name of the Project was corrected to more accurately reflect the Project.

e) A notarized statement that the information contained in the application is complete and accurate is provided as Attachment 1.

We have provided a copy of the Letter of Notification application by certified mail, with return receipt requested, to each official of the political subdivisions immediately affected by the proposed Project listed in Exhibit 1. Copies of the transmittal letters addressed to the local government representatives of Woodville Township, Sandusky County, Ohio and Troy Township, Wood County, Ohio are enclosed for your file. Copy of the transmittal letters to the local library is also enclosed. A list of the property owners affected by the proposed Project and who will receive a letter describing this Project is attached as Exhibit 2. These materials are being provided as proof of compliance with OAC Rule 4906-6-07.

After docketing this filing, please return one time-stamped copy of the Letter of Notification application for our records in the enclosed envelope. Should Staff of the Ohio Power Siting Board desire further information or discussion of this submittal, please contact me at (330) 384-2743.

Sincerely,

A handwritten signature in black ink, appearing to read 'Robt J Maggiore', with a stylized flourish at the end.

Robert J. Maggiore
Transmission Specialist II
Energy Delivery
Transmission and Substation Design
FirstEnergy Service Company

Attachments

**Fostoria West End (AEP)-Lemoyne-West Fremont 138kV Transmission Line
and Woodville No. 2 Substation Upgrade Project
Case Number 19-1337-EL-BLN**

Date: September 9, 2019

**Attachment 1
Affidavit of Robert Maggiore**

BEFORE THE
OHIO POWER SITING BOARD

In The Matter Of:)
The Application of American Transmission)
Systems, Incorporated for a Certificate of)
Environmental Compatibility and Public)
Need for the Construction of the Fostoria)
West End (AEP)-Lemoyne-West Fremont)
138kV Transmission Line and Woodville)
No. 2 Substation Upgrade Project)

Case No. 19-1337-EL-BLN

AFFIDAVIT OF ROBERT MAGGIORE

I, Robert Maggiore, state the following:

Pursuant to Ohio Administrative Code Rule 4906-2-04(A)(3)(e), I am the authorized representative of the Applicant in this case and I affirm that the Letter of Notification application filed in this matter is true and accurate to the best of my information and belief.



Robert Maggiore
FirstEnergy Service Company

State of Ohio)
County of Summit) ss:

Sworn and subscribed before me this 9th day of September 2019.



Notary Public



Terese M. Miller
Resident Summit County
Notary Public, State of Ohio
My Commission Expires: 04/07/2020

EXHIBIT 1
Officials Served Copy of Letter of Notification
Fostoria West End (AEP)-Lemoyne-West Fremont 138kV Transmission
Line and Woodville No. 2 Substation Upgrade Project
Case No. 19-1337-EL-BLN

Sandusky County

Ms. Kay Reiter
Sandusky County Commissioner
622 Croghan Street
Fremont, OH 43420

Mr. Carlos Baez, P.E., P.S.
Sandusky County Engineer
2500 West State Street
Fremont, OH 43420

Mr. Scott Miller
Sandusky County Commissioner
622 Croghan Street
Fremont, OH 43420

Ms. Jill Simpson, President
Sandusky County Regional
Planning Committee
108 South Park Avenue
Fremont OH, 43420

Mr. Russ Zimmerman
Sandusky County Commissioner
622 Croghan Street
Fremont, OH 43420

Ms. Sandy Yohe, Office Manager
Sandusky County Soil & Water
District
2000 Countryside Drive, Suite A
Fremont, OH 43420

Woodville Township

Mr. Ken Green, Trustee
Woodville Township
321 East Main Street
P.O. Box 121
Woodville, OH 43469

Mr. Paul Runion, Trustee
Woodville Township
321 East Main Street
P.O. Box 121
Woodville, OH 43469

Mr. Bill Hammer, Trustee
Woodville Township
321 East Main Street
P.O. Box 121
Woodville, OH 43469

Ms. Lori Kepus, Fiscal Officer
Woodville Township
321 East Main Street
P.O. Box 121
Woodville, OH 43469

Wood County

Dr. Theodore Bowlus
Board of County Commissioners
One Courthouse Square, 5th Floor
Bowling Green, OH 43402

Ms. Doris Herringshaw
Board of County Commissioners
One Courthouse Square, 5th Floor
Bowling Green, OH 43402

Mr. Craig LaHote
Board of County Commissioners
One Courthouse Square, 5th Floor
Bowling Green, OH 43402

Mr. John Musteric
Wood County Engineer's Office
One Courthouse Square, 5th Floor
Bowling Green, OH 43402

Troy Township

Mr. Matthew Brinker, Trustee
Troy Township
4707 Dowling Road
Perrysburg, OH 43551

Mr. Skip Recker, Chairman
Troy Township
1651 Ottawa Road
Genoa, OH 43430

Libraries

Luckey Branch Library
Ms. Susan Titkemeier, Director
228 Main Street
Luckey, OH 43443

Mr. Dave Steiner, Director
Wood County Planning Commission
One Courthouse Square, 5th Floor
Bowling Green, OH 43402

Mr. Jim Carter, District Admin.
Wood County Soil & Water District
1616 E. Wooster Street, Suite 32
Bowling Green, OH 43402

Mr. Richard Greulich Jr., Trustee
Troy Township
23445 Stony Ridge Road
Perrysburg, OH 43551

Ms. Linda Biniker, Fiscal Officer
Troy Township
5929 Fremont Pike
P.O. Box 205
Stony Ridge, OH 43463

Woodville Public Library
Ms. Pam Hoesman, Director
101 East Main Street
Woodville, OH 43469

September 9, 2019

Ms. Kay Reiter
Sandusky County Commissioner
622 Croghan Street
Fremont, OH 43420

Letter of Notification
Fostoria West End (AEP)-Lemoyne-West Fremont 138kV Transmission
Line and Woodville No. 2 Substation Upgrade Project
Case No. 19-1337-EL-BLN

Ms. Reiter,

American Transmission Systems, Incorporated (“ATSI”), a FirstEnergy company, has filed with the Public Utilities Commission of Ohio, Docketing Division, a Letter of Notification application for a Certificate of Environmental Compatibility and Public Need to construct the Fostoria West End (AEP) – Lemoyne – West Fremont 138kV Transmission Line and Woodville No. 2 Substation Upgrade Project. This Project will improve the transmission system in the Project area as described in more detail in the application.

In the Project, ATSI proposes the expansion of the existing Woodville No. 2 138kV Substation to facilitate the installation of new equipment and eliminating a four-terminal transmission line configuration. The existing Woodville No. 2 138kV Substation is proposed to expand by 223% to facilitate the installation of new equipment. This Project will also involve replacing structures and rebuilding a 3.1-mile section of the existing 138kV transmission line from single circuit to double circuit from AEP West End Transmission Line to the Woodville No. 2 Substation. The Project will be located in Woodville Township, Sandusky County, Ohio and Troy Township, Wood County, Ohio.

In accordance with Ohio Administrative Code (“OAC”) Rule 4906-1-01, this Project falls within the Ohio Power Siting Board’s requirements for a Letter of Notification application. Therefore, in compliance with OAC 4906-6, we have prepared and filed the attached Letter of Notification application with the OPSB for their review and approval. The Letter of Notification application contains a description of the Project and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2743.

Sincerely,



Robert J. Maggiore
Transmission Specialist II
Energy Delivery
Transmission and Substation Design
FirstEnergy Service Company

September 9, 2019

Mr. Scott Miller
Sandusky County Commissioner
622 Croghan Street
Fremont, OH 43420

Letter of Notification
Fostoria West End (AEP)-Lemoyne-West Fremont 138kV Transmission
Line and Woodville No. 2 Substation Upgrade Project
Case No. 19-1337-EL-BLN

Mr. Miller,

American Transmission Systems, Incorporated ("ATSI"), a FirstEnergy company, has filed with the Public Utilities Commission of Ohio, Docketing Division, a Letter of Notification application for a Certificate of Environmental Compatibility and Public Need to construct the Fostoria West End (AEP) – Lemoyne – West Fremont 138kV Transmission Line and Woodville No. 2 Substation Upgrade Project. This Project will improve the transmission system in the Project area as described in more detail in the application.

In the Project, ATSI proposes the expansion of the existing Woodville No. 2 138kV Substation to facilitate the installation of new equipment and eliminating a four-terminal transmission line configuration. The existing Woodville No. 2 138kV Substation is proposed to expand by 223% to facilitate the installation of new equipment. This Project will also involve replacing structures and rebuilding a 3.1-mile section of the existing 138kV transmission line from single circuit to double circuit from AEP West End Transmission Line to the Woodville No. 2 Substation. The Project will be located in Woodville Township, Sandusky County, Ohio and Troy Township, Wood County, Ohio.

In accordance with Ohio Administrative Code ("OAC") Rule 4906-1-01, this Project falls within the Ohio Power Siting Board's requirements for a Letter of Notification application. Therefore, in compliance with OAC 4906-6, we have prepared and filed the attached Letter of Notification application with the OPSB for their review and approval. The Letter of Notification application contains a description of the Project and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2743.

Sincerely,



Robert J. Maggiore
Transmission Specialist II
Energy Delivery
Transmission and Substation Design
FirstEnergy Service Company

September 9, 2019

Mr. Russ Zimmerman
Sandusky County Commissioner
622 Croghan Street
Fremont, OH 43420

Letter of Notification
Fostoria West End (AEP)-Lemoyne-West Fremont 138kV Transmission
Line and Woodville No. 2 Substation Upgrade Project
Case No. 19-1337-EL-BLN

Mr. Zimmerman,

American Transmission Systems, Incorporated ("ATSI"), a FirstEnergy company, has filed with the Public Utilities Commission of Ohio, Docketing Division, a Letter of Notification application for a Certificate of Environmental Compatibility and Public Need to construct the Fostoria West End (AEP) – Lemoyne – West Fremont 138kV Transmission Line and Woodville No. 2 Substation Upgrade Project. This Project will improve the transmission system in the Project area as described in more detail in the application.

In the Project, ATSI proposes the expansion of the existing Woodville No. 2 138kV Substation to facilitate the installation of new equipment and eliminating a four-terminal transmission line configuration. The existing Woodville No. 2 138kV Substation is proposed to expand by 223% to facilitate the installation of new equipment. This Project will also involve replacing structures and rebuilding a 3.1-mile section of the existing 138kV transmission line from single circuit to double circuit from AEP West End Transmission Line to the Woodville No. 2 Substation. The Project will be located in Woodville Township, Sandusky County, Ohio and Troy Township, Wood County, Ohio.

In accordance with Ohio Administrative Code ("OAC") Rule 4906-1-01, this Project falls within the Ohio Power Siting Board's requirements for a Letter of Notification application. Therefore, in compliance with OAC 4906-6, we have prepared and filed the attached Letter of Notification application with the OPSB for their review and approval. The Letter of Notification application contains a description of the Project and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2743.

Sincerely,



Robert J. Maggiore
Transmission Specialist II
Energy Delivery
Transmission and Substation Design
FirstEnergy Service Company

September 9, 2019

Mr. Carlos Baez, P.E., P.S.
Sandusky County Engineer
2500 West State Street
Fremont, OH 43420

Letter of Notification
Fostoria West End (AEP)-Lemoyne-West Fremont 138kV Transmission
Line and Woodville No. 2 Substation Upgrade Project
Case No. 19-1337-EL-BLN

Mr. Baez,

American Transmission Systems, Incorporated ("ATSI"), a FirstEnergy company, has filed with the Public Utilities Commission of Ohio, Docketing Division, a Letter of Notification application for a Certificate of Environmental Compatibility and Public Need to construct the Fostoria West End (AEP) – Lemoyne – West Fremont 138kV Transmission Line and Woodville No. 2 Substation Upgrade Project. This Project will improve the transmission system in the Project area as described in more detail in the application.

In the Project, ATSI proposes the expansion of the existing Woodville No. 2 138kV Substation to facilitate the installation of new equipment and eliminating a four-terminal transmission line configuration. The existing Woodville No. 2 138kV Substation is proposed to expand by 223% to facilitate the installation of new equipment. This Project will also involve replacing structures and rebuilding a 3.1-mile section of the existing 138kV transmission line from single circuit to double circuit from AEP West End Transmission Line to the Woodville No. 2 Substation. The Project will be located in Woodville Township, Sandusky County, Ohio and Troy Township, Wood County, Ohio.

In accordance with Ohio Administrative Code ("OAC") Rule 4906-1-01, this Project falls within the Ohio Power Siting Board's requirements for a Letter of Notification application. Therefore, in compliance with OAC 4906-6, we have prepared and filed the attached Letter of Notification application with the OPSB for their review and approval. The Letter of Notification application contains a description of the Project and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2743.

Sincerely,



Robert J. Maggiore
Transmission Specialist II
Energy Delivery
Transmission and Substation Design
FirstEnergy Service Company

September 9, 2019

Ms. Jill Simpson, President
Sandusky County Regional Planning Committee
108 South Park Avenue
Freemont OH, 43420

Letter of Notification
Fostoria West End (AEP)-Lemoyne-West Fremont 138kV Transmission
Line and Woodville No. 2 Substation Upgrade Project
Case No. 19-1337-EL-BLN

Ms. Simpson,

American Transmission Systems, Incorporated ("ATSI"), a FirstEnergy company, has filed with the Public Utilities Commission of Ohio, Docketing Division, a Letter of Notification application for a Certificate of Environmental Compatibility and Public Need to construct the Fostoria West End (AEP) – Lemoyne – West Fremont 138kV Transmission Line and Woodville No. 2 Substation Upgrade Project. This Project will improve the transmission system in the Project area as described in more detail in the application.

In the Project, ATSI proposes the expansion of the existing Woodville No. 2 138kV Substation to facilitate the installation of new equipment and eliminating a four-terminal transmission line configuration. The existing Woodville No. 2 138kV Substation is proposed to expand by 223% to facilitate the installation of new equipment. This Project will also involve replacing structures and rebuilding a 3.1-mile section of the existing 138kV transmission line from single circuit to double circuit from AEP West End Transmission Line to the Woodville No. 2 Substation. The Project will be located in Woodville Township, Sandusky County, Ohio and Troy Township, Wood County, Ohio.

In accordance with Ohio Administrative Code ("OAC") Rule 4906-1-01, this Project falls within the Ohio Power Siting Board's requirements for a Letter of Notification application. Therefore, in compliance with OAC 4906-6, we have prepared and filed the attached Letter of Notification application with the OPSB for their review and approval. The Letter of Notification application contains a description of the Project and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2743.

Sincerely,



Robert J. Maggiore
Transmission Specialist II
Energy Delivery
Transmission and Substation Design
FirstEnergy Service Company

September 9, 2019

Ms. Sandy Yohe, Office Manager
Sandusky County Soil & Water District
2000 Countryside Drive, Suite A
Fremont, OH 43420

Letter of Notification
Fostoria West End (AEP)-Lemoyne-West Fremont 138kV Transmission
Line and Woodville No. 2 Substation Upgrade Project
Case No. 19-1337-EL-BLN

Ms. Yohe,


American Transmission Systems, Incorporated ("ATSI"), a FirstEnergy company, has filed with the Public Utilities Commission of Ohio, Docketing Division, a Letter of Notification application for a Certificate of Environmental Compatibility and Public Need to construct the Fostoria West End (AEP) – Lemoyne – West Fremont 138kV Transmission Line and Woodville No. 2 Substation Upgrade Project. This Project will improve the transmission system in the Project area as described in more detail in the application.

In the Project, ATSI proposes the expansion of the existing Woodville No. 2 138kV Substation to facilitate the installation of new equipment and eliminating a four-terminal transmission line configuration. The existing Woodville No. 2 138kV Substation is proposed to expand by 223% to facilitate the installation of new equipment. This Project will also involve replacing structures and rebuilding a 3.1-mile section of the existing 138kV transmission line from single circuit to double circuit from AEP West End Transmission Line to the Woodville No. 2 Substation. The Project will be located in Woodville Township, Sandusky County, Ohio and Troy Township, Wood County, Ohio.

In accordance with Ohio Administrative Code ("OAC") Rule 4906-1-01, this Project falls within the Ohio Power Siting Board's requirements for a Letter of Notification application. Therefore, in compliance with OAC 4906-6, we have prepared and filed the attached Letter of Notification application with the OPSB for their review and approval. The Letter of Notification application contains a description of the Project and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2743.

Sincerely,



Robert J. Maggiore
Transmission Specialist II
Energy Delivery
Transmission and Substation Design
FirstEnergy Service Company

September 9, 2019

Mr. Ken Green, Trustee, Woodville Township
321 East Main Street
P.O. Box 121
Woodville, OH 43469

Letter of Notification
Fostoria West End (AEP)-Lemoyne-West Fremont 138kV Transmission
Line and Woodville No. 2 Substation Upgrade Project
Case No. 19-1337-EL-BLN

Mr. Green,


American Transmission Systems, Incorporated ("ATSI"), a FirstEnergy company, has filed with the Public Utilities Commission of Ohio, Docketing Division, a Letter of Notification application for a Certificate of Environmental Compatibility and Public Need to construct the Fostoria West End (AEP) – Lemoyne – West Fremont 138kV Transmission Line and Woodville No. 2 Substation Upgrade Project. This Project will improve the transmission system in the Project area as described in more detail in the application.

In the Project, ATSI proposes the expansion of the existing Woodville No. 2 138kV Substation to facilitate the installation of new equipment and eliminating a four-terminal transmission line configuration. The existing Woodville No. 2 138kV Substation is proposed to expand by 223% to facilitate the installation of new equipment. This Project will also involve replacing structures and rebuilding a 3.1-mile section of the existing 138kV transmission line from single circuit to double circuit from AEP West End Transmission Line to the Woodville No. 2 Substation. The Project will be located in Woodville Township, Sandusky County, Ohio and Troy Township, Wood County, Ohio.

In accordance with Ohio Administrative Code ("OAC") Rule 4906-1-01, this Project falls within the Ohio Power Siting Board's requirements for a Letter of Notification application. Therefore, in compliance with OAC 4906-6, we have prepared and filed the attached Letter of Notification application with the OPSB for their review and approval. The Letter of Notification application contains a description of the Project and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2743.

Sincerely,



Robert J. Maggiore
Transmission Specialist II
Energy Delivery
Transmission and Substation Design
FirstEnergy Service Company

September 9, 2019

Mr. Bill Hammer, Trustee, Woodville Township
321 East Main Street
P.O. Box 121
Woodville, OH 43469

Letter of Notification
Fostoria West End (AEP)-Lemoyne-West Fremont 138kV Transmission
Line and Woodville No. 2 Substation Upgrade Project
Case No. 19-1337-EL-BLN

Mr. Hammer,


American Transmission Systems, Incorporated ("ATSI"), a FirstEnergy company, has filed with the Public Utilities Commission of Ohio, Docketing Division, a Letter of Notification application for a Certificate of Environmental Compatibility and Public Need to construct the Fostoria West End (AEP) – Lemoyne – West Fremont 138kV Transmission Line and Woodville No. 2 Substation Upgrade Project. This Project will improve the transmission system in the Project area as described in more detail in the application.

In the Project, ATSI proposes the expansion of the existing Woodville No. 2 138kV Substation to facilitate the installation of new equipment and eliminating a four-terminal transmission line configuration. The existing Woodville No. 2 138kV Substation is proposed to expand by 223% to facilitate the installation of new equipment. This Project will also involve replacing structures and rebuilding a 3.1-mile section of the existing 138kV transmission line from single circuit to double circuit from AEP West End Transmission Line to the Woodville No. 2 Substation. The Project will be located in Woodville Township, Sandusky County, Ohio and Troy Township, Wood County, Ohio.

In accordance with Ohio Administrative Code ("OAC") Rule 4906-1-01, this Project falls within the Ohio Power Siting Board's requirements for a Letter of Notification application. Therefore, in compliance with OAC 4906-6, we have prepared and filed the attached Letter of Notification application with the OPSB for their review and approval. The Letter of Notification application contains a description of the Project and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2743.

Sincerely,



Robert J. Maggiore
Transmission Specialist II
Energy Delivery
Transmission and Substation Design
FirstEnergy Service Company

September 9, 2019

Mr. Paul Runion, Trustee, Woodville Township
321 East Main Street
P.O. Box 121
Woodville, OH 43469

Letter of Notification
Fostoria West End (AEP)-Lemoyne-West Fremont 138kV Transmission
Line and Woodville No. 2 Substation Upgrade Project
Case No. 19-1337-EL-BLN

Mr. Runion,

American Transmission Systems, Incorporated ("ATSI"), a FirstEnergy company, has filed with the Public Utilities Commission of Ohio, Docketing Division, a Letter of Notification application for a Certificate of Environmental Compatibility and Public Need to construct the Fostoria West End (AEP) – Lemoyne – West Fremont 138kV Transmission Line and Woodville No. 2 Substation Upgrade Project. This Project will improve the transmission system in the Project area as described in more detail in the application.

In the Project, ATSI proposes the expansion of the existing Woodville No. 2 138kV Substation to facilitate the installation of new equipment and eliminating a four-terminal transmission line configuration. The existing Woodville No. 2 138kV Substation is proposed to expand by 223% to facilitate the installation of new equipment. This Project will also involve replacing structures and rebuilding a 3.1-mile section of the existing 138kV transmission line from single circuit to double circuit from AEP West End Transmission Line to the Woodville No. 2 Substation. The Project will be located in Woodville Township, Sandusky County, Ohio and Troy Township, Wood County, Ohio.

In accordance with Ohio Administrative Code ("OAC") Rule 4906-1-01, this Project falls within the Ohio Power Siting Board's requirements for a Letter of Notification application. Therefore, in compliance with OAC 4906-6, we have prepared and filed the attached Letter of Notification application with the OPSB for their review and approval. The Letter of Notification application contains a description of the Project and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2743.

Sincerely,



Robert J. Maggiore
Transmission Specialist II
Energy Delivery
Transmission and Substation Design
FirstEnergy Service Company

September 9, 2019

Ms. Lori Kepus, Fiscal Officer, Woodville Township
321 East Main Street
P.O. Box 121
Woodville, OH 43469

Letter of Notification
Fostoria West End (AEP)-Lemoyne-West Fremont 138kV Transmission
Line and Woodville No. 2 Substation Upgrade Project
Case No. 19-1337-EL-BLN

Ms. Kepus,

American Transmission Systems, Incorporated ("ATSI"), a FirstEnergy company, has filed with the Public Utilities Commission of Ohio, Docketing Division, a Letter of Notification application for a Certificate of Environmental Compatibility and Public Need to construct the Fostoria West End (AEP) – Lemoyne – West Fremont 138kV Transmission Line and Woodville No. 2 Substation Upgrade Project. This Project will improve the transmission system in the Project area as described in more detail in the application.

In the Project, ATSI proposes the expansion of the existing Woodville No. 2 138kV Substation to facilitate the installation of new equipment and eliminating a four-terminal transmission line configuration. The existing Woodville No. 2 138kV Substation is proposed to expand by 223% to facilitate the installation of new equipment. This Project will also involve replacing structures and rebuilding a 3.1-mile section of the existing 138kV transmission line from single circuit to double circuit from AEP West End Transmission Line to the Woodville No. 2 Substation. The Project will be located in Woodville Township, Sandusky County, Ohio and Troy Township, Wood County, Ohio.

In accordance with Ohio Administrative Code ("OAC") Rule 4906-1-01, this Project falls within the Ohio Power Siting Board's requirements for a Letter of Notification application. Therefore, in compliance with OAC 4906-6, we have prepared and filed the attached Letter of Notification application with the OPSB for their review and approval. The Letter of Notification application contains a description of the Project and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2743.

Sincerely,



Robert J. Maggiore
Transmission Specialist II
Energy Delivery
Transmission and Substation Design
FirstEnergy Service Company

September 9, 2019

Dr. Theodore Bowlus
Board of County Commissioners
One Courthouse Square, 5th Floor
Bowling Green, OH 43402

Letter of Notification
Fostoria West End (AEP)-Lemoyne-West Fremont 138kV Transmission
Line and Woodville No. 2 Substation Upgrade Project
Case No. 19-1337-EL-BLN

Dr. Bowlus,


American Transmission Systems, Incorporated ("ATSI"), a FirstEnergy company, has filed with the Public Utilities Commission of Ohio, Docketing Division, a Letter of Notification application for a Certificate of Environmental Compatibility and Public Need to construct the Fostoria West End (AEP) – Lemoyne – West Fremont 138kV Transmission Line and Woodville No. 2 Substation Upgrade Project. This Project will improve the transmission system in the Project area as described in more detail in the application.

In the Project, ATSI proposes the expansion of the existing Woodville No. 2 138kV Substation to facilitate the installation of new equipment and eliminating a four-terminal transmission line configuration. The existing Woodville No. 2 138kV Substation is proposed to expand by 223% to facilitate the installation of new equipment. This Project will also involve replacing structures and rebuilding a 3.1-mile section of the existing 138kV transmission line from single circuit to double circuit from AEP West End Transmission Line to the Woodville No. 2 Substation. The Project will be located in Woodville Township, Sandusky County, Ohio and Troy Township, Wood County, Ohio.

In accordance with Ohio Administrative Code ("OAC") Rule 4906-1-01, this Project falls within the Ohio Power Siting Board's requirements for a Letter of Notification application. Therefore, in compliance with OAC 4906-6, we have prepared and filed the attached Letter of Notification application with the OPSB for their review and approval. The Letter of Notification application contains a description of the Project and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2743.

Sincerely,



Robert J. Maggiore
Transmission Specialist II
Energy Delivery
Transmission and Substation Design
FirstEnergy Service Company

September 9, 2019

Mr. Craig LaHote
Board of County Commissioners
One Courthouse Square, 5th Floor
Bowling Green, OH 43402

Letter of Notification
Fostoria West End (AEP)-Lemoyne-West Fremont 138kV Transmission
Line and Woodville No. 2 Substation Upgrade Project
Case No. 19-1337-EL-BLN

Mr. LaHote,

American Transmission Systems, Incorporated ("ATSI"), a FirstEnergy company, has filed with the Public Utilities Commission of Ohio, Docketing Division, a Letter of Notification application for a Certificate of Environmental Compatibility and Public Need to construct the Fostoria West End (AEP) – Lemoyne – West Fremont 138kV Transmission Line and Woodville No. 2 Substation Upgrade Project. This Project will improve the transmission system in the Project area as described in more detail in the application.

In the Project, ATSI proposes the expansion of the existing Woodville No. 2 138kV Substation to facilitate the installation of new equipment and eliminating a four-terminal transmission line configuration. The existing Woodville No. 2 138kV Substation is proposed to expand by 223% to facilitate the installation of new equipment. This Project will also involve replacing structures and rebuilding a 3.1-mile section of the existing 138kV transmission line from single circuit to double circuit from AEP West End Transmission Line to the Woodville No. 2 Substation. The Project will be located in Woodville Township, Sandusky County, Ohio and Troy Township, Wood County, Ohio.

In accordance with Ohio Administrative Code ("OAC") Rule 4906-1-01, this Project falls within the Ohio Power Siting Board's requirements for a Letter of Notification application. Therefore, in compliance with OAC 4906-6, we have prepared and filed the attached Letter of Notification application with the OPSB for their review and approval. The Letter of Notification application contains a description of the Project and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2743.

Sincerely,



Robert J. Maggiore
Transmission Specialist II
Energy Delivery
Transmission and Substation Design
FirstEnergy Service Company

September 9, 2019

Mr. John Musteric
Wood County Engineer's Office
One Courthouse Square, 5th Floor
Bowling Green, OH 43402

Letter of Notification
Fostoria West End (AEP)-Lemoyne-West Fremont 138kV Transmission
Line and Woodville No. 2 Substation Upgrade Project
Case No. 19-1337-EL-BLN

Mr. Musteric,

American Transmission Systems, Incorporated ("ATSI"), a FirstEnergy company, has filed with the Public Utilities Commission of Ohio, Docketing Division, a Letter of Notification application for a Certificate of Environmental Compatibility and Public Need to construct the Fostoria West End (AEP) – Lemoyne – West Fremont 138kV Transmission Line and Woodville No. 2 Substation Upgrade Project. This Project will improve the transmission system in the Project area as described in more detail in the application.

In the Project, ATSI proposes the expansion of the existing Woodville No. 2 138kV Substation to facilitate the installation of new equipment and eliminating a four-terminal transmission line configuration. The existing Woodville No. 2 138kV Substation is proposed to expand by 223% to facilitate the installation of new equipment. This Project will also involve replacing structures and rebuilding a 3.1-mile section of the existing 138kV transmission line from single circuit to double circuit from AEP West End Transmission Line to the Woodville No. 2 Substation. The Project will be located in Woodville Township, Sandusky County, Ohio and Troy Township, Wood County, Ohio.

In accordance with Ohio Administrative Code ("OAC") Rule 4906-1-01, this Project falls within the Ohio Power Siting Board's requirements for a Letter of Notification application. Therefore, in compliance with OAC 4906-6, we have prepared and filed the attached Letter of Notification application with the OPSB for their review and approval. The Letter of Notification application contains a description of the Project and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2743.

Sincerely,



Robert J. Maggiore
Transmission Specialist II
Energy Delivery
Transmission and Substation Design
FirstEnergy Service Company

September 9, 2019

Ms. Doris Herringshaw
Board of County Commissioners
One Courthouse Square, 5th Floor
Bowling Green, OH 43402

Letter of Notification
Fostoria West End (AEP)-Lemoyne-West Fremont 138kV Transmission
Line and Woodville No. 2 Substation Upgrade Project
Case No. 19-1337-EL-BLN

Ms. Herringshaw,

American Transmission Systems, Incorporated ("ATSI"), a FirstEnergy company, has filed with the Public Utilities Commission of Ohio, Docketing Division, a Letter of Notification application for a Certificate of Environmental Compatibility and Public Need to construct the Fostoria West End (AEP) – Lemoyne – West Fremont 138kV Transmission Line and Woodville No. 2 Substation Upgrade Project. This Project will improve the transmission system in the Project area as described in more detail in the application.

In the Project, ATSI proposes the expansion of the existing Woodville No. 2 138kV Substation to facilitate the installation of new equipment and eliminating a four-terminal transmission line configuration. The existing Woodville No. 2 138kV Substation is proposed to expand by 223% to facilitate the installation of new equipment. This Project will also involve replacing structures and rebuilding a 3.1-mile section of the existing 138kV transmission line from single circuit to double circuit from AEP West End Transmission Line to the Woodville No. 2 Substation. The Project will be located in Woodville Township, Sandusky County, Ohio and Troy Township, Wood County, Ohio.

In accordance with Ohio Administrative Code ("OAC") Rule 4906-1-01, this Project falls within the Ohio Power Siting Board's requirements for a Letter of Notification application. Therefore, in compliance with OAC 4906-6, we have prepared and filed the attached Letter of Notification application with the OPSB for their review and approval. The Letter of Notification application contains a description of the Project and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2743.

Sincerely,



Robert J. Maggiore
Transmission Specialist II
Energy Delivery
Transmission and Substation Design
FirstEnergy Service Company

September 9, 2019

Mr. Dave Steiner, Director
Wood County Planning Commission
One Courthouse Square, 5th Floor
Bowling Green, OH 43402

Letter of Notification
Fostoria West End (AEP)-Lemoyne-West Fremont 138kV Transmission
Line and Woodville No. 2 Substation Upgrade Project
Case No. 19-1337-EL-BLN

Mr. Steiner,

American Transmission Systems, Incorporated ("ATSI"), a FirstEnergy company, has filed with the Public Utilities Commission of Ohio, Docketing Division, a Letter of Notification application for a Certificate of Environmental Compatibility and Public Need to construct the Fostoria West End (AEP) – Lemoyne – West Fremont 138kV Transmission Line and Woodville No. 2 Substation Upgrade Project. This Project will improve the transmission system in the Project area as described in more detail in the application.

In the Project, ATSI proposes the expansion of the existing Woodville No. 2 138kV Substation to facilitate the installation of new equipment and eliminating a four-terminal transmission line configuration. The existing Woodville No. 2 138kV Substation is proposed to expand by 223% to facilitate the installation of new equipment. This Project will also involve replacing structures and rebuilding a 3.1-mile section of the existing 138kV transmission line from single circuit to double circuit from AEP West End Transmission Line to the Woodville No. 2 Substation. The Project will be located in Woodville Township, Sandusky County, Ohio and Troy Township, Wood County, Ohio.

In accordance with Ohio Administrative Code ("OAC") Rule 4906-1-01, this Project falls within the Ohio Power Siting Board's requirements for a Letter of Notification application. Therefore, in compliance with OAC 4906-6, we have prepared and filed the attached Letter of Notification application with the OPSB for their review and approval. The Letter of Notification application contains a description of the Project and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2743.

Sincerely,



Robert J. Maggiore
Transmission Specialist II
Energy Delivery
Transmission and Substation Design
FirstEnergy Service Company

September 9, 2019

Mr. Jim Carter, District Admin.
Wood County Soil & Water District
1616 E. Wooster Street, Suite 32
Bowling Green, OH 43402

Letter of Notification
Fostoria West End (AEP)-Lemoyne-West Fremont 138kV Transmission
Line and Woodville No. 2 Substation Upgrade Project
Case No. 19-1337-EL-BLN

Mr. Carter,

American Transmission Systems, Incorporated ("ATSI"), a FirstEnergy company, has filed with the Public Utilities Commission of Ohio, Docketing Division, a Letter of Notification application for a Certificate of Environmental Compatibility and Public Need to construct the Fostoria West End (AEP) – Lemoyne – West Fremont 138kV Transmission Line and Woodville No. 2 Substation Upgrade Project. This Project will improve the transmission system in the Project area as described in more detail in the application.

In the Project, ATSI proposes the expansion of the existing Woodville No. 2 138kV Substation to facilitate the installation of new equipment and eliminating a four-terminal transmission line configuration. The existing Woodville No. 2 138kV Substation is proposed to expand by 223% to facilitate the installation of new equipment. This Project will also involve replacing structures and rebuilding a 3.1-mile section of the existing 138kV transmission line from single circuit to double circuit from AEP West End Transmission Line to the Woodville No. 2 Substation. The Project will be located in Woodville Township, Sandusky County, Ohio and Troy Township, Wood County, Ohio.

In accordance with Ohio Administrative Code ("OAC") Rule 4906-1-01, this Project falls within the Ohio Power Siting Board's requirements for a Letter of Notification application. Therefore, in compliance with OAC 4906-6, we have prepared and filed the attached Letter of Notification application with the OPSB for their review and approval. The Letter of Notification application contains a description of the Project and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2743.

Sincerely,



Robert J. Maggiore
Transmission Specialist II
Energy Delivery
Transmission and Substation Design
FirstEnergy Service Company

September 9, 2019

Mr. Matthew Brinker, Trustee
Troy Township
4707 Dowling Road
Perrysburg, OH 43551

Letter of Notification
Fostoria West End (AEP)-Lemoyne-West Fremont 138kV Transmission
Line and Woodville No. 2 Substation Upgrade Project
Case No. 19-1337-EL-BLN

Mr. Brinker,

American Transmission Systems, Incorporated ("ATSI"), a FirstEnergy company, has filed with the Public Utilities Commission of Ohio, Docketing Division, a Letter of Notification application for a Certificate of Environmental Compatibility and Public Need to construct the Fostoria West End (AEP) – Lemoyne – West Fremont 138kV Transmission Line and Woodville No. 2 Substation Upgrade Project. This Project will improve the transmission system in the Project area as described in more detail in the application.

In the Project, ATSI proposes the expansion of the existing Woodville No. 2 138kV Substation to facilitate the installation of new equipment and eliminating a four-terminal transmission line configuration. The existing Woodville No. 2 138kV Substation is proposed to expand by 223% to facilitate the installation of new equipment. This Project will also involve replacing structures and rebuilding a 3.1-mile section of the existing 138kV transmission line from single circuit to double circuit from AEP West End Transmission Line to the Woodville No. 2 Substation. The Project will be located in Woodville Township, Sandusky County, Ohio and Troy Township, Wood County, Ohio.

In accordance with Ohio Administrative Code ("OAC") Rule 4906-1-01, this Project falls within the Ohio Power Siting Board's requirements for a Letter of Notification application. Therefore, in compliance with OAC 4906-6, we have prepared and filed the attached Letter of Notification application with the OPSB for their review and approval. The Letter of Notification application contains a description of the Project and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2743.

Sincerely,



Robert J. Maggiore
Transmission Specialist II
Energy Delivery
Transmission and Substation Design
FirstEnergy Service Company

September 9, 2019

Mr. Skip Recker, Chairman
Troy Township
1651 Ottawa Road
Genoa, OH 43430

Letter of Notification
Fostoria West End (AEP)-Lemoyne-West Fremont 138kV Transmission
Line and Woodville No. 2 Substation Upgrade Project
Case No. 19-1337-EL-BLN

Mr. Recker,

American Transmission Systems, Incorporated ("ATSI"), a FirstEnergy company, has filed with the Public Utilities Commission of Ohio, Docketing Division, a Letter of Notification application for a Certificate of Environmental Compatibility and Public Need to construct the Fostoria West End (AEP) – Lemoyne – West Fremont 138kV Transmission Line and Woodville No. 2 Substation Upgrade Project. This Project will improve the transmission system in the Project area as described in more detail in the application.

In the Project, ATSI proposes the expansion of the existing Woodville No. 2 138kV Substation to facilitate the installation of new equipment and eliminating a four-terminal transmission line configuration. The existing Woodville No. 2 138kV Substation is proposed to expand by 223% to facilitate the installation of new equipment. This Project will also involve replacing structures and rebuilding a 3.1-mile section of the existing 138kV transmission line from single circuit to double circuit from AEP West End Transmission Line to the Woodville No. 2 Substation. The Project will be located in Woodville Township, Sandusky County, Ohio and Troy Township, Wood County, Ohio.

In accordance with Ohio Administrative Code ("OAC") Rule 4906-1-01, this Project falls within the Ohio Power Siting Board's requirements for a Letter of Notification application. Therefore, in compliance with OAC 4906-6, we have prepared and filed the attached Letter of Notification application with the OPSB for their review and approval. The Letter of Notification application contains a description of the Project and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2743.

Sincerely,



Robert J. Maggiore
Transmission Specialist II
Energy Delivery
Transmission and Substation Design
FirstEnergy Service Company

September 9, 2019

Mr. Richard Greulich Jr., Trustee
Troy Township
23445 Stony Ridge Road
Perrysburg, OH 43551

Letter of Notification
Fostoria West End (AEP)-Lemoyne-West Fremont 138kV Transmission
Line and Woodville No. 2 Substation Upgrade Project
Case No. 19-1337-EL-BLN

Mr. Greulich,


American Transmission Systems, Incorporated ("ATSI"), a FirstEnergy company, has filed with the Public Utilities Commission of Ohio, Docketing Division, a Letter of Notification application for a Certificate of Environmental Compatibility and Public Need to construct the Fostoria West End (AEP) – Lemoyne – West Fremont 138kV Transmission Line and Woodville No. 2 Substation Upgrade Project. This Project will improve the transmission system in the Project area as described in more detail in the application.

In the Project, ATSI proposes the expansion of the existing Woodville No. 2 138kV Substation to facilitate the installation of new equipment and eliminating a four-terminal transmission line configuration. The existing Woodville No. 2 138kV Substation is proposed to expand by 223% to facilitate the installation of new equipment. This Project will also involve replacing structures and rebuilding a 3.1-mile section of the existing 138kV transmission line from single circuit to double circuit from AEP West End Transmission Line to the Woodville No. 2 Substation. The Project will be located in Woodville Township, Sandusky County, Ohio and Troy Township, Wood County, Ohio.

In accordance with Ohio Administrative Code ("OAC") Rule 4906-1-01, this Project falls within the Ohio Power Siting Board's requirements for a Letter of Notification application. Therefore, in compliance with OAC 4906-6, we have prepared and filed the attached Letter of Notification application with the OPSB for their review and approval. The Letter of Notification application contains a description of the Project and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2743.

Sincerely,



Robert J. Maggiore
Transmission Specialist II
Energy Delivery
Transmission and Substation Design
FirstEnergy Service Company

September 9, 2019

Ms. Linda Biniker, Fiscal Officer, Troy Township
5929 Fremont Pike
P.O. Box 205
Stony Ridge, OH 43463

Letter of Notification
Fostoria West End (AEP)-Lemoyne-West Fremont 138kV Transmission
Line and Woodville No. 2 Substation Upgrade Project
Case No. 19-1337-EL-BLN

Ms. Biniker,

American Transmission Systems, Incorporated ("ATSI"), a FirstEnergy company, has filed with the Public Utilities Commission of Ohio, Docketing Division, a Letter of Notification application for a Certificate of Environmental Compatibility and Public Need to construct the Fostoria West End (AEP) – Lemoyne – West Fremont 138kV Transmission Line and Woodville No. 2 Substation Upgrade Project. This Project will improve the transmission system in the Project area as described in more detail in the application.

In the Project, ATSI proposes the expansion of the existing Woodville No. 2 138kV Substation to facilitate the installation of new equipment and eliminating a four-terminal transmission line configuration. The existing Woodville No. 2 138kV Substation is proposed to expand by 223% to facilitate the installation of new equipment. This Project will also involve replacing structures and rebuilding a 3.1-mile section of the existing 138kV transmission line from single circuit to double circuit from AEP West End Transmission Line to the Woodville No. 2 Substation. The Project will be located in Woodville Township, Sandusky County, Ohio and Troy Township, Wood County, Ohio.

In accordance with Ohio Administrative Code ("OAC") Rule 4906-1-01, this Project falls within the Ohio Power Siting Board's requirements for a Letter of Notification application. Therefore, in compliance with OAC 4906-6, we have prepared and filed the attached Letter of Notification application with the OPSB for their review and approval. The Letter of Notification application contains a description of the Project and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2743.

Sincerely,



Robert J. Maggiore
Transmission Specialist II
Energy Delivery
Transmission and Substation Design
FirstEnergy Service Company

September 9, 2019

Luckey Branch Library
Ms. Susan Titkemeier, Director
228 Main Street
Luckey, OH 43443

Letter of Notification
Fostoria West End (AEP)-Lemoyne-West Fremont 138kV Transmission
Line and Woodville No. 2 Substation Upgrade Project
Case No. 19-1337-EL-BLN

Dear Ms. Titkemeier,

Enclosed please find one copy of the Letter of Notification application of American Transmission Systems, Incorporated ("ATSI"), a FirstEnergy company, for the Fostoria West End (AEP)-Lemoyne-West Fremont 138kV Transmission Line and Woodville No.2 Substation Upgrade Project ("Project") that has been filed with the Ohio Power Siting Board ("OPSB"). Please make the Letter of Notification application available for public reference in the Woodville Public Library.

We are providing a copy of the Letter of Notification application for placement in your library in response to the requirements of the Ohio Administrative Code ("OAC") Section 4906-6-07(A)(2), which requires us to place a copy of the Letter of Notification application in the main public libraries of the political subdivisions in which any portion of the Project is to be located.

In this Project, ATSI proposes the expansion of the existing Woodville No. 2 138kV Substation to convert the substation to a five (5) breaker ring bus and to eliminate the existing Fostoria West End (AEP)-Lemoyne-West Fremont four-terminal line configuration. The existing Woodville No. 2 138kV Substation is proposed to expand by 223% to facilitate the installation of new equipment. This Project will also involve replacing structures and rebuilding a 3.1-mile section of Fostoria West End (AEP)-Lemoyne-West Fremont 138 kV line from single circuit to double circuit. The Project will improve the transmission system in the Project area.

The Project will be located in Woodville Township, Sandusky County, Ohio and Troy Township, Wood County, Ohio.

Please feel free to call me with any question you have on making the Letter of Notification application available to your patrons. My phone number is (330) 384-2743.

Sincerely,



Robert Maggioro
Transmission Specialist II
Energy Delivery
Transmission and Substation Design
FirstEnergy Service Company

Enclosure

September 9, 2019

Woodville Public Library
Ms. Pam Hoesman, Director
101 East Main Street
Woodville, OH 43469

Letter of Notification
Fostoria West End (AEP)-Lemoyne-West Fremont 138kV Transmission
Line and Woodville No. 2 Substation Upgrade Project
Case No. 19-1337-EL-BLN

Dear Ms. Hoesman,

Enclosed please find one copy of the Letter of Notification application of American Transmission Systems, Incorporated ("ATSI"), a FirstEnergy company, for the Fostoria West End (AEP)-Lemoyne-West Fremont 138kV Transmission Line and Woodville No.2 Substation Upgrade Project ("Project") that has been filed with the Ohio Power Siting Board ("OPSB"). Please make the Letter of Notification application available for public reference in the Woodville Public Library.

We are providing a copy of the Letter of Notification application for placement in your library in response to the requirements of the Ohio Administrative Code ("OAC") Section 4906-6-07(A)(2), which requires us to place a copy of the Letter of Notification application in the main public libraries of the political subdivisions in which any portion of the Project is to be located.

In this Project, ATSI proposes the expansion of the existing Woodville No. 2 138kV Substation to convert the substation to a five (5) breaker ring bus and to eliminate the existing Fostoria West End (AEP)-Lemoyne-West Fremont four-terminal line configuration. The existing Woodville No. 2 138kV Substation is proposed to expand by 223% to facilitate the installation of new equipment. This Project will also involve replacing structures and rebuilding a 3.1-mile section of Fostoria West End (AEP)-Lemoyne-West Fremont 138 kV line from single circuit to double circuit. The Project will improve the transmission system in the Project area.

The Project will be located in Woodville Township, Sandusky County, Ohio and Troy Township, Wood County, Ohio.

Please feel free to call me with any question you have on making the Letter of Notification application available to your patrons. My phone number is (330) 384-2743.

Sincerely,



Robert Maggioro
Transmission Specialist II
Energy Delivery
Transmission and Substation Design
FirstEnergy Service Company

Enclosure

Exhibit 5
Property Owners Affected by the
Fostoria West End (AEP)-Lemoyne-West Fremont 138 kV Transmission Line
and Substation Upgrade Project
Case No. 19-1337-EL-BLN

Property Owners

Parcel ID	Owner Name	Address	Easement Status
U69-612-260000009000	Perry Thomas E & Colleen E	2606 Middleton Pike, Luckey, OH, 43443	Existing; to be Modified
U69-612-260000003000	Avers Dale J Trustee	2873 Middleton Pike, Luckey, OH, 43443	Existing; to be Modified
U69-612-260000010000	Carter Richard A & Sandra R	2450 Middleton Pike, Luckey, OH, 43443	Existing; to be Modified
U69-612-260000001500, U69-612-260000001001	Kriston Andrew & Gayle	20565 Bradner Rd, Luckey, OH, 43443	Existing; to be Modified
U69-612-260000011000, U69-612-260000012000, U69-612-260000013000	Oberhouse Steven R & Deborah L	2354 Middleton Pike, Luckey, OH, 43443	Existing; to be Modified
U69-612-260000015000, U69-612-260000014000, U69-612-260000016000	Burke Todd J & Burke Sarah A	2262 Middleton Pike, Luckey, OH, 43443	Existing; to be Modified
U69-612-260000017000, U69-612-260000018000	Harpel Lucas M & Ashley M	2240 Middleton Pike, Luckey, OH, 43443	Existing; to be Modified
U69-612-260000019000	Richardson James J & Annette L	2196 Middleton Pike, Luckey, OH, 43443	Existing; to be Modified
U69-612-260000046000	Rentz William O & Susan L	20533 Bradner Rd, Luckey, OH, 43443	Existing; to be Modified
U69-612-250000009000, U69-612-250000008000	Krotzer Richard E	1980 Middleton Pike, Luckey, OH, 43443	Existing; to be Modified
U69-612-250000010501	Poiry Lawrence & Christie	326 Harding Ave, Northwood, OH, 43619	Existing; to be Modified
U69-612-250000010502	Sheldrick Alexis L & Jacob M	1832 Middleton Pike, Luckey, OH, 43443	Existing; to be Modified
U69-612-250000010503	Couch James H Jr & Sharon K	1776 Middleton Pike, Luckey, OH, 43443	Existing; to be Modified
U69-612-250000010504	Tressel Timothy J & Susan M	1738 Middleton Pike, Luckey, OH, 43443	Existing; to be Modified

Parcel ID	Owner Name	Address	Easement Status
U69-612-250000012000, U69-612-250000010500	Holliday Edgar & Judith	1560 Middleton Pike, Luckey, OH, 43443	Existing; to be Modified
U69-612-250000014000	Huss Susan Kay	1442 Middleton Pike, Luckey, OH, 43443	Existing; to be Modified
U69-612-250000013000	Mundrick Daniel J & Ashley N	1458 Middleton Pike, Luckey, OH, 43443	Existing; to be Modified
U69-612-250000002000	Moritz Betty L / Moritz John A	13 Drba Way, New Castle, DE, 19720	Existing; to be Modified
U69-612-250000001001	Haar Richard A & Debrah	1226 Middleton Pike, Luckey, OH, 43443	Existing; to be Modified
U69-612-250000001006	Prey Donald G & Patricia A	1166 Middleton Pike, Luckey, OH, 43443	Existing; to be Modified
U69-612-250000001005	Cleveland Kelly	1110 Middleton Pike, Luckey, OH, 43443	Existing; to be Modified
U69-612-250000001008	Myers Loren D	1050 Middleton Pike, Luckey, OH, 43443	Existing; to be Modified
2830000001501	Crouse, Paul W & Roger P	2922 Bays Rd, Risingsun, OH, 43457	Existing; to be Modified
2830000001500, 2830000000100	American Title Agency Inc	19410 Dunbridge Rd, Bowling Green, OH, 43402	Existing; to be Modified
2830000000200	Leking, Christopher G	1113 Gibsonburg Rd, Bradner, OH, 43406	Existing; to be Modified
2830000000409	Baumgartner Steven A & Kimberly A	7214 Sr 582, Woodville, OH, 43469	Existing; to be Modified
2830000000410	Chagnon, James A & Margaret Baker	7192 Sr 582, Woodville, OH, 43469	Existing; to be Modified
2830000000405	Harrington Timothy D & Michele Ann	7180 Sr 582, Woodville, OH, 43469	Existing; to be Modified
2830000000404	Ahrens, Sherri L	7163 Sr 582, Woodville, OH, 43469	Existing; to be Modified
2830000000401	Rood, Jeffery P & Karen	7150 Sr 582, Woodville, OH, 43469	Existing; to be Modified
2830000000402	Tipton, Gary R & Susan J	7138 Sr 582, Woodville, OH, 43469	Existing; to be Modified
2830000000403	Bankey, Troy W & Jennifer L	3868 Cr 16, Woodville, OH, 43469	Existing; to be Modified
2829000000200	Moran, Peter L	4912 Skelly Rd, Toledo, OH, 43623	Existing; to be Modified
2829000000600	Nedelco, Jeff & Migliori, Donna	6845 W Sr 582, Woodville, OH, 43469	Existing; to be Modified
2829000000502	Kelley, Robert E & Linda M	6833 Sr 582, Woodville, OH, 43469	Existing; to be Modified
2829000000504	Kelley, Krista L	6821 Sr 582, Woodville, OH, 43469	Existing; to be Modified
2829000000500	Konesky, Emil J Trustee	842 Pemberville Rd, Woodville, OH, 43469	Existing; to be Modified
2829000000503	Judy, Steven A	846 Pemberville Rd, Woodville, OH, 43469	Existing; to be Modified