



The Dayton Power and Light Company  
1900 Dryden Road  
Dayton, Ohio 45439

July 13, 2020

Chairman Sam Randazzo  
Ohio Power Siting Board  
180 East Broad Street  
Columbus, Ohio 43215

Re: **West Milton Substation Expansion Project**  
Ohio Power Siting Board Case Number 19-1346-EL-BNR  
Notification of Commencement of Construction

Dear Chairman Randazzo,

The Dayton Power and Light Company hereby files this proof of compliance with the notice requirements set forth in Rule 4906-6-11(C) of the Ohio Administrative Code for the above-referenced project application.

Please contact me if you have any questions.

Respectfully submitted,

ss:/ *Randall V. Griffin*

Randall V Griffin (Ohio Bar No. 0080499)  
Chief Regulatory Counsel  
The Dayton Power and Light Company  
937-479-8983  
Randall.griffin@aes.com



The Dayton Power and Light Company  
1900 Dryden Road  
Dayton, Ohio 45439

July 1, 2020

Mr. Shawn Brandon  
6733 S Jay Rd  
West Milton, OH 45383

Dear Valued Customer,

DP&L values you as a customer and makes every effort to keep you informed of changes that may affect your property. We are writing to share the improvements The Dayton Power and Light Company ("DP&L") is making to an electric transmission substation that is close to your property. The work is being done at the West Milton Substation which is located in West Milton, Miami County, Ohio.

As described in the Construction Notice Application, which was approved by the Ohio Power Siting Board ("OPSB") on December 10, 2019 (Case Number 19-1346-EL-BNR), the improvements will consist of adding a second 345/138kV transformer, adding a second 138/69kV transformer, and facilities for the new West Milton-Eldean 138kV transmission line. This project is being undertaken to comply with mandatory North American Electric Reliability Corporation (NERC) reliability requirements. The improvements will strengthen the electric system and will improve reliability by ensuring that system voltages do not drop below minimum acceptable levels and relieving thermal loading issues under certain contingencies.

The entire construction of the substation expansion will be on existing DP&L property. Therefore, your property will not be disturbed.

Actual construction for the project is scheduled to begin in August 2020 and the new equipment is expected to be in-service by June 2021. Customers should not see any interruption to their electric service because of this work. We understand the construction project will present a temporary inconvenience as we work to strengthen our infrastructure to provide safe, reliable electric service.

Please note, DP&L employees always carry company identification. Contracted personnel also carry company identification along with documentation that they are working for DP&L. If you have any questions about whether someone works for DP&L please call 800-433-8500 to verify.

For additional details about the OPSB and this project, please refer to the OPSB website at <https://www.opsb.ohio.gov/>. To view an electronic version of the application, search Case Number 19-1346-BNR.

If you have questions, please contact Scott Teeters by email at [dpltransmissionmaintenancegroup@aes.com](mailto:dpltransmissionmaintenancegroup@aes.com) or call 937-331-4545.

Sincerely,

Dayton Power and Light Transmission Department



The Dayton Power and Light Company  
1900 Dryden Road  
Dayton, Ohio 45439

July 1, 2020

Ms. Teresa Bunch  
150 Rue Grand Drive  
Lake Saint Louis, MO 63367

Dear Valued Customer,

DP&L values you as a customer and makes every effort to keep you informed of changes that may affect your property. We are writing to share the improvements The Dayton Power and Light Company ("DP&L") is making to an electric transmission substation that is close to your property. The work is being done at the West Milton Substation which is located in West Milton, Miami County, Ohio.

As described in the Construction Notice Application, which was approved by the Ohio Power Siting Board ("OPSB") on December 10, 2019 (Case Number 19-1346-EL-BNR), the improvements will consist of adding a second 345/138kV transformer, adding a second 138/69kV transformer, and facilities for the new West Milton-Eldean 138kV transmission line. This project is being undertaken to comply with mandatory North American Electric Reliability Corporation (NERC) reliability requirements. The improvements will strengthen the electric system and will improve reliability by ensuring that system voltages do not drop below minimum acceptable levels and relieving thermal loading issues under certain contingencies.

The entire construction of the substation expansion will be on existing DP&L property. Therefore, your property will not be disturbed.

Actual construction for the project is scheduled to begin in August 2020 and the new equipment is expected to be in-service by June 2021. Customers should not see any interruption to their electric service because of this work. We understand the construction project will present a temporary inconvenience as we work to strengthen our infrastructure to provide safe, reliable electric service.

Please note, DP&L employees always carry company identification. Contracted personnel also carry company identification along with documentation that they are working for DP&L. If you have any questions about whether someone works for DP&L please call 800-433-8500 to verify.

For additional details about the OPSB and this project, please refer to the OPSB website at <https://www.opsb.ohio.gov/>. To view an electronic version of the application, search Case Number 19-1346-BNR.

If you have questions, please contact Scott Teeters by email at [dpltransmissionmaintenancegroup@aes.com](mailto:dpltransmissionmaintenancegroup@aes.com) or call 937-331-4545.

Sincerely,

Dayton Power and Light Transmission Department



The Dayton Power and Light Company  
1900 Dryden Road  
Dayton, Ohio 45439

July 1, 2020

Dack Properties LLC  
7555 S Peters RD  
TIPP City, OH 45371

Dear Valued Customer,

DP&L values you as a customer and makes every effort to keep you informed of changes that may affect your property. We are writing to share the improvements The Dayton Power and Light Company ("DP&L") is making to an electric transmission substation that is close to your property. The work is being done at the West Milton Substation which is located in West Milton, Miami County, Ohio.

As described in the Construction Notice Application, which was approved by the Ohio Power Siting Board ("OPSB") on December 10, 2019 (Case Number 19-1346-EL-BNR), the improvements will consist of adding a second 345/138kV transformer, adding a second 138/69kV transformer, and facilities for the new West Milton-Eldean 138kV transmission line. This project is being undertaken to comply with mandatory North American Electric Reliability Corporation (NERC) reliability requirements. The improvements will strengthen the electric system and will improve reliability by ensuring that system voltages do not drop below minimum acceptable levels and relieving thermal loading issues under certain contingencies.

The entire construction of the substation expansion will be on existing DP&L property. Therefore, your property will not be disturbed.

Actual construction for the project is scheduled to begin in August 2020 and the new equipment is expected to be in-service by June 2021. Customers should not see any interruption to their electric service because of this work. We understand the construction project will present a temporary inconvenience as we work to strengthen our infrastructure to provide safe, reliable electric service.

Please note, DP&L employees always carry company identification. Contracted personnel also carry company identification along with documentation that they are working for DP&L. If you have any questions about whether someone works for DP&L please call 800-433-8500 to verify.

For additional details about the OPSB and this project, please refer to the OPSB website at <https://www.opsb.ohio.gov/>. To view an electronic version of the application, search Case Number 19-1346-BNR.

If you have questions, please contact Scott Teeters by email at [dpltransmissionmaintenancegroup@aes.com](mailto:dpltransmissionmaintenancegroup@aes.com) or call 937-331-4545.

Sincerely,

Dayton Power and Light Transmission Department



The Dayton Power and Light Company  
1900 Dryden Road  
Dayton, Ohio 45439

July 1, 2020

Mr. Kevin Dohner  
7031 W. Fred-Garland Rd  
West Milton, OH 45383

Dear Valued Customer,

DP&L values you as a customer and makes every effort to keep you informed of changes that may affect your property. We are writing to share the improvements The Dayton Power and Light Company ("DP&L") is making to an electric transmission substation that is close to your property. The work is being done at the West Milton Substation which is located in West Milton, Miami County, Ohio.

As described in the Construction Notice Application, which was approved by the Ohio Power Siting Board ("OPSB") on December 10, 2019 (Case Number 19-1346-EL-BNR), the improvements will consist of adding a second 345/138kV transformer, adding a second 138/69kV transformer, and facilities for the new West Milton-Eldean 138kV transmission line. This project is being undertaken to comply with mandatory North American Electric Reliability Corporation (NERC) reliability requirements. The improvements will strengthen the electric system and will improve reliability by ensuring that system voltages do not drop below minimum acceptable levels and relieving thermal loading issues under certain contingencies.

The entire construction of the substation expansion will be on existing DP&L property. Therefore, your property will not be disturbed.

Actual construction for the project is scheduled to begin in August 2020 and the new equipment is expected to be in-service by June 2021. Customers should not see any interruption to their electric service because of this work. We understand the construction project will present a temporary inconvenience as we work to strengthen our infrastructure to provide safe, reliable electric service.

Please note, DP&L employees always carry company identification. Contracted personnel also carry company identification along with documentation that they are working for DP&L. If you have any questions about whether someone works for DP&L please call 800-433-8500 to verify.

For additional details about the OPSB and this project, please refer to the OPSB website at <https://www.opsb.ohio.gov/>. To view an electronic version of the application, search Case Number 19-1346-BNR.

If you have questions, please contact Scott Teeters by email at [dpltransmissionmaintenancengroup@aes.com](mailto:dpltransmissionmaintenancengroup@aes.com) or call 937-331-4545.

Sincerely,

Dayton Power and Light Transmission Department



The Dayton Power and Light Company  
1900 Dryden Road  
Dayton, Ohio 45439

July 1, 2020

Mr. Mark Herkins  
6990 W Emerick Rd  
West Milton, OH 45383

Dear Valued Customer,

DP&L values you as a customer and makes every effort to keep you informed of changes that may affect your property. We are writing to share the improvements The Dayton Power and Light Company ("DP&L") is making to an electric transmission substation that is close to your property. The work is being done at the West Milton Substation which is located in West Milton, Miami County, Ohio.

As described in the Construction Notice Application, which was approved by the Ohio Power Siting Board ("OPSB") on December 10, 2019 (Case Number 19-1346-EL-BNR), the improvements will consist of adding a second 345/138kV transformer, adding a second 138/69kV transformer, and facilities for the new West Milton-Eldean 138kV transmission line. This project is being undertaken to comply with mandatory North American Electric Reliability Corporation (NERC) reliability requirements. The improvements will strengthen the electric system and will improve reliability by ensuring that system voltages do not drop below minimum acceptable levels and relieving thermal loading issues under certain contingencies.

The entire construction of the substation expansion will be on existing DP&L property. Therefore, your property will not be disturbed.

Actual construction for the project is scheduled to begin in August 2020 and the new equipment is expected to be in-service by June 2021. Customers should not see any interruption to their electric service because of this work. We understand the construction project will present a temporary inconvenience as we work to strengthen our infrastructure to provide safe, reliable electric service.

Please note, DP&L employees always carry company identification. Contracted personnel also carry company identification along with documentation that they are working for DP&L. If you have any questions about whether someone works for DP&L please call 800-433-8500 to verify.

For additional details about the OPSB and this project, please refer to the OPSB website at <https://www.opsb.ohio.gov/>. To view an electronic version of the application, search Case Number 19-1346-BNR.

If you have questions, please contact Scott Teeters by email at [dpltransmissionmaintenancegroup@aes.com](mailto:dpltransmissionmaintenancegroup@aes.com) or call 937-331-4545.

Sincerely,

Dayton Power and Light Transmission Department





The Dayton Power and Light Company  
1900 Dryden Road  
Dayton, Ohio 45439

July 1, 2020

Mr. Gary Knife  
7111 W. Fred Garland Rd  
Englewood, OH 45322

Dear Valued Customer,

DP&L values you as a customer and makes every effort to keep you informed of changes that may affect your property. We are writing to share the improvements The Dayton Power and Light Company ("DP&L") is making to an electric transmission substation that is close to your property. The work is being done at the West Milton Substation which is located in West Milton, Miami County, Ohio.

As described in the Construction Notice Application, which was approved by the Ohio Power Siting Board ("OPSB") on December 10, 2019 (Case Number 19-1346-EL-BNR), the improvements will consist of adding a second 345/138kV transformer, adding a second 138/69kV transformer, and facilities for the new West Milton-Eldean 138kV transmission line. This project is being undertaken to comply with mandatory North American Electric Reliability Corporation (NERC) reliability requirements. The improvements will strengthen the electric system and will improve reliability by ensuring that system voltages do not drop below minimum acceptable levels and relieving thermal loading issues under certain contingencies.

The entire construction of the substation expansion will be on existing DP&L property. Therefore, your property will not be disturbed.

Actual construction for the project is scheduled to begin in August 2020 and the new equipment is expected to be in-service by June 2021. Customers should not see any interruption to their electric service because of this work. We understand the construction project will present a temporary inconvenience as we work to strengthen our infrastructure to provide safe, reliable electric service.

Please note, DP&L employees always carry company identification. Contracted personnel also carry company identification along with documentation that they are working for DP&L. If you have any questions about whether someone works for DP&L please call 800-433-8500 to verify.

For additional details about the OPSB and this project, please refer to the OPSB website at <https://www.opsb.ohio.gov/>. To view an electronic version of the application, search Case Number 19-1346-BNR.

If you have questions, please contact Scott Teeters by email at [dpltransmissionmaintenancegroup@aes.com](mailto:dpltransmissionmaintenancegroup@aes.com) or call 937-331-4545.

Sincerely,

Dayton Power and Light Transmission Department



The Dayton Power and Light Company  
1900 Dryden Road  
Dayton, Ohio 45439

July 1, 2020

Mr. Courtney Russell  
7050 W. Fred Garland Rd  
Englewood, OH 45322

Dear Valued Customer,

DP&L values you as a customer and makes every effort to keep you informed of changes that may affect your property. We are writing to share the improvements The Dayton Power and Light Company ("DP&L") is making to an electric transmission substation that is close to your property. The work is being done at the West Milton Substation which is located in West Milton, Miami County, Ohio.

As described in the Construction Notice Application, which was approved by the Ohio Power Siting Board ("OPSB") on December 10, 2019 (Case Number 19-1346-EL-BNR), the improvements will consist of adding a second 345/138kV transformer, adding a second 138/69kV transformer, and facilities for the new West Milton-Eldean 138kV transmission line. This project is being undertaken to comply with mandatory North American Electric Reliability Corporation (NERC) reliability requirements. The improvements will strengthen the electric system and will improve reliability by ensuring that system voltages do not drop below minimum acceptable levels and relieving thermal loading issues under certain contingencies.

The entire construction of the substation expansion will be on existing DP&L property. Therefore, your property will not be disturbed.

Actual construction for the project is scheduled to begin in August 2020 and the new equipment is expected to be in-service by June 2021. Customers should not see any interruption to their electric service because of this work. We understand the construction project will present a temporary inconvenience as we work to strengthen our infrastructure to provide safe, reliable electric service.

Please note, DP&L employees always carry company identification. Contracted personnel also carry company identification along with documentation that they are working for DP&L. If you have any questions about whether someone works for DP&L please call 800-433-8500 to verify.

For additional details about the OPSB and this project, please refer to the OPSB website at <https://www.opsb.ohio.gov/>. To view an electronic version of the application, search Case Number 19-1346-BNR.

If you have questions, please contact Scott Teeters by email at [dpltransmissionmaintenancengroup@aes.com](mailto:dpltransmissionmaintenancengroup@aes.com) or call 937-331-4545.

Sincerely,

Dayton Power and Light Transmission Department





Hi. Your package was  
delivered Fri, 07/03/2020 at  
12:28pm.



Delivered to  
Received by Signature Not Req

**OBTAIN PROOF OF DELIVERY**

**TRACKING NUMBER** [770850167862](#)

**FROM** ARCADIS  
222 S MAIN ST STE 200  
AKRON, OH, US, 44308

**TO** Mark Herkins  
6990 EMERICK RD W  
WEST MILTON, OH, US, 45383

**PURCHASE ORDER NUMBER** DP&L Letter

**REFERENCE** 30042292 99

**SHIP DATE** Thu 7/02/2020 12:00 AM

**ORIGIN** AKRON, OH, US, 44308

**DESTINATION** WEST MILTON, OH, US, 45383

**NUMBER OF PIECES** 1

**TOTAL SHIPMENT WEIGHT** 1.00 LB

**SERVICE TYPE** FedEx Home Delivery




Hi. Your package was  
delivered Fri, 07/03/2020 at  
1:36pm.



Delivered to  
Received by Signature Not Req

**OBTAIN PROOF OF DELIVERY**

<b>TRACKING NUMBER</b>	<a href="#">770849760301</a>
<b>FROM</b>	ARCADIS 222 S MAIN ST STE 200 AKRON, OH, US, 44308
<b>TO</b>	Dack Properties LLC 7555 PETERS RD TIPP CITY, OH, US, 45371
<b>PURCHASE ORDER NUMBER</b>	DP&L Letter
<b>REFERENCE</b>	30042292 99
<b>SHIP DATE</b>	Thu 7/02/2020 12:00 AM
<b>ORIGIN</b>	AKRON, OH, US, 44308
<b>DESTINATION</b>	TIPP CITY, OH, US, 45371
<b>NUMBER OF PIECES</b>	1
<b>TOTAL SHIPMENT WEIGHT</b>	1.00 LB
<b>SERVICE TYPE</b>	FedEx Home Delivery





Hi. Your package was  
delivered Fri, 07/03/2020 at  
2:07pm.



Delivered to  
Received by Signature Not Req

**OBTAIN PROOF OF DELIVERY**

**TRACKING NUMBER** [770850129688](#)

**FROM** ARCADIS  
222 S MAIN ST STE 200  
AKRON, OH, US, 44308

**TO** Shawn Brandon  
6733 S JAY RD  
WEST MILTON, OH, US, 45383

**PURCHASE ORDER NUMBER** DP&L Letter

**REFERENCE** 30042292 99

**SHIP DATE** Thu 7/02/2020 12:00 AM

**ORIGIN** AKRON, OH, US, 44308

**DESTINATION** WEST MILTON, OH, US, 45383

**NUMBER OF PIECES** 1

**TOTAL SHIPMENT WEIGHT** 1.00 LB

**SERVICE TYPE** FedEx Home Delivery



Hi. Your package was  
delivered Friday, 07/03/20 at  
15:35.



Delivered to



Received by Signature Not Req

**OBTAIN PROOF OF DELIVERY**

<b>TRACKING NUMBER</b>	<a href="#">770850081852</a>
<b>FROM</b>	ARCADIS 222 S MAIN ST STE 200 AKRON, OH, US, 44308
<b>TO</b>	Gary Knife 7111 FREDERICK GARLAND RD ENGLEWOOD, OH, US, 45322
<b>PURCHASE ORDER NUMBER</b>	DP&L Letter
<b>REFERENCE</b>	30042292 99
<b>SHIP DATE</b>	Thu 7/02/2020 12:00 AM
<b>ORIGIN</b>	AKRON, OH, US, 44308
<b>DESTINATION</b>	ENGLEWOOD, OH, US, 45322
<b>NUMBER OF PIECES</b>	1
<b>TOTAL SHIPMENT WEIGHT</b>	1.00 LB
<b>SERVICE TYPE</b>	FedEx Home Delivery



*Hi. Your package was  
delivered Friday, 07/03/20 at  
15:36.*



*Delivered to  
Received by Signature Not Req*

**[OBTAIN PROOF OF DELIVERY](#)**

**TRACKING NUMBER**     [770849896864](#)

**FROM**     ARCADIS  
222 S MAIN ST STE 200  
AKRON, OH, US, 44308

**TO**     Courtney Russell  
7050 W Fred Garland Rd  
ENGLEWOOD, OH, US, 45322

**REFERENCE**     30042292 99

**SHIP DATE**     Thu 7/02/2020 12:00 AM

**ORIGIN**     AKRON, OH, US, 44308

**DESTINATION**     ENGLEWOOD, OH, US, 45322

**NUMBER OF PIECES**     1

**TOTAL SHIPMENT WEIGHT** 1.00 LB

**SERVICE TYPE** FedEx Ground



Hi. Your package was  
delivered Fri, 07/03/2020 at  
3:38pm.



Delivered to  
Received by Signature Not Req

**OBTAIN PROOF OF DELIVERY**

**TRACKING NUMBER** [770850044424](#)

**FROM** ARCADIS  
222 S MAIN ST STE 200  
AKRON, OH, US, 44308

<b>TO</b>	Kevin Dohner 7031 W FREDERICK GARLAND RD WEST MILTON, OH, US, 45383
<b>PURCHASE ORDER NUMBER</b>	DP&L Letter
<b>REFERENCE</b>	30042292 99
<b>SHIP DATE</b>	Thu 7/02/2020 12:00 AM
<b>ORIGIN</b>	AKRON, OH, US, 44308
<b>DESTINATION</b>	WEST MILTON, OH, US, 45383
<b>NUMBER OF PIECES</b>	1
<b>TOTAL SHIPMENT WEIGHT</b>	1.00 LB
<b>SERVICE TYPE</b>	FedEx Home Delivery



Hi. Your package was  
delivered Sat, 07/04/2020 at  
2:35pm.



Delivered to  
Received by Signature Not Req

**OBTAIN PROOF OF DELIVERY**

<b>TRACKING NUMBER</b>	<a href="#">770850005313</a>
<b>FROM</b>	ARCADIS 222 S MAIN ST STE 200 AKRON, OH, US, 44308
<b>TO</b>	Teresa Bunch 150 RUE GRAND DR LAKE SAINT LOUIS, MO, US, 63367
<b>PURCHASE ORDER NUMBER</b>	DP&L Letter
<b>REFERENCE</b>	30042292 99
<b>SHIP DATE</b>	Thu 7/02/2020 12:00 AM
<b>ORIGIN</b>	AKRON, OH, US, 44308
<b>DESTINATION</b>	LAKE SAINT LOUIS, MO, US, 63367
<b>NUMBER OF PIECES</b>	1
<b>TOTAL SHIPMENT WEIGHT</b>	1.00 LB
<b>SERVICE TYPE</b>	FedEx Home Delivery



**This foregoing document was electronically filed with the Public Utilities**

**Commission of Ohio Docketing Information System on**

**7/13/2020 1:36:07 PM**

**in**

**Case No(s). 19-1346-EL-BNR**

Summary: Notice of compliance of notification to affected property owners of commencement of construction electronically filed by Mr. Michael F Russ on behalf of The Dayton Power and Light Company