

**Duke Energy Ohio  
Case No. 20-1610-EL-BLN  
STAFF Second Set of Data Requests  
Date Received: January 13, 2021**

**STAFF-DR-02-001**

**REQUEST:**

The Existing structure 107H-1695 appears to be located very close to an eroding stream bank. Staff would recommend that this structure be removed by cutting it at the grade level and leaving the underground portion in place in order to prevent further erosion issues. Is this the applicant's present plan, and if not, is the applicant willing to commit to this removal method for this structure?

**RESPONSE:** Duke Energy Ohio is willing to commit to this removal method for this structure.

**PERSON RESPONSIBLE:** Dustin Giesler

**This foregoing document was electronically filed with the Public Utilities**

**Commission of Ohio Docketing Information System on**

**1/14/2021 11:46:16 AM**

**in**

**Case No(s). 20-1610-EL-BLN**

Summary: Correspondence Duke Energy Ohio, Inc.'s Response to Staff Data Request 02-001 electronically filed by Carys Cochern on behalf of Duke Energy Ohio, Inc.