

180 E. BROAD STREET, SUITE 3400 COLUMBUS, OH 43215-3192 TELEPHONE: (614) 591-5461 FACSIMILE: (844) 670-6009 http://www.dickinsonwright.com

CHRISTINE M.T. PIRIK
CPirik@dickinsonwright.com

July 28, 2023

Ms. Tanowa Troupe, Secretary Ohio Power Siting Board Docketing Division 180 East Broad Street, 11<sup>th</sup> Floor Columbus, Ohio 43215-3797

Re: Case No. 23-459-EL-BGA

In the Matter of the Application of Grover Hill Wind, LLC to Amend its Certificate Issued in Case No. 20-417-EL-BGN.

**Supplement to Amendment Application—Geotechnical Investigation Report** 

Dear Ms. Troupe:

On May 3, 2023, Grover Hill Wind, LLC ("Applicant") filed an application with the Ohio Power Siting Board for a Certificate of Environmental Compatibility and Public Need to Amend Its Certificate Issued in Case No. 20-417-EL-BGN.

The purpose of this Supplement to the Amendment Application is to submit a Geotechnical Investigation Report. Attached please find the report.

We are available, at your convenience, to answer any questions you may have.

Respectfully submitted,

/s/ Christine M.T. Pirik

Christine M.T. Pirik (0029759)

(Counsel of Record)

Terrence O'Donnell (0074213)

Matthew C. McDonnell (0090164)

Dickinson Wright PLLC

180 E. Broad Street, Suite 3400

Columbus, Ohio 43215

Phone: (614) 591-5461

Email: cpirik@dickinsonwright.com

todonnell@dickinsonwright.com

mmcdonnell@dickinsonwright.com

(Counsel agrees to receive service by email.)

Attorneys for Grover Hill Wind, LLC

Jim O'Dell

Jon Pawley

Grant Zeto

Mike Williams

Enclosure

CC:

Ms. Tanowa Troupe Grover Hill Wind, LLC Case No. 23-459-EL-BGA Page 2

#### **CERTIFICATE OF SERVICE**

The Ohio Power Siting Board's e-filing system will electronically serve notice of the filing of this document on the parties referenced in the service list of the docket card who have electronically subscribed to these cases. In addition, the undersigned certifies that a copy of the foregoing document is also being served upon the persons below this 28<sup>th</sup> day of July, 2023.


/s/ Christine M.T. Pirik
Christine M.T. Pirik (0029759)

Counsel via email: <a href="mailto:shaun.lyons@OhioAGO.gov">shaun.lyons@OhioAGO.gov</a> thomas.lindgren@ohioAGO.gov

Administrative Law Judges via email:

matthew.sandor@puco.ohio.gov Nicholas.Walstra@puco.ohio.gov

4879-9642-5587 v2 [73809-23]



PREPARED FOR:



PREPARED BY:



# Westwood

# Supplemental Geotechnical Investigation Report

**Grover Hill Wind Project** 

Paulding County, OH

#### **Prepared For:**

Grover Hill Wind, LLC. 591 West Putnam Avenue Greenwich, CT 06830

#### **Prepared By:**

Westwood Professional Services Michigan LLC 12701 Whitewater Drive, Suite 300 Minnetonka, MN 55343 (952) 937-5150

Project Number: R0015695.00

Date: July 27, 2023



# **Table of Contents**

1.0			ction				
		•	ct Description				
2.0		Methods					
			Borings				
			ratory Testing				
	2.3	Electi	rical Resistivity Testing	7			
3.0	Site	e Con	ditions	7			
		_	onal Geology				
	3.2		azards				
		3.2.1	Karst	8			
		3.2.2	Seismicity	9			
		3.2.3	Slope Stability/Landslides	9			
		3.2.4	Expansive Soils	10			
	3.3	Subsu	urface Stratigraphy	10			
	3.4	Grou	ndwater	11			
4.0	Dis	cussi	ion and Recommendations	13			
	4.1	Soil P	Properties	13			
		4.1.1	Moisture and Density	13			
		4.1.2	Shear Strength of Soil	13			
		4.1.3	Electrical Resistivity	13			
		4.1.4	Thermal Resistivity	13			
		4.1.5	Soil Corrosivity	14			
	4.2	Gene	ral Earthwork Considerations	14			
		4.2.1	Clearing and Grubbing	14			
		4.2.2	Excavations and Water Control	14			
		4.2.3	Permanent Cut and Fill Slopes	15			
		4.2.4	Subgrade Preparation	16			
		4.2.5	Fill Placement and Compaction	16			
		4.2.6	Excavation Below Subgrade Procedures	17			



4.3	Gene	ral Foundation Considerations	18
	4.3.1	Lateral Resistance	18
	4.3.2	Seismic Considerations	18
	4.3.3	Frost Depth	18
4.4	Wind	Turbine Foundation Design Parameters	19
	4.4.1	Bearing Capacity	19
	4.4.2	Differential Settlement	19
	4.4.3	Rotational Stiffness	20
	4.4.4	Buoyancy	20
4.5	Wind	Turbine Foundation Considerations	20
	4.5.1	Subgrade Preparation and Testing	20
	4.5.2	Ground Improvement	21
	4.5.3	Previously Excavated Foundations	22
4.6	Const	truction Considerations	22
5.0 Lin	nitati	ons	22
6.0 Ref	feren	ces	<b>24</b>
Tables			
		ındwater (GW) Depth Summary	
Table ₄.	1 Fill a	and Backfill Material Recommendations	16





# **Attachments**

#### **Exhibits**

Exhibit 1: **Project Overview Map** Exhibit 2: **USGS Topography Map** Exhibit 3: Surficial Soils Map

#### **Appendices**

Appendix A: Soil Boring Logs and Rock core Logs SPT and RQD Summary Appendix B: **Laboratory Testing Reports** Appendix C: **Electrical Resistivity Test Results** Appendix D:





# **Executive Summary**

Westwood Professional Services (Westwood) is pleased to present this supplemental geotechnical investigation report to Grover Hill Wind, LLC., for the proposed Grover Hill Wind Project (Project) located in Paulding County, Ohio. The scope of work for this investigation included subsurface exploration, field and laboratory testing, engineering analysis, and preparation of this report for the proposed wind project. This investigation has generally revealed no subsurface conditions that would preclude development of the moved turbine locations within the proposed project.

Based on the information obtained from the supplemental borings at five turbine locations with standard penetration tests (SPT) advanced to depths of up to 41 feet below ground surface (bgs), the subsurface conditions at the site generally consist of 1 to 3 inches of topsoil overlying stiff to hard lean clay with variable amount of sand and gravel extending to dolomite bedrock at depths between 21 and 28 feet.

Piezometers were installed at each of the four supplemental turbine locations and re-measured at the piezometers from the initial geotechnical investigation in 2021. Groundwater was measured at depths between 3 and 6 feet below grade in the piezometers. Groundwater level fluctuations occur due to seasonal variation in the amount of rainfall, runoff, and other factors not evident at the time the borings were performed; therefore, groundwater levels during construction or at other times in the life of the structure may be higher or lower than those observed during the investigation.

The below summary of recommendations may be used for wind turbine foundation designs for the locations investigated. These recommendations assume wind turbines will bear on very stiff native clay:

- Minimum depth to groundwater = 3 feet (may be confirmed with additional readings)
- Foundation backfill density (moist) = 105 pcf
- Gross allowable bearing capacity, normal loads = 3,500 psf
- Gross allowable bearing capacity, extreme loads = 5,000 psf
- Differential settlement = 1.6 inches (approximately 0.17 degrees rotation)
- Rotational stiffness = 525 GN-m/rad.

This executive summary should be read in context of the entire report for full understanding of the subsurface conditions encountered and associated recommendations. Westwood's Geotechnical Investigation Report (2021) should also be read for a full understanding of the subsurface conditions encountered across the entirety of the site.

### 1.0 Introduction

This report presents the findings of the supplemental geotechnical investigation conducted by Westwood Professional Services (Westwood) for the proposed Grover Hill Wind Project (Project) located in Paulding County, Ohio, surrounding the Village of Grover Hill (Exhibit 1). The primary purpose of this report is to provide geotechnical test data and analysis to support the design and construction of the proposed Project. This investigation focuses on five of the proposed wind turbine locations that have moved locations since Westwood's initial investigation in 2021. The services provided were in general conformance with the scope of work and assumptions outlined in Westwood's proposal dated April 18, 2022. This report is intended for exclusive use by Grover Hill Wind, LLC.

#### 1.1 Project Description

Westwood understands that the proposed project will consist of 23 wind turbine generators, with up to four different turbine models being considered. The proposed project will also consist of access roads, electrical collection system, MET towers, O&M building, and collector substation. Topography across the project site can be described as generally flat to lightly undulating. The present land use is predominately agricultural fields.

# 2.0 Methods

A supplemental geotechnical investigation program was completed by Westwood with field work performed between May 23<sup>rd</sup> through 27<sup>th</sup>, 2022 and April 24<sup>th</sup> through 27<sup>th</sup>, 2023. EnviroCore, Inc. was retained by Westwood to perform geotechnical drilling with standard penetration testing (SPT). Westwood and Soil Engineering Testing (SET) performed laboratory testing on soil samples collected during the investigation. A Westwood geotechnical representative coordinated the field work, logged the borings, collected samples, and performed the electrical resistivity testing. The field investigation consisted of the following scope of work:

 Conducting soil borings at five proposed wind turbine locations to a target depth of 60 ft below ground surface (bgs). If auger refusal was encountered prior to a depth of 30 ft, rock coring would be performed to a minimum depth of 35 ft bgs. These five turbine locations (T-26a, 31a,

34b, 35a, and 43a) were re-drilled as a part of the supplemental investigation due to their locations moving greater than 50 ft from the original boring locations.

- Performing electrical resistivity surveys at two of the supplemental turbine locations.
- Collecting soil samples at all boring locations for laboratory testing.

Geotechnical test locations are shown on Exhibit 1. Boring locations were provided by Grover Hill Wind, LLC. based on the site layout available at the time of the field work. All test locations were staked by a Westwood engineer. Coordinates are provided on the boring logs.

#### 2.1 Soil Borings

Soil borings were drilled using hollow stem augers and soil samples were obtained using an automatic hammer and split-spoon samplers in general accordance with ASTM D1586. Rock coring was performed in general conformance with ASTM D2113 (Standard Practice for Rock Core Drilling and Sampling of Rock for Site Exploration). Standard penetration test (SPT) N-values are recorded on the boring logs and a summary is provided in Appendix B. A Westwood geotechnical representative logged the borings and collected the soil/rock samples. Bulk soil samples were also collected from shallow auger cuttings at the substation and several turbine locations for laboratory testing. Rock coring was performed after auger refusal to a maximum depth of 41 ft bgs. Soil and rock samples were shipped to Westwood and SET for laboratory testing. Soil boring logs are included in Appendix A.

Groundwater observation piezometers were installed within each of the boreholes. Piezometers consisted of 2 inch diameter PVC pipe installed to a depth of approximately 15 ft bgs with 3 ft of pipe stickup. The bottom 5 ft of pipe was screened and backfilled with sand then bentonite above the sand. Refer to Section 3.4 for additional information on groundwater observations.

#### 2.2 Laboratory Testing

Laboratory tests were conducted on representative soil and rock samples to aid in classification and evaluation of the physical properties and engineering characteristics of the material. Soil samples were sent to Westwood and SET for testing, which included the following:

- Moisture content (ASTM D2216)
- Sieve analysis (ASTM D6913 and D7928)
- Atterberg limits (ASTM D4318)
- Standard Proctor moisture-density relationship (ASTM D698)
- Unconfined compression (ASTM D7012)
- Chemical analysis (pH, Sulfates, Chlorides)
- Thermal resistivity with dry-out curves (ASTM D5334)

A summary of laboratory testing results is included in Appendix C, and complete test reports are included in Appendix C.

The bulk sample collected for thermal resistivity testing was prepared near the as-received moisture content and compacted to 90% of the standard Proctor maximum dry density, representing the compaction conditions typical of a backfilled utility trench, and subsequently dried out to zero moisture. Thermal resistivity measurements were taken at the compacted moisture content, zero moisture, and at several intermediate moisture contents during drying. Results of the thermal resistivity tests are discussed in Section 4.1.4 and test reports are included in Appendix C.

#### 2.3 Electrical Resistivity Testing

Electrical resistivity measurements were taken at two of the proposed wind turbine locations, as shown on Exhibit 1. Tests were performed using the Wenner Four-Electrode Method and an AEMC Instruments Model 6470-B Multi-Function Digital Ground Resistance Tester, in general accordance with ASTM G57. At each wind turbine test location, resistivity tests were performed along two perpendicular profiles with a minimum electrode spacing of 5, 10, 20, 30, 50, and 100 feet. Refer to Section 4.1.3 and the attached Appendix D for results of the electrical resistivity tests.

## 3.0 Site Conditions

#### 3.1 Regional Geology

The Grover Hill Wind Project is located within the Eastern Lake Section of the Central Lowland province (USGS, 1946) of the Interior Plains Physiographic Region. The Central Lowlands province is the largest physiographic province in the continuous US and is largely level. The Central Lowlands were subject to repeated Pleistocene glaciations, which define the landforms throughout the region (NPS, 2022). The present glacial topography at the project site is the product of the most recent glaciation event that ended approximately 10,000 years ago during the Late Wisconsin's glaciation event of the Pleistocene Epoch, where a massive continental ice sheet grew and gradually expanded southward. This created several finger-like lobes of glacial ice that engulfed the region and moved through the Superior basin. The project site is located within a geologic area known as the Maumee Lake Plain. During the Wisconsin glaciation, the project site was covered by Glacial Lake Maumee, an ancestor of present-day Lake Erie. As the glacier and lake slowly receded to the north, sediments were deposited along the path, resulting in the flat topography observed in the region today (Fullerton et. al., 2003).

The proposed project area is mapped within one geologic unit (Slucher et al, 2006), The Salina Group. The Salina Group formation is Silurian in age and primarily comprised of gray, thin bedded to laminated dolostone. Minor units of gypsum, shale, and anhydrite have also been identified within the formation. Refer to Exhibit 4 for mapped geologic units.

Based on Web Soil Survey data available through the United States Department of Agriculture (USDA, 2022), three major soil units and several minor units are mapped within the project area, as shown on Exhibit 3. The three major units include Paulding Clay, Latty Silty Clay, and the Nappanee Silty Clay Loam. They Latty silty clay and Paulding clay are classified as clayey glaciolacustrine deposits over clayey till, and the Nappanee silty clay is classified as till. All three units contain lean clay and fat clay throughout the soil profile, generally with a majority fat clay in the upper 5 feet.

#### 3.2 **Geohazards**

#### 3.2.1 Karst

Karst features generally develop in areas with wet subsurface conditions and soluble rock that may dissolve over time to form underground caves and ground instability. Karst geology can be particularly hazardous as caves develop slowly, while failures are rapid, often causing several feet of subsidence. According to the USGS map of Karst Hazard Potential in the United States (USGS, 2014), the project site is mapped within an area of karst potential in the form of carbonate rocks buried under less than 50 ft of glacially derived insoluble sediments in a humid climate (Exhibit 5). The Ohio Department of Natural Resources (ODGS, 2006) maps the project site in a region containing Silurian- and Devonian-age carbonate bedrock overlain by more than 20 feet of glacial drift and/or alluvium; however, the project site is not mapped in a probable karst area.

Although karst formations are relatively common in Ohio, the majority of mapped probable karst areas are located in the far north-central and far south-central portions of the state (Exhibit 5; ODNR, 2006). Although sporadic regions of probable karst have been identified throughout the western portion of the state, the nearest mapped area of probable karst is approximately 50 miles east of the project site (ODGS, 2006). According to the Ohio Department of Natural Resources' Karst Interactive Map (ODGS, 2022), there are no verified or suspected karst sinkholes or other features identified near the project site. Furthermore, Dolomite is considered the least susceptible of the karst-prone geologic formations, as compared to limestone or anhydrous/evaporate formations (BGS, 2013).

Results of the supplemental investigation indicate that the depth to dolomitic bedrock at the four supplemental turbine locations ranges between 21 ft and 28 ft bgs. At the four supplemental borings, no locations experienced notable core barrel drops. Although sandy infilling was observed at T-31 in 2021, this unit was not during the supplemental investigation at boring T-31a. It should be noted, however, that the limited recovery observed suggests highly weathered/poor quality

bedrock that may be karst-susceptible. The rock cores also exhibited relatively small (<2" diameter) dissolution features, known as pits and vugs.

In general, the potential for development of surficial sinkholes on site is considered low due to the presence of relatively small dissolution features encountered and lack of mapped karst features in the region. Although no surface depressions, sinkholes, or large voids were observed during the field exploration, it is still possible that karst features exist beyond the extents of our explorations. A detailed karst/sinkhole study was beyond the scope of this investigation. Additional on-site testing and analysis may be performed to further evaluate the potential for karst features if the risk is considered unacceptable to the Owner. Supplemental borings with video logging may be performed at select turbine locations to better assess the risk of subsurface voids.

#### 3.2.2 Seismicity

Ohio is not a historically active seismic region, as only 10 earthquake events with a magnitude greater than 2.5 on the Richter scale have been recorded within 50 miles of the site in the past 50 years. The nearest and most recent of these events was magnitude 2.6 earthquake that occurred in 2015, approximately 14 miles southwest of the project site. The largest of these events was a magnitude 4.5 event that occurred in 1986, approximately 33 miles south of the project site. According to a USGS ShakeMap available for the magnitude 4.5 earthquake, this event is expected to have been classified as a 3.0 to 4.0 on the Modified Mercalli Intensity scale at the project site, which is defined as an event that would induce a weak to light shaking with negligible to light potential for damage to structures (USGS, 2022a).

According to the USGS, there are no active fault zones within the project boundary (USGS, 2022b). The nearest mapped fault zone is the New Madrid seismic zone, located more than 200 miles southwest of the project site. The risk of liquefaction on site is also considered low due to the lack of historic seismic activity, clayey overburden soil, and shallow bedrock. See Section 4.3.2 for discussion on seismic design parameters.

#### 3.2.3 Slope Stability/Landslides

Deep-seated slope failure can occur on steep natural slopes that experience heavy rainfall events and/or are subjected to large surcharge loads at the crest of the slope. While the project site is generally on relatively flat ground with minimal risk of slope instability, one of the supplemental turbine locations (T-31a) is sited within 200 feet of a creek or irrigation channel. Northwest Ohio does not commonly experience slope failures, as most slope failures are mapped in the southeast portion of the site, northern Lake Erie shoreline, or along the banks of the Ohio River (ODNR, 1995). Furthermore, no evidence of recent slope failure along the creek banks or irrigation channels was observed during on-site activities. The risk of landslides for these wind turbine locations may be considered low due to the lack of prior evidence of slope failure in the region,

relatively flat topography, and the relatively high undrained shear strength of the soils on site. Reasonable crane walk and road setbacks should be established from the existing creeks or irrigation channels to allow for future erosion of the river banks without impacting the project site roads and turbine pads.

Any modifications to the existing slopes, including increased loads at the top of slope, removal of material from the toe of slope, and changes to surficial infiltration, can significantly affect slope stability. Discussion on fill slopes is provided in Section 4.2.3, but a detailed slope stability analysis was not a part of the scope of this investigation.

#### 3.2.4 Expansive Soils

Based on USDA Soil Survey data, the majority of the shallow soil is classified as having moderate swell potential, although scattered pockets of soil with high potential exist throughout the site, including fat clay (CH) soil units (USDA, 2022). The U.S. Army Corps of Engineers Technical Manual (1983) maps the project site within a region where the occurrence of expansive materials are extremely limited. Although swelling soils will likely not affect the deeper turbine foundations and the humid climate will generally limit significant moisture fluctuations, shallow foundations may still be impacted by soil expansion following extreme droughts if bearing directly on high plasticity clay. Refer to sections 4.2.4 and 4.2.5 for recommendations on subgrade preparation and fill material to mitigate risk of soil expansion below foundations.

#### 3.3 **Subsurface Stratigraphy**

Based on the conditions encountered at the soil boring locations within the Grover Hill Wind Project site, the general subsurface stratigraphic profile is described as follows:

- **Topsoil.** Topsoil at the four supplemental borings generally ranges from 1 to 3 inches thick, although a thicker rootzone should be expected. The topsoil encountered was generally dark brown and clayey with moderate organics and active roots. Topsoil depths could be greater in some portions of the site, particularly in topographic low areas.
- Glacial Till Lean Clay, Lean Clay with Sand, Clayey Gravel w/ Sand (CL, GC). Beneath the topsoil was stiff to hard glacial till lean clay with varying fractions of sand and gravel. The soil was typically various shades of brown and gray and damp to moist. The sand and gravel fraction of this material was typically between 15 and 25%.
- Bedrock Dolomite. Dolomitic bedrock was encountered at all four boring locations between 21 and 28 feet below grade. The upper 2- to 5-feet of the bedrock surface was typically highly weathered and transitioned into more competent bedrock with depth. Rock cores were typically light gray and had rock quality designation (RQD) values ranging from 0% to 90%, with the highest variability in RQD occurring in the initial 5 feet of coring. The majority of rock cores had

RQD values greater than 60%, demonstrating fair to good rock quality with moderate to sound rock continuity. Most samples had a vuggy texture with evidence of minor dissolution.

More detailed descriptions of the subsurface conditions are provided on the boring logs found in Appendix A. Rock coring photo logs are also provided in Appendix A.

#### 3.4 Groundwater

Boreholes were observed during and shortly after drilling for the presence and level of groundwater. Piezometers were installed after completion of drilling during the initial investigation in 2021 and measured 2 to 4 weeks after installation and again during this supplemental investigation approximately 7 months after their initial measurement. Piezometers were also installed after completion of drilling during this supplemental investigation and measured more than 24 hours after installation. Depth to groundwater on site varied from 17 feet to greater than 30 feet bgs during drilling, between 5.8 and 18.7 feet bgs from the initial piezometer monitoring trip in 2021, and between 3 and 6 feet bgs during the second piezometer monitoring trip as a part of the supplemental investigation. It should be noted that only 8 of the original 23 piezometers were able to be measured during the second trip, as many of the wells had been removed by landowners. Water levels were observed shallower during the second monitoring trip than during the initial trip. Depth to groundwater measured during drilling and after the piezometer monitoring trips are recorded Table 3.1 below. The water level encountered during drilling was generally deeper compared to the longer-term water level measured in the piezometers, as expected in clayey soil.

Groundwater level fluctuations occur due to seasonal variation in the amount of rainfall, runoff, and other factors not evident at the time the borings were performed; therefore, groundwater levels during construction or at other times in the life of the structure may be higher or lower than those observed during the investigation. Additional groundwater depth measurements should be taken to further evaluate groundwater fluctuations over time. Refer to Sections 4.2.2 for recommendations regarding water control.

Table 3.1 Groundwater (GW) Depth Summary

Boring ID	GW Measured During Drilling (ft)	GW Measured in Piezometer (October 2021) (ft)	GW Measured in Piezometer (May 2022) (ft)
T-11	30	5.8	*
T-13	-	18.7	4.0
T-14	22	8.7	*
T-15	-	8.1	6.0
T-16	-	7.8	4.0
T-17	22	6.3	*
T-25	-	10.5	*
T-26	-	10.4	6.0
T-27	-	12.7	*
T-28	20	9.8	*
T-29	-	10.4	*
T-30	-	*	*
T-31	-	11.0	5.0
T-32	-	13.5	*
T-33	-	7.6	3.0
T-34b	-	6.3	4.0
T-35a	-	10.5	*
T-36	-	9.5	*
T-37	-	11.3	*
T-38	-	11.3	*
T-40	17	16.7	*
T-41	25	18.5	*
T-43	21	6.2	4.0

<sup>\*</sup>Unable to check piezometer due to land access or removed piezometer

# 4.0 Discussion and Recommendations

#### 4.1 Soil Properties

#### 4.1.1 Moisture and Density

The in situ gravimetric moisture content of the soil at the four supplemental borings ranges from approximately 15% to 25%, with an average moisture content of approximately 19%. For wind turbine foundation design purposes, the recommended long-term moist unit weight of the native soil backfill compacted to 95% of the standard Proctor maximum dry density is 105 pcf based on a dry density of 95 pcf and 10% residual moisture.

#### 4.1.2 Shear Strength of Soil

Based on correlations to SPT blowcounts and pocket penetrometer tests, the clayey soils at the four supplemental turbine locations demonstrated undrained shear strength between 1,250 and greater than 5,000 psf. Based on these results, a design undrained shear strength of 1,250 psf is recommended for the soil between 0 to 10 feet below grade, and a design undrained strength of 2,000 psf is recommended for the soil greater than 10 feet below grade.

#### 4.1.3 Electrical Resistivity

Electrical resistivity measurements were collected at two supplemental turbine boring locations using the Wenner Four-Electrode Method in accordance with ASTM G57 using electrode spacings between 2 feet and 100 feet. Electrical resistivity generally varies with material type and moisture content, and ranged between 22 ohm-meters ( $\Omega$ -m) and 201  $\Omega$ -m based on test results. Resistivity general increased with depth, with the largest readings typically occurring at the largest spacing. These observed values are generally in agreement with typical published values for clay and limestone (Palacky, 1987). Results of the electrical resistivity tests are presented in Appendix D. Refer to Section 2.3 for additional information on the electrical resistivity test method.

#### 4.1.4 Thermal Resistivity

A thermal resistivity dry-out curve was developed for a shallow soil sample collected at boring T-34a between 1 and 5 feet bgs. The bulk sample was re-compacted at the natural moisture content to 90% of the standard Proctor maximum dry density. The thermal resistivity of the soil varied with moisture content and ranged from 84°C·cm/W (natural moisture content) to 191°C·cm/W (dry). Results of the thermal resistivity test is included in Appendix C. The underground cable designer shall choose an appropriate thermal resistivity (rho) value for trench backfill with consideration to soil drying due to environmental factors as well as cable heat generation.

#### 4.1.5 Soil Corrosivity

The chemical constituent test results indicate that the soil is neutral with a pH ranging from 7.0 to 7.3. Soluble sulfates were measured as high as 163 mg/kg and soluble chlorides measured as high as 93.1 mg/kg. Test results are presented in Appendix C and summarized in the Lab Test Summary Table.

#### 4.2 General Earthwork Considerations

#### 4.2.1 Clearing and Grubbing

Prior to site grading activities, existing vegetation, trees, large roots, topsoil, uncontrolled fill, old foundations, and abandoned underground utilities should be removed from the proposed structural (foundation) areas and areas to receive fill. Areas disturbed during demolition and clearing should be properly backfilled and compacted as described in Section 4.2.6. Uncontrolled fill was encountered at the substation area to depths between 2.5 and 5 feet below grade which should be fully removed and replaced with structural fill below foundations.

Topsoil or organic material should not be used for structural fill and should be stockpiled away from native excavated soil. This material may be used as fill in non-structural areas outside of the foundation, assembly area, access road, crane pad, and crane walk areas where soil strength and compressibility would not impact site infrastructure or construction.

#### 4.2.2 Excavations and Water Control

Overburden soil at the site can generally be excavated with conventional excavation equipment, such as backhoes, dozers, loaders, or scrapers. Bedrock is not expected to impact excavations less than 15 feet below grade. Excavations should be constructed using safe side slopes unless adequately shored and/or braced as necessary for construction and safety. Per Occupational Safety and Health Administration (OSHA) Part 1926, the soil on site may generally be inferred to be a Type B material unless the excavation is below groundwater in which the soil should be considered Type C. It is the responsibility of the competent field personnel to verify in situ conditions during construction. Excavations should be constructed in conformance with applicable federal, state, and local standards. Refer to Section 3.2.3 for additional discussion on the stability of excavation faces.

Groundwater was measured in piezometers installed at all but one of the wind turbine boring locations (T-30), due to an inability to check on the piezometer level due to land access restrictions. Groundwater measurements are provided in the boring logs in Appendix A, and summarized in Table 3.1. Some dewatering of excavations will likely be required across the site due to the shallow groundwater levels at most turbine locations, although the clay soil profile may generally limit the total amount of groundwater infiltration into the excavations. Water and snow

should be prevented from accumulating in foundation excavations at the time of foundation material placement. Sumps and portable pumps can generally be used to control water within these excavations for relatively short time periods, although more robust dewatering systems (such as well points) may be required where higher infiltration rates are encountered due to saturated sand seams. Excavations should be kept free of standing water and snow during foundation construction. The foundation subgrade should be inspected by the construction-phase geotechnical engineer, or their representative, after excavation and before placement of materials to verify water control.

#### 4.2.3 Permanent Cut and Fill Slopes

Cut and fill slopes in native soil may be designed at an inclination of 3H:1V or flatter. Fill slopes should be constructed in horizontal lifts in accordance with the recommendations in Section 4.2.5 and 4.2.6. Although not anticipated, slopes greater than 5 feet in height should be benched into the existing slope to prevent movement between the fill and native soils. A 2 foot deep by 8 foot wide keyway should be cut down into native soil at the toe of fill slopes, extending back under the toe of the fill. As fill placement progresses up the existing slope, benches should be cut into the existing slope to bond the mass of the fill to the existing ground. Benches should generally follow the existing ground slope, with a minimum of 3 feet high and approximately 10 feet wide. Benches should be approved by the construction phase geotechnical engineer prior to placement of fill. Positive drainage is required at benched areas and at the toe of fill to remove surface water and minimize soil saturation. Appropriate erosion control measures (e.g., vegetation or erosion control matting) should be implemented immediately after cut and fill slopes are constructed to reduce the potential for significant erosion. See figure 4.1 for a detail of the benching requirements.




Figure 4.1 Benching detail for fill slopes greater than 5 ft

Steeper cut and fill slopes may be acceptable if adequate erosion control and/or reinforcement are utilized. Additional testing and/or analyses should be performed for steeper slopes, and the geotechnical engineer should be consulted if steeper slopes are desired. Vehicles, cranes, material storage, and foundations should be located a safe distance (as determined by the construction phase geotechnical engineer) from the top of steep slopes to avoid slope instability. Detailed global slope stability analyses are beyond the scope of this investigation, but should be performed as needed once design grades and site specific surcharge loading (e.g., cranes, component storage, etc.) information becomes available.

#### 4.2.4 Subgrade Preparation

After clearing and grubbing, exposed areas to receive fill, including the subgrade below shallow foundation over-excavations (i.e. substation and laydown yard) and road aggregate, should be scarified to a minimum depth of 8 inches, moisture conditioned to within 0% to +4% of optimum moisture, and re-compacted to 95% of the standard Proctor maximum dry density (ASTM D698). Subgrade should also be inspected by the construction-phase geotechnical engineer, or their representative, to ensure adequate bearing capacity and water control.

Disturbance to subgrades prepared for foundations, access roads, and other areas to be filled should be minimized. Repeated traffic loading and excessive moisture due to surface water runoff, seepage, or precipitation may degrade subgrade soil. Where unsuitable subgrade is encountered, such as areas with soft soil, the unsuitable subgrade should be over-excavated as recommended by the construction-phase geotechnical engineer and replaced with structural fill in accordance with Section 4.2.6. Refer to Section 4.5.1 for wind turbine foundation subgrade preparation recommendations.

#### 4.2.5 Fill Placement and Compaction

The native soil encountered throughout the site may be used as general fill for road embankments and wind turbine assembly areas, and may be suitable for backfilling around and above foundations, provided that organics, frozen soil, foreign material, and rock fragments larger than 6 inches in diameter are removed and all compaction requirements are met. Backfill material within 1 foot of all foundations should have no particle sizes greater than 1 inch. Cobbles and boulders, if encountered, should be removed from general fill. The moisture content of the fill should be adjusted, as necessary, to achieve compaction. See Table 4.1 below for additional recommendations.

Table 4.1 Fill and Backfill Material Recommendations.

Material	Uses	Loose Lift Thickness	Required Compaction <sup>(2)</sup>	Moisture Content <sup>(2)</sup>
----------	------	----------------------	---------------------------------------	------------------------------------

Imported select structural fill <sup>(1)</sup>	Fill below turbine foundations, , or crane pad over-excavations	≤ 12" with heavy compaction equipment	≥ 98%	±3% of optimum moisture
General Fill - Non-organic native clay	Foundation backfill, embankments, access road subgrade, and general site grading	≤ 9" with heavy compaction equipment ≤ 6" with hand compaction equipment	≥ 95%	0% to +4% of optimum moisture
Native topsoil and organic soil	Landscaping non- structural areas	N/A	N/A	N/A

<sup>&</sup>lt;sup>1</sup>See Section 4.2.6 for detailed select structural fill recommendations

#### 4.2.6 Excavation Below Subgrade Procedures

Disturbance to subgrades prepared for foundations, access roads, crane walks, crane pads, and areas to be filled should be minimized. Fine-grained clayey soils are particularly sensitive to disturbance from repeated traffic loading and excessive moisture due to surface water runoff, seepage, or precipitation, which are likely to degrade subgrade soil. Care should be taken to limit disturbance to subgrade soils across the site and prevent ponding water by promoting positive drainage. Where unsuitable turbine foundation subgrade is encountered, as discussed in Sections 4.5.1 and 4.5.3, excavation of subgrade and replacement with suitable structural fill or alternative subgrade improvement techniques may be required.

If soft/loose, disturbed, or otherwise unsuitable turbine foundation bearing soil is encountered, as determined by quality control testing described in Section 4.5.1, the subgrade should be scarified, moisture conditioned, and re-compacted to 98% of the standard Proctor maximum dry density and within 3% of optimum moisture content. Over-excavations below foundations should extend laterally beyond all edges of the footing. The lateral extent should be at least 12 inches per foot (1H:1V) of over-excavation depth below foundation base elevation. All over-excavations should be sloped or shored as required by OSHA regulations to provide stability and safe working conditions. All over-excavations should be free of water and snow prior to backfilling.

Excavations below turbine foundation and crane pad subgrade should be backfilled with select structural fill, as described in Section 4.5.1. Select structural fill should consist of well-graded aggregate with less than 10% fines, such as Ohio DOT Specification 703.11 for structural backfill. Imported select structural fill should be sampled, tested, and approved by the construction phase geotechnical engineer prior to use on site.

<sup>&</sup>lt;sup>2</sup>Relative to the standard Proctor maximum dry density and optimum moisture content (ASTM D698)

#### 4.3 General Foundation Considerations

#### 4.3.1 Lateral Resistance

A friction factor of 0.40 may be used for the ultimate frictional resistance to lateral sliding along the base of concrete footings founded on properly compacted subgrade. We recommend a factor of safety of 1.5 or greater to determine the allowable frictional resistance to lateral sliding.

#### 4.3.2 Seismic Considerations

At the time of this report the State of Ohio has adopted the 2015 International Building Code with amendments (International Code Council, 2015). The maximum considered earthquake spectral response accelerations are presented in Table 4.2 below (ATC, 2022).

Table 4.2 Seismic Design Parameters

Parameter	Design Value
Reference	2015 IBC
Site Class	С
Coordinates (Lat., Long.)	40.99138, - 84.510207
Mapped Spectral Acceleration for Short (0.2 sec) Periods − S <sub>s</sub>	0.144 g
Mapped Spectral Acceleration for 1-second Periods – S <sub>1</sub>	0.063 g
Acceleration-Based Site Coefficient – Fa	1.2
Velocity-Based Site Coefficient − F <sub>v</sub>	1.7
Max. Considered Spectral Response Acceleration – S <sub>MS</sub>	0.173 g
Max. Considered Spectral Response Acceleration – S <sub>M1</sub>	0.107 g
Design Spectral Response Acceleration (Short Periods) – S <sub>DS</sub>	0.115 g
Design Spectral Response Acceleration (1-second Period) – S <sub>D1</sub>	0.071 g
Peak Ground Acceleration, PGA	0.074 g

#### 4.3.3 Frost Depth

Frost action can result in differential heaving and a reduction in soil strength during periods of thaw. The degree of frost action is based on frost depth, availability of water, and frostsusceptibility of shallow soil. The most severe effects of frost heave occur when ice lenses form in the voids of soil containing fine particles (i.e., silt and clay). Shallow foundations (or the structures they support) can be damaged if the foundations bear above soils that experience frost heave. The bearing capacity of soil is also reduced during periods of thaw, which can reduce the lateral capacity of pile foundations and cause bearing capacity and/or settlement issues for shallow foundations bearing above the frost depth.

The recommended design frost depth for the area is 3 ft (Bowles, 1996). Critical foundations and pipes should be placed a minimum of 3 ft below final grade or on non-frost susceptible soil extending to a depth of 3 ft for protection against frost, unless they are designed to accommodate the effects of frost.

#### 4.4 Wind Turbine Foundation Design Parameters

Westwood understands that two different wind turbine models are being considered for the project, a Vestas 162 and Siemens-Gamesa 5MW. No preliminary foundation designs or turbine loading documents were provided prior to preparation of this report, and therefore for the basis of this analysis it was assumed turbines will be supported on 75 foot diameter octagonal or circular spread footings bearing 13 feet below grade. The recommendations provided in this report should be re-evaluated after preliminary foundation designs and loading documents are available, including alternate buoyant foundation designs for turbines bearing below the expected groundwater depth. Refer to Section 3.4 for specific turbine locations with shallow groundwater. Soil parameters recommended for use in turbine spread foundation design are discussed in Section 4.1.

#### 4.4.1 Bearing Capacity

Design of wind turbine spread footing foundations supported on suitable subgrade may be designed for a maximum allowable gross bearing capacity of 3,500 psf for normal loading conditions and 5,000 psf for extreme loading conditions at all turbine locations. This bearing capacity likely exceeds the actual bearing pressures that may develop from a spread footing foundation design used for this site. The recommended allowable bearing pressure is based on a factor of safety of 3.0 for normal wind loading conditions and 2.25 for extreme loading conditions. An effective bearing area of 45 feet by 60 feet was assumed. Normal loading bearing capacity is controlled by the assumed maximum allowable settlement tolerance (Section 4.4.2) and extreme loading is controlled by bearing capacity failure.

#### 4.4.2 Differential Settlement

Differential settlement or rotation of the foundation was evaluated under normal operating loads. Normal operating loads result in an eccentrically loaded foundation with a higher bearing pressure than the dead load condition. Under normal operating loads the leeward side of the foundation carries the majority of the load compared to the windward side of the foundation, causing differential settlement or rotation of the foundation.

Results of the consolidation settlement analyses indicate that the assumed turbine foundation, consisting of a 75-foot diameter spread footing embedded 13 feet bgs with a gross bearing pressure of 3,500 psf will experience a total settlement of approximately 1.6 inches and a differential rotation of 0.17 degrees across the foundation width, which is within the assumed maximum allowable differential foundation tilt of 0.17 degrees.

#### 4.4.3 Rotational Stiffness

Based on the calculated dynamic shear modulus, as described in Section 4.1.4 of Westwood's Geotechnical Investigation Report (2021), the anticipated rotational stiffness of the foundation is expected to be approximately 525 GN-m/rad, which is presumed greater than the minimum requirement established by the turbine manufacturer. Therefore, with the assumed turbine foundation geometry and manufacturers requirement, the foundation should provide adequate rotational stiffness with no special considerations or enhancements. Rotational stiffness should be re-evaluated by the foundation designer once foundation dimensions, strain levels, and rotational stiffness requirements are known.

#### 4.4.4 Buoyancy

The depth to groundwater was evaluated with short-term observations in boreholes during drilling and in piezometers several weeks after installation and again more than 6 months later, as discussed in Section 3.4. Results of groundwater measurements performed at each wind turbine boring location are provided in Table 3.1. The minimum depth to groundwater measured was approximately 3 feet. In general, it should be expected that all turbine locations will require a buoyant foundation considering a design groundwater depth of 3 feet below existing grades. Additional groundwater depth measurements may be taken prior to final foundation design to confirm design depth to groundwater and evaluate the potential for zoning parts of the site for different design groundwater depths. It should be noted that turbine T-30 was inaccessible during the piezometer monitoring trip and therefore does not have groundwater measurements after drilling. Although the depth to groundwater was not measured at this location during the followup monitoring trip, the depth to groundwater at the other locations suggests groundwater is likely shallow throughout the site.

Foundations bearing below groundwater should be designed to resist overturning while accounting for buoyant forces. The foundation designer may consider providing at least two different foundation designs based on varying depths to groundwater. Refer to Sections 3.4 and 4.2.2 for additional discussion regarding groundwater, and Table 3.1 for groundwater depths for turbine foundation design. Additional groundwater measurements are recommended to confirm seasonal groundwater fluctuation at each turbine location prior to final foundation design.

#### 4.5 Wind Turbine Foundation Considerations

#### 4.5.1 Subgrade Preparation and Testing

Wind turbine foundations should bear on the native stiff to hard lean clay, or native bedrock (although not anticipated), as discussed in Section 4.2.6. Based on the conditions encountered during this investigation, the soil beneath the anticipated turbine foundation bearing depths typically exhibits sufficient properties to support spread foundations.

Foundation subgrade should consist of a uniform bearing material, such that the foundation does not bear on part soil and part rock. Care should be taken during foundation excavations to minimize disturbance of the subgrade. If encountered, soft/loose soil, frozen soil, and rock fragments larger than 6 inches should be removed. Field inspection and quality control of the subgrade may identify the need for additional subgrade modification. The foundation subgrade should be inspected by a qualified geotechnical engineer, or their representative, after excavation and before placement of materials to confirm conditions. Static cone penetrometer (SCP) testing is recommended to confirm subgrade soil strength and identify areas of softer clay. SCP testing should be performed at a minimum of five (5) locations on the foundation bearing surface, one in each quadrant and one in the middle. Testing should extend a minimum of 3 feet below the surface. Foundation subgrade consisting of clay should exceed a minimum undrained shear strength of 2,000 psf. If foundation subgrade consists predominantly of sand, Westwood should be contacted for further evaluation. Field inspection and quality control of the subgrade may identify the need for additional subgrade modification. Westwood should be notified in the event that unsuitable subgrade conditions are encountered.

The foundation subgrade should be protected against freezing and snow/water accumulation after inspection and prior to foundation placement. To facilitate turbine foundation construction and to protect the subgrade, a minimum 2- to 3 inch-thick layer of lean concrete (mud mat) over the subgrade is recommended. During winter construction, heating of the subgrade may be necessary to protect the subgrade from freezing.

Dolomitic bedrock was encountered within 28 ft bgs at each of the four turbine foundations included in this report. The depth to bedrock ranged from approximately 21 ft to 28 ft bgs. Bedrock was not encountered within anticipated foundation bearing depths (less than 13 ft bgs) at any of the turbine borings. The SPT and RQD Summary attached in Appendix B summarizes depth to bedrock at each boring location. Excavations into bedrock are not anticipated for the wind turbines, but rock rippability is discussed in the seismic study report in Appendix E.

#### 4.5.2 Ground Improvement

Although poor subgrade was not encountered below the anticipated foundation bearing depth at any of the four supplemental turbine borings, the possibility still exists for undetected soft to medium stiff clay within the turbine footprint at these locations. The foundation subgrade should be tested at all turbine locations prior to construction of the foundation per the recommendations outlined in Section 4.5.1 to confirm soil conditions. After subgrade testing at these locations, any unsuitable subgrade encountered should be remediated prior to construction of the foundations. Pending the depth of poor subgrade soil, the foundation may also bear deeper, below the weak material. Although not anticipated, over-excavation and replacement can become prohibitively

expensive at improvement depths greater than 4 to 6 feet, and deep soil improvement techniques may be required.

#### 4.5.3 Previously Excavated Foundations

Prior to the start of the 2021 field investigation, Westwood understands that excavations were conducted at two proposed turbine sites (T-26 and T-43) to approximate depths ranging from 5 ft to 10 ft. Westwood also understands that these excavations have remained open for several months, leaving the exposed subgrade susceptible to degradation from ponding water, freeze/thaw cycles, growth of vegetation, and erosion/scour. At the time of the initial investigation, both excavations were observed containing standing water and were inaccessible. These two locations were explored with geotechnical soil borings conducted outside of the excavation areas, approximately 60 feet from the turbine center point.

Westwood understands that these turbine locations have since been shifted such that they no longer overlap with the existing excavations. The new locations were drilled as a part of this supplemental geotechnical investigation. Should the original locations be used for final design, however, supplemental testing should be performed at T-26 and T-43, as well as any other locations where the proposed turbine is not within at most 50 feet of the original SPT soil boring or CPT sounding performed by Westwood. Supplemental testing at these locations shall include soil boring, CPT soundings, and/or static cone penetration (SCP) tests performed within the proposed foundation footprint during the pre-construction design phase.

#### 4.6 Construction Considerations

To a large degree, satisfactory foundation and earthwork performance depends on construction quality control; therefore, subgrade preparation, subgrade compaction, proof-rolling, cut slopes, and placement and compaction of fill and backfill material should be observed and tested by qualified personnel. In addition, qualified staff who are experienced with the foundation design requirements should monitor and document foundation preparation and construction activities. A qualified geotechnical engineer should also inspect cut faces in rock to evaluate overall stability.

# 5.0 Limitations

This report has been prepared in accordance with generally accepted geotechnical engineering practice for the exclusive use by Grover Hill Wind, LLC., for the Grover Hill Wind Project. The primary focus of this report was recommendations for site grading activities and wind turbine foundation design at the four supplemental turbine boring locations.


The borings are representative of the subsurface conditions at the sampled locations and intervals, and therefore do not necessarily reflect strata variations that may exist between sampled locations and intervals. If variations from the subsurface conditions described in this study are noted during construction, recommendations in this report must be re-evaluated. Any user of this report should verify all boring locations against the final location of the respective infrastructure to determine if infrastructure has moved prior to using the recommendations provided by Westwood. In the event that any changes in the nature, design, or location of the facilities are planned, the conclusions and recommendations contained in this report should not be considered valid unless the changes are reviewed and the conclusions of this report are modified or verified in writing by Westwood. Westwood is not responsible for any claims, damages, or liability associated with the interpretation of subsurface data by others.


After plans for the facility are developed in sufficient detail and project-specific wind turbine foundation load documents and preliminary foundation designs are available, Westwood should be consulted regarding additional subsurface information required to arrive at final recommendations for design and construction. The current recommendations are based on previous projects that are similar in size, however the loads experienced by the subsurface and foundations will likely be different due to specific turbine parameters.


# 6.0 References

- Applied Technology Council (ATC). 2021. Hazard by Location: Seismic. Accessed from: https://hazards.atcouncil.org/
- American Concrete Institute (ACI). 2014. ACI 318-14 Building Code Requirements for Structural Concrete.
- British Geological Survery (BGS). November 2013. UK Geohazard Note Soluble Rocks. Accessed From www.bgs.ac.uk
- Det Norske Veritas (DNV/Risø). 2002. Guidelines for Design of Wind Turbines (2nd ed.). Copenhagen, Denmark: Det Norske Veritas & Risø National Laboratory.
- Fullerton, D. S., Bush, C. A. and Pennell, J. N., 2003. Map of Surficial Deposits and Materials in the Eastern and Central United States (East of 102° West Longitude), USGS Investigations Series Map I-2789.
- International Code Council. 2015. International Building Code.
- National Park Service (NPS). 2021. "Physiographic Provinces: Central Lowland Province". Accessed from: https://www.nps.gov/articles/centrallowlandprovince.htm
- Naval Facilities Engineering Command (NAVFAC) (1982). DM7.1, Soil Mechanics, US Department of the Navy.
- Ohio Geological Survey (OGS). 2003. 1:24,000-scale bedrock-topography contours for Ohio.
- Ohio Department of Natural Resources (ODNR). 2006. Division of Geological Survey. Known and Probable Karst in Ohio. Ohio Karst Areas.
- Ohio Department of Natural Resources (ODNR). 2020a. Division of Water Resources. Water Well Logs. Accessed: http://water.ohiodnr.gov/search-file-well-logs
- Ohio Department of Natural Resources (ODNR). 2020b. Division of Geologic Survey. Sinkholes and Karst Geology in Ohio. Accessed: http://geosurvey.ohiodnr.gov/geologic-hazards/karstgeology/karst-mapping
- Ohio Department of Natural Resources (ODNR). 2020c. Division of Geologic Survey. Accessed: http://geosurvey.ohiodnr.gov/geologic-hazards/abandoned-underground-mines/aum-home
- Ohio Department of Natural Resources (ODNR). September 1995. Geofacts, No. 8 Landslides in Ohio.
- Slucher, E.R., Mac Swinford, E. and Powers, D.M., 2006. Bedrock geologic map of Ohio. Ohio Department of Natural Resources, Division of Geological Survey.
- United States Department of Agriculture (USDA). 2021. Natural Resources Conservation Service. Web Soil Survey. Accessed from https://websoilsurvey.sc.egov.usda.gov/
- United States Geological Survey (USGS). 1946. A Tapestry of Time and Terrain. Accessed from: https://www.nrc.gov/docs/ML0933/ML093340269.pdf
- United States Geological Survey (USGS). 2014. Karst in the United States: A Digital Map Compilation and Database. D.J. Weary, and D.H. Doctor.
- United States Geological Survey (USGS). 2021a. Earthquake Hazards Program. Accessed from: https://earthquake.usgs.gov/earthquakes/

# **Exhibits**







# **Appendix A**

Soil Boring Logs



# General Notes – Boring Log Unified Soil Classification System (USCS)

#### **Sample Description Format**

Group Name (Group Symbol), Percent and Range of Particle Sizes, Plasticity, Color, Density/Consistency, Moisture, Additional Comments, Geologic Origin (Stratigraphic Unit)

#### **Grain Size Terminology**

Soil Fra	action_	Particle Size	U.S. Standard Sieve Size
Boulder	rs	Larger than 12"	Larger than 12"
Cobble	S	3" to 12"	3" to 12"
Gravel: Coarse		3⁄4" to 3"	3/4" to 3"
	Fine	4.75mm to 3/4"	no. 4 to ¾"
Sand:	Coarse	2.00 mm to 4.75 mm	no. 10 to no. 4
	Medium	0.42 mm to 2.00 mm	no. 40 to no. 10
	Fine	0.075 mm to 0.42 mm	no. 200 to no 40.
Silt		0.005 mm to 0.075 mm	Smaller than no. 200
Clay		Smaller than 0.005 mm	Smaller than no. 200

Plasticity characteristics differentiate between silt and clay

# Percentages of Gravel Relative Proportions of Cohesionless Soils

Sand and Fines (Optional)

Proportional Term	Defining Range By Percentage of Weight		
Trace Few	0% - 5% 5% - 10%		
Little	15% - 25%		
Some	30% - 45%		
Mostly	50% - 100%		

#### **Relative Density and Consistency**

Noncohesive		Cohesive		
Relative Density	N-Value	N-Value	Consistency	Pp-tons/sq.ft
		< 2	Very Soft	0.0 to 0.25
Very Loose Loose Medium Dense Dense Very Dense	0-4 4-10 10-30 30-50 Over 50	2-4 4-8 8-15 15-30 Over 30	Soft Medium Stiff Stiff Very Stiff Hard	0.25 to 0.50 0.50 to 1.0 1.0 to 2.0 2.0 to 4.0 Over 4.0

The penetration resistance, N, is the summation of the number of blows required to advance two successive 6" penetrations of the 2" split-barrel sampler. The sampler is driven with a 140 lb. weight falling 30" and is seated to a depth of 6" before commencing the standard penetration test.


# Abbreviations

**Drilling and Sampling** 

HSA	Hollow-Stem Auger
SSA	Solid-Stem Auger
HA	Hand Auger
CWR	Clear-Water Rotary
MR	Mud Rotary
AR	Air Rotary
SC	Spin-Casing
DC	Drive-Casing
SS	2" Split-Barrel Sampler
MC	Modified California Ring Sampler
ST	2" Thin-Walled Tube Sampler
ST 3	3" Thin-Walled Tube Sampler
PS	Piston Sampler
AS	Auger Cuttings Sample
RS	Rotary Cuttings Sample
SC	Soil Core
RC	Rock Core


# Sample Description Abbreviations

br.	Brown	tr.	Trace			
gr.	Gray	Itl.	Little			
yel.	Yellow	ls.	Limestone			
lt.	Light	sh.	Shale			
dk.	Dark	qtz.	Quartz			
blk.	Black	dol.	Dolomite			
gvl.	Gravel	SS.	Sandstone			
sd.	Sand	lg.	Igneous			
si.	Silt	meta.	Metamorphic			
cl.	Clay					
f.	Fine	PP	Pocket			
m.	Medium		Penetrometer			
C.	Coarse					
٧.	Very	Tv	Torvane			





# **Unified Soil Classification System** (Visual-Manual Procedure)



Note 1-Percentages are based on estimating amounts of fines, sand, and gravel to the nearest 5 %. FIG. 2 Flow Chart for Identifying Coarse-Grained Soils (less than 50 % fines)

(From ASTM 2488)

➤ <15% gravel

≥15% gravel

<15% gravel <u>► ≥</u>15% gravel ➤ Silty sand

Silty sand with gravel → Clayey sand



#### **General Notes – Description of Rock Core**

#### <u>General</u>

Rock descriptions may include these components in the sequence in which they are listed:

Lithology
 Rock Core Continuity
 Field hardness

4. Weathering of rock mass5. Color

6. Texture

Bedding or foliation
 Discontinuities
 Solution cavities

10. Other characteristics11. Rock Quality Designation

(RQD) (usually noted in separate column on log)

#### Lithology

Identify the rock classification (type) and mineralogic/textural modifiers; and, if possible, accepted formation names. The principal constituent is written in capital letters, e.g., SANDSTONE, Calcareous SHALE; Biotite GRANITE; Amygdaloidal BASALT.

#### Rock (Core) Continuity

Any break in a rock core whether or not it has undergone relative displacement (including natural and mechanical breaks):

Extremely Fractured – Core segments less than 1 inch long

Moderately Fractured – Core segments 1 to 4 inches long

Slightly Fractured – Core segments 4 to 8 inches long

Sound – Core segments greater than 8 inches long

#### Field Hardness

A measure of resistance to scratching or abrasion:

Very Hard (VH) Cannot be scratched with a knife or sharp

pick.

Hard (H) Can be scratched with knife or pick only

with difficulty.

 $Moderately\ Hard\ (MH) \qquad Can\ be\ readily\ scratched\ with\ knife\ or\ pick.$ 

Medium (M) Can be grooved or gouged 1/16 inch deep by

firm pressure on knife or pick point.

Soft (S) Can be gouged or grooved easily with knife

or pick point.

Very Soft (VS) Can be carved with knife or excavated with

pick point.

#### Weathering of Rock Mass

The degree of alteration produced by chemical and/or mechanical

processes:

(MW)

(HW)

Fresh (FR) No visible sign of alteration; perhaps slight

discoloration on major discontinuity

surfaces.

Slightly Weathered Discoloration of rock material and

(SW)

discontinuity surfaces. Less than half the rock material is

Moderately Weathered

decomposed to soil. Some fresh or

discolored rock as continuous framework

or corestones.

Highly Weathered More than half the rock material is

decomposed and/or disintegrated to a soil.

Fresh or discolored rock as corestones or

discontinuous framework.

Saprolite (SP) All rock material disintegrated to soil. The

original mass structure is still largely intact.

Residual Soil (RS) All rock material converted to soil. Volume

of mass has changed, but material has not

been significantly transported.

#### Color

Rock color is described as basic colors or combinations such as gray, green-gray, red, red-brown; or modified such as light gray or dark brown

#### **Texture**

General physical appearance or character of a rock, including geometric aspects and arrangement of particles or crystals. Use the following grain size ranges to describe the rock:

Fine-grained Grains barely visible to the unaided eye, up

to 1/16 inch in diameter.

Medium-grained Grains between 1/16 and 3/16 inch in

diameter.

Coarse-grained Grains between  $\frac{3}{16}$  and  $\frac{1}{4}$  inch in diameter Very coarse-grained Grains larger than  $\frac{1}{4}$  inch in diameter.

#### **Bedding or Foliation**

The relative thickness of the beds, or the frequency of layering or bedding planes:

Laminar < 1/16 inch Extremely Thin 1/16 to 3/4 inch Very Thin 3/4 to 21/2 inches 21/2 to 8 inches Thin Medium 8 to 24 inches Thick 24 to 80 inches Very Thick 80 to 240 inches Extremely Thick > 240 inches

Massive No stratification observed

Occasional Occurring less than once per foot
Frequently Occurring more than once per foot

Interbedded Alternating beds of different composition

varying in thickness, and in approximately

equal amounts

#### **Discontinuities**

Natural breaks separating the intact rock material into discrete units:

Joint Simple fracture, along which no

displacement, has occurred. May occur as group of parallel joints called a Set. May also occur as Bedding joints, Cleavage joints or Foliation joints forming parallel to

the respective features.

Shear Fracture, along which differential

movement has occurred. Surfaces may be

slickensided (polished or striated).

Fault Major fracture, along which there has been

appreciable displacement.

Shear or Fault Zone Band or zone of parallel, closely space

fractures, along which differential

movement has occurred.



### **General Notes – Description of Rock Core**

### **Discontinuities - Orientation**

Orientation of a rock discontinuity is generally described as dip angle relative to horizontal:

 Horizontal
 0 - 5

 Low Angle
 5 - 35

 Moderately Dipping
 35 - 55

 High Angle
 55 - 85

 Vertical
 85 - 90

### **Discontinuities - Spacing**

The distance between discontinuities normal to the plane of the fractures in a single system:

Extremely Wide < 20 feet

### **Discontinuities - Roughness**

The texture of the discontinuity surface:

Rough Stepped Smooth Planar Slickensided (polished) Undulating

### **Discontinuities - Weathering**

A description of the state of weathering of the rock comprising the walls of a discontinuity:

Fresh No visible sign of weathering of the rock

material.

Discolored The color of the original rock material is

changed. Indicate degree of change from original color. Note if color change is limited to particular mineral constituents.

Decomposed The rock is weathered to the condition of a

soil in which the original fabric is still intact, but some or all of the mineral grains

are decomposed.

Disintegrated The rock is weathered to the condition of a

soil in which the original fabric is still intact. The rock is friable, but the mineral

grains are not decomposed.

### **Discontinuities - Aperture**

A description of the "gap" between the walls of a discontinuity. For rock core logging, the following descriptive terminology is used:

Tight Core pieces on either side of a discontinuity

can be fitted together by hand so that no

visible void spaces remain.

Open Core pieces on either side of a discontinuity

cannot be fitted tightly together and voids

are visible.

Note:

A completely healed fracture or vein is not considered to be a discontinuity and is <u>not</u> included when describing rock core fracturing or calculating RQD. However, it may be described as a special set of discontinuities and include a record of the altitude (dip), spacing, thickness, type of filling, and any observed alteration.

### Discontinuities - Infilling

This is material separating adjacent rock walls of discontinuities, e.g., calcite, chlorite, clay, silt, fault gouge, or breccia. The discontinuity infilling description may include the mineralogy type, thickness, and hardness of the infilling material, the relative amount of infilling (Stained, Coated, Lined, Partially Filled), water content, evidence of shear displacement, wall roughness, fracturing, or crushing of wall rock.

### **Solution Cavities**

Approximate size of openings produced by direct solution by water penetrating pre-existing interstices:

Pit	Barely visible up	Solution features may be
	to ¼ inch	open, crystal lined, or
Vug	1/4 to 2 inches	partially or completely filled
Cavity	2 inches to 2 feet	with hydrothermal minerals, clay, silt, or ore.
Cave	> 2 feet	ciay, siit, of ofc.

### **Other Characteristics**

Supplemental characteristics of the rock being described are used where applicable. Such characteristics are the formation name, the presence of solution cavities or voids, secondary mineralization, filling within rock discontinuities, fossils, zones of nodules, brecciation, and swelling or slaking behavior.

### **Core Recovery**

Core recovery is the length of core recovered from a corehole in relation to the length of core drilled in a given core run, expressed as a percentage.

### Rock Quality Designation (RQD)

Rock Quality Designation (RQD) is defined as the sum in inches of all pieces of moderately weathered or less weathered rock core, 4 inches in length or longer, divided by the total length in inches of the core drilled in a given core run, expressed as a percentage. If the core is broken by handling or drilling procedures, the pieces of core are fitted together and counted as one piece, provided they constitute the required 4-inch length. Where the core recovery is greater than 100 percent, RQD values are adjusted to account for the portion of the core left in the hole from the previous run. Length determination is measured down the centerline of the core. RQD determination is conducted on cores 1.875 inches in diameter and greater.

90 - 100	Excellent
75 - 90	Good
50 - 75	Fair
25 - 50	Poor
0 - 25	Very Poor

### References

- ASTM D4879 Standard Guide for Geotechnical Mapping of Large Underground Openings in Rock
- ASTM D5878 Standard Guides for Using Rock-Mass Classification Systems for Engineering Purposes
- ASTM D6032 Test Method for Determining Rock Quality Designation (RQD) of Rock Core

We	st	:W	000	ł		SOIL E	BOR	ING	LOG		В	ORI	NG	NO.	T-2	
Facility/Proj	ect Na	ame:	Grover I	Hill Wind Proje	ct		Lat		031422	Surface	Elev.	(ft):	Total	Depth		Page 1 of 1  Borehole Dia. (in):  4.25
Drilling Firm				g County, Ohio		ner	Pers	ng: -& onnel: ger - B.	4.482228 Hawk	Date S				Comp	leted:	Water Depth (ft bgs)
	nviro	core	, Inc.	110110	W Otelli Aug	JC1		er - S. C	Guyer		23/22		,	5/23/	22	DNE
NUMBER AND TYPE RECOVERY (%)	BLOW COUNTS	DEPTH IN FEET		LITHOLO DESCRIF	OGIC PTION		nscs	GRAPHIC LOG	N VALUE (BLOWS) 0 10 20 30 40	POCKET PEN (tsf) (* = brittle failure)	IN-SITU UNIT WEIGHT (PCF)	MOISTURE CONTENT (%)	LIQUID	PLASTICITY INDEX	P 200 (%)	COMMENTS
01 SS 72	1 1 3	_	Topsoi	il - 1", gravel Clay (CL) - brov	vn. damp to				•	2.0						Coordinates are NAD83 Datum.
02 SS 67	2 3 4	-	moist,	soft to medium	stiff				<b>+</b>	3.0		25.2				
03 SS 100	2 2 4	5-					CL			2.5 2.3						
04 SS 100	4 9 12	-	- very s	stiff												
05 SS 100	4 6 14	10-	Lean C damp,	lay w/ Sand (Covery stiff to ha	<b>L)</b> - brown, rd				•	3.5		15.3	32	14	76	
06 SS 100	5 10 13	-	- dark (	grayish brown					•	4.5+						
07 SS 100	5 8 16	15- -	- dark (	gray					•	4.5+	-					
07   100 08   100 SS   100	7 11	20-					CL		1	4.5+						
	_13_	- -														
09 SS 100	6 11 17	25- - -							•	4.5+						
RC 94 (0)		30-	modera	<b>MITE</b> - hard, sli ately weathere and vug		)										Begin rock coring at 28.5'
09 100 RC 94 (0) RC (74)		- - 35- -	Boring reache	terminated. T d.	arget depth	1										
		_														
Checked B	•	Da	te: 7/1/22	Approved By: S. Jorgensen	Date: 7/6/22				Professiona tewater Driv			0 Mi	innet	onka		(952) 937-5150 55343

3[	Checked By:	Date:	Approved By:	Date:	Firm:	Westwood Professional Services	(952) 937-5150
	C. Enos	7/1/22	S. Jorgensen	7/6/22		12701 Whitewater Drive, Suite 300 Minnetonka,	MN 55343

West	wood		SOIL B	OR	ING	LOG		ВС	RIN	NG	NO.	T-3	
Facility/Project Nam	Grover Hi	Il Wind Project County, Ohio		Lat	ig Loca : 41.0 ng: -8		Surface	Elev. (1	ft):	Total I	Depth 41.0		Page 1 of 1 ): Borehole Dia. (in): 4.25
Drilling Firm: Enviroc	ore, Inc.	Drilling Method: Hollow Stem Au	uger	Logg	onnel: ger - B. er - S. G		Date St	arted: 24/22			Comp 5/24/2		Water Depth (ft bgs
- 1 - 1 - 1	DEPTH IN FEET	LITHOLOGIC DESCRIPTION		nscs	GRAPHIC LOG	N VALUE (BLOWS) 0 10 20 30 40	POCKET PEN (tsf) (* = brittle failure)	IN-SITU UNIT WEIGHT (PCF)	MOISTURE CONTENT (%)	LIQUID	PLASTICITY INDEX	P 200 (%)	COMMENTS
01 94 ½ SS 94 ½ 02 72 ¾ SS 72 ¾ SS 100 ¾ 6	Lean Cla medium	- 3", organics ay (CL) - brown, damp, s stiff brown, stiff to hard	soft to	CL			2.25 1.75 4.5+						Coordinates are NAD83 Datum.
05 100 8 11	Lean Cla dark gra	<b>ay w/ Sand (CL)</b> - brown y, very stiff to hard	n to	CL			4.5+		17.1	37	19	82	
RC 29 (0)	very den  DOLOMI  weathere	Gravel w/ Sand (GC) - gr se TE - hard, moderately ed, gray, few pitting	ray,	GC			•					1 1	Auger scraping Begin rock coring at 27'
RC 18 (0)	Boring to reached.	erminated. Target dept	h										
Checked By: C. Enos	Date: A	approved By: Date: S. Jorgensen 7/6/22				Professiona tewater Driv			Mir	nnet	onka		(952) 937-5150 55343

West	woc	d	S	OIL BO	OR	ING	LOG				В	OR	ING	NO	. <b>T-34b</b> Page 1 of 1
Facility/Project Nar	Grove	er Hill Wind Proje ding County, Ohi	0		Lat:		tion: 0122165 4.4672998	Su	urface	Elev.	(ft):	Total	Depth 35.0	(ft bgs	): Borehole Dia. (in):
	oCore	Drilling Methology Hollow Auto-l	od: v Stem Auger Hammer SPT	ı	Logg	onnel: er - D. r - B. R		Da		arted: 26/23	3		Comp 4/26/	leted: 23	Water Depth (ft bgs): >25
NUMBER BY AND TYPE BECOVERY (%) THE (RQD) BLOW COUNTS	DEPTH IN FEET	LITHOLO DESCRIF			USCS	GRAPHIC LOG	N VALUE (BLOWS) 0 10 20 30 4	0 50	POCKET PEN (TSF)	COMPRESSIVE STRENGTH (TSF)	MOISTURE CONTENT (%)	LIQUID LIMIT	PLASTICITY INDEX	P 200 (%)	COMMENTS
01 28 2 SS 53 3 SS 56 2 SS 56 2 SS 76 2 SS	TOF Lear very  5 bro hard  10-  15 Lear mois  20- 25 Dole frac hori diss  30-	SOIL - 4 inches of Clay (CL) - brown stiff  own, yellow, and yellow, yell	d gray mottling oderately hard, fresh, gle fracturing	ng,	CL				2.5 2.5 2.5 3.5 1.5 2.5 4.5+ 4.5+ 4.5+	548	12.5	30	16		Coordinates are WGS84 Datum  Auger refusal at 25 ft
Checked By:	Date: 7/7/23	Approved By:	Date: F				Profession tewater Dri				), Mi	nnet	conka	a, MN	(952) 937-5150 I 55343

We	S	:W	<b>700</b> 0			SOIL E	3OR	ING	LOG				E	BOR	ING	NO	<b>7. T-35a</b> Page 1 of 1
Facility/Pro		ame:		Hill Wind Proje g County, Ohio	)		Lat Lor	ng: -8	ation: 0093822 34.47138			e Elev.	. ,		35.0	0	s): Borehole Dia. (in):
Drilling Firn		riroC	ore	Drilling Metho Hollow Auto-H	<sup>ld:</sup> ⁄ Stem Auger Hammer SPT		Log	onnel: ger - D. er - B. F				Started: /26/2			Comp 4/26/		Water Depth (ft bgs) >17
NUMBER AND TYPE RECOVERY (%)	BLOW COUNTS	DEPTH IN FEET		LITHOLO DESCRIP	TION		nscs	GRAPHIC LOG	N VA (BLO 0 10 20	WS)	POCKET PEN (TSF)	COMPRESSIVE STRENGTH (TSF)	MOISTURE CONTENT (%)	LIQUID	PLASTICITY INDEX	P 200 (%)	COMMENTS
01	2 3 4 2 3 6 5 9 14 4 14 14 16 6 13 17 5 12 16	5- - - - - - - - - - - - - - - - - - -	Lean C stiff to v	OIL - 6 inches  Play (CL) - brovery stiff  Play with Grave moist, hard  One - gray, mand fractured, had a fracturing s	vel (CL) - o	Jark to	CL				3.0 3.5 3.5 4.5 4.5 4.5 4.5		12.9			73	Coordinates are WGS84 Datum  Auger refusal at 17 ft
		- - -	FEET E	BGS. TARGE IED	T DEPTH												
Checked B	•	Da	te: 7/7/23	Approved By: C.Enos	Date: 7/26/23				Profess tewater				0, M	innet	tonka	a, MN	(952) 937-5150 I 55343

We	251	W	ood			SOIL E	BOR	ING	LOG		E	BOR	NG	NO.	. T-4	
Facility/Pro	ject N	ame:		lill Wind Proje g County, Ohi			Lat		tion: 009978 4.489744	Surfa	ce Ele	v. (ft):	Total	Depth		Page 1 of 1 ): Borehole Dia. (in): 4.25
		core	, Inc.	Drilling Meth		ger	Perso	onnel: ger - B. er - S. G	Hawk		Starte	22		Comp 5/24/		Water Depth (ft bgs)
NUMBER AND TYPE BY RECOVERY (%)	BLOW COUNTS	DEPTH IN FEET		LITHOL DESCRIF	OGIC PTION		nscs	GRAPHIC LOG	N VALUE (BLOWS)	9 POCKET PEN (tsf)	(* = brittle failure) IN-SITU	MOISTURE CONTENT (%)	LIQUID LIMIT	PLASTICITY INDEX	P 200 (%)	COMMENTS
01 78 02 94 03 83 04 78 05 100 06 100 07 0 08 100 RC 100 (69) RC 100 (91) RC 100 (91)	4 4 4 6 6 9 13 23 6 10 11 20 41 18	- 10- - 15- - 15- - 20- / - 33- - 35-	Lean Chard  Lean Chard  Lean Chard  Lean Chard  Lean Chard  Silt w/ S  DOLON  gray, litt	lay w/ Sand (fatiff to hard prayish brown lay (CL) - brown lay w/ Sand (very stiff to have stiff to	wn, very stiff  CL) - dark gr  ark gray, har  ightly weath  vugging	rd ——ered,	CL		10 20 30 40	4.5	5	16.5	33	15	75	Coordinates are NAD83 Datum.  Begin rock coring at 21'
Checked B	•	Da	te: 7/1/22	Approved By: S. Jorgensen	Date: 7/6/22				Professiona tewater Driv				inne	tonka		(952) 937-5150 55343

3[	Checked By:	Date:	Approved By:	Date:	Firm:	Westwood Professional Services	(952) 937-5150
	C. Enos	7/1/22	S. Jorgensen	7/6/22		12701 Whitewater Drive, Suite 300 Minnetonka,	MN 55343

### **Nestwood**

# **ROCK CORE PHOTO**

**BORING NO. T-26a** 

Project Name:		Boring Location:	Surface Elev. (ft):	Total Depth (ft bgs):	Borehole Dia. (in):
GROVER HILL	RHILL	Lat: 41.031422	-	35	4.25
Paulding County, OH	ounty, OH	Long: -84.482228			
Drilling Firm:	Drilling Method:	Personnel:	Date Started:	Date Completed:	Water Depth (ft bgs):
EnviroCore	RC - Rock Core	Logger: B. Hawk Driller: S. Guyer	5/23/2022	5/23/2022	DNE



### **Nestwood**

# **ROCK CORE PHOTO**

**BORING NO. T-31a** 

Project Name:						
		Boring Location:	Surface Elev. (ft):	Total Depth (ft bgs):	Borehole Dia. (in):	
GROVER HILL		Lat: 41.009978	1	41	4.25	
Paulding County, OH		Long: -84.489744				
Drilling Firm: Drilling Method:	thod:	Personnel:	Date Started:	Date Completed:	Water Depth (ft bgs):	
EnviroCore RC - Ro	RC - Rock Core	Logger: b. Hawk Driller: S. Guyer	5/24/2022	5/24/2022	DNE	



# **ROCK CORE PHOTO**

**BORING NO. T-34b** 


Project Name:		Boring Location:	Surface Elev. (ft):	Total Depth (ft bgs):	Borehole Dia. (in):
Grover Hill Wind Project	/ind Project	Lat: 41.0122048°	1	35.0	8.0
Paulding County, Ohio	unty, Ohio	Long: -84.4672936°			
Drilling Firm:	Drilling Method:	Personnel:	Date Started:	Date Completed:	Water Depth (ft bgs):
EnviroCore, Inc.	RC - Rock Core	Logger: D. Welch Driller: B. Raush	4/26/2023	4/26/2023	> 25.0



# **ROCK CORE PHOTO**

**BORING NO. T-35a** 

Project Name:		Boring Location:	Surface Elev. (ft):	Total Depth (ft bgs):	Borehole Dia. (in):
Grover Hill Wind Project Paulding County, Ohio	Vind Project unty, Ohio	Lat: 41.0093819° Long: -84.4713857°	ı	35.0	8.0
<b>Drilling Firm:</b> EnviroCore, Inc.	<b>Drilling Method:</b> RC - Rock Core	Personnel: Logger: D. Welch Driller: B. Raush	<b>Date Started:</b> 4/26/2023	Date Completed: 4/26/2023	Water Depth (ft bgs): > 17.0





### **Nestwood**

# **ROCK CORE PHOTO**

**BORING NO. T-43a** 

Borehole Dia. (in): 4.25	Water Depth (ft bgs):  DNE
Total Depth (ft bgs): 35.5	<b>Date Completed:</b> 5/24/2022
Surface Elev. (ft): 	<b>Date Started:</b> 5/24/2022
<b>Boring Location:</b> Lat: 40.999784 Long: -84.481634	Personnel: Logger: B. Hawk Driller: S. Guyer
R HILL ounty, OH	<b>Drilling Method:</b> RC - Rock Core
Project Name: GROVER HILL Paulding County, OH	<b>Drilling Firm:</b> EnviroCore



### **Appendix B**

SPT and RQD Summary Table

# SPT N-Value and (RQD) Summary Grover Hill Wind Project - Paulding County, Ohio

	T-26a	T-31a	T-34b	T-35a	Т-43а
Latitude:	41.031422	41.009978	41.012217	41.009382	40.999784
Longitude:	-84.482228	-84.489744	-84.467300	-84.471385	-84.481634
Depth (ft)					
0-1.5	4	4	10	5	6
2.5-4	7	7	9	7	10
5-6.5	9	10	4	6	77
7.5-9	21	17	56	23	98
10-11.5	20	19	23	28	23
12.5-14	23	28	76	30	77
15-16.5	24	33	27	28	65
20-21.5	24	89	62	(48)	74
25-26.5	28	REF	REF	(69)	(69)
30-31.5	(0)	(0)	(63)	(62)	(16)
35-36.5	(74)	(0)	(93)	(64)	(52)
40-41.5		(0)			
*Depth To Rock (ft)	33.5	27	25	17	35.5

\*Depth to rock is an estimate and gradual transitions between soil and rock make it challenging to define a top of rock surface. Excavations may still encounter challenges above this depth.

### Legend Fat Clay Lean Clay Granular Weathered Rock Bedrock

(##) = Rock Quality Designation (RQD) REF = SPT Refusal

### **Appendix C**

**Laboratory Testing Report** 



1 Systems Drive Appleton, WI 54914

main (920) 735-6900

### **LABORATORY TESTS OF SOILS**

ASTM: D2216, D4318, D6913

**Project:** Grover Hill Wind Energy - Grover Hill, OH

**Report To:** Starwood Energy Group **Date:** 6/10/2022

Westwood Prj. No. R0015695.00 Date Delivered: 5/26/2022

			Moisture	Atte	rberg Lin	nits*	Percent	Passing
Boring	Depth	Sample	Content	LL	PL	PI	#4	#200
T-26	2.5-4	SS-02	25.2%					
T-26	10-11.5	SS-05	15.3%	31.7	18.1	13.6	96	76
T-31	10-11.5	SS-05	17.1%	37.4	18.3	19.1	99	82
T-34	7.5-9	SS-04	15.6%	34.5	17.0	17.5	96	77
T-43	10-11.5	SS-05	16.5%	32.8	17.9	14.9	94	75
T-43	20-21.5	SS-08	17.0%	17.4	14.9	2.6	100	83

main (920) 735-6900

6/9/2022

Date:

# Westwood

# REPORT OF: LABORATORY TESTS OF SOILS

**Project:** Grover Hill Wind Energy - Grover Hill, OH

Report To: Starwood Energy Group

Westwood Prj. No. R30015695.00 Date Delivered: 5/26/2022

Tests Performed: Grain Size Analysis, Atterberg Limits
Boring No. T-34
Sample No. Bulk
Depth 1-5'
USCS LEAN CLAY, olive brown
Classification: (CL)
USDA/ NRCS
Silty Clay Loam
Classification:


### **TEST RESULTS**;

# Grain Size Analysis (ASTM:D6913 & D7928)

% PASSING	100	100	66	86	95	06	98	80.3	71.5	53.9	38.4
SIEVE SIZE	3/4" (19 mm)	3/8" (9.5 mm)	#4 (.475 mm)	#10 (2.0 mm)	#40 (.425 mm)	#100 (.15 mm)	#200 (.075 mm)	.050 mm	.020 mm	.005 mm	.002 mm

## Atterberg Limits (ASTM: D4318)

49.4	22.0	27.5
Liquid Limit, LL (%)	Plastic Limit, PL (%)	Platicity Index (%)



### **MOISTURE-DENSITY CURVE**

Project:Grover Hill Wind Energy - Grover Hill, OHWestwood Prj. No.:R0015695.00Report To:Starwood Energy GroupDate:6/10/2022


**Boring Number:** T-34 **Depth:** 1-5'

Unified Soils Classification (ASTM:D2487): LEAN CLAY, olive brown (CL)

Tests Method: Standard ASTM:D698, Method B

Preparation: Wet Automatic Hammer

Max. Dry Density (pcf):103.0Optimum Moisture (%):19.4Gravel Content (%):< 5</th>As-received Moisture (%):23.0



### Synergy Environmental Lab, LLC.

1990 Prospect Ct., Appleton, WI 54914 \*P 920-830-2455 \* F 920-733-0631

PAUL EGGEN WESTWOOD PROFESSIONAL SERVICES ONE SYSTEMS DRIVE APPLETON WI 54914-1654

Report Date 16-Jun-22

Project Name GROVER HILL Invoice # E41032

**Proiect** # R0015695.00 **Lab Code** 5041032A

Sample ID T-26 SS-02
Sample Matrix Soil

**Sample Date** 

	Result	Unit	LOD I	LOQ	Dil	Method	Ext Date	Run Date	Analyst	Code
General General										
Solids Percent	95.9	%			1	5021		6/6/2022	NJC	1
Wet Chemistry General										
Sulfate, Unfiltered	59.4	mg/kg	25	82.5	50	300.0		6/13/2022	BLE	1
Chlorides, Unfiltered	56.3	mg/kg	5	16.75	50	300.0		6/13/2022	BLE	1

Lab Code 5041032B Sample ID T-34 BULK

Sample Matrix Soil

**Sample Date** 

	Result	Unit	LOD I	LOQ	Dil	Method	Ext Date	Run Date	Analyst	Code
General General Solids Percent	94.5	%			1	5021		6/6/2022	NJC	1
Wet Chemistry General										
Sulfate, Unfiltered	163	mg/kg	25	82.5	50	300.0		6/13/2022	BLE	1
Chlorides, Unfiltered	93.1	mg/kg	5	16.75	50	300.0		6/13/2022	BLE	1

Project Name GROVER HILL Invoice # E41032

**Project** # R0015695.00

LOD Limit of Detection

LOQ Limit of Quantitation

Code Comment

"J" Flag: Analyte detected between LOD and LOQ

1 Laboratory QC within limits.

BLE denotes sub contract lab - Certification #445023150

All solid sample results reported on a dry weight basis unless otherwise indicated. All LOD's and LOQ's are adjusted for dilutions but not dry weight. Subcontracted results are denoted by SUB in the analyst field.

Michaelyllul

**Authorized Signature** 

1 Systems Drive Appleton, WI 54914

main (920) 735-6900

Date: #######

# LABORATORY TESTS OF SOILS

ASTM: G187, G51

Project: Grover Hill Wind Energy - Grover Hill, OH

Report To: Starwood Energy Group

Westwood Prj. No. R0015695.00

Date Delivered: 5/26/2022

						Electrical Resistivity	<b>Resistivity</b>				
				Ą	As-Received				Saturated		
				Temp.	Temp. Resistance	Resistivity		Temp.	Temp. Resistance	Resistivity	
Boring	Depth Sample		Moist%	၁ွ	(Ohms)	Moist% °C (Ohms) (Ohms-cm)*   Moist% °C (Ohms) (Ohms-cm)*	Moist%	၁့	(Ohms)	(Ohms-cm)*	рН
T-26	2.5-4' SS-02	SS-02	25.2	26.4	2,550	1,700	42.4 24.1	24.1	2,550	1,700	7.3
T-34	1-5'	Bulk	23.0	24.4	2,100	1,400	42.5 25.1	25.1	1,850	1,200	7.0

<sup>\*</sup> Soil box factor = 0.67



1 Systems Drive Appleton, WI 54914

main (920) 735-6900

**REPORT OF: THERMAL RESISTIVITY** 


ASTM; D5334


Project: Grover Hill Wind Energy - Grover Hill, OH

Report To: Starwood Energy Group

Westwood Project No. R0015695.00 Date: 6/22/2022

					Ini	tial Condi	tion	Thermal Res	istivity Results
Reconstiuted			Soil	Drostor	Sample	Dry Density	Moisture Content		Thermal Resistivity (°C-
Specimen	Boring	Depth	Type	Proctor Method	Comp. (%)	(pcf)		Moisture (%)	cm/W)
								0	191
				ASTM:				5.0	147
T-34	T-34	1-5'	CL		90	92.7	23.3	8.8	120
				D698, B				14.7	91
								23.3	84







main (920) 735-6900

### **REPORT OF: TESTS OF CORED ROCK SPECIMENS**

**Project:** Grover Hill Wind Energy - Grover **Westwood Prj. No.** R0015695.00

**Report To:** Starwood Energy Group DATE: 6/3/2022

### Unconfined Compressive Strength of Rock Cores (ASTM: D7012, Method C)

Core Number	T-34	T-43
Sample ID	RC-01	RC-01
Depth	21-25.5'	20-25'
Rock Type:	Dolomite	Dolomite
D'	4.06	4.06
Diameter (in.)	1.86	1.86
Area (sq. in.)	2.72	2.72
Length (in)	4.08	3.92
Length/Diameter (L/D)	2.19	2.11
Date Tested	6/3/22	6/3/22
Load at Failure (lbs)	24,860	26,230
Compressive Strength (psi)	9,150	9,650

### Unit Weight of Cored Soil or Rock (ASTM: 2216, D7263)

Bulk Specific Gravity	2.638	2.604
Density (lbs/cf)	164.2	162.1

### Remarks:



1 Systems Drive Appleton, WI 54914

main (920) 735-6900

# REPORT OF: TESTS OF CORED ROCK SPECIMENS

Westwood Prj. No. R0015695.00 6/29/2023 DATE: Project: Grover Hill Wind Energy - Grover Hill, OH

Report To: Starwood Energy Group

# Unconfined Compressive Strength of Rock Cores (ASTM: D7012, Method C)

Core Number	T-34B	T-35A
Sample ID	RC-01	RC-01
Depth	27.0'-27.8'	20.2'-21.0'
Rock Description:	Gray DOLOSTONE	Gray DOLOSTONE w/ some 1/8" to 1/4"
		sgnv
Diameter (in.)	1.86	1.86
Area (sq. in.)	2.72	2.72
Length (in)	4.72	4.74
Length/Diameter (L/D)	2.54	2.55
Date Tested	6/2/23	6/2/23
Load at Failure (lbs)	20,700	8,970
Compressive Strength (psi)	7,620	3,300

# Unit Weight of Cored Soil or Rock (ASTM: 2216, D7263)

2.665	165.9
2.632	163.8
Bulk Specific Gravity	Density (lbs/cf)

### Remarks:

### **Appendix D**

**Electrical Resistivity Test Data** 



### Electrical Resistivity Test Results Wenner 4-Electrode Method Grover Hill - Paulding County, OH

ER-01 (T-34a)

Location:

Site Description: 65 F, cloudy with light rain, flat agriculture field, lean clay, damp

North-South Transect East-West Transect

ELECTROD	E SPACING	Resistance (Ω)	APPARENT RESISTIVITY		
(feet)	(meters)	Resistance (12)	ohm-feet	ohm-meters	
5.000	1.5	2.43	76.3	23.3	
10	3.0	1.52	95.5	29.1	
20	6.1	1.16	146	44.4	
30	9.1	1.10	207	63.2	
50	15	1.06	333	102	
100	30	1.05	660	201	

ELECTRO	E SPACING	Resistance (Ω)	APPARENT RESISTIVITY	
(feet)	(meters)	Resistance (12)	ohm-feet	ohm-meters
5	1.5	2.41	75.7	23.1
10	3.0	1.59	100	30.5
15	4.6	1.19	112	34.2
20	6.1	1.07	134	41.0
50	15	1.04	327	100
100	30	1.01	634	193

Date: 5/25/22

Date: 5/23/22

ER-02 (T-26a)

Location:

Site Description: 70 F, cloudy, flat agriculture field, lean clay, damp

North-South Transect

ELECTROD	E SPACING	Resistance (Ω)	APPARENT RESISTIVITY	
(feet)	(meters)	Resistance (11)	ohm-feet	ohm-meters
5	1.5	2.34	73.5	22.4
10	3.0	1.38	86.7	26.4
20	6.1	0.92	116	35.2
30	9.1	0.79	149	45.4
50	15	0.72	226	68.9
100	30	0.69	433	132

### East-West Transect

East-West Hallsect				
ELECTRODE SPACING		Resistance (Ω)	APPARENT RESISTIVITY	
(feet)	(meters)	Resistance (12)	ohm-feet	ohm-meters
5	1.5	2.32	72.9	22.2
10	3.0	1.42	89.2	27.2
20	6.1	0.92	116	35.2
30	9.1	0.80	151	46.0
50	15	0.73	229	69.9
100	30	0.70	440	134

### This foregoing document was electronically filed with the Public Utilities Commission of Ohio Docketing Information System on

7/28/2023 3:49:04 PM

in

Case No(s). 23-0459-EL-BGA

Summary: Application - Supplement to Amendment Application - Geotechnical Investigation Report electronically filed by Christine M.T. Pirik on behalf of Grover Hill Wind, LLC.