



Legal Department

American Electric Power  
1 Riverside Plaza  
Columbus, Ohio 43215-2373  
AEP.com

April 22, 2024

The Honorable Greta See  
Attorney Examiners  
Public Utilities Commission of Ohio  
180 East Broad Street  
Columbus Ohio 43215-3793

Steven T. Nourse  
Vice President - Legal  
(614) 716-1608 (P)  
(614) 716-2014 (F)  
stnourse@aep.com

*Re: In the Matter of the Application of Ohio Power Company for an Increase in Electric Distribution Rates, Case No. 20-585-EL-AIR; In the Matter of the Application of Ohio Power Company for Tariff Approval, Case No. 20-586-EL-ATA; In the Matter of the Application of Ohio Power Company for Approval to Change Accounting Methods, Case No. 20-587-EL-AAM*

Dear Examiner:

Under Paragraph III.C.4 of the March 12, 2021 Joint Stipulation and Recommendation adopted by the Commission in resolving this case, the Company agreed to annually report its performance under the stipulated metrics for the prior year. The 2023 results were reported in case 24-992-EL-ESS and the Company is enclosing the results for 2022 in the attached file.

Thank you for your attention to this matter.

Respectfully Submitted,

*/s/ Steven T. Nourse*

cc: Parties of Record

Base Case DIR Recovery Stipulation Reliability for Performance Year 2023

from Rule 10 Table 6a: cause breakdown excluding transmission and major event days

Outage Cause	Events	Customers Interrupted	Customer Minutes Interrupted	DIR Cause Group
Distribution Station	165	118,105	20,343,985	DIR: D-Station
Equipment Hardware Failure	7,028	314,855	40,562,843	DIR: D-Line Equip
Flooding/Slide	6	173	25,545	DIR: Weather
High Winds	145	4,835	1,695,623	DIR: Weather
Lightning	338	7,052	1,385,563	DIR: Weather
Unknown By Weather	587	32,638	5,701,941	DIR: Weather
Accidental Ground	149	23,061	938,682	DIR: Remaining
Animal	5,106	98,248	8,320,315	DIR: Remaining
Contamination/Flashover	1	1	126	DIR: Remaining
Corrosion	265	2,575	402,421	DIR: Remaining
Facilitation of Work	123	13,231	511,050	DIR: Remaining
Operations Incident	22	2,435	228,881	DIR: Remaining
Other	154	3,063	546,538	DIR: Remaining
Overload	68	1,046	111,135	DIR: Remaining
Unbalance	2	311	25,639	DIR: Remaining
Unknown	2,881	103,349	10,492,237	DIR: Unk (non-weather)
DIR Cause Totals	17,040	724,978	91,292,524	
	Customers Served	SAIFI	SAIDI	2023 SAIDI Standard
2023	1,524,255	0.476	59.9	85.8

**This foregoing document was electronically filed with the Public Utilities  
Commission of Ohio Docketing Information System on**

**4/22/2024 4:32:52 PM**

**in**

**Case No(s). 20-0585-EL-AIR, 20-0586-EL-ATA, 20-0587-EL-AAM**

Summary: Report Annual Performance. electronically filed by Mr. Steven T. Nourse  
on behalf of Ohio Power Company.