


file

LEGAL SERVICES

RECEIVED DOCKETING DIV
01 MAR -2 AM 10:21
PUCO



1310 Fairmont Avenue
P.O. Box 1392
Fairmont, WV 26555-1392
Phone: (304) 366-3000
FAX: (304) 367-3157
gjack@alleghenyenergy.com
Writer's Direct Dial No. (304) 367-3423

March 1, 2001

VIA UPS NEXT DAY AIR

The Public Utilities Commission
of Ohio
Docketing Division
180 East Broad Street
Columbus, OH 43215

RE: **Monongahela Power Company,
dba Allegheny Power
Electric Transition Plan Filing
Case No. 00-02-EL-ETP**

Dear Docketing Division:

Enclosed please find the **Transmission/Distribution Separation Filing of Monongahela Power Company** pursuant to the above-referenced case. Only one copy of Allegheny Power's map of major transmission facilities and Allegheny Power's system operating diagram (6 pages) is provided due to the volume and cost of reproduction.

Sincerely yours,

A handwritten signature in black ink, appearing to read 'Gary A. Jack', written over a horizontal line.

Gary A. Jack
Senior Attorney

GAJ:tmw

cc: Parties of Record

This is to certify that the images appearing are an accurate and complete reproduction of a case file document delivered in the regular course of business
Technician T.M.N. Date Processed 3-2-01

ENTRY Item (4), Part 1) –
Discussion of Facilities and FERC's Seven-Factor Test

AP T&D Facilities Classification

Allegheny Power (AP) is preparing to place control of its transmission facilities into the hands of the PJM Office of Interconnection before the end of 2001. This requires a simple identification of the facilities to be controlled; it neither affects ownership of electrical facilities nor requires changes in plant accounting.

Allegheny Power also is contemplating subsequent development of a wholly-owned Transmission Company (TRANSCO) that would own all of its present transmission assets. We presently believe that if there were such a transfer of asset ownership, any resulting net changes in plant accounting would be minor.

Allegheny Power believes that, if separation of existing assets into a TRANSCO is to be accomplished, the initial classification and valuation of transmission and distribution assets should be thorough, and that any subsequent reclassification of existing facilities should be minimized.

The ruleset developed for this purpose is intended to be comprehensive, in order to minimize the need for future changes. Nevertheless, circumstances could change (for example, the interconnection of a new wholesale generator), and require that certain facilities be reclassified. The rules that follow are intended to minimize the need for future reclassifications.

AP's ruleset is not designed or intended to change the existing balance of plant accounting. It is intended to identify facilities for initial PJM control, and possible TRANSCO ownership, and to ensure reliable transmission operation.

FERC's Seven-Factor Test


The FERC "Seven-Factor Test" (SFT) provides the overall distinction between distribution and transmission facilities. The SFT is general in nature, and clearly indicates that there can be exceptions to the general criteria. FERC has provided no guidance as to an acceptable range of interpretation of the general rules. Therefore, additional rules and definitions have been established to guide AP's classification decisions.

AP's T&D Separation Rules

For the purpose of classifying AP's transmission and distribution facilities, the following additional rules apply.

- 1) Transmission voltages are defined as 100 kV and higher. There are some exceptions. (See Rules 4 and 5.)
- 2) Network substations are defined as those that are connected to three or more other network substations by lines operating at a transmission voltage.
- 3) A transmission line operates at transmission voltage and connects two or more network substations.
 - a) A transmission line can consist of multiple serial segments due to intervening substations that tap the transmission line to serve distribution load.
 - b) A transmission line can consist of three segments that connect three network substations at a junction point.
- 4) Lines and substation facilities that provide a path interconnecting the AP network with another are classified as transmission facilities, regardless of the operating voltage, and even if operated normally open.
- 5) Facilities providing the primary path to the transmission network to interconnect a generation source that produces power for the wholesale market are classified as transmission facilities, regardless of generating capacity or operating voltage.
- 6) Capacitors installed on transmission busses are transmission facilities. Radial lines operating at transmission voltages, and substations served by such radial lines, are transmission facilities if a shunt capacitor, or other reactive support device, operating at transmission voltage is present on the substation bus.
- 7) Transformers connecting voltage levels, both (or all) of which are transmission voltages, are transmission facilities. Transformers connecting transmission facilities to lower voltage levels do so for delivery of power to the distribution system, and are therefore distribution facilities.

ENTRY Item (4), Part 2) – Load-flow Data (In support of separation rules.)



Local Distribution Networks

This diagram is a transcription of the results of AP's 2000 Summer base case power flow study. (Results are tabulated in the following eight pages.) System conditions in the base case are normal, and all confirmed regional transactions are included.

[Lake Lynn / Snowy Creek / William], [Guilford / Grand Point / Greene], [Linwood / Durbin], and [Sutton Hill / Buckhannon / Rivesville] are all multiple supply points for local 69 kV networks. As the diagram shows, there are substantial power flows into each of these four local networks at every supply point; no power flows out. Operating experience confirms that the study results are correct, and are consistent with AP's design and operation of bulk power supply facilities serving local distribution. AP's local distribution networks are unaffected by regional power flows under normal operating circumstances. These facts verify that AP's proposed nomination of transmission and distribution facilities is consistent with FERC's "Seven Factor Test."

The transformations at Edgellawn and Bays are purely radial; that is, the 69 kV facilities in those areas have no other connections to the higher-voltage network.

ENTRY Item (4), Part 2) — Load-flow Data

PTI INTERACTIVE POWER SYSTEM SIMULATOR—PSS/E FRI, FEB 09 2001 13:20
2000 SUMMER MON POWER WITH WVP AND SUBTRANSMISSION AREAS

OUTPUT FOR AREA 1 (APS A)

FROM BUS				BUS DATA				<				TO				LINE DATA				>											
NAME	ZONE	AREA	VOLT	ANGLE	GEN	LOAD	SHUNT	NAME	CTK	AREA	MW	MVAR	RATIO	ANGLE	%	MVA	TRANSFORMER	RATING	AREA	NAME	CTK	AREA	MW	MVAR	RATIO	ANGLE	%	MVA	TRANSFORMER	RATING	AREA
8386 ALPINE	69.0	1	0.977	-37.8	0.0	2.7	0.0	8467 ALPINE	69.0	1	1	-2.7	-0.4	7	39																
		98	67.43		0.0	0.4	0.0																								
8387 AMBOY	69.0	1	0.976	-37.2	0.0	2.0	0.0	8400 SNOW C	69.0	1	1	-2.4	1.6	8	37																
		98	67.37		0.0	1.0	0.0	8403 WILLIAM	69.0	1	1	0.4	-2.5	7	37																
8388 BAYARD	69.0	1	0.975	-37.9	0.0	0.4	0.0																								
		98	67.29		0.0	0.3	0.0	8401 STONY RT	69.0	1	1	-2.0	-3.7	11	39																
8389 BLACKWTR	69.0	1	0.980	-37.5	0.0	2.0	0.0	8466 N BRAN	69.0	1	1	1.5	3.4	10	39																
		98	67.59		0.0	0.6	0.0	8403 WILLIAM	69.0	1	1	-2.0	-0.6	6	39																
8390 BUFF CL	69.0	1	0.978	-38.1	0.0	0.7	0.0																								
		98	67.50		0.0	0.0	0.0	8401 STONY RT	69.0	1	1	-1.5	4.3	11	41																
8391 CASCADE	69.0	1	0.959	-36.9	0.0	9.8	0.0	8402 STONY R	69.0	1	1	0.8	-4.3	11	41																
		98	66.16		0.0	7.4	0.0	8448 PRESKO	69.0	1	1	-9.8	-7.4	30	43																
8392 CHER RGT	69.0	1	0.974	-37.9	0.0	0.0	0.0																								
		98	67.19		0.0	0.0	0.0	8393 CHER RG	69.0	1	1	3.0	1.5	8	41																
					0.0	0.0	0.0	8394 GRANT CT	69.0	1	1	-1.1	-3.3	9	41																
					0.0	0.0	0.0	8456 GORMAN	69.0	1	1	-1.9	1.8	4	63																
8393 CHER RG	69.0	1	0.972	-38.0	0.0	2.5	0.0																								
		98	67.09		0.0	1.2	0.0	8392 CHER RGT	69.0	1	1	-3.0	-1.5	8	41																
					0.0	0.0	0.0	8465 KUHN	69.0	1	1	0.5	0.3	2	41																
8394 GRANT CT	69.0	1	0.974	-37.9	0.0	0.0	0.0																								
		98	67.19		0.0	0.0	0.0	8392 CHER RGT	69.0	1	1	1.1	3.3	9	41																
					0.0	0.0	0.0	8466 N BRAN	69.0	1	1	-1.2	-3.3	9	41																
					0.0	0.0	0.0	8495 GRANT C	69.0	1	1	0.0	0.0	0	41																
8395 LAKE LYN	69.0	1	0.979	-35.7	0.0	0.0	0.0																								
		98	67.57		0.0	0.0	0.0	8067 LAKE LYN	138	72	90	-10.7	-4.5	34	35																
					0.0	0.0	0.0	8448 PRESKO	69.0	1	1	10.7	4.5	20	58																
8396 N BRAN	69.0	1	0.975	-37.9	0.0	0.4	0.0																								
		98	67.25		0.0	0.2	0.0	8466 N BRAN	69.0	1	1	-0.4	-0.2	1	39																
8397 OAKLAND	69.0	1	0.974	-37.5	0.0	2.2	0.0																								
		98	67.20		0.0	0.8	0.0	8400 SNOW C	69.0	1	1	-5.8	0.5	15	39																
					0.0	0.0	0.0	8456 GORMAN	69.0	1	1	3.6	-1.3	10	39																
8398 ROWLEB	69.0	1	0.962	-37.2	0.0	2.8	0.0																								
		98	66.38		0.0	1.4	0.0	8399 ROWLEB	69.0	1	1	-2.8	-1.4	8	41																

8399 ROWLEB T69.0	1	0.966	-37.0	0.0	0.0	0.0	0.0	0.0	0.0	8398 ROWLEB 59.0	1	1	2.8	1.3	8	41
	98	66.65		0.0	0.0					8400 SNOW C 59.0	1	1	-2.1	-4.0	8	58
8400 SNOW C 69.0	1	0.976	-36.9	0.0	5.2	0.0	0.0	0.0	0.0	8448 PRESCO 69.0	1	1	-0.7	2.7	5	58
	98	67.37		0.0	2.6	-4.7				8118 SNOW C 138	1	90	-15.6	0.9	1.019UN	60
8401 STONY RT69.0	1	0.977	-37.9	0.0	0.0	0.0	0.0	0.0	0.0	8387 AMBOY 69.0	1	1	2.4	-1.7	8	37
	98	67.38		0.0	0.0					8397 OAKLAND 69.0	1	1	5.8	-0.7	15	39
8402 STONY R 69.0	1	0.979	-38.2	0.0	0.8	0.0	0.0	0.0	0.0	8399 ROWLEB T69.0	1	1	2.1	3.7	8	58
	98	67.59		0.0	0.3	-4.5				8388 BAYARD 69.0	1	1	2.0	3.6	11	39
8403 WILLIAM 69.0	1	0.981	-37.4	0.0	0.0	0.0	0.0	0.0	0.0	8390 BUFF CL 69.0	1	1	1.5	-4.4	12	41
	98	67.67		0.0	0.0					8467 ALPINE T69.0	1	1	-3.5	0.8	9	39
8404 ADRIAN 69.0	1	0.982	-35.5	0.0	0.2	0.0	0.0	0.0	0.0	8390 BUFF CL 69.0	1	1	-0.8	4.3	11	41
	99	67.79		0.0	0.1	0.0	0.0	0.0	0.0	8136 WILLIAM 138	2	90	-7.9	2.6	1.019UN	42
8405 BUCKHAN 69.0	1	0.987	-35.3	0.0	0.0	-5.4	0.0	0.0	0.0	8387 AMBOY 69.0	1	1	-0.3	2.3	6	37
	99	68.12		0.0	0.0					8389 BLACKWTR69.0	1	1	2.0	0.5	6	39
8406 BURNSV 69.0	1	0.957	-36.8	0.0	5.1	0.0	0.0	0.0	0.0	8467 ALPINE T69.0	1	1	6.2	-0.6	16	39
	99	66.06		0.0	2.3	0.0	0.0	0.0	0.0	8405 BUCKHAN 69.0	1	1	-4.1	-1.3	11	38
8407 CENTUR 69.0	1	0.984	-35.1	0.0	4.0	0.0	0.0	0.0	0.0	8411 GAME FRM69.0	1	1	3.9	1.2	11	38
	99	67.91		0.0	3.1	0.0	0.0	0.0	0.0	8018 BUCKHAN 138	1	90	-10.6	-1.2	0.995UN	31
8408 ELK C 69.0	1	0.987	-34.8	0.0	0.5	0.0	0.0	0.0	0.0	8404 ADRIAN 69.0	1	1	4.1	1.2	11	38
	99	68.12		0.0	0.2	0.0	0.0	0.0	0.0	8407 CENTUR 69.0	1	1	-0.7	2.9	8	37
8409 FRAMET 69.0	1	0.955	-36.9	0.0	2.8	0.0	0.0	0.0	0.0	8415 ROANOK 69.0	1	1	7.1	2.5	20	37
	99	65.92		0.0	1.2	0.0	0.0	0.0	0.0	8410 FRAMET T69.0	1	1	-0.6	-0.2	2	37
8410 FRAMET T69.0	1	0.958	-36.7	0.0	0.0	0.0	0.0	0.0	0.0	8415 ROANOK 69.0	1	1	-4.5	-2.1	14	37
	99	66.13		0.0	0.0	0.0	0.0	0.0	0.0	8405 BUCKHAN 69.0	1	1	0.7	-3.1	9	37
8411 GAME FRM69.0	1	0.979	-35.7	0.0	3.9	0.0	0.0	0.0	0.0	8408 ELK C 69.0	1	1	-4.7	0.0	13	37
	99	67.56		0.0	1.3	0.0	0.0	0.0	0.0	8407 CENTUR 69.0	1	1	4.7	-0.1	13	37
8412 LAMP PL 69.0	1	0.998	-33.4	0.0	0.3	0.0	0.0	0.0	0.0	8412 LAMP PL 69.0	1	1	-5.2	-0.1	14	37
	99	68.84		0.0	0.0	0.0	0.0	0.0	0.0	8410 FRAMET T69.0	1	1	-2.8	-1.2	8	38
8413 OTTER 69.0	1	0.979	-35.7	0.0	3.9	0.0	0.0	0.0	0.0	8406 BURNSV 69.0	1	1	0.6	-0.2	2	37
	99	67.56		0.0	1.3	0.0	0.0	0.0	0.0	8409 FRAMET 69.0	1	1	2.8	1.0	8	38
8414 ADRIAN 69.0	1	0.979	-35.7	0.0	3.9	0.0	0.0	0.0	0.0	8413 OTTER 69.0	1	1	-3.5	-0.9	10	38
	99	67.56		0.0	1.3	0.0	0.0	0.0	0.0	8404 ADRIAN 69.0	1	1	-3.9	-1.3	11	38
8415 LAMP PL 69.0	1	0.998	-33.4	0.0	0.3	0.0	0.0	0.0	0.0	8408 ELK C 69.0	1	1	5.3	-0.5	14	37
	99	68.84		0.0	0.0	-4.4	0.0	0.0	0.0							

8413 OTTER	69.0	1	0.958	-36.7	0.0	0.0	4.6	0.0	8414 RIVESVL	69.0	1	1	-9.0	4.7	27	37
	99	66.13			0.0	0.0	2.0		8410 FRAMET	T69.0	1	1	3.5	0.9	10	38
8414 RIVESVL	69.0	1	0.998	-33.2	0.0	0.0	21.3		8416 SUTTN H	69.0	1	1	-8.1	-2.8	23	38
	99	68.84			0.0	0.0	4.4		8104 RIVESVL	138 10	90	-17.5	0.1	44	40	
					0.0	0.0			8104 RIVESVL	138 8	90	-12.8	0.2	64	20	
8415 ROANOK	69.0	1	0.968	-36.4	0.0	0.0	2.6		8412 LAMP PL	69.0	1	1	9.1	-4.7	27	37
	99	66.80			0.0	0.0	0.9		8405 BUCKHAN	69.0	1	1	-7.1	-2.8	21	37
8416 SUTTN H	69.0	1	0.965	-36.4	0.0	0.0	0.0		8406 BURNSV	69.0	1	1	4.5	1.9	13	37
	99	66.62			0.0	0.0	0.0		8123 SUTTN H	138 1	90	-8.1	-2.8	0.995UN	25	35
8448 PRESCO	69.0	1	0.962	-36.9	0.0	0.0	0.0		8413 OTTER	69.0	1	1	8.1	2.8	23	38
	98	66.38			0.0	0.0	0.0		8391 CASCADE	69.0	1	1	9.9	7.4	30	43
8456 GORMAN	69.0	1	0.973	-37.9	0.0	0.0	1.7		8395 LAKE LYNE	69.0	1	1	-10.6	-4.5	21	58
	98	67.16			0.0	0.0	0.8		8399 ROWLEB	T69.0	1	1	0.7	-2.9	5	58
8465 KUHN	69.0	1	0.972	-38.0	0.0	0.0	0.5		8392 CHER RGT	69.0	1	1	1.9	-1.9	4	63
	98	67.07			0.0	0.0	0.4		8397 OAKLAND	69.0	1	1	-3.6	1.1	10	39
8466 N BRAN	T69.0	1	0.975	-37.9	0.0	0.0	0.0		8393 CHER RG	69.0	1	1	-0.5	-0.4	2	41
	98	67.25			0.0	0.0	0.0		8388 BAYARD	69.0	1	1	-1.5	-3.4	10	39
8467 ALPINE	T69.0	1	0.978	-37.8	0.0	0.0	0.0		8394 GRANT CT	69.0	1	1	1.2	3.3	9	41
	98	67.46			0.0	0.0	0.0		8396 N BRAN	69.0	1	1	0.4	0.2	1	39
8495 GRANT C	69.0	1	0.974	-37.9	0.0	0.0	0.0		8386 ALPINE	69.0	1	1	2.7	0.3	7	39
	98	67.19			0.0	0.0	0.0		8401 STONY RT	69.0	1	1	3.5	-0.9	9	39
					0.0	0.0	0.0		8403 WILLIAM	69.0	1	1	-6.1	0.5	16	39
					0.0	0.0	0.0		8394 GRANT CT	69.0	1	1	0.0	0.0	0	41

OUTPUT FOR AREA 92 JELKINS }

<----->										<----->										<----->										<----->										<----->									
FROM BUS	NAME	AREA ZONE	VOLT PU/KV	BUS DATA ANGLE	GEN MW/MVAR	LOAD MW/MVAR	SHUNT MW/MVAR	TO BUS	NAME	CKT	AREA	MW	MVAR	TRANSFORMER RATIO	ANGLE	RATING %I	FROM BUS	NAME	AREA ZONE	VOLT PU/KV	BUS DATA ANGLE	GEN MW/MVAR	LOAD MW/MVAR	SHUNT MW/MVAR	TO BUS	NAME	CKT	AREA	MW	MVAR	TRANSFORMER RATIO	ANGLE	RATING %I																
8165	DURBIN	69.0	92	0.970	-37.5	0.0	0.4	0.0	8033	DURBIN	138	1	90	-9.4	2.5	0.958RG	28	35	8166	FRANK	69.0	92	7.0	-3.1	7.0	0.5	5	38	8182	TROUT R	69.0	1	92	2.0	0.5	21	38												
8166	FRANK	69.0	92	0.970	-37.9	0.0	4.3	0.0	8165	DURBIN	69.0	1	92	-7.0	3.1		28	35	8170	ISNER	CK69.0	92	0.930	-37.2	0.0	9.8	0.0	8174	MONTEREY	69.0	1	92	2.8	0.7	21	38													
8170	ISNER	CK69.0	92	0.930	-37.2	0.0	0.9	-4.7	8165	DURBIN	69.0	1	92	-7.0	3.1		28	35	8172	LOUGHS	L69.0	1	92	4.2	0.0	0.0	0.0	8172	LOUGHS	L69.0	1	92	-9.8	-4.2	30	38													
8171	LINWOOD	69.0	92	0.985	-37.5	0.0	0.0	0.0	8071	LINWOOD	138	1	90	-12.1	5.2	1.019UN	35	38	8177	SNOWS T	69.0	1	92	12.1	-5.2	16	85	8073	LOUGHS L	138	1	90	-14.2	-5.2	1.044UN	46	35												
8172	LOUGHS	L69.0	92	0.938	-36.9	0.0	0.0	0.0	8170	ISNER	CK69.0	1	92	9.8	4.2		30	38	8183	TYGART	69.0	1	92	4.4	1.0	13	38	50	NEW BUS	69.0	1	89	3.0	-2.9	11	38													
8173	MARL	69.0	92	0.976	-39.9	0.0	5.2	0.0	8180	THORN	CT69.0	1	92	-8.3	1.8		23	38	8166	FRANK	69.0	1	92	-2.7	-1.1	8	38	8178	SNOWS	69.0	1	92	-12.0	5.2	16	85													
8174	MONTEREY	69.0	92	0.961	-38.3	0.0	1.2	0.0	8179	MARL T	69.0	1	92	9.9	-1.5		16	63	8177	SNOWS T	69.0	1	92	-2.1	3.7	7	63	8179	MARL T	69.0	1	92	-9.9	1.4	16	63													
8177	SNOWS T	69.0	92	0.987	-38.2	0.0	0.0	0.0	8171	LINWOOD	69.0	1	92	-12.0	5.2		16	63	8178	SNOWS	69.0	1	92	2.1	-3.7	7	63	8181	THORN C	69.0	1	92	1.5	0.5	4	41													
8178	SNOWS	69.0	92	0.988	-38.3	0.0	2.1	0.0	8179	MARL T	69.0	1	92	9.9	-1.5		4	41	8177	SNOWS T	69.0	1	92	-2.1	3.7	7	63	8180	THORN	CT69.0	1	92	-1.5	-0.6	4	41													
8179	MARL T	69.0	92	0.986	-38.4	0.0	0.6	-4.3	8177	SNOWS T	69.0	1	92	-2.1	3.7		4	41	8177	SNOWS T	69.0	1	92	-9.9	1.4	16	63	8180	THORN	CT69.0	1	92	9.9	-1.4	26	38													
8180	THORN	CT69.0	92	0.982	-38.9	0.0	0.0	0.0	8173	MARL	69.0	1	92	8.3	-1.9		23	38	8178	SNOWS	69.0	1	92	2.1	-3.7	7	63	8179	MARL T	69.0	1	92	-9.9	1.4	26	38													
8181	THORN C	69.0	92	0.981	-38.9	0.0	1.5	0.0	8179	MARL T	69.0	1	92	-9.9	1.4		26	38	8181	THORN C	69.0	1	92	1.5	0.5	4	41	8180	THORN	CT69.0	1	92	-1.5	-0.6	4	41													
8182	TROUT R	69.0	92	0.967	-37.7	0.0	0.0	0.0	8180	THORN	CT69.0	1	92	-1.5	-0.6		4	41	8177	SNOWS T	69.0	1	92	-9.9	1.4	16	63	8179	MARL T	69.0	1	92	-9.9	1.4	26	38													
8182	TROUT R	69.0	92	0.967	-37.7	0.0	2.0	0.0	8165	DURBIN	69.0	1	92	-2.0	-0.7		6	38	8165	DURBIN	69.0	1	92	-2.0	-0.7	6	38	8173	MARL	69.0	1	92	8.3	-1.9	23	38													
8182	TROUT R	69.0	92	0.967	-37.7	0.0	0.7	0.0	8165	DURBIN	69.0	1	92	-2.0	-0.7		6	38	8173	MARL	69.0	1	92	8.3	-1.9	23	38	8179	MARL T	69.0	1	92	-9.9	1.4	26	38													
8182	TROUT R	69.0	92	0.967	-37.7	0.0	0.7	0.0	8165	DURBIN	69.0	1	92	-2.0	-0.7		6	38	8181	THORN C	69.0	1	92	1.5	0.5	4	41	8180	THORN	CT69.0	1	92	-1.5	-0.6	4	41													

8183 TYGART 69.0 92 0.925 -37.6 0.0 4.3 0.0 0.0 8172 LOUGHS L69.0 1 92 -4.3 -1.3 13 38

OUTPUT FOR AREA 96 [PARKERSB]

<-----BUS DATA----->										-----LINE DATA-----									
FROM BUS	NAME	AREA	VOLT	ANGLE	GEN MW/MVAR	LOAD MW/MVAR	SHUNT MW/MVAR	TO BUS	NAME	CKT AREA	MW	MVAR	TRANSFORMER RATIO	ANGLE	RATING A %I				
8292	EDGEAWN69.0	96	0.966	-28.7	0.0	0.0	0.0	0.0	8036 EDGEAWN 138	1 90	-21.2	-11.5	0.995UN		71 35				
		96	66.66		0.0	0.0	0.0	0.0	8484 MINERL W69.0	1 96	21.2	11.5			56 44				
8293	ELIZAB	69.0	0.932	-30.3	0.0	3.0	0.0	0.0											
		96	64.27		0.0	1.8	0.0	0.0	8483 ELIZAB T69.0	1 96	-3.0	-1.8			9 41				
8312	PALESTIN69.0	96	0.931	-30.4	0.0	3.0	0.0	0.0											
		96	64.22		0.0	1.4	0.0	0.0	8483 ELIZAB T69.0	1 96	-3.0	-1.4			8 44				
8319	SLATE	69.0	0.937	-30.1	0.0	5.8	0.0	0.0											
		96	64.69		0.0	2.5	0.0	0.0	8318 SLATE 34.0	1 96	2.8	0.9	0.975LK		42 8				
8482	SLATE T 69.0	96	0.939	-30.0	0.0	0.0	0.0	0.0	8482 SLATE T 69.0	1 96	-8.6	-3.4			22 44				
		96	64.82		0.0	0.0	0.0	0.0											
8483	ELIZAB T69.0	96	0.933	-30.3	0.0	0.0	0.0	0.0	8319 SLATE 69.0	1 96	8.6	3.4			22 44				
		96	64.35		0.0	0.0	0.0	0.0	8483 ELIZAB T69.0	1 96	6.1	3.0			16 44				
									8484 MINERL W69.0	1 96	-14.7	-6.4			38 44				
8484	MINERL W69.0	96	0.956	-29.1	0.0	6.2	0.0	0.0											
		96	65.99		0.0	4.7	0.0	0.0	8293 ELIZAB 69.0	1 96	3.0	1.7			9 41				
									8312 PALESTIN69.0	1 96	3.0	1.3			8 44				
									8482 SLATE T 69.0	1 96	-6.0	-3.1			16 44				
									8292 EDGEAWN69.0	1 96	-21.0	-11.3			56 44				
									8482 SLATE T 69.0	1 96	14.8	6.6			38 44				

OUTPUT FOR AREA 97 [SOUTHERN]

<-----BUS DATA----->										<-----LINE DATA----->																			
FROM BUS		NAME		AREA	VOLT	ZONE		PV/KV	ANGLE	GEN	LOAD		SHUNT		TO BUS		NAME		CKT	AREA	MW	MVAR	TRANSFORMER	RATIO	ANGLE	RATING	#1	MVA	
										MW/MVAR	MW/MVAR	MW/MVAR	MW/MVAR																
8345	BAYS	69.0	97	0.929	-37.0	0.0	2.4	0.0	0.0	0.0	0.0	0.0	0.0	8009	BAYS	138	1	90	-10.9	-5.1	1.024UN	65	20						
			97	64.08		0.0	1.1	0.0	0.0	0.0	0.0	0.0	0.0	8365	JULIAN	69.0	1	97	8.5	4.0		16	63						
8351	BROOKS	R69.0	97	0.921	-37.4	0.0	5.5	0.0	0.0	0.0	0.0	0.0	0.0																
			97	63.58		0.0	2.1	0.0	0.0	0.0	0.0	0.0	0.0	8365	JULIAN	69.0	1	97	-5.5	-2.1		10	63						
8365	JULIAN	69.0	97	0.922	-37.4	0.0	2.9	0.0	0.0	0.0	0.0	0.0	0.0																
			97	63.62		0.0	2.0	0.0	0.0	0.0	0.0	0.0	0.0	8345	BAYS	69.0	1	97	-8.4	-4.1		16	63						

8351 BROOKS R69.0 1 97 5.5 2.1 10 63

PTI INTERACTIVE POWER SYSTEM SIMULATOR--PSS/E FRI, FEB 09 2001 14:26
2000 SUMMER MON POWER WITH WVP AND SUBTRANSMISSION AREAS

BUS DATA										LINE DATA									
FROM BUS	AREA	ZONE	NAME	PU/KV	ANGLE	GEN MW/MVAR	LOAD MW/MVAR	SHUNT MW/MVAR	TO BUS	NAME	CKT AREA	MW	MVAR	RATIO	ANGLE	TRANSFORMER RATIO	ANGLE	RATING %I	RATING MVA
8105 RIVESVL	90	11.5	90	1.053	-23.4	80.0	0.0	0.0	0.0	8104 RIVESVL	138 8 90	80.0	33.8					172	48
8106 RIVESVL	90	13.8	90	1.040	-27.3	53.0	0.0	0.0	0.0	8104 RIVESVL	138 10 90	53.0	33.8					81	75

OUTPUT FOR AREA 1 [APS A] PE AREA

BUS DATA										LINE DATA										TRANSFORMER				RATING A	
FROM BUS	NAME	AREA	VOLT	ANGLE	GEN	LOAD	SHUNT	TO BUS	NAME	CKT AREA	MW	MVAR	RATIO	ANGLE	%I	MVA	RATIO	ANGLE	%I	MVA					
375 CREE	69.0	1	0.969	-74.5	0.0	45.0	0.0	404 GRANDPOI	69.0	1	1	-45.0	-14.8												
404 GRANDPOI	69.0	1	0.972	-74.2	0.0	0.0	0.0	64 OIGRANDP	138	1	1	-45.1	-15.1	0.956UN	55	90									
406 GREENE	69.0	1	0.980	-72.1	0.0	0.0	0.0	375 CREE	69.0	1	1	45.1	15.1												
408 GUILFORD	69.0	1	0.985	-71.9	0.0	0.0	0.0	65 OIGREENE	138	1	1	-10.3	-2.1	0.956UN	32	34									
487 ROUTE	3069.0	1	0.980	-72.3	0.0	6.2	0.0	493 SALEM	69.0	1	1	10.3	2.1												
493 SALEM	69.0	1	0.979	-72.4	0.0	12.6	0.0	406 GREENE	69.0	1	1	-10.3	-2.1												
561 OAKLAND	69.0	1	0.961	-34.6	0.0	2.1	0.0	487 ROUTE	3069.0	1	1	-2.3	-2.1												
562 GORMAN	69.0	1	0.960	-34.7	0.0	2.0	0.0	562 GORMAN	69.0	1	1	6.1	1.5												
8386 ALPINE	69.0	1	0.961	-35.0	0.0	3.2	0.0	8400 SNOWY	CK69.0	1	1	-8.2	-2.2												
8387 AMBOY	69.0	1	0.967	-34.3	0.0	1.1	0.0	561 OAKLAND	69.0	1	1	-6.1	-1.6												
8388 BAYARD	69.0	1	0.957	-35.1	0.0	0.4	0.0	8392 CHR RG	T69.0	1	1	4.1	0.1												
8389 BLACKWTR	69.0	1	0.966	-34.9	0.0	2.0	0.0	8401 ST RIV	T69.0	1	1	-6.4	-2.3												
8390 BUFFALO	69.0	1	0.957	-35.2	0.0	1.1	0.0	8403 WILLIAM	69.0	1	1	-5.3	0.9												
8391 CASCADE	69.0	1	0.968	-33.4	0.0	10.9	0.0	8396 N BRANCH	69.0	1	1	0.4	1.9												
		10	66.81		0.0	2.5	0.0	8401 ST RIV	T69.0	1	1	-0.8	-2.1												
		10	66.02		0.0	0.6	0.0	8403 WILLIAM	69.0	1	1	-2.0	-0.6												
		10	66.05		0.0	0.0	0.0																		
		10	66.64		0.0	0.0	0.0																		
		10	66.81		0.0	0.0	0.0																		
		10	66.02		0.0	0.0	0.0																		
		10	66.05		0.0	0.0	0.0																		
		10	66.64		0.0	0.0	0.0																		
		10	66.81		0.0	0.0	0.0																		
		10	66.02		0.0	0.0	0.0																		
		10	66.05		0.0	0.0	0.0																		
		10	66.64		0.0	0.0	0.0																		
		10	66.81		0.0	0.0	0.0																		
		10	66.02		0.0	0.0	0.0																		
		10	66.05		0.0	0.0	0.0																		
		10	66.64		0.0	0.0	0.0																		
		10	66.81		0.0	0.0	0.0																		
		10	66.02		0.0	0.0	0.0																		
		10	66.05		0.0	0.0	0.0																		
		10	66.64		0.0	0.0	0.0																		
		10	66.81		0.0	0.0	0.0																		
		10	66.02		0.0	0.0	0.0																		
		10	66.05		0.0	0.0	0.0																		
		10	66.64		0.0	0.0	0.0																		
		10	66.81		0.0	0.0	0.0																		
		10	66.02		0.0	0.0	0.0																		
		10	66.05		0.0	0.0	0.0																		
		10	66.64		0.0	0.0	0.0																		
		10	66.81		0.0	0.0	0.0																		
		10	66.02		0.0	0.0	0.0																		
		10	66.05		0.0	0.0	0.0																		
		10	66.64		0.0	0.0	0.0																		
		10	66.81		0.0	0.0	0.0																		
		10	66.02		0.0	0.0	0.0																		
		10	66.05		0.0	0.0	0.0																		
		10	66.64		0.0	0.0	0.0																		
		10	66.81		0.0	0.0	0.0																		
		10	66.02		0.0	0.0	0.0																		
		10	66.05		0.0	0.0	0.0																		
		10	66.64		0.0	0.0	0.0																		
		10	66.81		0.0	0.0	0.0																		
		10	66.02		0.0	0.0	0.0																		
		10	66.05		0.0	0.0	0.0																		
		10	66.64		0.0	0.0	0.0																		
		10	66.81		0.0	0.0	0.0																		
		10	66.02		0.0	0.0	0.0																		
		10	66.05		0.0	0.0	0.0																		
		10	66.64		0.0	0.0	0.0																		
		10	66.81		0.0	0.0	0.0																		
		10	66.02		0.0	0.0	0.0																		
		10	66.05		0.0	0.0	0.0																		
		10	66.64		0.0	0.0	0.0																		
		10	66.81		0.0	0.0	0.0																		
		10	66.02		0.0	0.0	0.0																		
		10	66.05		0.0	0.0	0.0																		
		10	66.64		0.0	0.0	0.0																		
		10	66.81		0.0	0.0	0.0																		
		10	66.02		0.0	0.0	0.0																		
		10	66.05		0.0	0.0	0.0																		
		10	66.64		0.0	0.0	0.0																		
		10	66.81		0.0	0.0	0.0																		
		10	66.02		0.0	0.0	0.0																		
		10	66.05		0.0	0.0	0.0																		
		10	66.64		0.0	0.0	0.0																		
		10	66.81		0.0	0.0	0.0																		
		10	66.02		0.0	0.0	0.0																		
		10	66.05		0.0	0.0	0.0																		
		10	66.64		0.0	0.0	0.0																		
		10	66.81		0.0	0.0	0.0																		
		10	66.02		0.0	0.0	0.0																		
		10	66.05		0.0	0.0	0.0																		
		10	66.64		0.0	0.0	0.0																		
		10	66.81		0.0	0.0	0.0																		
		10	66.02		0.0	0.0	0.0																		
		10	66.05		0.0	0.0	0.0																		
		10	66.64		0.0	0.0	0.0																		
		10	66.81		0.0	0.0	0.0																		
		10	66.02		0.0	0.0	0.0																		
		10	66.05		0.0	0.0	0.0																		
		10	66.64		0.0	0.0	0.0																		
		10	66.81		0.0	0.0	0.0																		
		10	66.02		0.0	0.0	0.0																		
		10	66.05		0.0	0.0	0.0																		
		10	66.64		0.0	0.0	0.0																		
		10	66.81		0.0	0.0	0.0																		
		10	66.02		0.0	0.0	0.0																		
		10	66.05		0.0	0.0	0.0																		
		10	66.64		0.0	0.0	0.0																		
		10	66.81		0.0	0.0	0.0																		
		10	66.02		0.0	0.0	0.0																		
		10	66.05		0.0	0.0	0.0																		
		10	66.64		0.0	0.0	0.0													</					

ENTRY Item (4), Part 3) – Maps

- Allegheny Power's map, "MAJOR TRANSMISSION FACILITIES – As of December 31, 2000", is provided as an attachment. It is a geographic representation of key regional facilities, including AP's electrical facilities down to the 69 kV level.
- AP's "SYSTEM OPERATING DIAGRAM" also is attached. This six-page schematic diagram represents AP's high-voltage electrical facilities and key facilities of systems surrounding AP. The diagram has been color-enhanced to illustrate AP's proposed nomination of transmission facilities.

Transmission facilities are colored green. Distribution facilities, and facilities owned by others are black. The names of substations whose operation will be controlled by PJM (and that might be transferred to a TRANSCO) are highlighted in green. Those substations that would remain under the ownership of the distribution company, but contain transmission facilities, are highlighted in yellow. The names of substations owned by others are not highlighted.

ENTRY Item (4), Part 4) – Accounting Decisions, Specific Accounts, and Cost Separations

Accounting Decisions

The book value of AP's transmission and distribution facilities in Ohio, as presently allocated by accounts, is summarized in the table below. Even though it is premature to be making a thorough cost separation (owing to the fact that ownership by a TRANSCO is a consideration yet to be concluded), an estimate of the value of facilities that might be transferred is included.

AP currently views the possible transfer of transmission facilities ownership to a TRANSCO in terms of transferring each line and substation in its entirety. Certain substations that would be transferred include distribution facilities. Certain substations that would remain with the distribution company include transmission facilities. In these cases there would be an arrangement for leasing pertinent facilities from one company to the other in order to provide appropriate allocation of costs.


Substations that include both transmission and distribution facilities present an accounting challenge to ownership transfers and the lease-back concept. Accounting records, particularly for older facilities, do not permit a high degree of resolution of the costs represented by the items of hardware in a substation. It would be very taxing to examine the common facilities in every substation (control building, battery, fence, lighting, etc.) and develop a precise separation of costs. AP proposes to classify substations as, for example, 80/20 (80% transmission, 20% distribution), 70/30, etc. This is about the limit of resolution of accounting records. Using good judgment and applying percentages in moderate increments should facilitate the process of cost separation if it ever becomes necessary to implement a transfer of ownership and partial lease-back.

Cost Separations – Ohio

Asset Type	Current Book Value (\$000)		Value if Assigned to a TRANSCO (\$000)		Net Change to Transmission
	Transmission	Distribution	Transmission	Distribution	
Substations	\$5,016	\$6,984	\$4,768	\$7,232	(\$248)
Lines	\$6,556	\$0	\$6,461	\$95	(\$95)

The net change in T&D accounts due to a possible transfer of assets to a TRANSCO is estimated to be approximately \$343,000, which is 1.8% of the current book value of all AP T&D assets in Ohio. This small shift from transmission to distribution would result from application of the FERC Seven Factor Test and AP's asset classification ruleset.

ENTRY Item (4), Part 5) – Other Justification



KEISTERS
Butler SC
1-20-98 (1 of 2)

ENTRY Item (4), Part 5) – Other Justification

The substation diagram above is an illustration of AP's T&D Separation Rule #4, "*Lines and substation facilities that provide a path interconnecting the AP network with another are classified as transmission facilities, regardless of the operating voltage, and even if operated normally open.*" The facilities highlighted in green above would be nominated as transmission.

The AP and Penn Power transmission networks are interconnected at Keisters SS. The transmission path is through the Keisters 138-25 kV transformer, a portion of the 25 kV bus, and then through the 25-69 kV transformer.

Although there are other low-voltage paths elsewhere that interconnect AP with neighboring companies, all those paths have a negligible response to regional power flows. The Keisters path is moderately responsive, and occasionally has figured in transfer constraints. Network reconfiguration is usually sufficient to alleviate any operating security problems that occur at Keisters.

Facilities in substations that interconnect wholesale generators to the AP transmission network by way of a lower-voltage path would be nominated as transmission in a manner analogous to the separation illustrated for Keisters.

CERTIFICATE OF SERVICE

The undersigned hereby certifies that the foregoing ***Transmission/Distribution***

Separation Filing of Monongahela Power Company was served on or about the 1st day of

March, 2001, via e-mail upon the following:

Michael L. Kurtz, Esq.
for Kroger Company
Boehm, Kurtz & Lowry
2110 CBLD Ctr., 36 E Seventh St.
Cincinnati, OH 45202
Phone: 513-421-2255
Fax: 513-421-2764
E-mail: mkurtzlaw@aol.com

M. Howard Petricoff, Esq.
for Enron Corp.
Vorys, Sater, Seymour & Pease LLP
52 East Gay Street
Columbus, OH 43216-1008
Phone: 614-464-5414
Fax: 614-719-4904
E-mail: mhpetricoff@vssp.com

Janine L. Migden
Reg. Dir. of Govt. Affairs
Enron Corp.
400 Metro Place North
Dublin, OH 43017
Phone: 614-718-6335
Fax: 614-791-6149
E-mail: jmigden@enron.com

Derrick Williamson, Esq.
Kimberly J. Wile, Esq.
Gretchen J. Hummel, Esq.
for Industrial Energy Users-Ohio
McNees, Wallace & Nurick
Fifth Third Center
21 East State Street, Suite 1700
Columbus, OH 43215-4228
Phone: 614-469-8000
Fax: 614-469-4653
E-mail: dwilliam@mwncmh.com
E-mail: kwile@mwncmh.com
E-mail: ghummel@mwncmh.com

John W. Bentine, Esq.
Jeffrey L. Small, Esq.
for Ohio Council of Retail Merchants
Chester, Wilcox & Saxbe LLP
17 So. High Street, Suite 900
Columbus, OH 43215-3413
Phone: 614-221-4000
Fax: 614-221-4012
E-mail: jbentine@cwslaw.com
E-mail: jsmall@cwslaw.com

Sheldon A. Taft, Esq.
Stephen M. Howard, Esq.
for Ohio Manufacturers' Assoc.
Vorys, Sater, Seymour and Pease
52 East Gay Street
Columbus, OH 43215
Phone: 614-464-6308
Fax: 614-464-6350
E-mail: sataft@vssp.com
E-mail: smhoward@vssp.com

Sally W. Bloomfield
Elizabeth Watts
Amy S. Bartemes, Esq.
Bricker & Eckler LLP
100 S. Third Street
Columbus, OH 43215-4291
Phone: 614-227-2368
Fax: 614-227-2370
E-mail: sbloomfield@bricker.com
E-mail: ewatts@bricker.com
E-mail: abartemes@bricker.com

Wanda M. Schiller
Strategic Energy, LLC
Two Gateway Center
Pittsburgh, PA 15222
Phone: 412-394-5618
Fax: 412-394-6576
E-mail: wschiller@sel.com

Jesse A. Dillon, Esq.
PP&L EnergyPlus Co., LLC
Two North Ninth Street
Allentown, PA 18101
Phone: 610-774-5013
Fax: 610-774-6726
E-mail: jadillon@pplweb.com

Craig G. Goodman, Esq.
for National Energy Marketers Assoc.
3333 K. Street, N.W., Suite 425
Washington, DC 20007
Phone: 202-333-3288
Fax: 202-333-3266
E-mail: cgoodman@energymarketers.com

David Rinebolt
for Ohio Partners for Aff. Energy
P.O. Box 1793
Findlay, OH 45839-1793
Phone: 419-425-8860
Fax: 419-425-8862
E-mail: drinebolt@aol.com

Ann M. Hotz
Barry Cohen
Ohio Consumers' Counsel
10 W. Broad St., Suite 1800
Columbus, OH 43215-3485
Phone: 614-466-9573
Fax: 614-466-9475
E-mail: hotz@occ.state.oh.us
E-mail: cohen@occ.state.oh.us

Ellis Jacobs
for Corp. for Ohio Appalachian Dev.
Legal Aid Society of Dayton
333 W. First St., Ste. 500
Dayton, OH 45402
Phone: 937-228-8088
Fax: 937-449-8131
E-mail: ellis@daytonlegalaids.org

Robert P. Mone, Esq.
Scott A. Campbell, Esq.
Thompson Hine & Flory LLP
10 West Broad St., 7th Floor
Columbus, OH 43215
Phone: 614-469-3200
Fax: 614-469-3361
E-mail: monerp@thf.com
E-mail: campbesa@thf.com


David Berger, VP Adm. & Op.
Buckeye Power, Inc.
Ohio Rural Elec. Coop, Inc.
6677 Busch Boulevard
Columbus, OH 43229
Phone: 614-846-5757
Fax: 614-846-7108
E-mail: dberger@buckeyepower.com

David Dulick
Exelon Energy
2600 Monroe Blvd.
Norristown, PA 19403
Phone: 610-676-7364
Fax: 610-676-7266
E-mail: ddulick@exeloncorp.com

Jodi Bair
Ed Hess
Anne Hammerstein
Douglas Maag
Public Utilities Commission of Ohio
180 East Broad Street
Columbus, OH 43215
Phone: 614-644-8599
Fax: 614-644-8764
E-mail: Jodi.Bair@puc.state.oh.us
E-mail: Ed.Hess@puc.state.oh.us
E-mail: Anne.Hammerstein@puc.state.oh.us
E-mail: Douglas.Maag@puc.state.oh.us

Jodi M. Elsass-Locker,
Asst. Attorney General
Ohio Department of Development
77 S. High Street, 29th Floor
Columbus, OH 43215
Phone: 614-644-9605
Fax: 614-728-4920
E-mail: jelsass-locker@odod.state.oh.us

William M. Ondrey Gruber, Esq.
for Ohio Environmental Council
2714 Leighton Road
Shaker Heights, OH 44120
Phone: 216--371-3570
Fax: 801-697-4625
E-mail: GruberWL@aol.com



Gary A. Jack, Esquire

OVERSIZE DOCUMENT(S)

CASE NUMBER 00-02-EL-ETP NUMBER OF IMAGES 7

DESCRIPTION

00912AA.DGN
00913AA.DGN
00914AA.DGN
00915AA.DGN

000916AA.DGN
000917AA.DGN
050581AA.DGN

REMOVED BY _____
DATE _____
SENT OUT _____

REVISED 3/14/89