Duke Energy Ohio Case No. 20-0262-EL-BNR STAFF Third Set of Data Requests Date Received: June 1, 2020

STAFF-DR-03-001

REQUEST:

Please verify the below sentence:

This project was identified by stakeholders to resolve a system reliability criteria violation.

RESPONSE:

The project is from the 2017 RTEP study. It eliminates NERC criteria violations found for certain contingencies at Pierce.

PERSON RESPONSIBLE:

Dane Vandewater