

**Attachment 1**

**Table 1**

<b>AEP Ohio Reliability Indices (major storms excluded)</b>						
	<b>CSP</b>			<b>Ohio Power</b>		
	<b>SAIFI</b>	<b>CAIDI</b>	<b>SAIDI</b>	<b>SAIFI</b>	<b>CAIDI</b>	<b>SAIDI</b>
<b>1998</b>	1.200	120.0	138.0	1.000	198.0	198.0
<b>1999</b>	1.399	121.8	170.4	0.914	142.2	130.0
<b>2000</b>	1.572	141.6	222.6	0.918	160.2	147.1
<b>2001</b>	1.474	120.4	177.5	1.240	140.1	173.7
<b>2002</b>	1.620	122.8	198.9	1.345	167.4	225.1
<b>2003</b>	1.905	123.6	235.5	1.415	151.5	214.3
<b>2004</b>	1.861	116.8	217.4	1.451	144.4	209.5
<b>2005</b>	1.894	130.7	247.6	1.511	146.7	221.7
<b>2006</b>	1.340	116.9	156.0	1.190	143.9	172
<b>Avg. 1998-2001</b>	1.411	126.0	177.1	1.018	160.1	162.2
<b>Avg. 2002-2006</b>	1.724	121.2	211.1	1.382	150.8	208.5
<b>Increase</b>	22.16%	-3.01%	19.17%	35.8%	-5.84%	28.57%

<sup>1</sup> *In the Matter of the Self Complaint of Columbus Southern Power Company and Ohio Power Company Concerning the Implementation of Programs to Enhance Their Currently Reasonable Level of Distribution Service Reliability, Case No. 06-222-EL-SLF, Supplemental Testimony of Peter J. Lanzalotta (April 11, 2007) at 14.*

Attachment 2

Table 2

AEP Ohio Reliability Indices (major storms included)							
	CSP				Ohio Power		
	SAIFI	CAIDI	SAIDI		SAIFI	CAIDI	SAIDI
<b>1998</b>	1.264	121.2	153.2		1.066	228.0	243.1
<b>1999</b>	1.439	118.5	170.6		0.973	134.1	130.5
<b>2000</b>	1.678	132.9	223.1		1.051	141.1	148.3
<b>2001</b>	1.485	119.5	177.5		1.380	126.5	174.6
<b>2002</b>	1.779	148.7	264.5		1.643	231.3	380.1
<b>2003</b>	2.506	347.9	871.8		2.068	431.2	891.6
<b>2004</b>	2.759	652.7	1,801.0		2.126	466.0	990.7
<b>2005</b>	2.130	141.1	300.4		1.880	369.2	694.4
<b>2006</b>	1.69	141.71	239.01		1.85	310.36	574.6
<b>Avg. 1998 – 2001</b>	1.467	123.1	181.1		1.118	157.4	174.1
<b>Avg. 2002 – 2006</b>	2.294	322.6	809.4		1.929	374.4	739.2
<b>Increase</b>	56.39%	162.15%	346.98%		72.64%	137.84%	324.53%

Source: ESSS Rule 10 Reports. <sup>2</sup>

<sup>2</sup> Id. at 17.