

## **Exhibit A**

### **University of Cincinnati System Description**

The attached plant layout labeled as Attachment 1 shows that the University of Cincinnati has two 12.5 MW combustion turbine generators (CTGs) each CTG has a waste heat boiler with natural gas auxiliary burners which produce an additional twenty five percent (25%) of the annual steam production. These waste heat boilers capture the turbine exhaust to produce high pressure steam as shown in red. This steam goes to a common header that is used for two purposes. The steam can be used by a single 24 MW steam turbine generator (STG), and it can also be used to provide steam to our campus distribution system. In order to use the steam on campus the pressure is reduced from 600psi to 125 psi by running through a pressure reduction valve coupled with a de-superheater spray system. This process increases the volume of steam but reduces the total enthalpy for the steam that goes to campus.

The basis of the University's system of tracking its waste heat recovery is state of the art metering. Attachment 2 is a screen shot from UC's plant operating system. The screen shot illustrates how the University measures and records many power production parameters. This screen shot shows the steam output of one of our two waste heat recovery boiler. It is shown as the left pointing arrow in the middle of the screen and reads 43.7 kpph at 750.3 degrees Fahrenheit when this image was captured. This data is collected in a SQL database for both meters. The steam meters are described in the Meter Specification section of the application. .

All of the above described metered data is summarized daily and then totalized monthly in a spreadsheet shown as attachment 3. The spreadsheet shows how much energy is produced and how much fuel was consumed. These spreadsheets are saved in UC's billing system on a secure server. The data in the SQL database is also stored on a secure server, and all of this information can be retrieved at anytime for auditing.


Since we are a state institution of higher education with an in service date of 6/1/04, all of this generation should be classified as renewable. To convert the steam data into renewable energy credits we will add the two steam meters together and multiply by the enthalpy (BTU content) of the steam and divide by the average efficiency of natural gas fired generators. The enthalpy for 600 PSIG steam superheated to 750 degrees Fahrenheit can be found in a steam table which is shown as 1,378.57 BTU/lb in attachment 5. This BTU/lb figure is the same regardless of whether the steam is used on campus or in the steam turbine generator. We used Spirax Sarco's online calculator for our steam table. Their website is listed below the attachment. We will then divide these total BTUs by 10,416 which is the average heat rate listed for gas steam turbine generators by the Energy Information Administration (EIA). This value is shown in shown in Attachment 4 and the EIA's website is listed below the attachment.

As an example, we can look at the heat we recovered in August, 2012. As show in attachment 3, we recovered a total of 72,279 klbs of steam. We multiply this number by 1,000 to get pounds and then multiply by 1,378.57 to get total BTUs recovered and then divide by 10,416 to get kWhs which is equal to 9,566,212 kWh or 9,566 RECs. This data will be recorded monthly in GATS.

UC Central Utility Plant 6/15/2005



Combustion Turbine Generator #1



Combustion Turbine Generator # 2




## Steam Turbine Generator




- LEGEND**
- EQUIPMENT
  - CONDENSATION AIR
  - BOILER
  - STEAM/CONDENSATE
  - COOLING WATER
  - WATER
  - NATURAL GAS
  - HIGH PRESSURE GAS
  - FUEL GAS

# Attachment 1 Plant Layout One Line



## Attachment 2 Screen Shot



<p align="center">Attachment 3 Plant Billing Reports</p>
--

Co-Gen-8-12

**CO-  
GENERATION**

DATE	STEAM GENERATED (klb)		
	HRSG 1	HRSG 2	TOTAL
1	2233.2	2255.7	4488.9
2	2138.5	2312.2	4450.7
3	2167.6	2252.3	4419.9
4	1039.3	1052.8	2092.1
5	1026.5	1053.0	2079.5
6	1016.2	1055.9	2072.1
7	1033.0	1053.0	2086.0
8	1031.6	1052.9	2084.5
9	1027.6	1049.8	2077.4
10	1026.8	1047.4	2074.2
11	1025.2	1066.8	2092.0
12	1026.4	1060.1	2086.5
13	1033.4	1059.1	2092.5
14	1036.0	1075.9	2111.9
15	1033.1	1073.4	2106.5
16	1053.7	950.4	2004.1
17	1035.3	1045.5	2080.8
18	1019.7	1016.7	2036.4
19	1019.4	1060.0	2079.4
20	1014.7	1099.2	2113.9
21	1024.7	1192.4	2217.1
22	1030.2	1125.3	2155.5
23	1035.2	1084.9	2120.1
24	1043.6	1071.8	2115.4
25	1048.9	1075.6	2124.5
26	1046.7	1075.7	2122.4
27	1034.4	1057.9	2092.3
28	1049.9	1074.3	2124.2
29	1060.1	1091.7	2151.8
30	1066.0	1107.9	2173.9
31	1066.3	1085.9	2152.2
TOT.	35,543	36,736	72,279

## Attachment 4 EIA Efficiency Website

Independent Statistics & Analysis

U.S. Energy Information Administration

[Sources & Uses ▾](#)
[Topics ▾](#)
[Geography ▾](#)

[Tools ▾](#)
[Learn About Energy ▾](#)

OVERVIEW
DATA
ANALYSIS & PROJECTIONS

SEE ENTIRE ELECTRIC POWER ANNUAL

# ELECTRICITY

## Electric Power Annual 2010 Data Tables

With Data for 2010 | Release Date: November 09, 2011 | Next Release Date: November 2012

[GLOSSARY >](#)

[SEE ENTIRE ELECTRIC POWER ANNUAL](#)

## Electric Power Annual 2010 Data Tables

With Data for 2010 | Release Date: November 09, 2011 | Next Release Date: November 2012

Table 5.4. Average Heat Rates by Prime Mover and Energy Source, 2010  
(Btu per Kilowatthour)

Prime Mover	Coal	Petroleum	Natural Gas <sup>[1]</sup>	Nuclear
Steam Turbine	10,142	10,249	10,416	10,452
Gas Turbine <sup>[2]</sup>	--	13,386	11,590	--
Internal Combustion	--	10,429	9,917	--
Combined Cycle	W	10,474	7,619	--

[1] Includes a small number of generators for which waste heat is the primary energy source.

[2] Includes binary turbines.

W = Withheld to avoid disclosure of individual company data.

Notes:

• See Glossary reference for definitions.

• Totals may not equal sum of components because of independent rounding.

• Heat rate is reported at full load conditions for electric utilities and independent power producers.


• The average heat rates above are weighted by Net Summer Capacity.

• In 2010, EIA changed the way it treated blank values in its methodology for calculating average heat rates.

Source: U.S. Energy Information Administration, Form EIA-860, "Annual Electric Generator Report."

<http://www.eia.gov/electricity/annual/html/table5.4.cfm>

## Attachment 5 Spirax Sarco Steam Table Data



International site for Spirax Sarco

Visit your national Spirax Sarco website Go

Search  
[Advanced Search](#) [Site Map](#)

[Home](#)
[About Us](#)
[Products & Services](#)
[Industries & Applications](#)
[Training](#)
[Resources](#)
[Contact](#)

**Steam Tables**

Sub Saturated Water Region

Saturated Water Line

Wet Steam Region

Dry Saturated Steam Line

**Superheated Steam Region**

You are here: [Home](#) > [Resources](#) > [Steam Tables](#) > Superheated Steam Region

### Superheated Steam Region - Steam Table

The superheated steam region depicts steam at a temperature higher than its saturation temperature. Should saturated steam be heated at constant pressure, its temperature will rise, producing superheated steam.

Learn more about steam in our tutorial - [What is Steam?](#)

Set your [preferences](#) for these steam tables.

**Note: - You cannot use commas (,) as decimal points.  
Please use periods (.)  
Example: 1.02 not 1,02**

**Inputs**

**Output**

Pressure

Superheat Temperature

Saturation Temperature

Degrees Superheat

Specific Enthalpy of Water ( $h_f$ )

Specific Enthalpy of Evaporation ( $h_{fg}$ )

Specific Enthalpy of Superheated Steam ( $h$ )

Pressure and Superheat Temperature


☒ Single Value
☐ Table

psi gauge  
 °F

Calculate
Reset
Print


  

°F  
 °F  
 Btu/lb  
 Btu/lb  
 Btu/lb



**Feature**

[Training](#)



Training that targets plant improvements and energy/cost savings.

[Empower your team](#)

<http://www.spiraxsarco.com/resources/steam-tables/superheated-steam.asp>

## Attachment 6 Steam Meter Specification

CONTROL-SOFT  
ENTERPRISES

<b>EBG FLOW PRODUCTS DIVISION</b> <b>P.O. BOX 17725, AUSTIN, TEXAS, 78760 U.S.A.</b> <b>PHONE: 800-426-9156 / FAX: 800-435-6629</b>			
FE-Sizer for Windows 95/98/Me/NT/2000/XP/2003 Server - Version 3.0, Release 3.46.5. Copyright © 1994-2012 Control-Soft Enterprises All rights reserved. Licensed to:			
Service Data			
Tag:	C2b	Client:	UNIVERSITY OF CINCINNATI
Serv:		Project:	TJM-347988
Line No.:		J.O./P.O. No.:	
Calculation Method & Base Conditions			
Sizing Parameter:	FLOWMETER dP	C-Std:	ASME MFC-3M (1989 Edition)
Atm Press, Patm:	14.696 psia	Tap Loc:	UPSTREAM
Meter/Pipe Data			
Meter Type:	VENTURI - 15 DEG EXIT	Meter Matl:	304/304L SS
Meter Style:	MACHINED INLET	Tap Style:	D & THROAT d/2 TAPS
Nom Pipe Size:	8.00 in	Matl @ Upstr Tap:	CARBON STEEL
Pipe I.D., D(ref):	7.625 in	Pipe Sched:	80
Sizing Data			
Maximum Flow, Wm:	125000.0 lb/h		
Normal Flow, Wn:	117000.0 lb/h		
Orifice Bore, d (68.0 deg F):	5.5000 in		
Fluid Data			
Fluid:	SUPERHEATED STEAM		
State-Units-Equation-Condition:	VAPOR-MASS-DENSITY-FLOWING		
Density (Flowing), Df1:	0.9333 lb/ft3		
Pressure (Flowing), Pfl:	620.00 psig		
Temperature (Flowing), Tfl:	755.0 deg F		
Viscosity, U:	0.02444 cPoise		
Specific Heat Ratio (Cp/Cv), k:	1.2755		
Calculated Results			
Sizing Factor, Sm:	0.605671		
Pipe Reynolds Number @ Maximum Flow, RD:	4214636		
Pipe Reynolds Number @ Normal Flow, RD:	3944899		
Discharge Coefficient, C:	0.995000		
Expansion Factor, Y1:	0.995493		
Bore Expansion Factor, Fad:	1.006527		
Pipe Expansion Factor, FaD:	1.005191		
Permanent dP Loss:	12.26 %		
Throat Velocity @ Max Flow:	225.49 ft/s		
Beta, B (68.0 deg F):	0.72131		
Maximum Differential, dPm (ref dP - H2O @ 68.0 deg F):	102.650 in WC		
Normal Differential, dPn (ref dP - H2O @ 68.0 deg F):	89.9312 in WC		
Orifice Uncertainty, Uo:	1.00 %		
Calc Number: FREEBIE		Sht: ___ of ___ Chk: ___	
By: John Miller		Rev: 0 Date: 13 Mar 2013	